

B R I E F I N S T R U C T I O N S

Place your mouse here to see the PHPP help.

If no help appears when the mouse passes over cell B4, you can activate it by going into the Menu Bar Tools/Options/View, and under "Comments", select "Comment Indicator Only".

Passive House Verification: Meaning of Field Formats

Example	Field Format	Meaning
78,8	Courier New, blue, bold on yellow background	Input Field: Please enter the required value here
01ud triple-low-e-cr08	Arial Narrow, blue, bold on brown	Data entry field with drop down list
6619	Arial, black, standard on white background	Calculation field; please do not change
78,8	Courier New, purple, bold on white background	Field with references to another sheet - should not be changed.
126,0	Arial, black, large & bold on green background	Important result

Passive House Planning: Worksheet Directory

Worksheet name (to show/hide worksheets please use the separate 'Profile settings' tool)	Function	Brief Description	Required for the certification?
Verification	Building data; summary of results	Building description, selection of the calculation method, summary of results	yes
Overview	Overview of the specific data of the project entered	In-depth project description, overview of all results and input variables, specific details on building envelope, building services systems as well as general information.	no
Variants	Variant calculation	Input parameters and results for the variant calculations. Predefined fields for frequent entries, as well as user-defined area.	no
Comparison	Comparison between two variants	Comparison between two variants under the energy demand and economic viability perspective. Input of comparison configurations.	no
Climate	Climate Region Selection or Definition of User Data	Climate data for: Annual Heating, Windows, Heating Load, Heating, Summer, Cooling, Cooling Units, Cooling Load worksheets	yes
U-Values	Calculation of Standard building assembly U-Values	Heat transmission coefficient calculations in accordance with DIN EN ISO 6946.	yes
Areas	Areas summary	Building assembly Areas, Thermal Bridges, Treated Floor Area. Use exterior dimension references!	yes
Ground	Calculation of reduction factors against ground	More precise calculation of heat losses through the ground	if applicable
Components	Building component database	Database of certified, Passive House suitable components and entry of user-defined components	yes
Windows	Uw-Value Determination	Input of geometry, orientation, frame lengths, frame widths, Ug and U-values of the frame, and the thermal bridge heat loss coefficients of the connections; from these inputs, determine Uw and total radiation.	yes
Shading	Determination of shading coefficients	Input of shading parameters, e.g. balcony, neighbouring building, window reveal and calculating the shading factors	yes
Ventilation	Air Flow Rates, Exhaust/Supply Air Balancing, Pressurization Test Results	Sizing the ventilation system from extract and supply air requirements, infiltration air change rate and actual efficiency of heat recovery, input of pressurization test results	yes
Additional Vent	Design and planning of ventilation systems with diverse ventilation units	Extension of the Ventilation worksheet for dimensioning air flows, for special building uses and systems with various ventilation units	if used
Annual heating	Annual heating demand / Annual Method	Calculation of the annual space heating demand according to the energy balance method following EN 13790: Transmission + Ventilation · h (Solar Gains + Internal Gains)	no
Heating	Space heating demand calculation Monthly method according to EN 13790	Calculation procedure for the monthly method following EN 13790. Make appropriate selection in the Verification worksheet, if calculations should be performed following this procedure	yes
Heating Load	Building Heating Load Calculation	Calculation of the nominal heating load using a balance procedure for the design day: max transmission + max ventilation · η (minimum solar gains + internal heat gains)	yes
SummerVent	Determination of Summer Ventilation	Ventilation in cooling case and estimation of air flow rates for natural ventilation during the summer period	yes
Summer	Assessment of Summer Climate	Calculation of the frequency of overheating as a measure of summer comfort	yes
Cooling	Monthly Method for Cooling Demand	Annual useful cooling demand calculation	if present
Cooling units	Latent Cooling Energy	Calculation of the energy demand for dehumidification and choice of cooling method	if present
Cooling load	Building Cooling Load Calculation	Calculation of the daily average cooling load of the building	no
DHW+Distribution	Distribution losses; DHW Requirement and Losses	Heat loss calculation of the distribution systems (heating; DHW); calculation of the useful heat requirement of DHW and storage losses	yes
SolarDHW	Solar DHW Heating	Solar contribution calculation for DHW and space heating contribution	if solar panels are used
PV	Electricity generation by photovoltaic	Electricity generation calculation of PV system	no
Electricity	Electricity Demand for Dwellings	Calculation of the electricity demand of Passive Houses with residential use	yes
Use non-res	Patterns of non-residential Utilisation	Input or selection of utilisation patterns for planning of electricity demand and internal heat gains	no
Electricity non-res	Electricity Demand for non-residential Use	Calculation of the electricity demand for lighting, electric devices and kitchens for non-residential buildings	no
Aux Electricity	Auxiliary Electricity Demand	Calculation of auxiliary electricity and corresponding primary energy demand	yes
IG	Internal Heat Gains in Dwellings	Calculation of the internal heat gains based on the Electricity and Aux Electricity sheets.	no
IG non-res	Internal Heat Gains for non-residential Use	Calculation of the internal heat gains for non-residential buildings based on the Electricity non-res worksheet and the occupancy	no
PE-Value	Specific Primary Energy and CO ₂ Demands	Selection of heat generators, calculation of the specific primary energy and CO ₂ demands from the present results	yes
Compact	Efficiency of Heat Generator Compact Heat Pump Unit	Calculation of combined heat generation efficiency for heating and DHW only by means of a electric heat pump compact unit, considering the specific project boundary conditions.	if present
HP	Heat generation efficiency of the heat pump	Calculation of heat generation efficiency for one to two electric-run heat pumps, considering the specific project boundary conditions.	if present
HP Ground	Ground probe or ground collector in combination with a heat pump	Heat source calculation for a ground probe or horizontal subsoil heat exchanger for ground-coupled heat pumps, considering the specific project boundary conditions.	if present
Boiler	Efficiency of Heat Generator Boiler	For the calculation of the efficiency of heat generation with standard boilers (NT and calorific boilers) for the project given boundary conditions.	if present
District Heating	District Heat Transfer Station	Calculation of the final and primary energy demands (heat)	if present
Data	Database	Table of primary energy factors following [GEMIS] and database of EnEV (German energy efficiency regulation).	no

EnerPHit verification



Architecture:			
Street:			
Postcode/City:			
Energy consulting:			
Street:			
Postcode/City:			
Year of Construction:	2014	Interior temperature winter [C°]	18,0
Number of dwelling units:	1	Internal heat gains winter [W/m ²]	5,4
Number of Occupants:	60,0	Interior temp. summer [C°]	24,0
Exterior vol. V _e :	4180,4 m ³	IHG summer [W/m ²]	5,4
		Spec. capacity [Wh/K per m ² TFA]	204
		Mechanical cooling:	0
Altitude of building site (in [m] above sea level): 426			
Building:	Primary School 8 "Sveti Sveti Kiril I Mетодий"		
Street:	69 Mogilov blv.		
Postcode/City:	Gabrovo		
Country:	Bulgaria		
Building type:	School		
Climate:	Велико Търново		
Home owner/client:	Municipality of Gabrovo		
Street:	3 Vazrazhdane square		
Postcode/City:	Gabrovo		
Mechanical System:			
Street:			
Postcode/City:			
Certification:			
Street:			
Postcode/City:			

Specific building demands with reference to the treated floor area					
	Treated floor area	719,4 m ²		Requirements	Fulfilled?*
Space heating	Annual heating demand	55 kWh/(m ² a)	25 kWh/(m ² a)	no	
	Heating load	44 W/m ²	-	-	
Space cooling	Overall specific space cooling demand	kWh/(m²a)	-	-	
	Cooling load	W/m²	-	-	
	Frequency of overheating (> 24 °C)	7,8 %	-	-	
Primary Energy	Heating, cooling, domestic hot water, auxiliary electricity, lighting, etc.	171 kWh/(m ² a)	168 kWh/(m ² a)	no	
	DHW, space heating and auxiliary electricity	143 kWh/(m ² a)	-	-	
	Specific primary energy reduction through solar electricity	kWh/(m²a)	-	-	
Airtightness	Pressurization test result n ₅₀	2,0 1/h	1 1/h	no	

* empty field: data missing; -: no requirement

<p>I confirm that the values given herein have been determined following the PHPP methodology and were determined based on the characteristics of the building. The PHPP calculations are attached to this application.</p>		EnerPHit building retrofit (acc. to heating demand)? no
Name:		Company:
Surname:		Registration number PHPP:
		Signature

Basic data		
Building, name of the object	Primary School 8 "Sveti Sveti Kiril I Metodi" - 69 Mogilov blv.	
Street:	Gabrovo	
Postcode/City:	Bulgaria	
Country:		
Building type:		
Climate: region / climate data set	User Data	
Climate: degree days / altitude	77	kKh/a
Building type / building status	User data - България	
Context of urban development	School University	
Building type / construction	Urban development	
Building category, in terms of energy	EnerPHit building retrofit (acc. to heating demand)	
Year of construction / year of construction of existing building	2014	1970,0
Amount of dwelling units for residential use / non-residential use	Dwelling units	7
Number of occupants standard / planned	P	60
Standard / design occupancy rate	m ² /P	12
Home owner / client	Municipality of Gabrovo	
Architect		
Building services		
PHP/Energy balance		
Building physics		
Structural engineering		
Contractor / tradesperson / other (max. 5000 characters)		
Interior temperatures winter/summer	18	°C
IHG winter / summer	5,43	W/m ²
Type of certification	EnerPHit building retrofit (acc. to heating demand)	
Project certification / Certificate ID		
Certification body		
PHPPE-version / PHPP-registration number	Version 9.0 beta	
Characteristic value according to EnerPHit verification		
Treated floor area A _{TFA} / exterior volume V _e	719,39	m ²
Space heating demand	55	kWh/(m ² a)
Heating load residential	44	kWh/(m ² a)
Heating load Non-residential	8	%
Frequency of overheating		Recommendation: < 10%
Overall specific space cooling demand		
Cooling load residential		
Cooling load non-residential	44	kWh/(m ² a)
Airtightness pressure air exchange rate test n ₅₀	2,0	1/h
Total PE Value	171	kWh/(m ² a)
Heating, cooling, DHW, auxiliary electricity, lighting, electrical appliances	143	kWh/(m ² a)
Specific PE Demand - Mechanical System / CO ₂ -Equivalent		34
Heating, DHW, auxiliary electricity (no lighting and electrical appliances)		
Solar power: Primary energy savings / CO ₂ emissions		

Average building quality		
	Specific Demand	Requirement
Average U-value of external insulation to outside air	0,13 W/(m ² K)	-
Average U-value of external insulation to ground		-
Average U-value interior insulation to outside air		-
Average U-value interior insulation to ground	0,29 W/(m ² K)	-
Average U-value of thermal bridges ΔU	0,01 W/(m ² K)	-
Average U-value windows	2,75 W/(m ² K)	-
Average U-value of exterior doors	2,25 W/(m ² K)	-
Ventilation system eff. heat recovery efficiency	81,07 %	-

Building envelope and site		
Building envelope area A _{total} / treated floor area A _{TFA}	1785 m ²	719
A/V-ratio / Envelope area use (A _{total} /A _{TFA})	0,43	2,48
Window area / Window area percentage	228 m ²	12,8%
Specific solar aperture / Passive solar heating mode	2,4%	11407
Building site area / built-up area		
Gross floor area BGF / Gross external volume BRI		
Floor space ratio / Amount of complete storeys		

Building description (max.5000 characters)

Opaque building components		
Exterior wall: U-value (average value) / area	0 ,14	W/(m ² K)
Standard exterior wall: U-value / thickness		
Standard exterior wall: total area / area fraction		
Standard exterior wall: name / certified?		
Standard exterior wall: short description (materials, manufacturer, product name, special features)		
Exterior wall against ground: U-value (average value) / area	0 ,27	W/(m ² K)
Standard exterior wall against ground: U-value / thickness		
Standard exterior wall against ground: area / area fraction		
Standard exterior wall against ground: name / certified?		
Standard exterior wall against ground: short description (materials, manufacturer, product name, special features)		
Roof / top floor ceiling: U-value (average value) / area	0 ,11	W/(m ² K)
Standard roof / top floor ceiling: U-value / thickness		
Standard roof / top floor ceiling: area / area percentage		
Standard roof / top floor ceiling: name / certified?		
Standard roof / top floor ceiling: short description (materials, manufacturer, product name, special features)		

Floor slab / basement ceiling: U-value (average value) / area

Standard floor slab / basement ceiling: U-value / thickness

Floor slab / basement ceiling standard: area / area fraction

Standard floor slab / basement ceiling: name / certified?

Standard floor slab / basement ceiling: short description
(materials, manufacturer, product name, special features)0,30 W/(m²K)

400,34

W/(m²K)

0,0

W/(m²K)**Thermal bridges: Y-value (Average value) / length**

Thermal bridge free limit value / Complied?

0,057 W/(mK)

223,70

0,01 W/(mK)

no


Thermal bridges: short description (max.5000 letters)
(additional notices, manufacturer, product name, materials, others)


Windows / doors / shading systems		
windows/facades: U-value (average value) / area	2,75	W/(m²K)
window/facade frames: U-value (average value) / area	2,32	W/(m²K)
Glazing: U-value (Average value) / areas	2,70	W/(m²K)
Ψ-Value Glazing edge (average) / Ψ-Value Installation (average)	0,040	W/(mK)
Standard window frame: U-value / frame width		W/(m²K)
Standard window frame: window area / area percentage		W/(m²K)
Standard window frame: glass edge Ψ-value / installation Ψ-value		W/(mK)
Standard window frame: name, certified?		
Standard window frame: Short description (materials, manufacturer, product name, installation)		
Standard curtain wall facade: U-value / Frame width		W/(m²K)
Standard curtain wall facade: Facade area / Total area percentage		W/(m²K)
Standard curtain wall facade: Ψ-value glazing edge / Ψ-value installation		W/(mK)
Standard curtain wall facade: Description / Certified?		
Standard curtain wall facade: short description (materials, manufacturer, product name, installation)		
Standard glazing: U-value / g-value		W/(m²K)
Standard glazing: Facade area / Area ratio		W/(m²K)
Standard glazing: Description / Certified?		
Standard glazing: short description (description, manufacturer, product name, installation)		
Standard glazing 2: U-value / g-value		W/(m²K)
Standard glazing 2: Facade area / Area percentage		W/(m²K)
Standard glazing 2: Description / Certified?		
Standard glazing 2: short description (description, manufacturer, product name, installation)		
Roof lights / light domes: U-value / frame width		W/(m²K)
Roof lights / light domes: window area / area section		W/(m²K)
Roof lights / light domes: glazing U-value / g-value		W/(m²K)
Roof lights / light domes: Y-value glass edge / Installation Y-value		W/(mK)
Roof lights / light domes: name / certified?		
Roof lights / light domes: short description (materials, manufacturer, product name, installation situation)		
Exterior door: U-value (average value) / Area	2,25	W/(m²K)
Standard exterior door: door U-value / door U-value installed		W/(m²K)
Standard exterior door: frame U-value / door leaf U-value		W/(m²K)
Standard exterior door: door leaf thickness / frame width		mm
Standard exterior door: panel border Y-value / installation Y-value		W/(mK)
Standard exterior door: Name / certified?		
Standard exterior door: Short description (materials, manufacturer, product name, installation situation)		
Temporary sun protection: Type / Add. Reduction factor		W/(m²K)
Temporary sun protection: Area / Area ratio		W/(m²K)
Shading reduction factors: orientation		
North	100	%
East	78	%
South	13	%
West	51	%
Horizontal	100	%
Reduction factor winter		Summer reduction factor
		100
		55
		28
		28
		100


Ventilation		
Ventilation: Type of ventilation	Balanced PH-Ventilation with HR	
Calculated supply air demand / supply air per person	3600	m³/h
Calculated extract air demand / Amount extract air rooms	0	m³/h
Design air flow rate (maximum) / Average value reference to maximum	6600	m³/h
Average flow rate / Average air exchange		m³/h
Airtightness test pressure at n_{50} / Air permeability q_{50}	2,00	1/h
Net air flow for pressurization test / Infiltration flow $n_{V,Rest}$	3439	m³
Ventilation unit: Description / Certified?		
Ventilation system: effective heat recovery efficiency / electrical efficiency	0,84	%
Ventilation system: Description (type of heat recovery, manufacturer, product name)		
Ventilation system: installation site / Temperature of mechanical services room	Inside the thermal envelope 20	
Nominal width exterior or supply air / exhaust or extract air ducts	60	mm
Conductance ambient- or supply air duct / exhaust- or extract air duct		W/(mK)
Length ambient- or supply air duct / exhaust- or extract air duct	2,00	m
SHX: efficiency / effective heat recovery efficiency		%
HE defrosting / Defrosting at a minimum temperature of		
Effective energy recovery efficiency ventilation / Humidity recovery	yes	
		4,00
Ventilation system: Short description (installation site, ducts, silencers, others)		0,0
Summer ventilation		
Summer base ventilation: ventilation type	Without heat recovery	
Air exchange via ventilation system with supply air:		1,30
Air exchange via extract air system		1,30
Window ventilation air exchange		0,09
Night summer ventilation: Type of ventilation	Humidity differenceregulated	
Night air exchange Window Night Ventilation, Manual		0,00
Night air exchange mechanical, automatically Controlled ventilation		1,30
Summer ventilation: short description (window opening profiles, night ventilation concepts, others)		
Cooling		
Max. indoor absolute humidity / Internal humidity sources	12,0	g/kg
Frequency of overheating / Overtemperature limit:	7,8	%
Mechanical cooling: Applied cooling units		
		kW
		kW
	0,0	
		kWh/(m²a)
Mechanical cooling: Average annual coefficient of performance / Electricity demand		
Mechanical cooling: Short description (unit, manufacturer, product name, installation site, installation)		0,0


Heating and DHW			
DHW Demand	18,53	kWh/(m²a)	13329
Annual heating demand	54,68	kWh/(m²a)	39339
Direct electricity: contribution to space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
Direct electric heating / domestic hot water			
Final energy demand		kWh/(m²a)	
Direct electricity: short description (description, manufacturer, product name)			
Heat pump: covered fraction of space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
COP heat pump for heating / heat pump for DHW			
Final energy demand		kWh/(m²a)	
Compact unit: Short description (description, manufacturer, product name)			
Compact unit: covered fraction of space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
COP heat pump for heating / heat pump for DHW			
Final energy demand		kWh/(m²a)	
Compact unit: Short description (description, manufacturer, product name)			
Boiler: covered fraction of space heating / domestic hot water	100	%	100
PE value energy carrier / CO ₂ -emission factor	1,1	kWh/kWh	250
Heat generator: building type / COP	Low Temperature Boiler Gas		111
Final energy demand	81,1	kWh/(m²a)	
Boiler: short description (description, manufacturer, product name)			
District heating: Covered fraction of space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
Heat source / Performance of heat generator			
Final energy demand		kWh/(m²a)	
Compact unit: Short description (description, manufacturer, product name)			
Solarthermics			
Collector	Improved flat plate PK SL AL		
Collector area / Specific collector area	0,00	m ²	0,00
Deviation from north / Angle of inclination from the horizontal	180	°	45
Solarthermics: Short description (description, manufacturer, product name, installation location)			
Solar contribution to DHW	0,00	kWh/(m²a)	0
Solar contribution to space heating	0,00	kWh/(m²a)	0
Solar contribution total	0,00	kWh/(m²a)	0
Solar Storage	Simple storage 800 l		
PHOTOVOLTAIC			
Module technology	Amorph-Si		
Nominal current / Nominal voltage		A	
Nominal power / Number of modules	0,00	Wp	
Deviation from north / Angle of inclination from the horizontal		°	
Solarthermics: Short description (description, manufacturer, product name, installation location)			
Annual yield of PV modules		kWh/(m²a)	


Aux. electricity / Household electricity		
Aux Electricity		
Ventilation units / Electricity demand		13537
Heating system Devices / Electricity demand		1063
DHW-system units / Electricity demand		365
Aux. Electricity solar devices / electr. demand		
Total aux. Electricity	20,80	kWh/(m²a) 14964,96
Household electricity		
Dishwasher / useful energy demand		4290
Washing machine units / Energy demand		3762
Clothes dryer unit / Energy demand		10474
Refrigerator, Freezer or combination unit / Useful energy demand		574
Cooking unit / energy demand		7500
Lighting		10440
Consumer Electronics		2640
Small appliances, etc.		3000
Other		
Total household electricity	59,33	kWh/(m²a) 42679,53
Economic data		
Total gross construction costs / contained VAT	€	
Building costs (cost group 300+400) / (cost group 200-700)	€	
Total gross construction costs per m ² BGF / per m ³ BRI	€/m ²	
Explanation building costs		
Fostering (Passivhaus, refurbishment, etc.)		
Explanation fostering		
Other		
Ecological aspects: rainwater utilization, etc.		
Material used: Regional products / Natural products		
Special features: first project in the country / first project used as		
Building awards		
Research project / funded project		
Description of research / funded project		
Other		















	kWh/a
	%
	g/kWh
	%
	g/kWh
	%
	g/kWh
	%
	%
	g/kWh
	%
	%
	g/kWh
	%
	m²/P
	°
	%
	%
	%
	V
	pcs
	°
	kWh



EnerPHit planning:

select active variants
>>

Results	Units
Annual heating demand	kwh/(m ² a)
Heating Load	W/m ²
Overall specific space cooling demand	kwh/(m ² a)
Cooling load	W/m ²
Frequency of overheating	%
Total primary energy demand	kwh/(m ² a)
Certifiable as EnerPHit building retrofit (acc. to heating demand)?	yes / no
<< User defined	Units

Input variables	Units
<< Assembly layers ('U-value')	
<< Radiation balance ('Areas')	
<< Thermal bridges ('Areas')	
<< Glazing and frames ('Window', 'Shading')	
<< Ventilation ('Ventilation', 'SummVent')	
<< Heat generator ('PE-value')	

Passive House compact unit with supply air ventilation pump	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="padding: 2px;">Direct electricity</td><td style="padding: 2px;">Fraction of annual heating demand</td></tr> <tr> <td></td><td style="padding: 2px;">Fraction of domestic warm water</td></tr> <tr> <td style="padding: 2px;">Heat pump</td><td style="padding: 2px;">Selection HP</td></tr> <tr> <td></td><td style="padding: 2px;">Fraction of annual heating demand</td></tr> <tr> <td></td><td style="padding: 2px;">Fraction of domestic warm water</td></tr> <tr> <td style="padding: 2px;">Boiler (gas, oil & wood)</td><td style="padding: 2px;">Selection of device</td></tr> <tr> <td></td><td style="padding: 2px;">Fraction of annual heating demand</td></tr> <tr> <td></td><td style="padding: 2px;">Fraction of domestic warm water</td></tr> <tr> <td style="padding: 2px;"></td><td style="padding: 2px;">Selection of boiler</td></tr> <tr> <td></td><td style="padding: 2px;">Fraction of annual heating demand</td></tr> </table>	Direct electricity	Fraction of annual heating demand		Fraction of domestic warm water	Heat pump	Selection HP		Fraction of annual heating demand		Fraction of domestic warm water	Boiler (gas, oil & wood)	Selection of device		Fraction of annual heating demand		Fraction of domestic warm water		Selection of boiler		Fraction of annual heating demand
Direct electricity	Fraction of annual heating demand																				
	Fraction of domestic warm water																				
Heat pump	Selection HP																				
	Fraction of annual heating demand																				
	Fraction of domestic warm water																				
Boiler (gas, oil & wood)	Selection of device																				
	Fraction of annual heating demand																				
	Fraction of domestic warm water																				
	Selection of boiler																				
	Fraction of annual heating demand																				

District Heating	Fraction of domestic warm water
	Selection of heat source
	Fraction of annual heating demand
	Fraction of domestic warm water
Other	Efficiency
	Fraction of annual heating demand
	Fraction of domestic warm water

<< Compressor cooling unit ('Cooling units')

<< User defined

	Description	Units
1	Mechanical cooling	x
2	Light Transmission Glazing	-
3	Defroster HX	0/1
4	Solar Collector Area	m2
5	Insulation Thickness:	mm
6	Thermal Conductivity	W/mK
7	Gym hall lightings	W/m2
8		
9		
10		
11		
12		
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
26		
27		
28		
29		
30		

31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	
65	
66	
67	
68	
69	
70	
71	
72	
73	

74	
75	
76	
77	
78	
79	
80	
81	
82	
83	
84	
85	
86	
87	
88	
89	
90	
91	
92	
93	
94	
95	
96	
97	
98	
99	
100	

CALCULATION OF VARIANTS

Active

4-Step 3 (interior wall insulation)	No measures	Step 1 (roof insulation)	Step 2 (wall insulation, Ventilation and heating system)	Step 3 (interior wall insulation)
4	1	2	3	4
54,7	228,4	153,8	76,0	54,7
43,9	123,0	85,2	49,2	43,9
7,8	9,8	3,3	3,5	7,8
171,5	411,8	322,7	194,3	171,5
no	no	no	no	no
Link	Link	Link	Link	Link
Value	1	2	3	4


0%	0%	0%	0%	0%
0%	100%	100%	0%	0%
None	None	None	None	None
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
Low Temperature Boi-ler Gas				
100%	100%	100%	100%	100%

100%	0%	0%	100%	100%
None	None	None	None	None
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%

Step 5 (windows in 20 years), DHW solar panels				
5	6	7	8	9
18,5				
22,1				
7,3				
116,2				
yes				
Link	Link	Link	Link	
5	6	7	8	9

0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
None	None	None	None	None
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
Low Temperature Boiler Gas	None	None	None	None
100%	0%	0%	0%	0%





100%	0%	0%	0%	0%
None	None	None	None	None
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%




10




10



	0%
None	0%
	0%
	0%
	0%
	0%





EnerPHit planning:

C O M P A R I S O N B

Results are being calculated. Please wait...

Selection of comparison configuration

Description	9-Compl.Renovation
Component type	Complete building
Component	- No additional input

Calculation of selected configuration

Design according to variant	1-No measures
Annual heating demand	228,397
Minimal interior surface temperature	-
Design Temperature outside	-
Interior temperature	18,0
Normal surface thermal resistance	-
Increased Heat Transfer Resistance	-
Minimal surface temperature unobstructed	-

Lower Efficiency	Hig Effici
1-No measures	5-Step 5 (w:
228,397	18,
-	-
-	-
18,0	18
-	-
-	-
-	-

Treated Floor Area (TFA)	1,00
Investment costs less sum of financial support	0,00
Annuity (capital costs)	0,00

Inves		
Per m ² of TFA	Entire building	Per m ² of TFA
1,00	719	1,00
0,00	0	252,27
0,00	0	15,20

Area	1
Annual heating demand	228,40
Cooling + dehumidification demand	
Final energy demand	252,22
CO ₂ -Emissions	63,44
Primary energy demand	278,30
Total cost space conditioning	22,85

Energy (Space heating + c		
Per m ² of TFA	Entire building	Per m ² of TFA
1	719	1
228,40	164307	18,48
252,22	181446	57,10
63,44	45638	17,56
278,30	200205	70,10
22,85	16438	6,98

Economi		
Total annual costs	22,85	16438
		22,19

Maximal economically viable additional i

Cost per kWh of se

<<

Boundary conditions

Approximate estimate of cost effectiveness (all c)

Interest rate + Inflation	Boundary	Energy price
Nominal interest rate	6 ,50%	Electricity
Inflation	1 ,53%	Gas/Oil
Period under consideration [a]	20	Logs Pellet District heating Others

z

E T W E E N T W O V A R I A N T S

her ency	Difference / Savings / Profit
windows in 2	
481	kWh(m²a)
-	°C
-	°C
, 0	°C
-	m²K/W
-	m²K/W
-	°C

tment			
Entire building	Per m² of TFA	Entire building	
719	1,00	719	
181478	252,27	181478	m²
10937	15,20	10937	€
			€/a

ooling + mech. ventilation)			
Entire building	Per m² of TFA	Entire building	
719	1	719	m²
13295	209,92	151012	kWh/a
41076	195,12	140370	kWh/a
12631	45,88	33007	kg/a
50432	208,19	149772	kWh/a
5024	15,87	11413	€/a

c viability			
15961	0,66	476	€/a

investment costs	272,69	196170	€
aved final energy		7,8	Cent/kWh

omponents with the same mean lifetime)!

conditions

s [cent/kWh]	Period of use	
25	Build. assemblies	50
9	Vent. system	25
5	Thermal bridges	50
7	Complete building	35
13		30
20	Windows	



Input: comparison configuration

Description	S1:Roof	S2:Walls
Component type	Building assemblies ('U-Value')	Building assemblies ('U-Value')
Component	03ud Ventilated roof	01ud Brick walls
"Lower Efficiency" variant	1-No measures	2-Step 1 (only roof insulation)
Investment costs [€]	8.257,11	4.904,11
Annual maintenance costs [€/a]		
"Higher Efficiency" variant	2-Step 1 (only roof insulation)	3-Step 2 (only wall insulation, V)
Investment costs [€]	20.985,65	32.934,54
Annual maintenance costs [€/a]		
Financial support (present value) [€]		

Results (manual transfer)

3	4	5
S2:Ventilation	S2:Building	S3:Int.wall_ins
Ventilation system ("Ventilation")	Complete building	Building assemblies ("U-Value")
- No additional input	- No additional input	01ud Brick walls
2-Step 1 (only roof insulation)	2-Step 1 (roof insulation)	3-Step 2 (wall insulation, Ventila
2.996,76	7.900,88	
3-Step 2 (only wall insulation, V	3-Step 2 (wall insulation, Ventila	4-Step 3(interior wall insulation)
21.417,79	67.053,05	10.069,89
409,03	409,03	

6

7

8

S3:Floor	S4:windows	S4:Building
Building assemblies ('U-Value')	Windows ('Window')	Complete building
06ud Floor	b-Without winter shading	- No additional input
3-Step 2 (wall insulation, Ventila	4-Step 3(interior wall insulation)	4-Step 3(interior wall insulation)
9.336 , 08		
4-Step 3(interior wall insulation)	5-Step 5(windows in 20 years), I	5-Step 5(windows in 20 years), I
15.775 , 23	54.836 , 05	67.593 , 81


9

10

Compl. Renovation	
Complete building	
- No additional input	
1-No measures	
5-Step 5(windows in 20 years), DHW solar panels	
181.477,62	
409,03	



EnerPHit planning:



CLIMATE DATA





Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C
 Wedge-shaped building assemblies (tapered insulation), unventilated air layers and unheated attics

> Auxiliary calculation to the right

Assembly No.	Building assembly description	Interior insulation?				
01ud	Brick walls					
Heat transfer resistance [m ² K/W] interior R _{si} : 0,13 exterior R _{se} : 0,04						
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Inside plaster	0,700					40
2. Bricks	0,520					250
3. Outside plaster	0,870					40
4. EPS	0,032					200
5. Outside plaster	0,870					20
6.						
7.						
8.						
Percentage of sec. 1 100%		Percentage of sec. 2	Percentage of sec. 3			Total 55,0 cm
U-value supplement  W/(m ² K)		U-Value: 0,142 W/(m ² K)				

Assembly No.	Building assembly description	Interior insulation?				
02ud	Concrete wall socle					
Heat transfer resistance [m ² K/W] interior R _{si} : 0,13 exterior R _{se} : 0,04						
Area section 2	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Inside plaster	0,700					20
2. Concrete	0,520					400
3. Bouchardé	2,100					30
4. EPS	0,032					200
5. Outside plaster	0,870					20
6.						
7.						
8.						
Percentage of sec. 1 100%		Percentage of sec. 2	Percentage of sec. 3			Total 67,0 cm
U-value supplement  W/(m ² K)		U-Value: 0,138 W/(m ² K)				

Assembly No.	Building assembly description	Interior insulation?				
03ud	Roof					
Heat transfer resistance [m ² K/W] interior R _{si} : 0,10 exterior R _{se} : 0,04						
Area section 3	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Reinforcement plaster	0,000					0
2. Closed air	0,000					0
3. Concrete	2,100					120
4. Hydroinsulation	0,170					8
5. balast/XPS	0,035					300
6. new hydroinsulation	0,170					8
7. balast new	3,500					40
8.						
Percentage of sec. 1 100%		Percentage of sec. 2	Percentage of sec. 3			Total 47,5 cm
U-value supplement  W/(m ² K)		U-Value: 0,113 W/(m ² K)				

Assembly No. Building assembly description					Interior insulation?		
04ud	Ground walls				<input checked="" type="checkbox"/> yes		
Heat transfer resistance [m^2K/W] interior R_{si} : 0,13		exterior R_{se} :					
Area section 4		λ [$W/(mK)$]	Area section 2 (optional)	λ [$W/(mK)$]	Area section 3 (optional)	λ [$W/(mK)$]	Thickness [mm]
1. Inside plaster		0,700					20
2. Concrete		2,100					400
3. EPS		0,045					150
4. Inside plaster		0,700					10
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						58,0	cm
U-value supplement <input type="text"/> W/(m ² K)		U-Value: 0,271 W/(m ² K)					

Assembly No. Building assembly description					Interior insulation?		
05ud	Floor to unheated basement				<input checked="" type="checkbox"/>		
Heat transfer resistance [m^2K/W] interior R_{si} : 0,17		exterior R_{se} : 0,17					
Area section 5		λ [$W/(mK)$]	Area section 2 (optional)	λ [$W/(mK)$]	Area section 3 (optional)	λ [$W/(mK)$]	Thickness [mm]
1. Flooring		3,500					30
2. Cement		0,930					20
3. Concrete		2,100					150
4. Plaster		0,700					20
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						22,0	cm
U-value supplement <input type="text"/> W/(m ² K)		U-Value: 2,127 W/(m ² K)					

Assembly No. Building assembly description					Interior insulation?		
06ud	Floor				<input checked="" type="checkbox"/> yes		
Heat transfer resistance [m^2K/W] interior R_{si} : 0,17		exterior R_{se} :					
Area section 6		λ [$W/(mK)$]	Area section 2 (optional)	λ [$W/(mK)$]	Area section 3 (optional)	λ [$W/(mK)$]	Thickness [mm]
1. Flooring		3,500					30
2. Cement		0,930					20
3. Concrete		2,100					150
4. Rubble		3,500					150
5. XPS insulation		0,035					100
6. New flooring		0,140					20
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						47,0	cm
U-value supplement <input type="text"/> W/(m ² K)		U-Value: 0,302 W/(m ² K)					

Assembly No. Building assembly description					Interior insulation?		
07ud	Inside brick wall			<input checked="" type="checkbox"/>			
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,13				
		exterior R _{se} :	0,04				
Area section 7		λ _i [W/(mK)]	Area section 2 (optional)	λ _i [W/(mK)]	Area section 3 (optional)	λ _i [W/(mK)]	Thickness [mm]
1.	Inside plaster	0,700					40
2.	Bricks	0,520					250
3.	Inside plaster	0,070					40
4.							
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						33,0	cm
U-value supplement <input type="text"/> W/(m ² K)				U-Value: 0,782 W/(m ² K)			

Assembly No. Building assembly description					Interior insulation?		
08ud				<input checked="" type="checkbox"/>			
Heat transfer resistance [m ² K/W]		interior R _{si} :	<input type="text"/>				
		exterior R _{se} :	<input type="text"/>				
Area section 8		λ _i [W/(mK)]	Area section 2 (optional)	λ _i [W/(mK)]	Area section 3 (optional)	λ _i [W/(mK)]	Thickness [mm]
1.							
2.							
3.							
4.							
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						<input type="text"/> cm	
U-value supplement <input type="text"/> W/(m ² K)				U-Value: <input type="text"/> W/(m ² K)			

Assembly No. Building assembly description					Interior insulation?		
09ud				<input checked="" type="checkbox"/>			
Heat transfer resistance [m ² K/W]		interior R _{si} :	<input type="text"/>				
		exterior R _{se} :	<input type="text"/>				
Area section 9		λ _i [W/(mK)]	Area section 2 (optional)	λ _i [W/(mK)]	Area section 3 (optional)	λ _i [W/(mK)]	Thickness [mm]
1.							
2.							
3.							
4.							
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						<input type="text"/> cm	
U-value supplement <input type="text"/> W/(m ² K)				U-Value: <input type="text"/> W/(m ² K)			

EnerPHit planning:

U - V A L U E S O F B U I L D I N G E L E M E

Assembly No.	Building assembly description						Interior insulation?																																																																																										
10ud							<input type="checkbox"/>																																																																																										
Heat transfer resistance [m ² K/W]		interior R _{si} :	<input type="text"/>																																																																																														
		exterior R _{se} :	<input type="text"/>																																																																																														
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">Area section</th> <th>λ [W/(mK)]</th> <th colspan="2">Area section 2 (optional)</th> <th>λ [W/(mK)]</th> <th colspan="2">Area section 3 (optional)</th> <th>λ [W/(mK)]</th> <th>Thickness [mm]</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>2.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>3.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>4.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>5.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>6.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>7.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>8.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> </tbody> </table>								Area section		λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]	1.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	2.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	3.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	4.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	5.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	6.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	7.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	8.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
Area section		λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]																																																																																								
1.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
2.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
3.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
4.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
5.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
6.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
7.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
8.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3				Total																																																																																									
100%		<input type="text"/>		<input type="text"/>		<input type="text"/>		<input type="text"/> cm																																																																																									
U-value supplement <input type="text"/> W/(m ² K)				U-Value: <input type="text"/> W/(m ² K)																																																																																													

Assembly No.	Building assembly description						Interior insulation?																																																																																										
11ud							<input type="checkbox"/>																																																																																										
Heat transfer resistance [m ² K/W]		interior R _{si} :	<input type="text"/>																																																																																														
		exterior R _{se} :	<input type="text"/>																																																																																														
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">Area section</th> <th>λ [W/(mK)]</th> <th colspan="2">Area section 2 (optional)</th> <th>λ [W/(mK)]</th> <th colspan="2">Area section 3 (optional)</th> <th>λ [W/(mK)]</th> <th>Thickness [mm]</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>2.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>3.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>4.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>5.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>6.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>7.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>8.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> </tbody> </table>								Area section		λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]	1.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	2.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	3.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	4.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	5.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	6.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	7.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	8.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
Area section		λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]																																																																																								
1.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
2.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
3.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
4.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
5.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
6.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
7.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
8.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3				Total																																																																																									
100%		<input type="text"/>		<input type="text"/>		<input type="text"/>		<input type="text"/> cm																																																																																									
U-value supplement <input type="text"/> W/(m ² K)				U-Value: <input type="text"/> W/(m ² K)																																																																																													

Assembly No.	Building assembly description						Interior insulation?																																																																																										
12ud							<input type="checkbox"/>																																																																																										
Heat transfer resistance [m ² K/W]		interior R _{si} :	<input type="text"/>																																																																																														
		exterior R _{se} :	<input type="text"/>																																																																																														
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2">Area section</th> <th>λ [W/(mK)]</th> <th colspan="2">Area section 2 (optional)</th> <th>λ [W/(mK)]</th> <th colspan="2">Area section 3 (optional)</th> <th>λ [W/(mK)]</th> <th>Thickness [mm]</th> </tr> </thead> <tbody> <tr> <td>1.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>2.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>3.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>4.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>5.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>6.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>7.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> <tr> <td>8.</td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td></td> <td></td> <td><input type="text"/></td> <td><input type="text"/></td> </tr> </tbody> </table>								Area section		λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]	1.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	2.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	3.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	4.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	5.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	6.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	7.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>	8.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
Area section		λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]																																																																																								
1.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
2.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
3.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
4.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
5.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
6.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
7.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
8.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>																																																																																								
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3				Total																																																																																									
100%		<input type="text"/>		<input type="text"/>		<input type="text"/>		<input type="text"/> cm																																																																																									
U-value supplement <input type="text"/> W/(m ² K)				U-Value: <input type="text"/> W/(m ² K)																																																																																													

Assembly No.	Building assembly description						Interior insulation?
13ud							<input type="checkbox"/>
Heat transfer resistance [m ² K/W]		interior R _{si} :	<input type="text"/>				

EnerPHit planning:

U - V A L U E S O F B U I L D I N G E L E M E N T S

exterior R_{se} :						
Area section 13	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.						
2.						
3.						
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1 100%		Percentage of sec. 2		Percentage of sec. 3		Total cm
U-value supplement W/(m ² K)				U-Value: W/(m ² K)		

Assembly No. Building assembly description		Interior insulation?				
14ud						
Heat transfer resistance [m ² K/W]	interior R_{si} :					
	exterior R_{se} :					
Area section 14	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.						
2.						
3.						
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1 100%		Percentage of sec. 2		Percentage of sec. 3		Total cm
U-value supplement W/(m ² K)				U-Value: W/(m ² K)		

Assembly No. Building assembly description		Interior insulation?				
15ud						
Heat transfer resistance [m ² K/W]	interior R_{si} :					
	exterior R_{se} :					
Area section 15	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.						
2.						
3.						
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1 100%		Percentage of sec. 2		Percentage of sec. 3		Total cm
U-value supplement W/(m ² K)				U-Value: W/(m ² K)		

Assembly No. Building assembly description		Interior insulation?				
16ud						
Heat transfer resistance [m ² K/W]	interior R_{si} :					
	exterior R_{se} :					
Area section 16	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]

EnerPHit planning:

U - V A L U E S O F B U I L D I N G E L E M E N T S

1.								
2.								
3.								
4.								
5.								
6.								
7.								
8.								
Percentage of sec. 1 100%			Percentage of sec. 2			Percentage of sec. 3		
U-value supplement <input type="text"/> W/(m ² K)			U-Value: <input type="text"/> W/(m ² K)					

Assembly No. Building assembly description							Interior insulation?						
17ud							<input type="checkbox"/>						
		Heat transfer resistance [m ² K/W]		interior R _{si} : <input type="text"/>									
				exterior R _{se} : <input type="text"/>									
Area section		λ [W/(mK)]		Area section 2 (optional)		λ [W/(mK)]		Area section 3 (optional)		λ [W/(mK)]		Thickness [mm]	
17													
1.													
2.													
3.													
4.													
5.													
6.													
7.													
8.													
Percentage of sec. 1 100%			Percentage of sec. 2			Percentage of sec. 3							
U-value supplement <input type="text"/> W/(m ² K)			U-Value: <input type="text"/> W/(m ² K)										

Assembly No. Building assembly description							Interior insulation?						
18ud							<input type="checkbox"/>						
		Heat transfer resistance [m ² K/W]		interior R _{si} : <input type="text"/>									
				exterior R _{se} : <input type="text"/>									
Area section		λ [W/(mK)]		Area section 2 (optional)		λ [W/(mK)]		Area section 3 (optional)		λ [W/(mK)]		Thickness [mm]	
18													
1.													
2.													
3.													
4.													
5.													
6.													
7.													
8.													
Percentage of sec. 1 100%			Percentage of sec. 2			Percentage of sec. 3							
U-value supplement <input type="text"/> W/(m ² K)			U-Value: <input type="text"/> W/(m ² K)										

Assembly No. Building assembly description							Interior insulation?						
19ud							<input type="checkbox"/>						
		Heat transfer resistance [m ² K/W]		interior R _{si} : <input type="text"/>									
				exterior R _{se} : <input type="text"/>									
Area section		λ [W/(mK)]		Area section 2 (optional)		λ [W/(mK)]		Area section 3 (optional)		λ [W/(mK)]		Thickness [mm]	
19													
1.													
2.													
3.													
4.													

EnerPHit planning:

U - V A L U E S O F B U I L D I N G E L E M E N T S

5.									
6.									
7.									
8.									
Percentage of sec. 1 100%				Percentage of sec. 2			Percentage of sec. 3		Total
									cm
U-value supplement				W/(m ² K)			U-Value: W/(m ² K)		

Assembly No. Building assembly description								Interior insulation?	
20ud								<input type="checkbox"/>	
Heat transfer resistance [m ² K/W]		interior R _{si} :		<input type="text"/>					
		exterior R _{se} :		<input type="text"/>					
Area section 20		λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]
1.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
2.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
3.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
4.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
5.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
6.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
7.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
8.		<input type="text"/>			<input type="text"/>			<input type="text"/>	<input type="text"/>
Percentage of sec. 1 100%				Percentage of sec. 2			Percentage of sec. 3		Total
									cm
U-value supplement				W/(m ² K)			U-Value: W/(m ² K)		

Secondary Calculation: Equivalent Thermal Conductivity of Still Air Spaces

Air Layer Thickness	mm	Conductive heat transfer
Direction of the thermal flow:	Upwards	h_a W/(m ² K)
	Horizontal	Radiation heat transfer
	Downwards	h_r W/(m ² K)
Emissivity of surface 1		equivalent thermal conductivity
Emissivity of surface 2		λ W/(mK)

Secondary Calculation: Equivalent Thermal Conductivity of Still Air Spaces

Air Layer Thickness of the	100 mm	Conductive heat transfer
	x	h_a 1,95 W/(m ² K)
	Upwards	Radiation heat transfer
	Horizontal	h_r 4,17 W/(m ² K)
Emissivity of surface 1	0,90	equivalent thermal conductivity
Emissivity of surface 3	0,90	λ 0,61 W/(mK)

Wedge-shaped layers (at an inclination of max. 5%)

(Calculation following EN 6946 Appendix C)

Assembly No. Building assembly description					
1a	Exemplary flat roof with wedge-shaped insulation				
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,10		
		exterior R _{se} :	0,04		
A parallel assemblies layer					
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
1. Concrete Ceiling	2,100				
2. PS Rigid Foam	0,040				
3.					
4.					
5.					
6.					
7.					
8.					
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
100%					
Total Width					
Thickness d ₀ [mm]					
160 200					
Total cm					
36,0 cm					
B Wedge-Shaped Assembly Layer					
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
PS rigid foam insulation	0,040				
Thickness d ₁ [mm]					
150					
Percentage of sec. 2					
Percentage of sec. 3					
Thickness d ₁ [cm]					
15,0 cm					
Rectangular Area U-Value:					
U_t: 0,267 W/(m ² K)					
R_t: 3,750 (m ² K)/W					
U-value of triangular area with the thickest point at the apex:					
0,144 W/(m ² K)					
U-value of triangular area with the thinnest point at the apex:					
0,157 W/(m ² K)					
U-value of triangular area with the thinnest point at the apex:					
0,131 W/(m ² K)					

Wedge-shaped layers (at an inclination of max. 5%)

(Calculation following EN 6946 Appendix C)

Assembly No. Building assembly description					
2a					
Heat transfer resistance [$\text{m}^2\text{K}/\text{W}$]		interior R_{si} :	<input type="text"/>		
exterior R_{se} :		<input type="text"/>			
A parallel assemblies layer					
Area section 1	$\lambda_1 [\text{W}/(\text{mK})]$	Area section 2 (optional)	$\lambda_2 [\text{W}/(\text{mK})]$	Area section 3 (optional)	$\lambda_3 [\text{W}/(\text{mK})]$
1.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
2.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
3.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
4.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
5.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
6.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
7.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
8.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
100%		<input type="text"/>		<input type="text"/>	
Total Width					
Thickness d_0 [mm]					
B Wedge-Shaped Assembly Layer					
Area section 2 (optional)	$\lambda_2 [\text{W}/(\text{mK})]$	Area section 3 (optional)	$\lambda_3 [\text{W}/(\text{mK})]$	Thickness d_1 [mm]	
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	
Percentage of sec. 2		Percentage of sec. 3		Thickness d_1 [cm]	
<input type="text"/>		<input type="text"/>		<input type="text"/> cm	
Rectangular Area U-Value: <input type="text"/> $\text{W}/(\text{m}^2\text{K})$					
U-value of triangular area with the thinnest point at the apex: <input type="text"/> $\text{W}/(\text{m}^2\text{K})$					
U-value of triangular area with the thinnest point at the apex: <input type="text"/> $\text{W}/(\text{m}^2\text{K})$					

Non-conditioned attic

Building assembly description					
Roof					
Heat transfer resistance [m ² K/W]		interior R _{si} : 0,17	Exterior absorption coefficient		0,80
		exterior R _{se} : 0,04			Exterior emissivity 0,93
Area section 1		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)
1.	<u>Corrugated galvanised irc</u>	60,000			
2.					
3.					
4.					
5.					
6.					
7.					
8.					
		Thickness [mm]			
		3			
Percentage of sec. 1		Percentage of sec. 2	Percentage of sec. 3	Total	
100%				0,3 cm	
U-value supplement		W/(m ² K)	U-Value:		4,761 W/(m ² K)
Building assembly description					
Exterior attic wall					
Heat transfer resistance [m ² K/W]		interior R _{si} : 0,13	Exterior absorption coefficient		0,80
		exterior R _{se} : 0,04			Exterior emissivity 0,93
Area section 1		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)
1.	<u>Interior plaster</u>	0,350			
2.	<u>Masonry</u>	1,100			
3.	<u>Exterior Render</u>	0,800			
4.					
5.					
6.					
7.					
8.					
		Thickness [mm]			
		15			
		175			
		20			
Percentage of sec. 1		Percentage of sec. 2	Percentage of sec. 3	Total	
100%				21,0 cm	
U-value supplement		W/(m ² K)	U-Value:		2,519 W/(m ² K)

Building assembly description						
Intermediate ceiling						
Heat transfer resistance [m ² K/W] interior R _{si} : 0,17 exterior R _{se} : 0,17						
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Wooden floor	0,130					22
2.						
3.						
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
83%		16,7%				2,2 cm
U-value supplement			U-Value: 1,964 W/(m ² K)			
Attic area			emissivity in the attic		Air exchange in the attic	
Roof area	200,0	m ²	Inner side of the roof / exterior wall	0,93	Air change rate	0,20 1/h
Area of exterior walls and attic	200,0	m ²	Upper side of the interior ceiling	0,93	Volume	200,0 m ³
Area of intermediate ceiling	100,0	m ²				
Equivalent value for the intermediate ceiling (to be linked to worksheets "Components" and "Areas")						
U-Value:	2,732		Absorptivity:	0,780	Emissivity:	0,907
Total solar energy transmittance (informative): 0,085						

AREAS DETERMINATION

Building: Primary School 8 "Sveti Sveti Kiril I Metod" Heating Demand 55 kWh/(m²a)

Summary							Building assembly overview			Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit	Comment					7 months	8 months	
1	Treated Floor Area		719,39	m ²	Treated floor area according to PHPP manual							
2	North Windows	A	0,00	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas. which is displayed in the "Windows" worksheet.			North Windows		2,745	7485	11983
3	East Windows	A	101,98	m ²				East Windows		2,827	502	1524
4	South Windows	A	22,14	m ²				South Windows		2,737	5624	6456
5	West Windows	A	103,69	m ²				West Windows				
6	Horizontal Windows	A	0,00	m ²				Horizontal Windows				
7	Exterior Door	A	2,53	m ²	Please subtract area of door from respective building assembly			Exterior Door		2,250		
8	Exterior Wall - Ambient	A	518,51	m ²	Temperature zone "A" is ambient air.			Exterior Wall - Ambient		0,141	29	265
9	Exterior Wall - Ground	B	235,86	m ²	Temperature zone "B" is the ground.			Exterior Wall - Ground		0,271		
10	Roof/Ceiling - Ambient	A	400,34	m ²				Roof/Ceiling - Ambient		0,113	366	1186
11	Floor slab / basement ceiling	B	400,34	m ²				Floor slab / basement ceiling		0,302		
12	Floor over unheated base	B	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			Floor over unheated basement				
13			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"							
14		X	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f, < t):				75%			
							Thermal bridges - Overview			Ψ [W/(mK)]		
15	Thermal Bridges Ambient	A	164,60	m	Units in m			Thermal Bridges Ambient		0,087		
16	Perimeter Thermal Bridges	P	59,10	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).			Perimeter Thermal Bridges		-0,028		
17	Thermal bridges FS/BC	B	0,00	m	Units in m			Thermal bridges FS/BC				
18	Partition Wall to Neighbour	I	28,60	m ²	No heat losses, only considered for the heating load calculation.			Partition Wall to Neighbour		0,782		
Total thermal envelope				1785,39	m ²				Average Therm. Envelope		0,531	

[Go to building components list](#)

Area input										Sort: AS LIST												
Area Nr.	Building assembly description	Group Nr.	Assigned to group	Quantity	x (a [m]	x	b [m]	+ User-Determined [m ²] -	User Subtraction window areas [m ²] -	Subtraction window areas [m ²]) =	Area [m ²]) =	Selection of building element assembly / certified building system	Nr.	Description (certified component)	U-Value [W/(m²K)]	Deviation from North	Angle of inclination from the horizontal	Orientation	Reduction factor shading	Exterior absorptivity	Exterior emissivity
Treated floor area	1	Treated Floor Area		1	x (x		+ 719,39	-		= 719,4										
North Windows	2	North Windows										0,0	From 'Windows' worksheet			0,000						
East Windows	3	East Windows										102,0	From 'Windows' worksheet			2,745						
South Windows	4	South Windows										22,1	From 'Windows' worksheet			2,827						
West Windows	5	West Windows										103,7	From 'Windows' worksheet			2,737						
Horizontal Windows	6	Horizontal Windows										0,0	From 'Windows' worksheet			0,000						
Exterior Door	7	Exterior Door										2,5	U-value exterior door:			2,25						
Gym west	8	Exterior Wall - Ambient										97,4	01ud Brick walls			0,142	260	90	West	0,70	0,40	0,90
Gym north	8	Exterior Wall - Ambient										67,6	01ud Brick walls			0,142	0	90	North	0,70	0,40	0,90
Gym east	8	Exterior Wall - Ambient										96,0	01ud Brick walls			0,142	90	90	East	0,70	0,40	0,90
Gym south	8	Exterior Wall - Ambient										34,5	01ud Brick walls			0,142	180	90	South	0,70	0,40	0,90
Corridor west	8	Exterior Wall - Ambient										8,8	01ud Brick walls			0,142	260	90	West	0,70	0,40	0,90
Corridor east	8	Exterior Wall - Ambient										11,9	01ud Brick walls			0,142	90	90	East	0,70	0,40	0,90
Gym west ground	9	Exterior Wall - Ground										74,4	04ud Ground walls			0,271						
Gym north ground	9	Exterior Wall - Ground										25,4	04ud Ground walls			0,271						
Gym east ground	9	Exterior Wall - Ground										74,4	04ud Ground walls			0,271						
Gym south ground	9	Exterior Wall - Ground										44,3	04ud Ground walls			0,271						
Corridor west	9	Exterior Wall - Ground										8,7	04ud Ground walls			0,271						
Corridor east	9	Exterior Wall - Ground										8,7	04ud Ground walls			0,271						
Roof gym	10	Roof/Ceiling - Ambient										376,3	03ud Ventilated roof			0,113	0	0	Hor	0,70	0,90	0,90
Roof corridor	10	Roof/Ceiling - Ambient										24,0	03ud Ventilated roof			0,113	0	0	Hor	0,70	0,90	0,90
Floor gym	11	Floor slab / basement ceiling										376,3	06ud Floor			0,302						
Floor corridor	11	Floor slab / basement ceiling										24,0	06ud Floor			0,302						
Gym cocle west	8	Exterior Wall - Ambient							+ 83,46	-		17,8	02ud Concrete wall socle			0,138	260	90	West	0,70	0,40	0,90
Gym cocle north	8	Exterior Wall - Ambient							+ 39,06	-		0,0	02ud Concrete wall socle			0,138	0	90	North	0,70	0,40	0,90
Gym cocle east	8	Exterior Wall - Ambient							+ 83,46	-		17,8	02ud Concrete wall socle			0,138	90	90	East	0,70	0,40	0,90
Gym cocle south	8	Exterior Wall - Ambient							+ 20,16	-		3,2	02ud Concrete wall socle			0,138	180	90	South	0,70	0,40	0,90
Corridor cocle west	8	Exterior Wall - Ambient							+ 12,90	-		5,4	02ud Concrete wall socle			0,138	260	90	West	0,70	0,40	0,90
Corridor cocle east	8	Exterior Wall - Ambient							+ 12,90	-		7,5	02ud Concrete wall socle			0,138	90	90	East	0,70	0,40	0,90
Wall to Sector C	18	Partition Wall to Neighbour							+ 4,00	-		0,0	07ud Inside brick wall			0,782	180	90	South			
24									+ 7,15	-		0,0										
25									+ 0,0	-		0,0										
26									+ 0,0	-		0,0										
27									+ 0,0	-		0,0										
28									+ 0,0	-		0,0										
29									+ 0,0	-		0,0										
30									+ 0,0	-		0,0										
31									+ 0,0	-		0,0										
32									+ 0,0	-		0,0										
33									+ 0,0	-		0,0										
34									+ 0,0	-		0,0										
35									+ 0,0	-		0,0										

AREAS DETERMINATION

Building: Primary School 8 "Sveti Sveti Kiril I Metod" Heating Demand 55 kWh/(m²a)

Group Nr.	Area group	Temp.-zone	Area	Unit	Summary		Comment	Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
					7 months	8 months					
1	Treated Floor Area		719,39	m²	Treated floor area according to PHPP manual						
2	North Windows	A	0,00	m²				North Windows	2,745	7485	11983
3	East Windows	A	101,98	m²			Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas. which is displayed in the "Windows" worksheet.	East Windows	2,827	502	1524
4	South Windows	A	22,14	m²				South Windows	2,737	5624	6456
5	West Windows	A	103,69	m²				West Windows			
6	Horizontal Windows	A	0,00	m²				Horizontal Windows			
7	Exterior Door	A	2,53	m²	Please subtract area of door from respective building assembly			Exterior Door	2,250		
8	Exterior Wall - Ambient	A	518,51	m²	Temperature Zone "A" is ambient air.			Exterior Wall - Ambient	0,141	29	265
9	Exterior Wall - Ground	B	235,86	m²	Temperature zone "B" is the ground.			Exterior Wall - Ground	0,271		
10	Roof/Ceiling - Ambient	A	400,34	m²				Roof/Ceiling - Ambient	0,113	366	1186
11	Floor slab / basement ceiling	B	400,34	m²				Floor slab / basement ceiling	0,302		
12	Floor over unheated base	B	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			Floor over unheated basement			
13			0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"		Factor for X 75%				
14		X	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor (0 < f, < t):						
Total thermal envelope			1785,39	m²				Average Therm. Envelope	0,531		

[Go to building components list](#)

36			x (x	+	+) - 0,0 =					
37			x (x	+	-) - 0,0 =					
38			x (x	+	-) - 0,0 =					
39			x (x	+	-) - 0,0 =					
40			x (x	+	-) - 0,0 =					
41			x (x	+	-) - 0,0 =					
42			x (x	+	-) - 0,0 =					
43			x (x	+	-) - 0,0 =					
44			x (x	+	-) - 0,0 =					
45			x (x	+	-) - 0,0 =					
46			x (x	+	-) - 0,0 =					
47			x (x	+	-) - 0,0 =					
48			x (x	+	-) - 0,0 =					
49			x (x	+	-) - 0,0 =					
50			x (x	+	-) - 0,0 =					
Aend												

AREAS DETERMINATION

Building: Primary School 8 "Sveti Sveti Kiril I Metodij" Heating Demand: 55 kWh/(m²a)

Summary							Building assembly overview		Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit	Comment					7 months	8 months
1	Treated Floor Area		719,39	m ²	Treated floor area according to PHPP manual						
2	North Windows	A	0,00	m ²				North Windows			
3	East Windows	A	101,98	m ²				East Windows	2,745	7485	11983
4	South Windows	A	22,14	m ²				South Windows	2,827	502	1524
5	West Windows	A	103,69	m ²				West Windows	2,737	5624	6456
6	Horizontal Windows	A	0,00	m ²				Horizontal Windows			
7	Exterior Door	A	2,53	m ²	Please subtract area of door from respective building assembly			Exterior Door	2,250		
8	Exterior Wall - Ambient	A	518,51	m ²	Temperature Zone "A" is ambient air.			Exterior Wall - Ambient	0,141	29	265
9	Exterior Wall - Ground	B	235,86	m ²	Temperature zone "B" is the ground.			Exterior Wall - Ground	0,271		
10	Roof/Ceiling - Ambient	A	400,34	m ²				Roof/Ceiling - Ambient	0,113	366	1186
11	Floor slab / basement ceiling	B	400,34	m ²				Floor slab / basement ceiling	0,302		
12	Floor over unheated base	B	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			Floor over unheated basement			
13			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"						
14		X	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor ($f < 1$):			Factor for X	75%		
							Thermal bridges - Overview		Ψ [W/(mK)]		
15	Thermal Bridges Ambient	A	164,60	m	Units in m			Thermal Bridges Ambient	0,087		
16	Perimeter Thermal Bridges	P	59,10	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).			Perimeter Thermal Bridges	-0,028		
17	Thermal bridges FS/BC	B	0,00	m	Units in m			Thermal bridges FS/BC			
18	Partition Wall to Neighbour	I	28,60	m ²	No heat losses, only considered for the heating load calculation.			Partition Wall to Neighbour	0,782		
Total thermal envelope			1785,39	m ²				Average Therm. Envelope	0,531		

[Go to building components list](#)

Thermal Bridge Inputs											
Nr.	Thermal bridge description	Group Nr.	Assigned to group	Quan-ty	x (User deter-mined length [m]	Subtract-user-determine d length [m]	=) =	Length ℓ [m]	Input of thermal bridge heat loss coefficient W/(mK)	Ψ W/(mK)
1	Heated basement perimeter	16	Perimeter Thermal Bridges	1	x (59,10	-) =	59,10	Heated basement perimeter	-0,028
2	Connection to Block C	15	Thermal Bridges Ambient	1	x (4,00	-) =	4,00	Connection to Block C	0,029
3	Roof perimeter	15	Thermal Bridges Ambient	1	x (72,70	-) =	72,70	Roof perimeter	0,055
4	Connection Blocks D&D1	15	Thermal Bridges Ambient	1	x (4,00	-) =	4,00	Connection Blocks D&D1	0,029
5	Outside - inside wall in	15	Thermal Bridges Ambient	1	x (59,10	-) =	59,10	Outside - inside wall insulation	0,109
6	Roof perimeter ^	15	Thermal Bridges Ambient	1	x (24,80	-) =	24,80	Roof perimeter ^	0,148
7					x (-	-) =			
8					x (-	-) =			
9					x (-	-) =			
10					x (-	-) =			
11					x (-	-) =			
12					x (-	-) =			
13					x (-	-) =			
14					x (-	-) =			
15					x (-	-) =			
16					x (-	-) =			
17					x (-	-) =			
18					x (-	-) =			
19					x (-	-) =			
20					x (-	-) =			
21					x (-	-) =			
22					x (-	-) =			
23					x (-	-) =			
24					x (-	-) =			
25					x (-	-) =			
26					x (-	-) =			
27					x (-	-) =			
28					x (-	-) =			
29					x (-	-) =			
30					x (-	-) =			
31					x (-	-) =			
32					x (-	-) =			
33					x (-	-) =			
34					x (-	-) =			
35					x (-	-) =			
36					x (-	-) =			
37					x (-	-) =			
38					x (-	-) =			
39					x (-	-) =			

AREAS DETERMINATION

Building: Primary School 8 "Sveti Sveti Kiril I Metodij" Heating Demand: 55 kWh/(m²a)

Summary						Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit	Comment			7 months	8 months
1	Treated Floor Area		719,39	m ²	Treated floor area according to PHPP manual				
2	North Windows	A	0,00	m ²		North Windows	2,745	7485	11983
3	East Windows	A	101,98	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas.	East Windows	2,827	502	1524
4	South Windows	A	22,14	m ²		South Windows	2,737	5624	6456
5	West Windows	A	103,69	m ²	which is displayed in the "Windows" worksheet.	West Windows			
6	Horizontal Windows	A	0,00	m ²		Horizontal Windows			
7	Exterior Door	A	2,53	m ²	Please subtract area of door from respective building assembly	Exterior Door	2,250		
8	Exterior Wall - Ambient	A	518,51	m ²	Temperature zone "A" is ambient air.	Exterior Wall - Ambient	0,141	29	265
9	Exterior Wall - Ground	B	235,86	m ²	Temperature zone "B" is the ground.	Exterior Wall - Ground	0,271		
10	Roof/Ceiling - Ambient	A	400,34	m ²		Roof/Ceiling - Ambient	0,113	366	1186
11	Floor slab / basement ceiling	B	400,34	m ²		Floor slab / basement ceiling	0,302		
12	Floor over unheated base	B	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"	Floor over unheated basement			
13			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
14		X	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor ($0 < f, < 1$):	Factor for X 75%			
Total thermal envelope						Average Therm. Envelope	0,531		
Go to building components list									
40					x (-) =				
41					x (-) =				
42					x (-) =				
43					x (-) =				
44					x (-) =				
45					x (-) =				
46					x (-) =				
47					x (-) =				
48					x (-) =				
49					x (-) =				
50					x (-) =				
TBend									

A tool for thermal bridge conversion to exterior dimensions				
Description		Units	Example	
	Ψ Interior Dimensions	W/(mK)	0,027	
	Temperature Diff. TB	K	30,000	
Adjacent Area I	Temperature Diff. Δθ I	K	30,000	
	Exterior - Interior Dim. I	m	0,400	
	U-Value building assembly I	W/(m²K)	0,138	
Adjacent Area II	Temperature Diff. Δθ II	K	30,000	
	Exterior - Interior Dim. II	m	0,300	
	U-Value building assembly II	W/(m²K)	0,110	
	Ψ Exterior Dimensions	W/(mK)	-0,061	

HEAT LOSSES THROUGH THE GROUND

Building part 1

Ground characteristics		
Thermal conductivity	λ	2,0 W/(mK)
Heat capacity	p_c	2,0 MJ/(m³K)
Periodic Penetration Depth	δ	3,17 m

Climate data	
Av. Indoor Temp. Winter	T_i 18,0 °C
Av. Indoor Temp. Summer	T_i 24,0 °C
Average Ground Surface Temperature	$T_{g,ave}$ 11,4 °C
Amplitude of $T_{g,ave}$	$T_{g,\Delta}$ 11,4 °C
Phase shifting of $T_{e,m}$	τ 1,0 Months
Length of the Heating Period	n 6,4 Months
Heating Degree Hours - Exterior	G_e 67,4 kKh/a

Building data			U-value floor slab/basement ceiling	U_f	0,302 W/(m²K)
Area of ground floor slab / basement ceiling	A	400,3 m²	Thermal bridges floor slab/basement ceiling	Ψ_B *I	0,00 W/K
Perimeter length	P	133,7 m	U-value floor slab / basement ceiling incl. TB	U'_f	0,302 W/(m²K)
Charact. Dimension of floor slab	B'	5,99 m	Eq. Thickness Floor	d_f	6,63 m

Floor Slab Type (select only one)					
Slab on Grade					
Perimeter Insulation Width/Depth	D	m	Orientation of the Perimeter Ins.	horizontal	
Perimeter Insulation Thickness	d_n	m	(check only one field)	vertical	x
Conductivity perimeter insulation	λ_n	W/(mK)			
X Heated basement or floor slab completely / partially below ground level					
Basement wall height below ground level	z	2,09 m	U-Value below ground wall	U_{wB}	0,271 W/(m²K)
Unheated basement					
Height aboveground wall	h	m	U-Value above ground wall	U_w	
Basement wall height below ground level	z	m	U-Value below ground wall	U_{wB}	
Air Change Unheated Basement	n	h⁻¹	U-Value Basement Floor Slab	U_{IB}	
Air flow basement	V	m³			
Suspended Floor Above a Ventilated Crawl Space (at max. 0.5 m Below Ground)					
U-Value Crawl Space	U_{Crawl}	W/(m²K)	Area of Ventilation Openings	εP	m²
Height of crawl space wall	h	m	Wind Velocity at 10 m Height	v	4,0 m/s
U-Value crawl space wall	U_w	W/(m²K)	Wind Shield factor	f_w	0,05
Additional Thermal Bridge Heat Losses at Perimeter					
Phase shift	β	Months	Steady-State Fraction	$\Psi_{P,stat}^*I$	-1,655 W/K
			Harmonic Fraction	$\Psi_{P,harm}^*I$	-1,655 W/K

Groundwater correction			Groundwater Correction Factor	G_w	1,01144049 -
Depth of the Groundwater Table	z_w	3,0 m			
Groundwater flow rate	q_w	0,05 m/d			

Interim Results		Steady-state heat flow		Φ_{stat}	890,8 W
Phase shift	β	1,34 Months	Periodic Heat Flow	Φ_{harm}	271,3 W
Steady-state transmittance	L_s	135,30 W/K	Heat Losses During Heating Period	Q_{tot}	5410 kWh
Exterior Periodic transmittance	L_{pe}	52,41 W/K			
Transmittance building	L_0	194,73 W/K	Charact. Dimension of floor slab	B'	5,99 m

Monthly Average temperatures in the ground for monthly method (building assembly 1)													
Month	1	2	3	4	5	6	7	8	9	10	11	12	Average value
Winter	11,1	10,4	10,5	11,4	12,8	14,4	15,7	16,4	16,3	15,4	14,0	12,4	13,4
Summer	12,9	12,3	12,4	13,3	14,7	16,3	17,6	18,3	18,1	17,3	15,8	14,3	15,3

Design ground temperature for 'Heating load' worksheet	10,4	For 'Cooling load' worksheet	18,3
Reduction factor for 'Annual heating' worksheet	0,41		

Total result (all building parts)		Steady-state heat flow		Φ_{stat}	890,8 W
Phase shift	β	1,34 Months	Periodic Heat Flow	Φ_{harm}	271,3 W
Steady-state transmittance	L_s	135,30 W/K	Heat Losses During Heating Period	Q_{tot}	5410 kWh
Exterior Periodic transmittance	L_{pe}	52,41 W/K			
Transmittance building	L_0	194,73 W/K	Charact. Dimension of floor slab	B'	5,99 m

Monthly Average temperatures in the ground for monthly method (all building assemblies)													
Month	1	2	3	4	5	6	7	8	9	10	11	12	Average value
Winter	11,1	10,4	10,5	11,4	12,8	14,4	15,7	16,4	16,3	15,4	14,0	12,4	13,4
Summer	12,9	12,3	12,4	13,3	14,7	16,3	17,6	18,3	18,1	17,3	15,8	14,3	15,3

Design ground temperature for 'Heating load' worksheet	10,4	For 'Cooling load' worksheet	18,3
Reduction factor for 'Annual heating' worksheet	0,41		

Either there are inconsistencies between the building assemblies in contact with the ground entered in the worksheets 'Areas' and 'Ground' OR you made an incorrect selection of the typ

P A S S I V E H O U S E - C O M P O N E N T SGo to: [ARFAS](#)[Glazing](#)[Window frame](#)<http://www.passiv.de/komponentendatenbank/en-EN>[Ventilation units](#)[Compact units](#)**Building assemblies (U-values)**

ID	Building system	Building assembly	1		Interior insulation
			Total thickness	U-Value	
		Summary of the constructions calculated in 'U values' worksheet	m	W/(m²K)	-
01ud	Brick walls	Brick walls	0,550	0,142	
02ud	Concrete wall socle	Concrete wall socle	0,670	0,138	
03ud	Roof	Roof	0,475	0,113	
04ud	Ground walls	Ground walls	0,580	0,271	yes
05ud	Floor to unheated basement	Floor to unheated basement	0,220	2,127	
06ud	Floor	Floor	0,470	0,302	yes
07ud	Inside brick wall	Inside brick wall	0,330	0,782	
08ud					
09ud					
10ud					

Glazing		Glazing	
ID	Description	g-Value	U _g -Value
			W/(m ² K)
01ud	44 mm. triple glazing, 2 Low-E, air, alum.spacer	0,51	0,80
02ud			
03ud			
04ud			
05ud			
06ud			
07ud			
08ud			
09ud			
10ud			

Window frames															Window frames			
	Description	U _r -Value				Frame Width				Glazing edge thermal bridge				Installation thermal bridge				Curtain wall facades:
ID		left	right	bottom	above	left	right	bottom	above	Ψ _{Glazing edge left}	Ψ _{Glazing edge right}	Ψ _{Glazing edge bottom}	Ψ _{Glazing edge top}	Ψ _{Installation left}	Ψ _{Installation right}	Ψ _{Installation bottom}	Ψ _{Installation top}	Ψ _{GC ~value Glass carrier}
		W/(m ² K)	W/(m ² K)	W/(m ² K)	W/(m ² K)	m	m	m	m	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/K
01ud	Plastic window frame good	1,60	1,60	1,60	1,60	0,140	0,140	0,140	0,140	0,040	0,040	0,040	0,040	0,040	0,040	0,040	0,040	
02ud	VEKA AG ALPHALINE 90 MD	0,97	0,97	0,97	0,97	0,118	0,118	0,118	0,118	0,030	0,030	0,030	0,030	0,040	0,040	0,040	0,040	
03ud	Aluminium window frame, thermally separated	2,40	2,40	2,40	2,40	0,140	0,140	0,140	0,140	0,040	0,040	0,040	0,040	0,040	0,040	0,040	0,040	
04ud																		
05ud																		
06ud																		
07ud																		
08ud																		
09ud																		
10ud																		

Ventilation units with heat recovery												
					Additional Device Data							
ID	Description	Heat recovery efficiency	Energy recovery value η_{FRG}	Electric efficiency	Entry area		External pressure per line	Fittings Δp_{intern}	Frost protection required	Noise protection		Additional info
	User defined area	%	%	Wh/m³	m³/h	m³/h	Pa	Pa		35 dB(A)	Supply air dB(A)	Extract air dB(A)
01ud	Heat recovery unit	83%		0,40								
02ud	Tangra ventilation unit EVB 06 HiE	82%	0%	0,40	200	600	100	incl.	yes	—	57	57
03ud	Tangra ventilation unit EVB 04 HiE	82%	0%	0,40	100	400	100	incl.	yes	—	61	61
04ud												
05ud	Tangra ventilation unit EVB 16 HiE	82%	0%	0,40	400	1600	100	incl.	yes			
06ud	Tangra ventilation unit EVB 18 HiE	82%	0%	0,40	600	1800	100	incl.	yes			
07ud	Some other	82%	0%	0,40	800	3000	100					
08ud												
09ud												
10ud												

REDUCTION FACTOR SOLAR RADIATION, WINDOW U-VALUE

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C										Annual heating demand: 55 kWh/(m²a)		Heating degree hours: 67,4												
Climate:		User data - Велико Търново					g-Value					Solar radiation reduction factor		Window area		Window U-Value	Glazing area	Average global radiation	Transmission losses		Heat gains solar radiation			
Window area orientation	Global radiation (cardinal points)	Shading	Dirt	Non-perpendicular incident radiation	Glazing fraction					m ²	W/(m ² K)	m ²	kWh/(m ² a)											
maximum:	kWh/(m ² a)	0,75	0,95	0,85	0,000		0,00		0,00	m ²	W/(m ² K)	m ²	kWh/(m ² a)											
North	127	1,00	0,95	0,85	0,000		0,00		0,00		0,00	0,00	127											
East	251	0,78	0,95	0,85	0,507		0,77		0,32	101,98	2,74	51,73	251											
South	444	0,13	0,95	0,85	0,532		0,77		0,06	22,14	2,83	11,78	444											
West	253	0,51	0,95	0,85	0,512		0,77		0,21	103,69	2,74	53,08	281											
Horizontal	417	1,00	0,95	0,85	0,000		0,00		0,00	0,00	0,00	0,00	417											
Total or Average Value for All Windows.						0,77	0,24		227,81	2,75	116,59					42195	11407							
Go to glazing list Go to window frames list										Installation situation user-defined value for $\Psi_{\text{installed}}$ or '1': $\Psi_{\text{installed}}$ from worksheet 'Components' '0': in the case of abutting windows														
Quantity	Description	Deviation from North	Angle of inclination from the horizontal	Orientation	Width	Height	Selection from worksheet 'Areas'	Selection from worksheet 'Components'	Selection from worksheet 'Components'	Perpendicular Radiation	Glazing	Frames (centre)	Ψ_{spacer} (centre)	left	right	bottom	above	$\Psi_{\text{Installation (Average)}}$	Window Area	Glazing Area	U-Value Window	Glazed fraction per window	Transmission-losses	Solar gains
		Degrees	Degrees		m	m	Sort: AS LIST	Sort: AS LIST	-	W/(m ² K)	W/(m ² K)	W/(mK)		W/(mK) or 1/0	W/(mK)		W/(mK)	m ²	m ²	W/(m ² K)	%	kWh/a	kWh/a	
20	Gym Type 1	260	90	West	0,600	1,350	17-Gym cocle west	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	1	1	0,040	16,2	6,85	2,86	42%	3118	538
22	Gym Type 1	90	90	East	0,600	1,350	19-Gym cocle east	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	1	1	0,040	17,8	7,53	2,86	42%	3429	845
2	Gym Type 2	260	90	West	0,600	1,300	17-Gym cocle west	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	1	1	0,040	1,6	0,65	2,86	42%	300	78
6	Gym Type 3	180	90	South	0,600	0,900	20-Gym cocle south	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	1	1	0,040	3,2	1,19	2,87	37%	627	32
3	Gym Type 4	260	90	West	0,900	1,500	1-Gym west	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	1	1	0,040	4,1	2,27	2,82	56%	769	298
4	Gym Type 4	90	90	East	0,900	1,500	3-Gym east	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	1	1	0,040	5,4	3,03	2,82	56%	1026	372
6	Gym Type 4	180	90	South	0,900	1,500	4-Gym south	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	1	1	0,040	8,1	4,54	2,82	56%	1538	185
10	Gym Type 5 west	260	90	West	1,600	0,600	1-Gym west	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	0	1	0,040	9,6	4,22	2,79	44%	1801	379
10	Gym Type 5 west	260	90	West	0,800	1,400	1-Gym west	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	0	1	0	0,040	11,2	5,82	2,75	52%	2076	514
10	Gym Type 5 west	260	90	West	0,800	1,400	1-Gym west	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	0	1	1	0	0,040	11,2	5,82	2,75	52%	2076	514
10	Gym Type 5 east	90	90	East	1,600	0,600	3-Gym east	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	0	1	0,040	9,6	4,22	2,79	44%	1801	515
10	Gym Type 5 east	90	90	East	0,800	1,400	3-Gym east	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	0	1	0	0,040	11,2	5,82	2,75	52%	2076	698
10	Gym Type 5 east	90	90	East	0,800	1,400	3-Gym east	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	0	1	1	0	0,040	11,2	5,82	2,75	52%	2076	698
4	Type 6 west	260	90	West	0,900	1,500	21-Corridor cocle west	94ud Double glazing 4/16mm air4	01ud Plastic window frame good	0,77	2,70	1,60	0,040	1	1	1	1	0,040	5,4	3,03	2,47	56%	898	241
4	Type 6 east	90	90	East	0,900	1,500	22-Corridor cocle east	94ud Double glazing 4/16mm air4	01ud Plastic window frame good	0,77	2,70	1,60	0,040	1	1	1	1	0,040	5,4	3,03	2,47	56%	898	372
4	Type 7 west	260	90	West	1,200	2,600	5-Corridor west	94ud Double glazing 4/16mm air4	01ud Plastic window frame good	0,77	2,70	1,60	0,040	1	1	1	1	0,040	12,5	8,54	2,53	68%	2130	695
3	Type 7 east	90	90	East	1,200	2,600	6-Corridor east	94ud Double glazing 4/16mm air4	01ud Plastic window frame good	0,77	2,70	1,60	0,040	1	1	1	1	0,040	9,4	6,40	2,53	68%	1597	843
10	Gym Type 5 west	260	90	West	1,600	0,600	1-Gym west	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	0	1	0,040	9,6	4,22	2,79	44%	1801	395
10	Gym Type 5 west	260	90	West	0,800	1,400	1-Gym west	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	0	1	0	0,040	11,2	5,82	2,75	52%	2076	536
10	Gym Type 5 west	260	90	West	0,800	1,400	1-Gym west	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	0	1	1	0	0,040	11,2	5,82	2,75	52%	2076	536
10	Gym Type 5 east	90	90	East	1,600	0,600	3-Gym east	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	0	1	0,040	9,6	4,22	2,79	44%	1801	515
10	Gym Type 5 east	90	90	East	0,800	1,400	3-Gym east	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	0	1	0	0,040	11,2	5,82	2,75	52%	2076	698
10	Gym Type 5 east	90	90	East	0,800	1,400	3-Gym east	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	0	1	1	0	0,040	11,2	5,82	2,75	52%	2076	698
8	Gym Type 4	180	90	South	0,900	1,500	4-Gym south	94ud Double glazing 4/16mm air4	03ud Aluminium window frame, thermally	0,77	2,70	2,40	0,040	1	1	1	1	0,040	10,8	6,05	2,82	56%	2051	213

					Window rough openings		installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge	Installation situation user-defined value for $\Psi_{installed}$ or '1': $\Psi_{installed}$ from worksheet 'Components', '0': in the case of abutting windows					Results U- and Ψ -values from 'Components' worksheet can be shown through clicking the '+' sign on the top edge of the sheet.					
Quantity	Description	Deviation from North	Angle of inclination from the horizontal	Orientatio n	Width	Height	Selection from worksheet 'Areas'	Selection from worksheet 'Components'	Selection from worksheet 'Components'	Perpen-dicular Radiation	Glazing	Frames (centre)	Ψ_{spacer} (centre)	left	right	bottom	above	$\Psi_{Installation}$ (Average)	Window Area	Glazing Area	U-Value Window	Glazed fraction per window	Trans-mission-losses	Solar gains
		Degrees	Degrees		m	m		Sort: AS LIST	Sort: AS LIST	-	W/(m ² K)	W/(m ² K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m ²	m ²	W/(m ² K)	%	kWh/a	kWh/a

					Window rough openings		installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge	Installation situation					Results					
Quantity	Description	Deviation from North	Angle of inclination from the horizontal	Orientalion	Width	Height	Selection from worksheet 'Areas'	Selection from worksheet 'Components'	Selection from worksheet 'Components'	Perpendicular Radiation	Glazing	Frames (centre)	Ψ_{spacer} (centre)	left	right	bottom	above	$\Psi_{\text{Installation}}$ (Average)	Window Area	Glazing Area	U-Value Window	Glazed fraction per window	Transmission-losses	Solar gains
		Degrees	Degrees		m	m		Sort: AS LIST	Sort: AS LIST	-	W/(m²K)	W/(m²K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m²	m²	W/(m²K)	%	kWh/a	kWh/a

CALCULATING SHADING FACTORS

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C												Space heating demand: 54,7 kWh/(m²a)												
Latitude: 43,086 °												Useful Cooling Demand: 5,3 kWh/(m²a)												
Climate: User data - Велико Търново												Frequency of overheating: 7,8%												
Quantity	Description	Deviation from North	Angle of inclination from the horizontal	Orientation	Glazing width	Glazing height	Glazing area	Height of the shading object	Horizontal distance	Window reveal depth	Distance from glazing edge to reveal	Overhang depth	Distance from upper glazing edge to overhang	Additional reduction factor winter shading	Additional reduction factor summer shading	Reduction factor z for temporary sun protection	Horizontal shading reduction factor	Reveal shading reduction factor	Overhang shading reduction factor	Total shading reduction factor	Horizontal shading reduction factor	Reveal shading reduction factor	Overhang shading reduction factor	Total shading reduction factor
		Degrees	Degrees		m	m	m	m	m	m	m	m	m	%	%	%	%	%	%	%	%	%	%	%
20	Gym Type 1	260	90	West	0,32	1,07	6,8	22,40	44,00	0,20	0,10	0,15	0,14	95%	70%	60%	65%	77%	94%	45%	72%	91%	98%	27%
22	Gym Type 1	90	90	East	0,32	1,07	7,5			0,20	0,140	0,15	0,14			60%	100%	77%	94%	72%	100%	91%	98%	54%
2	Gym Type 2	260	90	West	0,32	1,02	0,7			0,20	0,140	0,15	0,14	95%	70%	60%	100%	77%	94%	68%	100%	91%	98%	37%
6	Gym Type 3	180	90	South	0,32	0,62	1,2	15,75	6,00	0,20	0,140	0,15	0,14			60%	12%	85%	94%	10%	51%	81%	87%	21%
3	Gym Type 4	260	90	West	0,62	1,22	2,3			0,20	0,140	0,15	0,14	95%	70%	60%	100%	84%	94%	75%	100%	94%	98%	39%
4	Gym Type 4	90	90	East	0,62	1,22	3,0			0,20	0,140	0,15	0,14			60%	100%	84%	94%	79%	100%	94%	98%	55%
6	Gym Type 4	180	90	South	0,62	1,22	4,5	11,53	6,00	0,20	0,140	0,15	0,14			60%	17%	90%	96%	15%	60%	87%	95%	29%
10	Gym Type 5 wes	260	90	West	1,32	0,32	4,2	19,60	44,00	0,20	0,140	0,15	0,14	95%	70%	60%	69%	90%	87%	51%	75%	96%	90%	27%
10	Gym Type 5 wes	260	90	West	0,52	1,12	5,8	19,60	44,00	0,20	0,140	0,15	0,14	95%	70%	60%	69%	82%	94%	50%	75%	93%	98%	29%
10	Gym Type 5 wes	260	90	West	0,52	1,12	5,8	19,60	44,00	0,20	0,140	0,15	0,14	95%	70%	60%	69%	82%	94%	50%	75%	93%	98%	29%
10	Gym Type 5 eas	90	90	East	1,32	0,32	4,2			0,20	0,140	0,15	0,14			60%	100%	90%	87%	78%	100%	97%	91%	53%
10	Gym Type 5 eas	90	90	East	0,52	1,12	5,8			0,20	0,140	0,15	0,14			60%	100%	82%	94%	77%	100%	93%	98%	55%
10	Gym Type 5 eas	90	90	East	0,52	1,12	5,8			0,20	0,140	0,15	0,14			60%	100%	82%	94%	77%	100%	93%	98%	55%
4	Type 6 west	260	90	West	0,62	1,22	3,0	19,85	44,00	0,20	0,140	0,15	0,14	84%	62%	60%	69%	84%	94%	46%	75%	94%	98%	26%
4	Type 6 east	90	90	East	0,62	1,22	3,0			0,20	0,140	0,15	0,14			60%	100%	84%	94%	79%	100%	94%	98%	55%
4	Type 6 east	90	90	East	0,62	1,22	3,0			0,20	0,140	0,15	0,14	84%	62%	60%	65%	88%	97%	47%	72%	95%	99%	25%
4	Type 7 west	260	90	West	0,92	2,32	8,5	22,40	44,00	0,20	0,140	0,15	0,14	84%	62%	60%	65%	88%	97%	47%	72%	95%	99%	25%
3	Type 7 east	90	90	East	0,92	2,32	6,4			0,20	0,140	0,15	0,14			60%	100%	87%	97%	84%	100%	95%	99%	57%
10	Gym Type 5 wes	260	90	West	1,32	0,32	4,2	17,30	44,00	0,20	0,140	0,15	0,14	95%	70%	60%	72%	90%	87%	53%	77%	96%	90%	28%
10	Gym Type 5 wes	260	90	West	0,52	1,12	5,8	17,30	44,00	0,20	0,140	0,15	0,14	95%	70%	60%	72%	82%	94%	53%	77%	93%	98%	30%
10	Gym Type 5 wes	260	90	West	0,52	1,12	5,8	17,30	44,00	0,20	0,140	0,15	0,14	95%	70%	60%	72%	82%	94%	53%	77%	93%	98%	30%
10	Gym Type 5 eas	90	90	East	1,32	0,32	4,2			0,20	0,140	0,15	0,14			60%	100%	90%	87%	78%	100%	97%	91%	53%
10	Gym Type 5 eas	90	90	East	0,52	1,12	5,8			0,20	0,140	0,15	0,14			60%	100%	82%	94%	77%	100%	93%	98%	55%
10	Gym Type 5 eas	90	90	East	0,52	1,12	5,8			0,20	0,140	0,15	0,14			60%	100%	82%	94%	77%	100%	93%	98%	55%
8	Gym Type 4	180	90	South	0,62	1,22	6,1	13,13	6,00	0,20	0,140	0,15	0,14			60%	15%	90%	96%	13%	56%	87%	95%	28%

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C

Treated floor area A_{TFA}

m ²	719
m	2,50
m ³	1798

(Areas worksheet)

Room Height h

Room ventilation volume ($A_{TFA} \cdot h$) = V_V

(Worksheet Annual heating)

Ventilation type

Please select

Balanced PH-Ventilation with HR

Infiltration air change rate

Wind protection coefficients e and f		
Coefficient e for screening class	Several side exposed	One side exposed
No screening	0,10	0,03
Moderate screening	0,07	0,02
High screening	0,04	0,01
Coefficient f	15	20

for annual demand: for Heating Load:

Wind protection coefficient, e	0,07	0,18
Wind protection coefficient, f	15	15
Air Change Rate at Press. Test n_{50}	1/h	2,00
		2,00
	Net Air Volume for Press. Test V_{n50}	3439 m ³
	Air permeability q_{50}	3,85 m ³ /(hm ²)
	for annual demand: for Heating Load:	
Excess extract air	0,00	0,00
Infiltration air change rate $n_{V,Rest}$	1/h	0,268
		0,669

Selection of ventilation data input - Results

The PHPP offers two methods for dimensioning the air quantities and choosing the ventilation unit. Fresh air or extract air quantities for residential buildings and parameters for ventilation system can be determined using the standard planning option in the 'Ventilation' sheet. The 'Additional Vent' sheet has been created for more complex ventilation systems and allows up to 10 different ventilation units. Furthermore, air quantities can be determined on a room-by-room or zone-by-zone basis. Please select your design method here.

Ventilation unit / Heat recovery efficiency design	Average		Extract air excess		Effective heat recovery		Specific power input		Heat recovery efficiency SHX	
	Air Exchange	Average Air Change Rate	(Extract air system)	efficiency	Energy recovery Unit	value	W/m ³	[-]	[-]	[-]
Standard design <input type="checkbox"/>	756	0,42	0,00	81,1%	0,0%	0,40	0,40	0,0%	0 %	0 %
Various vent. units, non residential <input checked="" type="checkbox"/>										

SHX efficiency

η_{SHX} 0 %

STANDARD INPUT FOR BALANCED VENTILATION

Ventilation dimensioning for systems with one ventilation unit

Calculation in sheet 'Additional Vent': Extended data input for balanced ventilation

Occupancy	m ² /P	12
Number of occupants	P	60,0
Supply air per person	m ³ (P*h)	60
Supply air requirement	m ³ /h	3600
Extract air rooms		Bathroom
Quantity	Kitchen	Bathroom (shower only)
Extract air requirement per room		WC
Total Extract Air Requirement	m ³ /h	20
	m ³ /h	20
Design air flow rate (maximum)	m ³ /h	6600

Design air flow rate (maximum)

Type of operation	Daily operation duration	Factors referenced to maximum	Air flow rate	Air change rate
			m ³ /h	1/h
maximum		1,00	6600	3,67
Standard	4,0	0,77	5077	2,82
Basic	6,0	0,54	3554	1,98
Minimum	14,0	0,40	2640	1,47
Average value		0,50	Average air flow rate (m ³ /h)	Average air change rate (1/h)

Selection of ventilation unit with heat recovery

Installation site of ventilation unit	inside the thermal envelope	Heat recovery efficiency	Specific power input [Wh/m ³]	Application range [m ³ /h]	Frost required
Ventilation unit selection	Sort: BY ID 0468v103 ComfoAir XL4400 - Zehnder	η _{HR} 0,84	η _{ERV} 0,00	0,42	1500 - 3200 yes
Go to ventilation units list					
Conductance value of exterior air duct Ψ W/(mK)					
Length of exterior air duct	m	2	See calculation below		
Conductance value of exhaust air duct Ψ W/(mK)	m	2	See calculation below		
Length of exhaust air duct	m	20	Room temperature (°C) Av. Ambient Temp. Heating P. (°C) Av. Ground Temp (°C)	18 4,5 11,4	
Temperature of mechanical services room (Enter only if the central unit is outside of the thermal envelope.)	°C				

Effective heat recovery efficiency η_{HR,eff}

Effective heat recovery efficiency subsoil heat exchanger	SHX efficiency	η _{SHX}
	Heat recovery efficiency SHX	0 %

Secondary calculation

Ψ-value supply or ambient air duct

Nominal width:	60	mm
Insul. Thickness:	80	mm
Reflective?	x	Yes
	x	No
Thermal conductivity	0,033	W/(mK)
Nominal air flow rate		m ³ /h
Δϑ	13 K	
Exterior duct diameter	0,060 m	
Exterior diameter	0,220 m	
α-Interior	#WERT!	W/(m ² K)
α-Surface		W/(m ² K)
Ψ-value		W/(mK)
Surface temperature difference		K

Secondary calculation

Ψ-value extract or exhaust air duct

Nominal width:	60	mm
Insul. Thickness:	80	mm
Reflective?	x	yes
	x	no
Thermal conductivity	0,033	W/(mK)
Nominal air flow rate		m ³ /h
Δϑ	13 K	
Exterior duct diameter	0,060 m	
Exterior diameter	0,220 m	
α-Interior	#WERT!	W/(m ² K)
α-Surface		W/(m ² K)
Ψ-value		W/(mK)
Surface temperature difference		K

Design of air quantities

When designing the air quantities, please consider the design recommendations given above.

The ventilation operation period can be determined on the basis of the daily utilisation hours including purging phase if applicable. In addition, time periods with reduced ventilation requirements (operation modes) can be

Taken into account by means of reduction factors.

Room Nr.	Amount a	Room name	Assignment to ventilation unit	Area A m ²	Clear height h m	Room vol. A x h m ³	Volume flow per room V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{TRANS} m ³ /h	Air change rate per room n 1/h	Utilisation times d/week	d	weeks/yr Weeks	Reduction Red.1	Operation Red. 1	Reduction Red.2	Operation Red.2	Reduction Red.3	Operation Red. 3	Cross check	Average volume flows V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{TRANS} m ³ /h	Average air change rate 1/h
1	1	Entrance	1	14,8	3,00	44	50	100	2,26	14	5	32	100%	0%	60%	70%	40%	30%		7	14	0,31		
2	1	Antechamber	1	16,0	3,00	48	125	100	2,61	14	5	32	100%	0%	60%	70%	40%	30%		17	14	0,36		
3	1	Changing-room	1	10,3	3,00	31	125		4,05	14	5	32	100%	0%	60%	70%	40%	30%		17		0,56		
4	1	WC	1	9,8	3,00	29	150		5,10	14	5	32	100%	0%	60%	70%	40%	30%		21		0,71		
5	1	Walkway	1	19,8	3,00	59	150		2,53	14	5	32	100%	0%	60%	70%	40%	30%		21		0,35		
6	1	Gym 1 - UG	2	271,4	4,90	1330	1000	1000	0,75	14	5	32	100%	0%	60%	80%	40%	20%		144	144	0,11		
7	1	Entrance	3	14,1	3,30	47	50	100	2,14	14	7	50	100%	0%	60%	70%	40%	30%		15		0,65		
8	1	Changing-room	3	16,4	3,30	54	200		3,70	14	7	50	100%	0%	60%	70%	40%	30%		61		1,12		
9	1	WC	3	10,8	3,30	36	100		2,81	14	7	50	100%	0%	60%	70%	40%	30%		30		0,85		
10	1	Walkway	3	21,2	3,30	70	150		2,15	14	7	50	100%	0%	60%	70%	40%	30%		45		0,65		
11	1	Corridor	3	9,2	3,30	30	100		3,28	14	7	50	100%	0%	60%	70%	40%	30%		30		0,99		
12	1	Changing-room	3	12,6	3,30	41	150		3,62	14	7	50	100%	0%	60%	70%	40%	30%		45		1,10		
13	1	Changing-room	3	11,0	3,30	36	150		4,15	14	7	50	100%	0%	60%	70%	40%	30%		45		1,26		
14	1	WC	3	10,8	3,30	36	100		2,81	14	7	50	100%	0%	60%	70%	40%	30%		30		0,85		
15	1	Others	3	8,8	3,30	29	100		3,45	14	7	50	100%	0%	60%	70%	40%	30%		30		1,04		
16	1	Gym	4	280,3	5,30	1485	1150	1200	0,81	14	7	50	100%	20%	60%	40%	40%	40%		387	404	0,27		
17	1	Teachers room	4	10,7	3,30	35	50		1,42	14	7	50	100%	20%	60%	40%	40%	40%		17		0,48		
18													100%											
19													100%											
20													100%											
21													100%											
22													100%											
23													100%											
24													100%											
25													100%											
26													100%											
27													100%											
28													100%											
29													100%											
30													100%											
31													100%											
32													100%											
33													100%											
34													100%											
35													100%											
36													100%											
37													100%											
38													100%											
39													100%											
40													100%											

Additional lines: Please mark complete lines above, copy and paste multiple times

756	756	---	0,22
-----	-----	-----	------

Ventilation unit selection

Up to 10 different ventilation units are considered. By changing the amount, identical units can be considered. The data from PHI certified ventilation units as well as the entry data lines for user data for other ventilation units can also be found in the worksheet "Components". When choosing to use a compact unit the standard design in the Ventilation worksheet has to be used.

[Go to ventilation units list](#)

Data entries for duct sections between the ventilation unit and the thermal envelope

The duct sections between the ventilation unit and the thermal envelope should be as short as possible and should be well insulated, both for interior location of the ventilation unit. These duct sections can be entered here. The heat losses of the overlying duct section will be considered for the effective heat recovery efficiency.

An entered duct section can also be used for multiple ventilation units.

If in the section "Ventilation unit - selection" in one line a ventilation unit is selected as multiple units (amount larger than 1 for identical units), then the corresponding duct sections may simply be entered (duct sections for one ventilation unit).

Temperature of the location of installation **11,0** (only enter when at least one unit is installed outside of the thermal envelope)

Additional lines: Please mark complete lines above, copy and paste multiple times

EnerPHit planning: **SPECIFIC ANNUAL HEATING DEMAND (annual method)**

Climate: User data - Велико Търново	Interior Temperature: 18,0 °C																																																																																																																																																																																																																																																																															
Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C	Building type: School																																																																																																																																																																																																																																																																															
Treated Floor Area A _{TFA} : 719,4 m ²	per m ²																																																																																																																																																																																																																																																																															
<table border="1"> <thead> <tr> <th>Building assembly</th> <th>Temperature Zone</th> <th>Area m²</th> <th>U-Value W/(m²K)</th> <th>Temp. Factor f_t</th> <th>G_t kWh/a</th> <th>kWh/a</th> <th>Treated Floor Area</th> </tr> </thead> <tbody> <tr><td>Exterior Wall - Ambient</td><td>A</td><td>518,5</td><td>* 0,141</td><td>* 1,00</td><td>* 67,4</td><td>= 4910</td><td>6,83</td></tr> <tr><td>Exterior Wall - Ground</td><td>B</td><td>235,9</td><td>* 0,271</td><td>* 0,41</td><td>* 67,4</td><td>= 1773</td><td>2,46</td></tr> <tr><td>Roof/Ceiling - Ambient</td><td>A</td><td>400,3</td><td>* 0,113</td><td>* 1,00</td><td>* 67,4</td><td>= 3041</td><td>4,23</td></tr> <tr><td>Floor slab / basement ceiling</td><td>B</td><td>400,3</td><td>* 0,302</td><td>* 0,41</td><td>* 67,4</td><td>= 3356</td><td>4,66</td></tr> <tr><td>Floor over unheated basement</td><td>B</td><td></td><td></td><td>* 1,00</td><td></td><td></td><td></td></tr> <tr><td></td><td>A</td><td></td><td></td><td>* 0,75</td><td></td><td></td><td></td></tr> <tr><td></td><td>X</td><td></td><td></td><td>* 1,00</td><td>* 67,4</td><td>= 42195</td><td>58,65</td></tr> <tr><td>Windows</td><td>A</td><td>227,8</td><td>* 2,749</td><td>* 1,00</td><td>* 67,4</td><td>= 383</td><td>0,53</td></tr> <tr><td>Exterior Door</td><td>A</td><td>2,5</td><td>* 2,250</td><td>* 1,00</td><td>* 67,4</td><td>= 966</td><td>1,34</td></tr> <tr><td>Exterior TB (length/m)</td><td>A</td><td>164,6</td><td>* 0,087</td><td>* 1,00</td><td>* 67,4</td><td>= -46</td><td>-0,06</td></tr> <tr><td>Perimeter TB (length/m)</td><td>P</td><td>59,1</td><td>* -0,028</td><td>* 0,41</td><td>* 67,4</td><td></td><td>0,00</td></tr> <tr><td>Ground TB (length/m)</td><td>B</td><td></td><td></td><td>* 0,41</td><td></td><td></td><td></td></tr> <tr> <td>Total of all building envelope areas</td> <td></td> <td>1785,4</td> <td></td> <td></td> <td></td> <td></td> <td>KWh/(m²a)</td> </tr> <tr> <td>Transmission heat losses Q_T</td> <td></td> <td></td> <td></td> <td></td> <td>Total 56578</td> <td>78,6</td> <td></td> </tr> <tr> <td colspan="2"> <table border="1"> <thead> <tr> <th>Ventilation System:</th> <th>Effective Air Volume, V_v m³</th> <th>A_{TFA} m²</th> <th>Clear Room Height m</th> <th>m³</th> </tr> </thead> <tbody> <tr><td>Effective heat recovery efficiency of heat recovery</td><td>81%</td><td>719,4</td><td>* 2,50</td><td>= 1798,5</td></tr> <tr><td>Efficiency of Subsoil Heat Exchanger</td><td>0%</td><td></td><td></td><td></td></tr> <tr><td>Energetically Effective Air Exchange n_v</td><td>0,420</td><td>* (1 - 0,81)</td><td>+ 0,268</td><td>= 0,347</td></tr> <tr> <td>V_v m³</td> <td>n_v 1/h</td> <td>c_{Air} W/(m²K)</td> <td>G_t kWh/a</td> <td>kWh/a</td> </tr> <tr> <td>1798,5</td> <td>* 0,347</td> <td>* 0,33</td> <td>* 67,4</td> <td>= 13882</td> <td>19,3</td> </tr> <tr> <td>Ventilation heat losses Q_V</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table> </td> <td></td> </tr> <tr> <td>Total heat losses Q_L</td> <td>(56578 + 13882)</td> <td>Reduction Factor Night/Weekend Saving 1,0</td> <td>70460</td> <td>97,9</td> <td></td> <td></td> </tr> <tr> <td>Orientation of the area</td> <td>Reduction Factor See 'Windows' worksheet</td> <td>g-Value (perp. radiation)</td> <td>Area</td> <td>Radiation HP</td> <td></td> <td></td> </tr> <tr> <td>1. North</td> <td>0,00</td> <td>* 0,00</td> <td>* 0,00</td> <td>* 127</td> <td>= 0</td> <td></td> </tr> <tr> <td>2. East</td> <td>0,32</td> <td>* 0,77</td> <td>* 101,98</td> <td>* 251</td> <td>= 6254</td> <td></td> </tr> <tr> <td>3. South</td> <td>0,06</td> <td>* 0,77</td> <td>* 22,14</td> <td>* 444</td> <td>= 430</td> <td></td> </tr> <tr> <td>4. West</td> <td>0,21</td> <td>* 0,77</td> <td>* 103,69</td> <td>* 281</td> <td>= 4723</td> <td></td> </tr> <tr> <td>5. Horizontal</td> <td>0,00</td> <td>* 0,00</td> <td>* 0,00</td> <td>* 417</td> <td>= 0</td> <td></td> </tr> <tr> <td>Available Solar Heat Gains Q_S</td> <td></td> <td></td> <td>Total 11407</td> <td>15,9</td> <td></td> <td></td> </tr> <tr> <td>Internal Heat Gains Q_I</td> <td>0,024 kh/d * 194 d/a</td> <td>Length heating period Spec. Power q_i W/m²</td> <td>A_{TFA} m²</td> <td>kWh/a</td> <td>kWh/(m²a)</td> </tr> <tr> <td></td> <td></td> <td>* 5,43</td> <td>719,4</td> <td>= 18185</td> <td>25,3</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td>Free Heat Q_F</td> <td>Q_S + Q_I</td> <td>29592</td> <td>41,1</td> </tr> <tr> <td></td> <td></td> <td></td> <td>Q_F / Q_L</td> <td>= 0,42</td> <td></td> </tr> <tr> <td>Utilisation Factor Heat Gains η_G</td> <td>(1 - (Q_F / Q_L)⁵) / (1 - (Q_F / Q_L)⁶)</td> <td>99%</td> <td>kWh/a</td> <td></td> <td></td> </tr> <tr> <td>Heat Gains Q_G</td> <td>η_G * Q_F</td> <td>= 29366</td> <td>40,8</td> <td></td> <td></td> </tr> <tr> <td>Annual heating demand QH</td> <td>Q_L - Q_G</td> <td>= 41094</td> <td>57</td> <td></td> <td></td> </tr> <tr> <td>Limiting value</td> <td>25 KWh/(m²a)</td> <td>Requirement met?</td> <td>no (Yes/No)</td> <td></td> <td></td> </tr> </tbody></table>		Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Temp. Factor f _t	G _t kWh/a	kWh/a	Treated Floor Area	Exterior Wall - Ambient	A	518,5	* 0,141	* 1,00	* 67,4	= 4910	6,83	Exterior Wall - Ground	B	235,9	* 0,271	* 0,41	* 67,4	= 1773	2,46	Roof/Ceiling - Ambient	A	400,3	* 0,113	* 1,00	* 67,4	= 3041	4,23	Floor slab / basement ceiling	B	400,3	* 0,302	* 0,41	* 67,4	= 3356	4,66	Floor over unheated basement	B			* 1,00					A			* 0,75					X			* 1,00	* 67,4	= 42195	58,65	Windows	A	227,8	* 2,749	* 1,00	* 67,4	= 383	0,53	Exterior Door	A	2,5	* 2,250	* 1,00	* 67,4	= 966	1,34	Exterior TB (length/m)	A	164,6	* 0,087	* 1,00	* 67,4	= -46	-0,06	Perimeter TB (length/m)	P	59,1	* -0,028	* 0,41	* 67,4		0,00	Ground TB (length/m)	B			* 0,41				Total of all building envelope areas		1785,4					KWh/(m ² a)	Transmission heat losses Q _T					Total 56578	78,6		<table border="1"> <thead> <tr> <th>Ventilation System:</th> <th>Effective Air Volume, V_v m³</th> <th>A_{TFA} m²</th> <th>Clear Room Height m</th> <th>m³</th> </tr> </thead> <tbody> <tr><td>Effective heat recovery efficiency of heat recovery</td><td>81%</td><td>719,4</td><td>* 2,50</td><td>= 1798,5</td></tr> <tr><td>Efficiency of Subsoil Heat Exchanger</td><td>0%</td><td></td><td></td><td></td></tr> <tr><td>Energetically Effective Air Exchange n_v</td><td>0,420</td><td>* (1 - 0,81)</td><td>+ 0,268</td><td>= 0,347</td></tr> <tr> <td>V_v m³</td> <td>n_v 1/h</td> <td>c_{Air} W/(m²K)</td> <td>G_t kWh/a</td> <td>kWh/a</td> </tr> <tr> <td>1798,5</td> <td>* 0,347</td> <td>* 0,33</td> <td>* 67,4</td> <td>= 13882</td> <td>19,3</td> </tr> <tr> <td>Ventilation heat losses Q_V</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>		Ventilation System:	Effective Air Volume, V _v m ³	A _{TFA} m ²	Clear Room Height m	m ³	Effective heat recovery efficiency of heat recovery	81%	719,4	* 2,50	= 1798,5	Efficiency of Subsoil Heat Exchanger	0%				Energetically Effective Air Exchange n _v	0,420	* (1 - 0,81)	+ 0,268	= 0,347	V _v m ³	n _v 1/h	c _{Air} W/(m ² K)	G _t kWh/a	kWh/a	1798,5	* 0,347	* 0,33	* 67,4	= 13882	19,3	Ventilation heat losses Q _V								Total heat losses Q _L	(56578 + 13882)	Reduction Factor Night/Weekend Saving 1,0	70460	97,9			Orientation of the area	Reduction Factor See 'Windows' worksheet	g-Value (perp. radiation)	Area	Radiation HP			1. North	0,00	* 0,00	* 0,00	* 127	= 0		2. East	0,32	* 0,77	* 101,98	* 251	= 6254		3. South	0,06	* 0,77	* 22,14	* 444	= 430		4. West	0,21	* 0,77	* 103,69	* 281	= 4723		5. Horizontal	0,00	* 0,00	* 0,00	* 417	= 0		Available Solar Heat Gains Q _S			Total 11407	15,9			Internal Heat Gains Q _I	0,024 kh/d * 194 d/a	Length heating period Spec. Power q _i W/m ²	A _{TFA} m ²	kWh/a	kWh/(m ² a)			* 5,43	719,4	= 18185	25,3									Free Heat Q _F	Q _S + Q _I	29592	41,1				Q _F / Q _L	= 0,42		Utilisation Factor Heat Gains η _G	(1 - (Q _F / Q _L) ⁵) / (1 - (Q _F / Q _L) ⁶)	99%	kWh/a			Heat Gains Q _G	η _G * Q _F	= 29366	40,8			Annual heating demand QH	Q _L - Q _G	= 41094	57			Limiting value	25 KWh/(m ² a)	Requirement met?	no (Yes/No)		
Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Temp. Factor f _t	G _t kWh/a	kWh/a	Treated Floor Area																																																																																																																																																																																																																																																																									
Exterior Wall - Ambient	A	518,5	* 0,141	* 1,00	* 67,4	= 4910	6,83																																																																																																																																																																																																																																																																									
Exterior Wall - Ground	B	235,9	* 0,271	* 0,41	* 67,4	= 1773	2,46																																																																																																																																																																																																																																																																									
Roof/Ceiling - Ambient	A	400,3	* 0,113	* 1,00	* 67,4	= 3041	4,23																																																																																																																																																																																																																																																																									
Floor slab / basement ceiling	B	400,3	* 0,302	* 0,41	* 67,4	= 3356	4,66																																																																																																																																																																																																																																																																									
Floor over unheated basement	B			* 1,00																																																																																																																																																																																																																																																																												
	A			* 0,75																																																																																																																																																																																																																																																																												
	X			* 1,00	* 67,4	= 42195	58,65																																																																																																																																																																																																																																																																									
Windows	A	227,8	* 2,749	* 1,00	* 67,4	= 383	0,53																																																																																																																																																																																																																																																																									
Exterior Door	A	2,5	* 2,250	* 1,00	* 67,4	= 966	1,34																																																																																																																																																																																																																																																																									
Exterior TB (length/m)	A	164,6	* 0,087	* 1,00	* 67,4	= -46	-0,06																																																																																																																																																																																																																																																																									
Perimeter TB (length/m)	P	59,1	* -0,028	* 0,41	* 67,4		0,00																																																																																																																																																																																																																																																																									
Ground TB (length/m)	B			* 0,41																																																																																																																																																																																																																																																																												
Total of all building envelope areas		1785,4					KWh/(m ² a)																																																																																																																																																																																																																																																																									
Transmission heat losses Q _T					Total 56578	78,6																																																																																																																																																																																																																																																																										
<table border="1"> <thead> <tr> <th>Ventilation System:</th> <th>Effective Air Volume, V_v m³</th> <th>A_{TFA} m²</th> <th>Clear Room Height m</th> <th>m³</th> </tr> </thead> <tbody> <tr><td>Effective heat recovery efficiency of heat recovery</td><td>81%</td><td>719,4</td><td>* 2,50</td><td>= 1798,5</td></tr> <tr><td>Efficiency of Subsoil Heat Exchanger</td><td>0%</td><td></td><td></td><td></td></tr> <tr><td>Energetically Effective Air Exchange n_v</td><td>0,420</td><td>* (1 - 0,81)</td><td>+ 0,268</td><td>= 0,347</td></tr> <tr> <td>V_v m³</td> <td>n_v 1/h</td> <td>c_{Air} W/(m²K)</td> <td>G_t kWh/a</td> <td>kWh/a</td> </tr> <tr> <td>1798,5</td> <td>* 0,347</td> <td>* 0,33</td> <td>* 67,4</td> <td>= 13882</td> <td>19,3</td> </tr> <tr> <td>Ventilation heat losses Q_V</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>		Ventilation System:	Effective Air Volume, V _v m ³	A _{TFA} m ²	Clear Room Height m	m ³	Effective heat recovery efficiency of heat recovery	81%	719,4	* 2,50	= 1798,5	Efficiency of Subsoil Heat Exchanger	0%				Energetically Effective Air Exchange n _v	0,420	* (1 - 0,81)	+ 0,268	= 0,347	V _v m ³	n _v 1/h	c _{Air} W/(m ² K)	G _t kWh/a	kWh/a	1798,5	* 0,347	* 0,33	* 67,4	= 13882	19,3	Ventilation heat losses Q _V																																																																																																																																																																																																																																															
Ventilation System:	Effective Air Volume, V _v m ³	A _{TFA} m ²	Clear Room Height m	m ³																																																																																																																																																																																																																																																																												
Effective heat recovery efficiency of heat recovery	81%	719,4	* 2,50	= 1798,5																																																																																																																																																																																																																																																																												
Efficiency of Subsoil Heat Exchanger	0%																																																																																																																																																																																																																																																																															
Energetically Effective Air Exchange n _v	0,420	* (1 - 0,81)	+ 0,268	= 0,347																																																																																																																																																																																																																																																																												
V _v m ³	n _v 1/h	c _{Air} W/(m ² K)	G _t kWh/a	kWh/a																																																																																																																																																																																																																																																																												
1798,5	* 0,347	* 0,33	* 67,4	= 13882	19,3																																																																																																																																																																																																																																																																											
Ventilation heat losses Q _V																																																																																																																																																																																																																																																																																
Total heat losses Q _L	(56578 + 13882)	Reduction Factor Night/Weekend Saving 1,0	70460	97,9																																																																																																																																																																																																																																																																												
Orientation of the area	Reduction Factor See 'Windows' worksheet	g-Value (perp. radiation)	Area	Radiation HP																																																																																																																																																																																																																																																																												
1. North	0,00	* 0,00	* 0,00	* 127	= 0																																																																																																																																																																																																																																																																											
2. East	0,32	* 0,77	* 101,98	* 251	= 6254																																																																																																																																																																																																																																																																											
3. South	0,06	* 0,77	* 22,14	* 444	= 430																																																																																																																																																																																																																																																																											
4. West	0,21	* 0,77	* 103,69	* 281	= 4723																																																																																																																																																																																																																																																																											
5. Horizontal	0,00	* 0,00	* 0,00	* 417	= 0																																																																																																																																																																																																																																																																											
Available Solar Heat Gains Q _S			Total 11407	15,9																																																																																																																																																																																																																																																																												
Internal Heat Gains Q _I	0,024 kh/d * 194 d/a	Length heating period Spec. Power q _i W/m ²	A _{TFA} m ²	kWh/a	kWh/(m ² a)																																																																																																																																																																																																																																																																											
		* 5,43	719,4	= 18185	25,3																																																																																																																																																																																																																																																																											
		Free Heat Q _F	Q _S + Q _I	29592	41,1																																																																																																																																																																																																																																																																											
			Q _F / Q _L	= 0,42																																																																																																																																																																																																																																																																												
Utilisation Factor Heat Gains η _G	(1 - (Q _F / Q _L) ⁵) / (1 - (Q _F / Q _L) ⁶)	99%	kWh/a																																																																																																																																																																																																																																																																													
Heat Gains Q _G	η _G * Q _F	= 29366	40,8																																																																																																																																																																																																																																																																													
Annual heating demand QH	Q _L - Q _G	= 41094	57																																																																																																																																																																																																																																																																													
Limiting value	25 KWh/(m ² a)	Requirement met?	no (Yes/No)																																																																																																																																																																																																																																																																													

(This page displays the sums of the monthly method over the heating period)

Climate:	Велико Търново	Interior Temperature:	18	°C
Building:	Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C	Building type:	School	
Spec. Capacity:	204 Wh/(m²K)	Treated Floor Area A _{TFA} :	719,4	m ²
	Temperature Zone	Area	U-Value	Month. Red. Fac.
Building assembly		m ²	W/(m²K)	G _i kWh/a
Exterior Wall - Ambient	A	518,5	* 0,141	* 1,00 * 69 = 5058
Exterior Wall - Ground	B	235,9	* 0,271	* 1,00 * 29 = 1878
Roof/Ceiling - Ambient	A	400,3	* 0,113	* 1,00 * 69 = 3133
Floor slab / basement ceiling	A	400,3	* 0,302	* 1,00 * 29 = 3556
Floor over unheated basement	B	*	*	*
Door	A	*	*	*
Door	X	*	*	*
Windows	A	227,8	* 2,749	* 1,00 * 69 = 43465
Exterior Door	A	2,5	* 2,250	* 1,00 * 69 = 395
Exterior TB (length/m)	A	164,6	* 0,087	* 1,00 * 69 = 995
Perimeter TB (length/m)	P	59,1	* -0,028	* 1,00 * 29 = -49
Ground TB (length/m)	B	*	*	*

Transmission heat losses Q_T

Total 58431 81,2

	Effective Air Volume V _v	A _{TFA} m ²	Clear Room Height m	m ³		
		719	*	2,50		
			=	1798		
	V _{v,system} 1/h	T _l *SHX	T _l HR	V _{v,Res} 1/h		
Effective Air Change Rate Ambient n _{v,a}	0,420	*(1- 0%)	*(1- 0,81)	+ 0,268		
Effective Air Change Rate Ground n _{v,g}	0,420	* 0%	*(1- 0,81)	= 0,347		
				= 0,000		
	V _v m ³	V _{v,equil,fraction} 1/h	C _{de} Wh/(m ³ K)	G _e kWh/a	kWh/a	kWh/(m ² a)
Ventilation losses ambient Q _v	1798	*	0,347	*	69	= 14300
Ventilation losses ground Q _{v,e}	1798	*	0,000	*	33	= 0

Ventilation heat losses Q_v

Total 14300 19,9

Total heat losses Q _L	(Q _T kW/h/a	+ Q _V kW/h/a) * 1,0, =	kWh/a	kWh/(m ²)
Orientation of the area						
See 'Windows' worksheet	Reduction Factor (perp. radiation)	g-Value (perp. radiation)	Area	Global Radiation		
North	0,00	*	0,00	*	0,0	*
East	0,32	*	0,77	*	102,0	*
South	0,06	*	0,77	*	22,1	*
West	0,21	*	0,77	*	103,7	*
Horizontal	0,00	*	0,00	*	0,0	*
Sum opaque areas					500	= 0
						1045


Available Solar Heat Gains Q_s

KVV1D(HM)

	Length Heat. Period d/a	Spec. Power q_i W/m ²	A _{TFA} m ²	kWh/a	kWh/(m ² a)						
Internal Heat Gains Q_I	0,024	*	212	*	5,4	*	719,4	=	19875	=	27,6
										kWh/a	kWh/(m ² a)
	Free Heat Q _F	Q _S + Q _I	=	34530	=	48,0					
		Q _F / Q _L	=	0,47							
Utilisation Factor Heat Gains η_G			=	97%							
				kWh/a							
Heat Gains Q_G		$\eta_G \cdot Q_F$	=	33402	=	46,4					
Annual heating demand QH		Q _L - Q _G	=	39328	=	55					
Limiting value											

Climate: Велико Търново
 Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C
 Interior Temperature: 18 °C
 Building type: School
 Treated Floor Area A_{TEFA}: 719 m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heating Degree Hours - Exterior	14,3	11,3	9,7	5,7	1,8	-0,9	-2,6	-2,3	1,8	5,5	9,1	13,7	67 kWh
Heating Degree Hours - Ground	5,1	5,1	5,6	4,7	3,8	1,3	0,3	-0,2	1,2	1,9	2,9	4,1	36 kWh
Losses - Exterior	13911	10941	9449	5580	1715	-860	-2475	-2256	1719	5309	8833	13323	65189 kWh
Losses - Ground	937	931	1016	866	701	230	59	-35	222	350	527	759	6563 kWh
Sum spec. losses	20,6	16,5	14,5	9,0	3,4	-0,9	-3,4	-3,2	2,7	7,9	13,0	19,6	99,7 kWh/m ²
Solar gains - North	0	0	0	0	0	0	0	0	0	0	0	0	0 kWh
Solar gains - East	699	873	1372	1996	2420	2495	2570	2221	1746	1247	699	599	18937 kWh
Solar gains - South	59	66	82	87	83	79	84	90	93	88	63	55	931 kWh
Solar gains - West	527	664	1057	1314	1555	1538	1634	1556	1299	1007	599	456	13205 kWh
Solar gains - Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0 kWh
Solar gains - Opaque	92	124	196	271	330	340	356	317	247	177	103	81	2634 kWh
Internal Heat Gains	2906	2625	2906	2813	2906	2813	2906	2906	2813	2906	2813	2906	34219 kWh
Sum spec. gains solar + internal	6,0	6,0	7,8	9,0	10,1	10,1	10,5	9,9	8,6	7,5	5,9	5,7	97,2 kWh/m ²
Utilisation Factor	100%	100%	100%	90%	33%	100%	100%	100%	31%	92%	100%	100%	46%
Annual heating demand	10564	7520	4860	632	0	0	0	0	0	682	5086	9984	39328 kWh
Spec. Heating Demand	14,7	10,5	6,8	0,9	0,0	0,0	0,0	0,0	0,0	0,9	7,1	13,9	54,7 kWh/m ²



Annual heating demand: Comparison

Monthly method

(Worksheet Heating) 39328 kWh/a

Annual method

(Worksheet Annual) 41094 kWh/a

54,7 kWh/(m²a) reference to treated floor area according to PHPP57,1 kWh/(m²a) reference to treated floor area according to PHPP

SPECIFIC SPACE HEATING LOAD

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C
 Building type: School
 Climate (HL): Велико Търново
 Treated Floor Area A_{TFA} : 719,4 m²
 Interior Temperature: 18 °C

Weather 1:	Design Temperature		Radiation: North		South		West		Horizontal		W/m ²
	-9,3	°C	19	39	82	35	56	W/m ²			
Weather 2:	-4,8		°C	16	23	40	24	36	W/m ²		
Ground Design Temp.:	10,4	°C	Area	U-value	Factor	TempDiff 1	TempDiff 2	P _{T 1}	P _{T 2}		
Building assembly		Temperature Zone	m ²	W/(m ² K)	Always 1 (except 'X')	K	K	W	W		
1. Exterior Wall - Ambient	A	518,5	*	0,141	1,00	27,3	or	1992	1664		
2. Exterior Wall - Ground	B	235,9	*	0,271	1,00	7,6	or	483	483		
3. Roof/Ceiling - Ambient	A	400,3	*	0,113	1,00	27,3	or	1234	1031		
4. Floor slab / basement ceiling	B	400,3	*	0,302	1,00	7,6	or	915	915		
5. Floor over unheated basement	B	*	*	*	1,00	7,6	or				
6.	A	*	*	*	1,00	27,3	or	22,8			
7.	X	*	*	*	0,75	27,3	or	22,8			
8. Windows	A	227,8	*	2,749	1,00	27,3	or	17121	14302		
9. Exterior Door	A	2,5	*	2,250	1,00	27,3	or	156	130		
10. Perimeter TB (length/m)	A	164,6	*	0,087	1,00	27,3	or	392	328		
11. Perimeter TB (length/m)	P	59,1	*	-0,028	1,00	7,6	or	-13	-13		
12. Ground TB (length/m)	B	*	*	*	1,00	7,6	or	7,6			
13. House/DU Partition Wall	I	28,6	*	0,782	1,00	1,0	or	22	22		

Transmission heat load P_T

$$\text{Total} = \boxed{22303} \text{ or } \boxed{18863}$$

Ventilation System:	A_{TFA} m ²	Clear Room Height m	
	Effective Air Volume, V _v m ³	*	m ³
	719,4	*	1798

$$\eta_{SHX 1} = 0\% \text{ or } \eta_{SHX 2} = 0\%$$

Heat recovery efficiency of the Heat Exchanger	η_{HR}	81%	Heat Recovery Efficiency SHX	0%	Efficiency SHX	$\eta_{SHX 1}$	$\eta_{SHX 2}$
--	-------------	-----	------------------------------	----	----------------	----------------	----------------

$$\eta_{V,Res} (\text{Heating Load}) = 0,669 \quad + \quad \eta_{V,system} = 0,420 \quad * (1 - 0,81) \text{ or } \Phi_{HR} = 0,81 \quad = \quad 1/h = 0,749 \text{ or } 1/h = 0,749$$

Energetically Effective Air Exchange n _v	$n_{V,Res}$ (Heating Load) 1/h	0,669	+ $n_{V,system}$ 1/h	0,420	* (1 - 0,81) or Φ_{HR} = 0,81	= 0,749	or 1/h = 0,749
---	-----------------------------------	-------	----------------------	-------	------------------------------------	---------	----------------

V _v m ³	n _v 1/h	n _v 1/h	C _{Air} Wh/(m ² K)	TempDiff 1 K	TempDiff 2 K	P _{V 1} W	P _{V 2} W
1798,5	*	0,749	0,33	*	27,3 or 22,8	= 12146	= 10147

Total heating load P_L

$$P_T + P_V = \boxed{34449} \text{ or } \boxed{29010}$$

Orientation of the area	Area m ²	g-Value (perp. radiation)	Reduction Factor (see 'Windows' worksheet)	Radiation 1 W/m ²	Radiation 2 W/m ²	P _{T 1} W	P _{T 2} W
1. North	0,0	*	0,0	*	19	or	0
2. East	102,0	*	0,8	*	39	or	973
3. South	22,1	*	0,8	*	82	or	80
4. West	103,7	*	0,8	*	41	or	687
5. Horizontal	0,0	*	0,0	*	56	or	0

$$\text{Total} = \boxed{1740} \text{ or } \boxed{1153}$$

Internal heating load P _I	Spec. Power W/m ²	1,6	*	A_{TFA} m ²	719	P _{I 1} W	P _{I 2} W
--------------------------------------	------------------------------	-----	---	--------------------------	-----	--------------------	--------------------

Heating power (gains) P _G	P _T + P _I	= 2891	or 2204
	P _L - P _G	= 31558	or 26806

$$\text{Heating load P}_H = \boxed{31558} \text{ W}$$

$$\text{Area specific space heating load PH / A}_{TFA} = \boxed{43,9} \text{ W/m}^2$$

Input Max. Supply Air Temperature 52 °C	Max. Supply Air Temperature $\dot{v}_{Supply,Max}$ 52 °C	Supply Air Temperature Without Heating	$\dot{v}_{Supply,Min}$ °C	12,8 °C	13,7 °C
---	--	--	---------------------------	---------	---------

$$\text{For comparison: heating load transportable by the supply Air. P}_{Supply\ Air,Max} = \boxed{9768} \text{ W specific: } 13,6 \text{ W/m}^2$$

(Yes/No)
Supply Air Heating Sufficient? **no**

SUMMER VENTILATION

Building: Primary School 8 "Sveti Sveti Kiril I Metodi"	- Building type: School
Building volume: 1798 m ³	Heat recovery η _{HRV} : 81%
Max. indoor absolute humidity: 12 g/kg	Energy recovery η _{ER} : 0%
Internal humidity sources: 2 g/(m ² h)	Subsoil heat exchanger η _{SHX} : 0%

Results passive cooling		Results active cooling	
Frequency of overheating: 7,8%	at the overheating limit θ _{max} = 24 °C	Useful Cooling Demand: 5,3 kWh/(m ² a)	
Frequency of exceeded humidity: 0,0%		Dehumidification demand: 0,2 kWh/(m ² a)	
max. humidity: 11,2 g/kg			

Summer background ventilation to ensure adequate air quality

Air exchange via ventilation system with supply 1,30 1/h	HRV/ERV in Summer (check only one field)
	None <input checked="" type="checkbox"/>
	automatic bypass, controlled by temperature difference <input type="checkbox"/>
	automatic bypass, controlled by enthalpy difference <input type="checkbox"/>
	always <input type="checkbox"/>
Air exchange via extract air system 1,30 1/h	Specific power consumption (for extract air system) 0,40 Wh/m ³
Window ventilation air exchange 0,09 1/h	

Effective air exchange

n _{V,system} 1/h	η _{V,SHX}	η _{HR}	n _{V,equi,fraction} 1/h
exterior n _{V,e} without HR 1,300	*(1- 0%))*(1- 0,81)	= 0,246
Ground n _{L,g} without HR 1,300	*(1- 0%))*(1- 0,81)	= 1,300
	*		= 0,000
	0%		= 0,000

Ventilation conductance

V _V m ³	n _{V,equi,fraction} 1/h	C _{Air} Wh/(m ² K)	
exterior H _{V,e} without HR 1798	* 0,246	* 0,33	= 146,1 W/K
	* 1,300	* 0,33	= 771,5 W/K
Ground H _{V,g} without HR 1798	* 0,000	* 0,33	= 0,0 W/K
Infiltration, window, extract air system 1798	* 0,000	* 0,33	= 0,0 W/K
	1,658	* 0,33	= 983,8 W/K

Additional Summer Ventilation for Cooling

Additional ventilation regulation
Minimum Acceptable Indoor Temperature 22,0 °C

Type of additional ventilation

Window Night Ventilation, Manual	Night ventilation value 0,00 1/h	
mechanical, automatically Controlled ventilation	Corresponding air change rate 1,30 1/h during operation, in addition to base air change Specific power consumption 0,40 Wh/m ³	Temperature difference Humidity difference <input checked="" type="checkbox"/>

Secondary Calculation: hygienic air exchange through window ventilation

Estimation for window air exchange to ensure sufficient air quality

Description	Day	Day				
Open duration [h/d]	2	2				

Climate Boundary Conditions

Temperature Diff Interior - Exterior	4	4				K
Wind Velocity	1	1				m/s

Window Group 1

Quantity	10	10				
Clear Width	0,55	0,70				m
Clear Height	1,25	1,90				m
Tilting window (check if appropriate)	x	x				m
Opening Width (for tilting windows)	0,070	0,070				m

Window Group 2 (Cross Ventilation)

Quantity	10	10				
Clear Width	0,60	0,75				m
Clear Height	1,35	1,35				m
Tilting window (check if appropriate)	x	x				m
Opening Width (for Tilting Window)	0,070	0,070				m

Difference in Height to Window 1

Result: air exchange	0,04	0,05	0,00	0,00	0,00	0,00	Total
	0,04	0,05	0,00	0,00	0,00	0,00	0,09 1/h

Secondary calculation: additional night ventilation for cooling

Air change value during additional window night ventilation

Description	Night	Night				
Reduction Factor	100%	100%				

Climate Boundary Conditions

Temperature Diff Interior - Exterior	1	1	1	1	1	K
Wind Velocity	0	0	0	0	0	m/s

Window Group 1

Quantity	10	10				
Clear Width	0,55	0,70				m
Clear Height	1,25	1,90				m
Tilting window (check if appropriate)	x	x				m
Opening Width (for Tilting Window)	0,070	0,070				m

Window Group 2 (Cross Ventilation)

Quantity	10	10				
Clear Width	0,60	0,75				m
Clear Height	1,35	1,35				m
Tilting window (check if appropriate)	x	x				m
Opening Width (for Tilting Window)	0,070	0,070				m

Difference in Height to Window 1

Result: night ventilation values	0,15	0,22	0,00	0,00	0,00	0,00	Total
	0,15	0,22	0,00	0,00	0,00	0,00	0,37 1/h

SUMMER: PASSIVE COOLING


Climate: Велико Търново	Building type: School																						
Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C	Treated Floor Area A_{TFA} : 719,4 m ²																						
Overtemperature limit: 24 °C	Building volume: 1798 m ³																						
Nominal humidity: 12 g/kg	Internal humidity sources: 2,0 g/(m ³ h)																						
Spec. Capacity: 204 Wh/(m ² K)																							
Building assembly	Temperature Zone	Area	U-Value	Red. Factor $f_{T,SUMMER}$	H_{SUMMER} Heat Conductance																		
1. Exterior Wall - Ambient	A	518,5	* 0,141	* 1,00	= 72,9																		
2. Exterior Wall - Ground	B	235,9	* 0,271	* 1,00	= 63,8																		
3. Roof/Ceiling - Ambient	A	400,3	* 0,113	* 1,00	= 45,1																		
4. Floor slab / basement ceiling	B	400,3	* 0,302	* 1,00	= 120,8																		
5. Floor over unheated basement	B			* 1,00	=																		
6.	A			* 1,00	=																		
7.	X			* 0,75	=																		
8. Windows	A	227,8	* 2,749	* 1,00	= 626,4																		
9. Exterior Door	A	2,5	* 2,250	* 1,00	= 5,7																		
10. Exterior TB (length/m)	A	164,6	* 0,087	* 1,00	= 14,3																		
11. Perimeter TB (length/m)	P	59,1	* -0,028	* 1,00	= -1,7																		
12. Ground TB (length/m)	B			* 1,00	=																		
					764,4 W/K																		
					182,9 W/K																		
Exterior Thermal Transmittance, $H_{T,e}$																							
Ground Thermal Transmittance, $H_{T,g}$																							
Summer Ventilation from 'SummVent' worksheet																							
Ventilation unit conductance		Ventilation parameter		Summer ventilation regulation																			
Exterior $H_{v,e}$	146,1 W/K	Temperature amplitude summer	11,2 K	HRV/ERV	x																		
without HR	771,5 W/K	Minimum Acceptable Indoor Temperature	22,0 °C	None																			
Ground $H_{v,g}$	0,0 W/K	Heat capacity air	0,33 Wh/(m ³ K)	Controlled by temperature																			
without HR	0,0 W/K	Supply air exchange	1,30 1/h	Controlled by enthalpy																			
Ventilation conductance, others		Ambient air exchange	1,66 1/h	always																			
Exterior	983,8 W/K	Window night ventilation air exchange rate, manual @ 1K	0,00 1/h																				
		Air change rate due to mechanical, automatically controlled ventilation	1,30 1/h	Controlled by temperature																			
		Specific power consumption for	0,40 Wh/m ³	Controlled by humidity	x																		
		η_{HR}	81%																				
		η_{ERV}	0%																				
		η^{SHX}	0%																				
Orientation of the area	Angle Factor Summer	Shading Factor Summer	Loss-Dirt	g-Value (perp. radiation)	Area	Portion of Glazing	Aperture																
1. North	0,9	*	1,00	* 0,95	* 0,0	* 0%	= 0,0																
2. East	0,9	*	0,55	* 0,95	* 102,0	* 51%	= 18,6																
3. South	0,9	*	0,28	* 0,95	* 22,1	* 53%	= 2,1																
4. West	0,9	*	0,28	* 0,95	* 103,7	* 51%	= 9,9																
5. Horizontal	0,9	*	1,00	* 0,95	* 0,0	* 0%	= 0,0																
6. Sum opaque areas							2,5																
Solar Aperture																							
Internal Heat Gains Q_i																							
<table border="1"> <tr> <td>Frequency of Overheating $h_{\vartheta} \geq \vartheta_{max}$</td> <td>7,8%</td> <td>At the overheating limit $\vartheta_{max} = 24$ °C</td> </tr> <tr> <td colspan="3">If the "frequency over 25°C" exceeds 10%, additional measures to protect against the heat during the summer are necessary.</td> </tr> </table>								Frequency of Overheating $h_{\vartheta} \geq \vartheta_{max}$	7,8%	At the overheating limit $\vartheta_{max} = 24$ °C	If the "frequency over 25°C" exceeds 10%, additional measures to protect against the heat during the summer are necessary.												
Frequency of Overheating $h_{\vartheta} \geq \vartheta_{max}$	7,8%	At the overheating limit $\vartheta_{max} = 24$ °C																					
If the "frequency over 25°C" exceeds 10%, additional measures to protect against the heat during the summer are necessary.																							
Daily internal temperature stroke <table style="width: 100%; text-align: center;"> <tr> <td>Transmission kWh/d</td> <td>+</td> <td>Ventilation kWh/d</td> <td>+</td> <td>Solar load kWh/d</td> <td>1/k</td> <td>Spec. Capacity Wh/(m²K)</td> <td>A_{TFA} m²</td> </tr> <tr> <td>(102,7)</td> <td>+</td> <td>325,4</td> <td>+</td> <td>162,4</td> <td>* 1000</td> <td>/ (204) * 719) = 4,0 K</td> <td></td> </tr> </table>								Transmission kWh/d	+	Ventilation kWh/d	+	Solar load kWh/d	1/k	Spec. Capacity Wh/(m ² K)	A_{TFA} m ²	(102,7)	+	325,4	+	162,4	* 1000	/ (204) * 719) = 4,0 K	
Transmission kWh/d	+	Ventilation kWh/d	+	Solar load kWh/d	1/k	Spec. Capacity Wh/(m ² K)	A_{TFA} m ²																
(102,7)	+	325,4	+	162,4	* 1000	/ (204) * 719) = 4,0 K																	

S P E C I F I C U S E F U L C O O L I N G D E M A N D

Climate: **Велико Търново**
 Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C

Interior Temperature: **24** °C
 Building type: **School**
 Treated Floor Area A_{TFA} : **719** m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heating Degree Hours - Exterior	18,8	15,3	14,2	10,1	6,3	3,5	1,9	2,2	6,1	10,0	13,4	18,2	120 kKh
Heating Degree Hours - Ground	9,6	9,1	10,0	9,1	8,3	5,6	4,8	4,3	5,5	6,4	7,2	8,6	88 kKh
Losses - Exterior	47183	38393	35582	25187	15528	8496	4659	5223	15198	24879	33677	45674	299678 kWh
Losses - Ground	1769	1684	1849	1671	1532	1029	884	789	1022	1178	1329	1590	16324 kWh
Losses summer ventilation	12450	10126	9379	6631	4079	2221	1267	1354	3995	6555	8884	12053	78995 kWh
Sum spec. heat losses	85,4	69,8	65,1	46,6	29,4	16,3	9,5	10,2	28,1	45,3	61,0	82,5	549,1 kWh/m ²
Solar load North	0	0	0	0	0	0	0	0	0	0	0	0	0 kWh
Solar load East	521	651	1023	1489	1805	1861	1917	1656	1303	930	521	447	14123 kWh
Solar load South	131	146	183	193	185	174	187	200	206	196	140	122	2063 kWh
Solar load West	311	391	623	774	916	906	963	917	765	593	353	269	7780 kWh
Solar load Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0 kWh
Solar load Opaque	92	124	196	271	330	340	356	317	247	177	103	81	2634 kWh
Internal Heat Gains	2906	2625	2906	2813	2906	2813	2906	2906	2813	2906	2813	2906	34219 kWh
Sum spec. loads solar + internal	5,5	5,5	6,9	7,7	8,5	8,5	8,8	8,3	7,4	6,7	5,5	5,3	84,5 kWh/m ²
Utilisation Factor Losses	6%	8%	11%	17%	29%	50%	50%	72%	26%	15%	9%	6%	15%
Useful Cooling Energy Demand	0	0	0	2	19	169	2956	673	11	1	0	0	3831 kWh
Spec. Cooling Demand	0,0	0,0	0,0	0,0	0,0	0,2	4,1	0,9	0,0	0,0	0,0	0,0	5,3 kWh/m ²
specif. dehumidification demand	0,0	0,0	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,0	0,0	0,2 kWh/m ²
Sensible Fraction	100%	100%	100%	100%	100%	100%	94%	100%	100%	100%	100%	100%	96%



S P E C I F I C U S E F U L C O O L I N G D E M A N D

(This page displays the sums of the monthly method over the cooling period)

Climate: Велико Търново	Building type: School
Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section	Treated Floor Area A_{TFA} : 719,4 m²
Interior temperature summer: 24 °C	Building volume: 1798 m³
Nominal humidity: 12 g/kg	Internal humidity sources: 2,0 g/(m³h)
Spec. Capacity: 204 Wh/(m²K)	

Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Mon. Red. Fac.	G_i kWh/a	kWh/a	per m ² Treated Floor Area	
							kWh/a	m ²
1. Exterior Wall - Ambient	A	518,5	* 0,141	* 1,00	* 54	= 3952	5,49	
2. Exterior Wall - Ground	B	235,9	* 0,271	* 1,00	* 54	= 3440	4,78	
3. Roof/Ceiling - Ambient	A	400,3	* 0,113	* 1,00	* 54	= 2448	3,40	
4. Floor slab / basement c	B	400,3	* 0,302	* 1,00	* 54	= 6512	9,05	
5. Floor over unheated bas	B		*	* 1,00		=		
6. X	A		*	* 1,00		=		
7. X	X		*	* 0,75		=		
8. Windows	A	227,8	* 2,749	* 1,00	* 54	= 33966	47,21	
9. Exterior Door	A	2,5	* 2,250	* 1,00	* 54	= 309	0,43	
10. Exterior TB (length/m)	A	164,6	* 0,087	* 1,00	* 54	= 778	1,08	
11. Perimeter TB (length/m)	P	59,1	* -0,028	* 1,00	* 54	= -90	-0,12	
12. Ground TB (length/m)	B		*	* 1,00		=	0,00	
								KWh/(m ² a)
						Total	51315	71,3

Transmission losses Q_T (negative: heat loads)Total **51315** **71,3****Summer Ventilation** from 'SummVent' worksheet

Ventilation unit conductance	Ventilation parameter	Summer ventilation regulation
Exterior $H_{v,e}$ 146,1 W/K	Temperature amplitude summer 11,2 K	HRV/ERV x
without HR 771,5 W/K	Minimum Acceptable Indoor Temperature 22,0 °C	None
Ground $H_{v,g}$ 0,0 W/K	Heat capacity air 0,33 Wh/(m²K)	Controlled by temperature
without HR 0,0 W/K	Supply air exchange 1,30 1/h	Controlled by enthalpy
Ventilation conductance, others	Ambient air exchange 1,66 1/h	always
Exterior 983,8 W/K	Window night ventilation air exchange rate, manual @ 1K 0,00 1/h	Additional ventilation
	Air change rate due to mechanical, automatically controlled > 1,30 1/h	
	Specific power consumption for 0,40 Wh/m³	
	η_{HR} 81%	
	η_{ERV} 0%	
	η^{*SHX} 0%	

Hygienic air change	$n_{V,system}$ t/h	η^{*SHX}	η_{HR} (considers bypass)	$n_{V,Rest}$ t/h	$n_{V,equifraction}$ t/h
Effective Air Change Rate Ambient $n_{v,a}$	1,300	* (1- 0%)	* (1- 0,00)	+ 1,658	= 2,958
Effective Air Change Rate Ground $n_{v,g}$	1,300	* (1- 0%)	* (1- 0,00)		= 0,000

V _v	$n_{V,equifraction}$	C _{Air} Wh/(m ² K)	G_i kWh/a	kWh/a	kWh/(m ²)
Ventilation losses ambient Q_v	1798	* 2,958	* 0,33	* 53	= 93389
Ventilation losses ground $Q_{V,e}$	1798	* 0,000	* 0,33	* 0	= 0
Heat losses summer ventilation	1798	* 1,117	* 0,33	* 54	= 35481

Total **128870** **179,1**

Total heat losses Q_L	Q_T kWh/a	Q_V kWh/a	kWh/a	kWh/(m ²)
	51315	+ 128870	= 180185	250,5

Orientation of the area	Reduction Factor	g-Value (perp. radiation)	Area m ²	Global Radiation kWh/(m ² a)	kWh/a
1. North	0,40	* 0,00	* 0,0	* 318	= 0
2. East	0,24	* 0,77	* 102,0	* 644	= 11983
3. South	0,13	* 0,77	* 22,1	* 709	= 1524
4. West	0,12	* 0,77	* 103,7	* 653	= 6456
5. Horizontal	0,40	* 0,00	* 0,0	* 1113	= 0
6. Sum opaque areas				2234	

Total **22197** **30,9**

Internal Heat Gains Q_i	kh/d	Length Heat Period d/a	Spec. Power q _i W/m ²	A_{TFA} m ²	kWh/a	kWh/(m ²)
	0,024	* 245	* 5,4	* 719,4	= 22969	31,9

Sum heat loads Q_F kWh/a **45166** **62,8**

Utilisation Factor Heat Losses η_G	Q_L / Q_F	= 23%	kWh/a	kWh/(m ²)
		=		

Useful heat losses $Q_{V,n}$ kWh/a **41335** **57,5**

Useful Cooling Demand Q_K	kWh/a	kWh/(m ²)
	3831	5

Limiting value	kWh/(m ² a)	(Yes/No)	Requirement met?
	15	=	

EnerPHit planning:

C O M P R E S S O R C O O L I N G U N I T S

Climate: Велико Търново	Building type: School
Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Търново	Treated Floor Area A _{TFA} : 719,4 m ²
Interior temperature summer: 24,0 °C	Mechanical cooling: 1,3
Nominal humidity: 12,0 g/kg	Air exchange via ventilation system with supply air: 1,3
Internal humidity sources: 2,0 g/(m ² h)	

Supply Air Cooling

check as appropriate

- On/Off Mode (check as appropriate)
max. cooling capacity (sensible + latent)
Temperature reduction dry
Seasonal energy efficiency ratio

0,0	kW
0,0	K
1,0	

Please select in the Verification sheet "Mechanical cooling".

Recirculation Cooling

check as appropriate

- On/Off Mode (check as appropriate)
max. cooling capacity (sensible + latent)
Volume flow rate at nominal power
Temperature reduction dry
Variable volume flow (check if appropriate)
Seasonal energy efficiency ratio

0,0	kW
0,0	m ³ /h
	K
1,0	

Additional Dehumidification

check as appropriate

- Waste heat to room (please check if applicable)
Seasonal energy efficiency ratio

1,0

Panel Cooling

check as appropriate

- Seasonal energy efficiency ratio

1,0

Useful cooling total

Cooling contribution by:

- Supply Air Cooling**
Recirculation Cooling
Dehumidification
Remaining for Panel Cooling

	sensible kWh/(m ² a)	latent kWh/(m ² a)	COP	Electricity Demand (kWh/a) kWh/(m ² a)	Sensible Fraction
Useful cooling total	5,3	0,2			96%
Supply Air Cooling	(+) / 1,0 = 				
Recirculation Cooling	(+) / 1,0 = 				
Dehumidification	 / 1,0 = 				0%
Remaining for Panel Cooling	 / 1,0 = 				100%
Total	(0,0 + 0,0) / = 0,0				0%

Total

(Yes/No)


Unsatisfied Demand

0,0	0,0
------------	------------

Cooling demand covered?

COMPRESSOR COOLING UNITS**Humidity loads and humidity removal**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Internal humidity sources:	1,1	1,0	1,1	1,0	1,1	1,0	1,1	1,1	1,0	1,1	1,0	1,1	12
Infiltration/Window/Extract air system	-22,9	-20,3	-20,8	-16,3	-10,4	-4,6	-2,2	-3,3	-8,6	-13,9	-17,6	-22,2	-163
Supply air ventilation system	-17,9	-15,9	-16,3	-12,8	-8,2	-3,6	-1,7	-2,6	-6,7	-10,9	-13,8	-17,4	-128
Summer ventilation window	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Summer ventilation mechanically	0,0	0,0	0,0	0,0	0,0	0,0	-0,7	0,0	0,0	0,0	0,0	0,0	-1
Total humidity load	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Dehumidification by supply air cooling	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Dehumidification by circulation cooling	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Additional Dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,0	0,0	0
Total dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,0	0,0	0
Unnecessary dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Missing dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0



COOLING LOAD

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C		Building type: School										
Climate (HL): Велико Търново		Treated Floor Area A _{TFA} : 719,4 m ²	Interior Temperature: 24 °C									
		Building volume: 1798 m ³	Spec. Capacity: 204 Wh/m ²									
		Nominal humidity: 12,0 g/kg	Internal humidity sources: 2,0 g/kg									
Temperature:	Ambient Air	Dew Point	Sky									
Weather 1:	27,9 °C	18,6 16,5 °C										
Weather 2:	24,3 °C	18,6 18,6 °C										
Ground Design Temp.:	18,3 °C	SHX 11,4 °C										
Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Factor 1 (except 'X')	TempDiff 1 K	TempDiff 2 K	P _T 1 W	P _T 2 W				
1. Exterior Wall - Ambient	A	518,5	* 0,141	* 1,00	* 3,9 or 0,3	=	282	or 19				
2. Exterior Wall - Ground	B	235,9	* 0,271	* 1,00	* 5,7 or -5,7	=	-366	or -366				
3. Roof/Ceiling - Ambient	A	400,3	* 0,113	* 1,00	* 3,9 or 0,3	=	175	or 12				
4. Floor slab / basement ceiling	B	400,3	* 0,302	* 1,00	* 5,7 or -5,7	=	-694	or -694				
5. Floor over unheated basement	B		*	* 1,00	* 5,7 or -5,7	=		or				
6.	A		*	* 1,00	* 3,9 or 0,3	=		or				
7.	X		*	* 0,75	* 3,9 or 0,3	=		or				
8. Windows	A	227,8	* 2,749	* 1,00	* 3,9 or 0,3	=	2421	or 167				
9. Exterior Door	A	2,5	* 2,250	* 1,00	* 3,9 or 0,3	=	22	or 2				
10. Exterior TB (length/m)	A	164,6	* 0,087	* 1,00	* 3,9 or 0,3	=	55	or 4				
11. Perimeter TB (length/m)	P	59,1	* -0,028	* 1,00	* 5,7 or -5,7	=	10	or 10				
12. Ground TB (length/m)	B		*	* 1,00	* 5,7 or -5,7	=		or				
13. House/DU Partition Wall	I	28,6	* 0,782	* 1,00	* 4,0 or 4,0	=	89	or 89				
14. Radiation correction ambient air			L _{Ambient} W/K -13,3		* 3,9 or 0,3	=	-52	or -4				
15. Radiation correction sky			L _{Sky} W/K 13,2	*	* -7,5 or -5,4	=	-98	or -71				
Transmission heat load P_T					Total	=	1844	or -833				
Ventilation load	V _v m ³	n _{v,equal,fraction} 1/h	n _{v,equal,fraction} 1/h	C _{Air} Wh/(m ² K)	TempDiff 1 K	TempDiff 2 K	P _v 1 W	P _v 2 W				
Exterior P _{V,o}	1798	*	2,958	or 2,958 *	0,33	* 3,9 or 0,3	= 6786	or 467				
Ground PL,e	1798	*	0,000	or 0,000 *	0,33	* -12,6 or +12,6	= 0	or 0				
Summer ventilation P _{L,s}	1798	*	0,000	or 0,000 *	0,33	* 0,0 or 0,0	= 0	or 0				
Ventilation heat load P_v					Total	=	6786	or 467				
Orientation of the area	Area m ²	g-Value (perp. radiation)	Reduction Factor (see 'Windows' worksheet)	Radiation 1 W/m ²	Radiation 2 W/m ²	P _T 1 W	P _T 2 W					
1. North	0,0	* 0,0	* 0,40	* 92 or 63	= 0	or 0	or 0					
2. East	102,0	* 0,8	* 0,24	* 197 or 158	= 3666	or 2945	or 2945					
3. South	22,1	* 0,8	* 0,13	* 185 or 236	= 398	or 508	or 508					
4. West	103,7	* 0,8	* 0,12	* 203 or 173	= 2012	or 1712	or 1712					
5. Horizontal	0,0	* 0,0	* 0,40	* 349 or 268	= 0	or 0	or 0					
6. Sum opaque areas					Total	=	6786	or 549				
Solar load P_s					Total	=	6768	or 5714				
Internal heating load P_i				Spec. Power W/m ²	A _{TFA} m ²	P _i 1 W	P _i 2 W					
				5,4 *	719	= 3906	or 3906					
P_r + P_v + P_s + P_i				Total	=	19304	or 9255					
Cooling load P_c				Total	=	19304	W					
Area specific cooling load P_c / A_{TFA}				Total	=	26,8	W/m ²					
Please enter the minimum supply air temperature: 3 °C		Supply air temperature without cooling		θ _{Supply,Min} °C		27,9 °C	24,3 °C					
				W		W	W					
For comparison: cooling load, transportable through the supply air P _{Supply,Max}				=	19185 W/m ²	16408 W/m ²						
				specific:	26,7	22,8						
				(yes/no)	Air conditioning over the supply air possible? no							
Daily internal temperature stroke	Transmission W	Ventilation W	Solar load W	Time h/d	Spec. Capacity Wh/(m ² K)	A _{TFA} m ²	P _T K					
	(1844,1 + 6786,3 + 6767,6) *	24	/ (204 * 719) = 2,5 K									
Dehumidification load P_d from 'Cooling' worksheet												
Absolute humidity exterior air	13,4 or 3518	g/kg kg/h	Absolute humidity supply air	13,4 or 2759	g/kg kg/h							
Ambient air mass flow	3518	kg/h	Supply air mass flow	3982	kg/h							
Summer ventilation air mass flow	0 or 5078	kg/h	Humidity load, supply air	3982 or 1439	g/h							
Humidity load, outside air	5078	g/h	Humidity load, internal	1439	g/h							
Enthalpy of vaporisation Wh/kg 707,122 / 1000		g/kg	Humidity load g/h 10499	or 10499	g/h	P _d 1 W 7424	P _d 2 W 7424					
					=							
Dehumidification load P_d				Total	=	7424	W					
Area specific dehumidification load P_d / A_{TFA}				Total	=	10,3	W/m ²					
Monthly Average values	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Spec. Cooling Demand	0,0	0,0	0,0	0,0	0,0	0,2	4,1	0,9	0,0	0,0	0,0	0,0
Spec. dehumidification demand	0,0	0,0	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,0	0,0
Sensible Fraction	100%	100%	100%	100%	100%	100%	94%	100%	100%	100%	100%	100%
Minimum of sensible cooling load fraction occurred 100%												

HEAT DISTRIBUTION AND DHW SYSTEM

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C

Interior Temperature:	18	°C
Building type:	School	
Treated Floor Area A _{TFK} :	719	m ²
Occupancy:	60,0	Pers
Number of dwelling units:	1	
Annual heating demand q _{Heating} :	39328	kWh/a
Length of Heating Period:	194	d
Average heating load Pave:	8,4	kW
Marginal Utilisability of Additional Heat Gains:	96%	

Space Heat Distribution

Length of Distribution Pipes	L _H (Project)
Heat Loss Coefficient per m Pipe	Ψ (Project)
Temperature of the Room Through Which the Pipes	ϑ _X Mechanical Room
Design Flow Temperature	ϑ _{dist} Flow, Design Value
Design system heating load	Q _{heating} (exist./calc.)
Flow Temperature Control (check)	
Design Return Temperature	ϑ _R = 0.714*(J _{dist} -20)+20
Annual Heat Emission per m of Plumbing	Q [*] _{HL} = Y (J _m -ϑ _X) t _{heating} * 0.024
Possible Utilization Factor of Released Heat	η _G
Annual Losses	Q _{HL} = L _H · q [*] _{HL} · (1-η _G)
Specif. losses	q _{HL} = Σ Q _{HL} / A _{TFK}
*Performance ratio of heat distribution	e _{a,HL} = (q _H + q _{HL}) / q _H

Warm region	Parts			Total
	1	2	3	
12,00				m
0,198				W/(mK)
18				°C
55,0				°C
14,0				kW
x				
45,0				°C
21				kWh/(m·a)
96%				-
10	0	0	10	kWh/a
				kWh/(m ² a)
100%				0,0

DHW: Standard Useful Heat

DHW Consumption per Person and Day (60 °C)	V _{DHW} (Project or Average Value 25 Litres/P/d)
Average Cold Water Temperature of the Supply	ϑ _{DHW} Temperature of drinking water
DHW Non-Electric Wash and Dish	(Electricity worksheet)
Useful heat - DHW	Q _{DHW}
Specif. useful heat - DHW	q _{DHW} = Q _{DHW} / A _{TFK}

10,0	litre/Person/d
11,4	°C
0	kWh/a
12342	kWh/a
	kWh/(m ² a)
17,2	

DHW Distribution and Storage

Length of Circulation Pipes (Flow + Return)	L _{HS} (Project)
Heat Loss Coefficient per m Pipe	Ψ (Project)
Temperature of the Room Through Which the Pipes	ϑ _X Mechanical Room
Design Flow Temperature	ϑ _{dist} Flow, Design Value
Daily circulation period of operation.	t _{Circ} (Project)
Design Return Temperature	ϑ _R = 0.875*(ϑ _{dist} -20)+20
Circulation period of operation per year	t _{Circ} = 365 t _{Circ}
Annual Heat Released per m of Pipe	q [*] _Z = Y (J _m -ϑ _X) t _{Circ}
Possible Utilization Factor of Released Heat	η _{G,DHW} = η _{heating} /365d * η _G
Annual Heat Loss from Circulation Lines	Q _Z = L _{HS} · q [*] _Z · (1-η _{G,DHW})

Warm region	Parts			Total
	1	2	3	
8,0				m
0,198				W/m/K
18				°C
60,0				°C
12,0				h/d
55				°C
4380				h/a
34				kWh/m/a
51%				-
134			134	kWh/a

Total length of individual pipes

L_U (Project)

Exterior pipe diameter

d_{U,Pipe} (Project)

Tap openings per person per day

Utilisation days per year

Heat loss per tap opening

Amount of tap openings per year

Annual Heat Loss

Possible Utilization Factor of Released Heat

Annual Heat Loss of individual pipes

$$Q_{individual} = (C_{H2O} V_{H2O} + C_{Mw} V_{Mw}) (\vartheta_{sum} - \vartheta_X)$$

$$n_{Tap} = n_{Pers} \cdot n_{Tap} \cdot d / n_{WE}$$

$$q_U = n_{Tap} \cdot q_{individual}$$

$$\eta_{G,U} = \eta_{heating}/365d * \eta_G$$

$$Q_U = q_U \cdot (1 - \eta_{G,U})$$

9,00				m
0,008				m
3	3	3	3	-
250	250	250	250	d
0,0127				kWh/tap opening
45000				Tap openings per year
574				kWh/a
51%				-
281			281	kWh/a

Average Heat Released from storage

P_S

Possible Utilization Factor of Released Heat

η_{G,S}

Annual Heat Losses from storage

Q_S

$$= \eta_{heating}/365d * \eta_G$$

$$= P_S \cdot 8,760 \text{ kWh} \cdot (1 - \eta_{G,S})$$

133				w
51%				
571			571	kWh/a

Total heat losses of the DHW system

Q_{WL}

$$= Q_Z + Q_U + Q_S$$

Specif. losses of the DHW system

Q_{WL}

$$= Q_{WL} / A_{TFK}$$

Performance ratio DHW-distribution + storage

e_{a,WL}

$$= (q_{TDHW} + q_{WL}) / q_{TDHW}$$

Total heating demand of DHW system

Q_{gDHW}

$$= Q_{DHW} + Q_{WL}$$

Totalspec. heating demand of DHW system

Q_{gDHW}

$$= Q_{gDHW} / A_{TFK}$$

986	1,4	kWh/a
108%	-	
13329		kWh/a

Secondary calculation: Ψ -values of plumbing

Nominal width:	50	mm
Insulation Thickness:	60	mm
Mirrored?	Yes	
	x	No
Thermal Conductivity	0,040	W/(mK)
$\Delta\vartheta$	30 K	
Interior Pipe Diameter:	0,050 m	
Exterior Pipe Diameter	0,052 m	
Exterior Pipe Diameter	0,172 m	
α -Surface	6,05 W/(m ² K)	
Ψ -Value	0,198 W/(mK)	
Surface Temperature Difference	1,812 K	

SOLAR THERMAL SYSTEM

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C

Building type: School

Treated Floor Area A_{TFA}: 719,4 m²**Solar fraction**

Heating Demand DHW	q _{DHW}	13329 kWh/a	(DHW+Distribution)
Annual heating demand		39339 kWh/a	(Worksheets Heating & DHW+Distribution)

Heating support (please check, if applicable)		
DHW priority (check if appropriate)	x	
Latitude:	43,1 °	(Worksheet Climate)

Collector: Improved flat plate PK SL AL

Solar Collector Area	0,00 m ²
Deviation from North	180 °
Angle of Inclination from the Horizontal	45 °
Height of the Collector Field	1,00 m
Height of Horizon	
Horizontal Distance	a _{Hori} m
Additional Reduction Factor Shading	r _{other}

Occupancy	60,0 Persons
Specific Collector Area	0,0 m ² /Pers

Estimated solar DHW fraction

0%
0%
0%


0 kWh/a
0 kWh/a
0 kWh/a

0 kWh/(m ² a)
0 kWh/(m ² a)
0 kWh/(m ² a)

Estimated solar coverage for heating**Solar heat contribution total****Secondary Calculation of Storage Losses**

Solar Storage: Simple storage 800 l

Total storage volume	800 litre
Volume Standby Part (above)	240 litre
Volume Solar Part (below)	560 litre
Specific heat losses storage (total)	3,8 W/K
Typical Temperature DHW	60 °C
Room Temperature	20 °C
Storage heat losses (standby part only)	40 W
Total storage heat losses	152 W



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heating demand DHW-preparation	1132	1022	1132	1096	1132	1096	1132	1132	1096	1132	1096	1132	13329
Heating demand space heating	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Heating demand	1132	1022	1132	1096	1132	1096	1132	1132	1096	1132	1096	1132	13329
Radiation on Tilted Collector Surface	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Please enter: Solar production for DHW													0
Please enter: Solar production for heating													0
DHW heat demand covered by solar	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Heating demand covered by solar	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Heating demand covered by solar	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Solar fraction	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-

Hit planning:

PHOTOVOLTAIC SYSTEM

Building:	Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C
Climate:	Велико Търново

Building type: school

Information from the module data sheet

Technology Amorph-Si

Nominal current	I_{MPP0}	A
Nominal voltage	U_{MPP0}	V
Nominal power	P_n	W _p
Temperature coefficient short-circuit current	α	%/K
Temperature coefficient open-circuit voltage	β	%/K

Further specifications


Latitude:
Number of modules
Deviation from North
Angle of inclination from the horizontal
Height of module array
Height of horizon
Horizontal distance
Additional Reduction Factor Shading
Efficiency of the inverter

n_M	43,1	°
		°
		°
		m
h_{Hori}		m
a_{Hori}		m
r_{other}		
η_{HRV}		

(Worksheet Climate)

Annual yield of the inverter
Annual losses due to shading
PE value (non-renewable)
CO₂-equivalent emission value

kWh
kWh
g/kWh



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Solar radiation on tilted surface	0	0	0	0	0	0	0	0	0	0	0	0	kWh/m²/a
Ambient temperature	-1	1	5	10	16	19	22	21	16	11	5	0	°C
total monthly generation	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Losses due to shading situation	0	0	0	0	0	0	0	0	0	0	0	0	kWh/a

E L E C T R I C I T Y D E M A N D

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" Calculation in worksheet 'Electricity non-res'!

Column Nr.	Households			Solar fraction of DHW Laundry&Dish			Prim. Energy Factors:			
	1 HH	2 P	3 m²	Marginal Performance Ratio DHW	110%	Marginal Performance Ratio Heating	110%	Electricity	2,6 kWh/kWh	
Application	Used ? (1/0)	Within the Thermal Envelope? (1/0)	Norm Demand	Utilization Factor	Frequency	Reference Quantity	Useful Energy (kWh/a)	Electric Fraction	Natural Gas	1,1 kWh/kWh
Dishwashing	1 1	1,10	kWh/Use	*	1,00	*	65 /P*a	*	4290	= 4290
Cold water connection				*	1,00	*	57 /P*a	*	3762	= 3762
Clothes washing	1 1	1,10	kWh/Use	*	0,88	*	60,0 /P*a	*	10474	= 10474
Cold water connection				Residual dampness	0,60	*	57 /P*a	*	0	= 0
Clothes drying with:	1 1	3,50	kWh/Use	*	0,60	*	60,0 /P*a	*	0	= 0
Condensation Dryer				*	1,00	*	365 d/a	*	285	= 285
Energy consumed by evaporation	0 1	3,13	kWh/Use	*	0,90	*	365 d/a	*	289	= 289
Refrigerating	1 1	0,78	kWh/d	*	1,00	*	365 d/a	*	0	= 0
Freezing	1 0	0,88	kWh/d	*	1,00	*	500 /P*a	*	7500	= 7500
or combination	0 1	1,00	kWh/d	*	1,00	*	60,0 /P*a	*	0	= 0
Cooking with:	1 1	0,25	kWh/Use	Percentage CFLs	0%	*	2,90 kh/(P*a)	*	10440	= 10440
Electricity				*	1,00	*	0,55 kh/(P*a)	*	2640	= 2640
Lighting	1 1	60	W	*	1,00	*	1,00 /P*a	*	3000	= 3000
Consumer electronics	1 1	80	W	*	1,00	*	1,00 /P*a	*	14965	= 14965
Small appliances, etc.	1 1	50	kWh							
Total aux. electricity										
Other:										
			kWh/a				0		0	= 0
			kWh/a				0		0	= 0
			kWh/a				0		0	= 0
Total							57644 kWh		57644 kWh	DHW Non-Electric - Wash&Dish
Specific Demand									0	= 0
Recommended maximum value								18	0,0 kWh/(m²a)	Non-Renewable Non-Electric DHW Wash&Dish
									208,3	= 208,3 kWh/(m²a)

UTILISATION non-residential Use

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C

Utilisation Pattern		Periods of utilisation and operation	Begin Utilisation [h]	End Utilisation [h]	Daily Utilisation Hours [h/d]	Annual Utilisation Days [da]	Annual Utilisation Hours [h/a]	Annual Utilisation Hours During Daytime [h/a]	Annual Utilisation Hours During Nighttime [h/a]	Daily operating hours of heating	Daily operating hours of ventilation	Lighting	Illumination Level [lux]	Height of utilisation level (0,8 or 0,0 m)	Height of utilisation level (0,8 or 0,0 m)	Relative Absenteism	Part Use Factor of Building Operating Period for Lighting	Average Occupancy [m²/Pers.]
1	Lobbies	7,5	20	12	250	3000	2627	373	14	14		200	0,0	0,0	0,80	1,00		
2	Corridors	7,5	20	12	180	2160	1891	269	14	14		100	0,0	0,0	0,80	1,00		
3	WC, Sanitary	7,5	22	15	250	3625	2630	995	17	17		200	0,8	0,8	0,90	1,00		
4				0	0	0	0	0	2	2			0,8					
5	Teacher offices	7,5	18	11	180	1890	1803	87	13	13		300	0,8	0,8	0,30	0,70	10,0	
6	Classroom	7,5	18	11	180	1890	1803	87	13	13		300	0,8	0,8	0,25	0,90	3,0	
7	Stairs	7,5	22	15	250	3625	2630	995	17	17		100	0,0	0,0	0,80	1,0		
8				0	0	0	0	0	2	2			0,8					
9				0	0	0	0	0	2	2			0,8					
10	Gymnasium	7,5	22	15	250	3625	2630	995	17	17		300	0,8	0,8	0,30	1,0		
11	Changing-room	7,5	22	15	250	3625	2630	995	17	17		300	0,8	0,8	0,80	0,4		
12	Gymnasium saloon	7,5	22	15	250	3625	2630	995	17	17		300	0,8	0,8	0,30	1,0		
13	Gymnasium underground	7,5	14	7	180	1170	1169	1	9	9		300	0,8	0,8	0,30	1,0		
14				0	0	0	0	0	2	2			0,8					
15				0	0	0	0	0	2	2			0,8					
16				0	0	0	0	0	2	2			0,8					
17				0	0	0	0	0	2	2			0,8					
18				0	0	0	0	0	2	2			0,8					
19				0	0	0	0	0	2	2			0,8					
20				0	0	0	0	0	2	2			0,8					
21	Single Office	7	18	11	250	2750	2543	207	13			500	0,8	0,8	0,30	0,70	10,00	
22	Group Office	7	18	11	250	2750	2543	207	13			500	0,8	0,8	0,30	0,70		
23	Open-Plan Office	7	18	11	250	2750	2543	207	13			500	0,8	0,8	0,00	1,00	15,00	
24	Meeting	7	18	11	250	2750	2543	207	13			500	0,8	0,8	0,50	1,00	2,00	
25	Counter Area	7	18	11	250	2750	2543	207	13			200	0,8	0,8	0,00	1,00		
26	Retail	8	20	12	300	3600	2999	601	14			300	0,8	0,8	0,00	1,00	7,00	
27	Classroom	8	15	7	200	1400	1398	2	9			300	0,8	0,8	0,25	0,90	2,00	
28	University Auditorium	8	18	10	150	1500	1409	91	12			500	0,8	0,8	0,25	0,70	0,75	
29	Bedroom	0	24	24	365	8760	4407	4353	24			300	0,8	0,8	0,00	0,50		
30	Hotel Room	21	8	11	365	4015	755	3260	24			200	0,8	0,8	0,25	0,30		
31	Canteen	8	15	7	250	1750	1748	2	9			200	0,8	0,8	0,00	1,00		
32	Restaurant	10	0	14	300	4200	2404	1796	16			200	0,8	0,8	0,00	1,00	1,50	
33	Kitchen Non-Residential	10	23	13	300	3900	2404	1496	15			500	0,8	0,8	0,00	1,00		
34	Kitchen, Storage, Preparation	7	23	16	300	3900	2404	1496	15			300	0,8	0,8	0,50	1,00		
35	WC, Sanitary	7	18	11	250	2750	2543	207	13			200	0,8	0,8	0,90	1,00		
36	Other Habitable Rooms	7	18	11	250	2750	2543	207	13			300	0,8	0,8	0,50	1,00		
37	Secondary Areas	7	18	11	250	2750	2543	207	13			100	0,8	0,8	0,90	1,00		
38	Circulation Area	7	18	11	250	2750	2543	207	13			100	0,0	0,0	0,80	1,00		
39	Storage, Services	7	18	11	250	2750	2543	207	13			100	0,8	0,8	0,98	1,00		
40	Server Room	0	24	24	365	8760	4407	4353	24			500	0,8	0,8	0,50	0,50		
41	Workshop	7	16	9	250	2250	2192	58	11			500	0,8	0,8	0,00	1,00		
42	Theatre Auditorium	19	23	4	250	1001	55	946	6			200	0,8	0,8	0,00	1,00		
43	Theatre Foyer	19	23	4	250	1001	55	946	6			300	0,8	0,8	0,50	1,00		
44	Theatre Stage	13	23	10	250	2500	1253	1247	12			1000	0,8	0,8	0,00	0,60		
45	Fair, Congress	13	18	5	150	1350	1260	90	11			300	0,8	0,8	0,50	1,00		
46	Exhibition	10	18	8	250	2001	1850	151	24			200	0,8	0,8	0,00	1,00		
47	Library Reading Room	8	20	12	300	3600	2999	601	14			500	0,8	0,8	0,00	1,00		
48	Open Access Library	8	20	12	300	3600	2999	601	14			200	0,8	0,8	0,00	1,00		
49	Library Repository	8	20	12	300	3600	2999	601	14			100	0,8	0,8	0,90	1,00		
50	Gymnasium	8	23	15	300	4500	3002	1498	17			300	0,8	0,8	0,30	1,00		
51	Parking Garage	7	18	11	250	2750	2543	207	0			75	0,0	0,0	0,95	1,00		
52	Public Parking Garage	9	0	15	365	5475	3290	2185	0			75	0,0	0,0	0,80	1,00		

E L E C T R I C I T Y D E M A N D Non-Residential Use

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C

Treated Floor Area A_{TFA} :	719,4	m^2
Auxiliary Electricity Demand:	14965,0	kWh/a
Primary Energy factors:		
Electricity:	2,6	kWh/kWh
Natural gas:	1,1	kWh/kWh
Energy Carrier for DHW:		kWh/kWh
Solar fraction of DHW	0%	
Marginal Performance Ratio DHW:		

Window Properties (from Windows worksheet):

	Shading	Dirt Factor	Non-Perpendicular Radiation	Glazing Fraction
North	1,00	0,95	0,85	0,00
East	0,78		0,51	
South	0,13		0,53	
West	0,51		0,51	

Lighting / non-residential	Percentage of treated floor area	Facade with Windows				
		Room Category	Nominal Illuminance Level	Deviation from North	Orientation	Light Transmission Glazing
Room / Zone		Lux	Degrees	-	[x]	
Walkway - level -1	1%	2 Corridors	100	90	East	78% [x]
Walkway - level -1	1%	2 Corridors	100	260	West	78% [x]
Entrance	4%	1 Lobbies	200	260	West	78% [x]
Antechamber	4%	1 Lobbies	200	180	South	78% [x]
Changing-room	1%	11 Changing-room	300	90	East	78% [x]
WC	1%	35 WC, Sanitary	200	180	South	78% [x]
Gymnasium - level -1	18%	13 Gymnasium underground	300	90	East	78% [x]
Gymnasium - level -1	18%	13 Gymnasium underground	300	260	West	78% [x]
Walkway - level 0	2%	2 Corridors	100	90	East	78% [x]
Walkway - level 0	2%	2 Corridors	100	260	West	78% [x]
Changing-room	2%	11 Changing-room	300	180	South	78% [x]
WC	3%	35 WC, Sanitary	200	180	South	78% [x]
Teachers office	1%	5 Teacher offices	300	260	West	78% [x]
Entrance	1%	1 Lobbies	200	0	North	78%
Changing-room 2	2%	11 Changing-room	300	180	South	78% [x]
Other 1	1%	5 Teacher offices	300	260	West	78% [x]
Other 2	0%	5 Teacher offices	300	180	South	78% [x]
Gymnasium - level 0	19%	12 Gymnasium saloon	300	90	East	78% [x]
Gymnasium - level 0	19%	12 Gymnasium saloon	300	260	West	78% [x]
					78%	
					78%	
					78%	

Room Depth	Room Width	Room Height	Lintel Height	Window Width	Input Warning	Daylight Utilisation	User Data: Installed Lighting Power (Standard)	Installed lighting Power (Standard)	Lighting Control	With motion?	Lighting Control	Utilisation Hours per Year [h/a]	User Determined: Lighting Full Load Hours	Full Load Hours of Lighting	Electricity Demand (kWh/a)	Spec. Electricity Demand (kWh/(m ² a))	Primary Energy Demand (kWh/a)
m	m	m	m	m			W/m ²	W/m ²	[x]			h/a	h/a	h/a	kWh/a	kWh/(m ² a)	kWh/a
1,7	6,0	3,0	2,7	3,6		good	4,6	1	Manual	Without motion	2160	1120,0	46,3	5,2	120,5		
1,7	6,0	3,0	2,7	3,6		medium	4,6	1	Manual	Without motion	2160	1150,0	47,6	5,3	123,7		
1,8	5,8	3,0	2,7	1,2		low	7,2	1	Manual	Without motion	3000	1910,0	395,7	13,8	1028,9		
5,6	2,9	3,0	2,7	1,2		none	7,2	1	Manual	Without motion	3000	2050,0	446,0	14,8	1159,5		
3,8	2,7	3,0	2,7	1,2		low	9,8	1	Manual	Without motion	3625	944,0	93,2	9,3	242,3		
1,3	3,8	3,0	2,7	1,8		none	7,2	1	Manual	Without motion	2750	1670,0	112,4	12,0	292,4		
5,8	23,6	4,9	4,4	12,0		medium	9,8	1	Manual	Without motion	1170	700,0	895,7	6,9	2328,8		
5,8	23,6	4,9	4,4	12,0		low	9,8	1	Manual	Without motion	1170	750,0	959,7	7,4	2495,2		
1,7	6,0	3,3	3,0	4,8		good	4,6	1	Manual	Without motion	2160	1110,0	55,1	5,1	143,3		
1,7	6,0	3,3	3,0	4,8		good	4,6	1	Manual	Without motion	2160	1120,0	55,6	5,2	144,5		
5,6	2,9	3,3	2,7	1,8		none	9,8	1	Manual	Without motion	3625	1056,0	163,8	10,3	425,8		
1,3	3,8	3,3	2,7	2,7		low	7,2	1	Manual	Without motion	2750	1610,0	216,8	11,6	563,7		
3,8	2,7	3,3	2,7	1,2		none	9,8	1	Manual	Without motion	1890	994,0	91,1	9,7	236,9		
1,2	7,7	3,3	2,7			none	7,2	1	Manual	Without motion	3000	2310,0	143,6	16,6	373,3		
4,4	2,9	3,3	2,7	1,8		none	9,8	1	Manual	Without motion	3625	1052,0	118,7	10,3	308,5		
2,1	3,0	3,3	2,7	0,9		low	9,8	1	Manual	Without motion	1890	875,0	49,4	8,6	128,3		
1,3	2,1	3,3	2,7	0,9		none	9,8	1	Manual	Without motion	1890	994,0	21,0	9,7	54,7		
5,9	23,8	5,4	5,0	16,0		medium	6	5,7	1	Manual	Without motion	3625	2490,0	1904,2	14,2	4951,0	
5,9	23,8	5,4	5,0	16,0		low	6	5,7	1	Manual	Without motion	3625	2580,0	1973,0	14,7	5129,9	
						none	0,0		Manual	Without motion				0,0			
						none	0,0		Manual	Without motion				0,0			
						none	0,0		Manual	Without motion				0,0			

Office Equipment		Room Category		Room Category		In the thermal envelope? (1/0)		Existing/Planned? (1/0)		Quantity		Power Rating (W)		Utilisation Hours per Year (h/a)		Duration of Utilisation in Energy Saving Mode (h/a)		Useful Energy (kWh/a)		Electricity Demand (kWh/a)		Primary Energy Demand (kWh/a)		
PC 1 PC in Energy Saving Mode		2				0	0	*	0	*	0	*	55	*	0	20	18	(-1-0)	0	0	0,0	0,0	0	0
Monitor 1 Monitor in Energy Saving Mode						0	0	*	0	*	0	*	20	*	0	0	0	(-1-0)	0	0	0,0	0,0	0	0
PC 2 PC in Energy Saving Mode						0	0	*	0	*	0	*	20	*	0	0	0	(-1-0)	0	0	0,0	0,0	0	0
Monitor 2 Monitor in Energy Saving Mode						0	0	*	0	*	0	*	20	*	0	0	0	(-1-0)	0	0	0,0	0,0	0	0
Copier Copier in Energy Saving Mode						0	0	*	0	*	0	*	400	*	0	0	-	-	0	0	0,0	0,0	0	0
Printer Printer in Energy Saving Mode						0	0	*	0	*	0	*	300	*	0	0	-	-	0	0	0,0	0,0	0	0
Server Server in Energy Saving Mode		5	Teacher offices			1	0	*	0	*	0	*	2	*	100	*	1890	-	0	0	0,0	0,0	0	0
Telephone System						1	0	*	1	*	1	*	94	*	8760	*	8760	-	0	0	0,0	0,0	0	0
Kitchen / Aux. Electricity	Room Category		Predominant Utilisation Pattern of Building	In the thermal envelope? (1/0)	Existing/Planned? (1/0)	Utilisation Days per Year (d/a)	Number of Meals per Utilisation Day	Norm. Consumption	Useful Energy (kWh/a)	Non-Electric Fraction	Electric Fraction	Additional demand	Marginal Performance Ratio	Solar Fraction	Other Primary Energy Demand (kWh/a)	Electricity Demand (kWh/a)	Primary Energy Demand (kWh/a)							
Cooking Electricity	31		Canteen			*	250	*	0	*	0	*	0,25	*	0	*	0	*	0	0	0,0	0,0	0	0
Dishwashing DHW connection						*	250	*	0	*	0	*	0,10	*	0	*	0	*	0	0	0,0	0,0	0	0
Refrigerating							365						0,38	*	0	*	0	*	0	0	0,0	0,0	0	0
Total Auxiliary Electricity													0,25	*	0	*	0	*	0	0	0,0	0,0	0	0
Total													0,38	*	0	*	0	*	0	0	0,0	0,0	0	0
Specific Demand													0,25	*	0	*	0	*	0	0	0,0	0,0	0	0

EnerPHit planning:

AUXILIARY ELECTRICITY

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C

Treated Floor Area Heating period Air Volume Dwelling Units Enclosed Volume	719 194 1798 1 4180	m ² d m ³ HH m ³	Operation Vent. System Winter Operation Vent. System Summer Air Change Rate Defrosting HX from	4,66 4,10 0,42 4,0	kh/a kh/a h ⁻¹ °C	Primary Energy factor - Electricity Annual Space Heating Demand Boiler Rated Power DHW System Heating Demand Design Flow Temperature	2,60 55 32 13329 55	kWh/kWh kWh/(m ² a) kW kWh/a °C
Column Nr.	1	2	3	4	5	6	7	8
Application	Used ? (1/0)	Within the Thermal Envelope ? (1/0)	Norm Demand	Utilization Factor	Period of Operation	Reference Size	Electricity Demand (kWh/a)	Available as Interior Heat
<u>Ventilation System</u>								
Winter Ventilation	1	0,40	0,40	0,42	h ⁻¹	4,7 kh/a	1798 m ³	= 1407 considered in heat recovery efficiency
Defroster HX	1	4110	1	1,00	kh/a	0,8	= 3139	* 1,0 / 4,66 = 674
Summer Ventilation	1	0,40	1,00	2,60	h ⁻¹	4,1 kh/a	1798 m ³	= 7678 * 1,0 / 4,10 =
Additional ventilation summer	1	0,40	0,44	0,44	h ⁻¹	4,1 kh/a	1798 m ³	= 1313 * 1,0 / 4,10 =
<u>Heating System</u>				Controlled/UnControlled (1/0)				
Circulation Pump	1	1	159	W	W	1,0	4,7 kh/a	= 739 * 1,0 / 4,66 = 159
Boiler Electricity Consumption at 30% Load								
Aux. Energy - Heat. Boiler	1	0	79	W	1,00	4,10 kh/a	1	= 324 * 1,0 / 4,66 = 0
Aux. Energy - Wood fired/pellet boiler	0	0						= 0 * 1,0 / 4,66 = 0
<u>DHW system</u>				Data entries in Boiler worksheet. Auxiliary energy demand including possible drinking water prod.				
Circulation Pump	1	1	38	W	1,00	7,0 kh/a	1	= 266 * 0,5 / 8,76 = 16
Storage Load Pump DHW			123	W	1,00	0,4 kh/a	1	= 0 * 1,0 / 4,66 = 0
DHW Boiler Aux. Energy	1	0	238	W	1,00	0,4 kh/a	1	= 99 * 1,0 / 4,66 = 0
Solar Aux Electricity	0	0	97	W	1,00	1,8 kh/a	1	= 0 * 0,5 / 8,76 = 0
<u>Misc. Aux. Electricity</u>								
Misc. Aux. Electricity								
Total							14965	849
Specific Demand	kWh/(m ² a) divided by treated floor area:						20,8	1887
								54,1

INTERNAL HEAT GAINS

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" Calculation in worksheet 'IHG non-res'!

Utilisation Pattern:	School	1,34	W/m ²
Type of Values Used:	PHPP calculation ('IHG non-res' worksheet)	9,00	W/m ² in summer

[Go to utilisation pattern selection](#)

1,34	W/m ²
------	------------------

Calculation Internal Heat Household	Column Nr.	1	2	3	4	5	6	7	8	9	10
Application		Existing (1/0), or number of people	In the Thermal Envelope (1/0)	Norm Consumption	Utilization Factor	Frequency	Useful Energy (kWh/a)	Included in Electricity Balance?	Availability	Used During Time Period (kh/a)	Internal heat source Winter (W)
Dishwashing		1	1	1,1	kWh/Use	1,00	4290	*	0,30	/ 8,76	= 147
Clothes Washing		1	1	1,1	kWh/Use	1,00	3762	*	0,30	/ 8,76	= 129
Clothes drying with:		1	1	3,5	kWh/Use	0,88	10474	*	0,70	/ 8,76	= 837
Condensation Dryer		1	1	0,0	kWh/Use	0,60	0	0,80	0,00	/ 8,76	= 0
Energy consumed by evaporation		0	1	-3,1	kWh/Use	0,60	0	* (1 - 0)	0,00	/ 8,76	= 0
Refrigerating		1	1	0,8	kWh/d	1,00	285	*	1,00	/ 8,76	= 33
Freezing		1	0	0,9	kWh/d	0,90	289	*	1,00	/ 8,76	= 0
or combination		0	1	1,0	kWh/d	1,00	0	*	1,00	/ 8,76	= 0
Cooking		1	1	0,3	kWh/Use	1,00	7500	*	0,50	/ 8,76	= 428
Lighting		1	1	60,0	W	1,00	10440	*	1,00	/ 8,76	= 1192
Consumer Electronics		1	1	80,0	W	1,00	2640	*	1,00	/ 8,76	= 301
Household Appliances/Other		1	1	50,0	kWh	1,00	3000	*	1,00	/ 8,76	= 342
Auxiliary Appliances (cf. Aux Electricity Sheet)											= 849
Other Applications (cf. Electricity Sheet)		0	0,0						0	/ 8,76	= 0
Persons		60	1	80,0	W/P	1,00	42048	*	0,55	/ 8,76	= 2640
Cold Water		60	1	-3,2	W/P	1,00	8,76	*			= -191
DHW - circulation		1	1	31,3	W	1,00	274	*	1,00	/ 8,76	= 31
DHW - individual pipes		1	1	65,5	W	1,00	574	*	1,00	/ 8,76	= 65
DHW - storage		1	1	133,0	W	1,00	1165	*	1,00	/ 8,76	= 133
Evaporation		60	1	-25,0	W/P	1,00	-13140	*	1,00	/ 8,76	= -1500
Total											W 5207
Specific Demand											W/m² 7,24
Heat Available From Internal Sources									194 d/a		kWh/(m²a) 33,7

INTERNAL HEAT GAINS non-residential Use

Building: Primary School 8 "Sveti Sveti Kiril I Metodi"

Calculation result from this worksheet

Utilisation Pattern: School

5,43 W/m²4,79 W/m²

Please fill the 'Electricity non-res' worksheet carefully!

Type of Values Used: PHPP calculation ('IHG non-res' worksheet)

Manual entry: 5,43 W/m² Wrong data entry

Calculation Internal Heat		Persons: 60,0 Treated floor area: 719,39 m ²		P m ²		Heating period: 193,97 d/a		Room Temperature: 18 °C		Internal Heat Gains Aux. Electricity: 849,2 W					
Column Nr.		Persons	Select	Utilisation Pattern	Select	Activity of Persons	Planning with the number of persons or via floor area of utilisation zone (planning via area only if the occupancy is available for this utilisation pattern). Pers./Area (1 / 0)	Number of Occupants	Floor Area of Utilisation Zone (m ²)	Average Occupancy (Persons / m ²)	Heat emitted per person (W)	Utilisation Hours per Year [h/a]	Relative Presence	Used in Time Span (h/a)	Average Heat Emitted by Persons (W)
Persons A	10	Gymnasium	10	>10 yr., standing or light work	3	>10 yr., standing or light work	1 Planning with occupancy	{ 20 }* or { 40 }* or { 60 }*	{ 271 }* or { 280 }* or { }	27	100 * 3625 * 9 * 18	0,70 / 8760 = 579			
Persons B							Planning with occupancy	{ }	{ }	No standard value	3625 * 0,70 / 8760 = 1159				
Persons C							Enter occupancy or floor area	{ }	{ }	No standard value	0 / 8760 = 0				
Persons D							Enter occupancy or floor area	{ }	{ }	No standard value	0 / 8760 = 0				
Persons E							Enter occupancy or floor area	{ }	{ }	No standard value	0 / 8760 = 0				
Persons F							Enter occupancy or floor area	{ }	{ }	No standard value	0 / 8760 = 0				
Persons G							Enter occupancy or floor area	{ }	{ }	No standard value	0 / 8760 = 0				
Evaporation (person specific)							Enter occupancy or floor area	{ }	{ }	No standard value	0 / 8760 = 0				
Lighting / Equipment / Aux. Electricity								Useful Energy [kWh/a]						Average Heat Release	
Lighting								7789		1,00 / 8,76 = 889					
Office Applications (Within Therm. Envelope)								0		1,00 / 8,76 = 0					
Cooking (Within Therm. Envelope)								0		0,50 / 8,76 = 0					
Dishwashing (Within Therm. Envelope)								0		0,30 / 8,76 = 0					
Cooling (Within Therm. Envelope)								0		1,00 / 8,76 = 0					
Other (Within Therm. Envelope)								0		1,00 / 8,76 = 0					
Auxiliary Appliances (See Aux Electricity Worksheet)														849	
Heat loss due to cold water (calculation from column AJ)	on/off (1 / 0)														
Cold Water Due to Flushing WC	1														
Total															
Specific Demand															
Heat Available From Internal Sources															
								Occupied Days per Year [d/a]		Loss daytime [W]		Loss Nighttime [W]		Availability	
								8 * (250 - 25 + 20) * 1,00 / 365 = -31						Used in Period (d/a)	
														Average Power Cold Water	
														3445	
														4,8	
														22	
								194 d/a							

PRIMARY ENERGY VALUE

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C		Building type: School
Treated Floor Area A _{FA} :	719	m ²
Space Heating Demand incl. Distribution:	55	kWh/(m ² a)
Useful cooling demand incl. dehumidification:	0	kWh/(m ² a)
Final Energy	Primary Energy	Emissions CO ₂ -Equivalent
kWh/(m ² a)	kWh/(m ² a)	kg/(m ² a)
Electricity Demand (without Heat Pump)		PE Value CO ₂ -Emissions Factor (CO ₂ -Equivalent)
Covered Fraction of Space Heating Demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	2,6 680
Direct Electric Heating Q _{H,de}	0,0	0,0 0,0
Hot water, direct electric (without DHW wash&dish) Q _{DHW,de} (DHW+Distribution, SolarDHW)	0,0	0,0 0,0
Electric Post heating DHW Wash&Dish (Electricity, SolarDHW)	0,0	0,0 0,0
Electricity demand lighting/auxiliary tools/kitchen Q _{EHH} (Electricity worksheet)	10,8	28,2 7,4
Electricity Demand - Auxiliary Electricity	20,8	54,1 14,1
Total electricity demand (without heat pump)	31,6	82,2 21,5
Heat pump		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of Space Heating Demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	2,6 680
Energy Carrier - Supplementary Heating	Electricity	2,6 680
Annual coefficient of performance of heat pump 1 (heating / heating&DHW) SPF _{H-1} (HP worksheet)	0%	kWh/kWh g/kWh
Annual coefficient of performance of heat pump 2 (DHW) SPF _{H-1} (HP worksheet)	0%	2,6 680
Heat generation efficiency (excl. DHW wash&dish) (HP worksheet)	0,0	0,0 0,0
Heat generation efficiency (incl. DHW wash&dish) (HP worksheet)	0,0	0,0 0,0
Electricity Demand Heat Pump (without DHW Wash&Dish) Q _{HP} (HP worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (HP worksheet)	0,0	0,0 0,0
Total electricity demand heat pump	0,0	0,0 0,0
Compact Heat Pump Unit		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	2,6 680
Energy Carrier - Supplementary Heating	Electricity	2,6 680
COP Heat Pump Heating SPF _{H-1} (Compact worksheet)	0,0	0,0 0,0
COP Heat Pump DHW SPF _{H-1} (Compact worksheet)	0,0	0,0 0,0
Heat generation efficiency (excl. DHW wash&dish) (Compact worksheet)	0,0	0,0 0,0
Heat generation efficiency (incl. DHW wash&dish) (Compact worksheet)	0,0	0,0 0,0
Electricity Demand Heat Pump (without DHW Wash&Dish) Q _{HP} (Compact worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (Compact worksheet)	0,0	0,0 0,0
Total Compact Unit	0,0	0,0 0,0
Boiler		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	100%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	100%	1,1 250
Boiler Type	Low Temperature Boiler Gas	
Performance Ratio of Heat Generator (Boiler worksheet)	111%	
Annual Energy Demand (without DHW Wash&Dish) (Boiler worksheet)	81,1	89,2 20,3
Non-Electric Demand, DHW Wash&Dish (Electricity worksheet)	0,0	0,0 0,0
Total heating oil/gas/wood	81,1	89,2 20,3
District Heat		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	0 0
Heat source (District heating worksheet)		
Performance Ratio of Heat Generator (District heating worksheet)	0%	
Heating Demand District Heat (without DHW Wash&Dish) (District heating worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (Electricity worksheet)	0,0	0,0 0,0
Total district heat	0,0	0,0 0,0
Other		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	0,2 55
Heat source (Project)	Wood	
Performance Ratio of Heat Generator (Project)	0%	
Annual Energy Demand, Space Heating (Project)	0,0	0,0 0,0
Annual Energy Demand, DHW (without DHW Wash&Dish) (Electricity worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (Electricity worksheet)	0,0	0,0 0,0
Non-Electric Demand Cooking/Drying (Gas) (Electricity worksheet)	0,0	0,0 0,0
Total - Other	0,0	0,0 0,0
Cooling with Electric Heat Pump		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of Cooling Demand (Project)	100%	kWh/kWh g/kWh
Heat source (Project)	Electricity	
Seasonal energy efficiency ratio cooling (Project)	0,0	0,0 0,0
Energy Demand Space Cooling	0,0	0,0 0,0
Heating, cooling, DHW, auxiliary electricity, lighting, electrical appliances	112,7	171,5 41,8
Total PE Value	171,5	
Total emissions CO₂-Equivalent	41,8	(Yes/No)
	168	kWh/(m²a)
		no
Heating, DHW, auxiliary electricity (no lighting and electrical appliances)	101,9	143,3 34,4
Specific PE Demand - Mechanical System	143,3	
Total emissions CO₂-Equivalent	34,4	
Solar electricity		PE-Value (Generation) CO ₂ -Emission Factor
Planned Annual Electricity Generation (Worksheet PV)	kWh/a	kWh/kWh g/kWh
Specific Demand		
PE Value: conservation by solar electricity		
Saved CO ₂ emissions through solar electricity		

HEAT PUMP

Building:	Primary School 8 "Sveti Sveti Kiril I Metodi"	Building type:	School
Climate:	Велико Търново	Treated Floor Area A _{TFA} :	719 m ²
<p>(n) Covered fraction of space heating demand Space Heat Demand + Distribution Losses Solar fraction for space heat Effective Annual Heat Demand</p> <p>(PE Value worksheet) $Q_{\text{H},\text{W}} = Q_{\text{H}} * (1 - \eta_{\text{Solar, H}})$</p> <p>$Q_{\text{H},\text{W}} = Q_{\text{H}} * (1 - \eta_{\text{DHW, H}})$</p> <p>$Q_{\text{DHW},\text{W}} = Q_{\text{DHW}} * (1 - \eta_{\text{Solar, DHW}})$</p> <p>Covered Fraction of DHW Demand Total heat demand of DHW system Solar fraction for DHW Effective DHW demand</p> <p>$Q_{\text{DHW},\text{W}} = Q_{\text{DHW}} * (1 - \eta_{\text{DHW, DHW}})$</p> <p>Number of heat pumps in the system Functionality</p>			
Heating	Selection of HP: None	Heat source:	Supply air heating
	Selection of distribution system	θ_{design} (DHW+Distribution)	55,00 °C
	Design distribution temperature	P_{nom}	16,00 kW
	Nominal Power of distribution system	P_{nom}	16,00 kW
	Radiator exponent	n	1,30
	Heating storage	U * A _{Storage}	No
	Specific heat losses storage	U * A _{Storage}	Inside
	Storage location in thermal envelope	Inside or outside of the thermal envelope	4,50 °C
	Room temperature (Storage location: outside of thermal envelope)	(DHW+Distribution)	55,00 °C
	Sink temperature of heat pump for heating	θ_{snk}	
Entries in relation to the domestic hot water system	Selection of HP: None	Heat source:	Electr. immersion heater
	DHW temperature	(DHW+Distribution)	60,00 °C
	DHW storage location	inside or outside of the thermal envelope	Outside
	Specific heat losses storage	U * A _{Storage}	2,5 W/K
	Room temperature (Storage location: outside of thermal envelope)	(DHW+Distribution)	0,00 °C
	Type of backup heater		
	Δθ of Electric flow type heater		5,0 K
In case of one heat pump with functionality: Heating & DHW	Same heat pump's sink temperature for Heating and for DHW	(Manufacturer, Techn. Data)	No
	Heat Pump Priority		DHW priority
Control	Control strategy		On / off
Heating	Depth (horizontal / vertical) ground heat exchanger	z	50,0 m
	Power of pump for ground heat exchanger	P_{pump}	0,05 kW

EnerPHit planning:

HEAT PUMP

Heating		0			
Heat pump:					
Source:					
Test Point 1		θ_{source} °C		θ_{sink} °C	Heating capacity kW
Test Point 2					COP
Test Point 3					
Test Point 4					
Test Point 5					
Test Point 6					
Test Point 7					
Test Point 8					
Test Point 9					
Test Point 10					
Test Point 11					
Test Point 12					
Test Point 13					
Test Point 14					
Test Point 15					

DHW		Heat pump:		Source:				
					θ _{source} °C	θ _{sink} °C	Heating capacity kW	COP
	Test Point 1							
	Test Point 2							
	Test Point 3							
	Test Point 4							
	Test Point 5							
	Test Point 6							
	Test Point 7							
	Test Point 8							
	Test Point 9							
	Test Point 10							
	Test Point 11							
	Test Point 12							
	Test Point 13							
	Test Point 14							
	Test Point 15							

Electrical energy consumption of pump (groundwater / ground)	Q_{pump}	0	kWh/a
Energy by Direct Electricity	$Q_{E,\text{dir}}$	0	kWh/a
Space heat supplied by HP	$Q_{\text{HP,Heating}}$	0	kWh/a
Winter DHW supplied by HP	$Q_{\text{HP,DHW,Winter}}$	0	kWh/a
Summer DHW supplied by HP	$Q_{\text{HP,DHW,Summer}}$	0	kWh/a
Space heating supplied by HP without storage losses	$Q_{\text{HP,Heating}}$	0	kWh/a
Winter DHW supplied by HP without storage losses	$Q_{\text{HP,DHW,Winter}}$	0	kWh/a
Summer DHW supplied by HP without storage losses	$Q_{\text{HP,DHW,Summer}}$	0	kWh/a
Electrical consumption of HP	$Q_{el,\text{HP}}$	0	kWh/a
Seasonal performance factor of Heat Pump	SPF_{H-1}	0	
Seasonal Performance factor of System	SPF_{H-3}	0	
Heat generation efficiency DHW & heating	Q_{final}	0	
Final electrical energy demand heat generation		0	
Annual primary energy demand		0	
Annual CO ₂ -Equivalent Emissions		0	

EnerPHit planning:

HP Ground (Ground probes / Ground collectors)

<p>Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Section C Building type: School</p> <p>Climate: Велико Търново Treated Floor Area A_{TFA}: 719 m²</p>																							
Ground probes																							
<p>Probe field configuration (HP worksheet)</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td>A</td><td>Individual probe</td></tr> <tr><td>H</td><td>50 m</td></tr> <tr><td>B</td><td>m</td></tr> <tr><td>z</td><td>25 m</td></tr> </table>		A	Individual probe	H	50 m	B	m	z	25 m														
A	Individual probe																						
H	50 m																						
B	m																						
z	25 m																						
<p>Type of probe: Double-U</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td>R_b</td><td>m</td></tr> <tr><td>R_i</td><td>m</td></tr> <tr><td>R_a</td><td>m</td></tr> <tr><td>BU</td><td>m</td></tr> <tr><td>R₁₂</td><td>m</td></tr> <tr><td>R_{s2}</td><td>m</td></tr> <tr><td>λ_R</td><td>W/(mK)</td></tr> <tr><td>λ_F</td><td>W/(mK)</td></tr> <tr><td>t_p</td><td>#DIV/0! d</td></tr> <tr><td>R_a</td><td>Km/W</td></tr> <tr><td>R_b</td><td>Km/W</td></tr> </table>		R _b	m	R _i	m	R _a	m	BU	m	R ₁₂	m	R _{s2}	m	λ _R	W/(mK)	λ _F	W/(mK)	t _p	#DIV/0! d	R _a	Km/W	R _b	Km/W
R _b	m																						
R _i	m																						
R _a	m																						
BU	m																						
R ₁₂	m																						
R _{s2}	m																						
λ _R	W/(mK)																						
λ _F	W/(mK)																						
t _p	#DIV/0! d																						
R _a	Km/W																						
R _b	Km/W																						
<p>Ground</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td>J</td><td>0</td></tr> <tr><td>ρ_E</td><td>0 kg/m³</td></tr> <tr><td>c_{pE}</td><td>0 J/(kgK)</td></tr> <tr><td>λ_E</td><td>0,0 W/(mK)</td></tr> <tr><td>α_E</td><td>#DIV/0! m/s²</td></tr> <tr><td>ΔT_G</td><td>0,022 K/m</td></tr> </table>		J	0	ρ _E	0 kg/m ³	c _{pE}	0 J/(kgK)	λ _E	0,0 W/(mK)	α _E	#DIV/0! m/s ²	ΔT _G	0,022 K/m										
J	0																						
ρ _E	0 kg/m ³																						
c _{pE}	0 J/(kgK)																						
λ _E	0,0 W/(mK)																						
α _E	#DIV/0! m/s ²																						
ΔT _G	0,022 K/m																						
<p>Brine</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td>E</td><td>0</td></tr> <tr><td>ρ_S</td><td>0 kg/m³</td></tr> <tr><td>η_S</td><td>0 kg/(ms)</td></tr> <tr><td>c_{pS}</td><td>0 J/(kgK)</td></tr> <tr><td>λ_S</td><td>0 W/(mK)</td></tr> <tr><td>m_S</td><td>kg/s</td></tr> </table>		E	0	ρ _S	0 kg/m ³	η _S	0 kg/(ms)	c _{pS}	0 J/(kgK)	λ _S	0 W/(mK)	m _S	kg/s										
E	0																						
ρ _S	0 kg/m ³																						
η _S	0 kg/(ms)																						
c _{pS}	0 J/(kgK)																						
λ _S	0 W/(mK)																						
m _S	kg/s																						
<p>Operation type</p> <p>Waste heat of active cooling to ground probe? Please check, if applicable.</p>																							
<p>Heat pump operation duration</p> <p>Specific heat extraction rate as an annual average</p>																							
<p>q_{ex} h/a H/R_b W/m W/K</p>																							
Ground collectors																							
<table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td>r_i</td><td>0,013 m</td></tr> <tr><td>r_a</td><td>0,016 m</td></tr> <tr><td>λ_r</td><td>0,420 W/(mK)</td></tr> <tr><td>z_{pipe}</td><td>50 m</td></tr> <tr><td>z_{gw}</td><td>m</td></tr> <tr><td>D</td><td>0,4 m</td></tr> <tr><td>Base area</td><td>80 m²</td></tr> <tr><td>Pipe outer surface</td><td>20,1 m²</td></tr> <tr><td>L</td><td>200,0 m</td></tr> </table>		r _i	0,013 m	r _a	0,016 m	λ _r	0,420 W/(mK)	z _{pipe}	50 m	z _{gw}	m	D	0,4 m	Base area	80 m ²	Pipe outer surface	20,1 m ²	L	200,0 m				
r _i	0,013 m																						
r _a	0,016 m																						
λ _r	0,420 W/(mK)																						
z _{pipe}	50 m																						
z _{gw}	m																						
D	0,4 m																						
Base area	80 m ²																						
Pipe outer surface	20,1 m ²																						
L	200,0 m																						
<p>Brine</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td>E</td><td>0</td></tr> <tr><td>ρ_S</td><td>0 kg/m³</td></tr> <tr><td>η_S</td><td>0 kg/(ms)</td></tr> <tr><td>c_{pS}</td><td>0 J/(kgK)</td></tr> <tr><td>λ_S</td><td>0 W/(mK)</td></tr> <tr><td>m_S</td><td>0,5 kg/s</td></tr> </table>		E	0	ρ _S	0 kg/m ³	η _S	0 kg/(ms)	c _{pS}	0 J/(kgK)	λ _S	0 W/(mK)	m _S	0,5 kg/s										
E	0																						
ρ _S	0 kg/m ³																						
η _S	0 kg/(ms)																						
c _{pS}	0 J/(kgK)																						
λ _S	0 W/(mK)																						
m _S	0,5 kg/s																						
<p>Specific heat extraction rate q_{ex} W/m²</p> <p>U * A W/K</p>																							
Climate																							
<table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td>Period duration</td><td>365 d</td></tr> <tr><td>Average ground surface temperature</td><td>T_{m0} 11,4 °C</td></tr> <tr><td>Surface temperature amplitude</td><td>T₁ 11,4 °C</td></tr> <tr><td>Phase shifting surface</td><td>t_{o2} 31 d</td></tr> </table>		Period duration	365 d	Average ground surface temperature	T _{m0} 11,4 °C	Surface temperature amplitude	T ₁ 11,4 °C	Phase shifting surface	t _{o2} 31 d														
Period duration	365 d																						
Average ground surface temperature	T _{m0} 11,4 °C																						
Surface temperature amplitude	T ₁ 11,4 °C																						
Phase shifting surface	t _{o2} 31 d																						

HP Ground (Ground probes / Ground collectors)

Ground characteristics		Thermal conductivity [W/(mK)]	Density [kg/m³]	Heat capacity [J/(kg K)]	Heat capacity [MJ/(m³ K)]	Temperature conductivity [10⁻⁷ m²/s]	Source
A	Sand, 9% moisture	0,980	1440	1507	2,170	4,520	[Neiß 1977]
B	Sand, 13% moisture	1,500	1600	1800	2,880	5,210	[Neiß 1977]
C	Ground, coarse gravel	0,520	2000	1840	3,680	1,410	[VDI 1984]
D	Loam, 36% moisture	2,300	1650	2847	4,700	4,900	[Neiß 1977]
E	Clay	1,280	1500	880	1,320	9,700	[VDI 1984]
F	Clay / Silt	2,200	2550	882	2,250	9,780	[VDI 2000]
G	Slate	2,100	2700	870	2,350	8,940	[VDI 2000]
H	Silt	1,500	1920	2938	5,640	2,660	[ISO 13370]
I	Rock	3,500	2500	2500	6,250	5,600	[ISO 13370]
J							

Result ground probe calculation	
Month	Borehole Temperature °C
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	

Properties of the brine		Temperature	Density	Heat capacity	Thermal conductivity	Dynamic viscosity
		[°C]	[kg/m³]	[J/(kg K)]	[W/(mK)]	[kg/(ms)]
A	Ethylene glycol 25%	2	1052	3950	0,480	0,0052
B	Potassium carbonate	2	1265	2941	0,544	0,0031
C	Potassium formate	2	1226	3190	0,534	0,00237
D	Water	2	997	4190	0,590	0,001307
E						

COMPACT UNIT WITH EXHAUST AIR HEAT PUMP

Calculation based on measured values of the laboratory evaluation for component certification

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Set	Building type: School
Treated Floor Area A _{FPA} :	719 m ²
Covered fraction of space heating demand (PE Value worksheet)	0%
Space Heating Demand + Distribution Losses Q _{H,DHW} (DHW+Distribution)	39339 kWh
Solar contribution for space heating η _{Solar, H} (SolarDHW worksheet)	0%
Effective Annual heating demand Q _{H,W} =Q _H *(1-η _{Solar, H})	0 kWh
Covered Fraction of DHW Demand (PE Value worksheet)	0%
Total Heating Demand of DHW system Q _{DHW} (DHW+Distribution)	13329 kWh
Solar contribution for DHW η _{Solar, DHW} (SolarDHW worksheet)	0%
Effective DHW Demand Q _{DHW,W} =Q _{DHW} *(1-η _{Solar, DHW})	0 kWh
Sort: AS LIST	
Go to list of compact units	
Invalid selection: for the time being compact HP units or combined HPs can ONLY be considered as single units, meaning they can ONLY be calculated with the 'Ventilation' worksheet (please check the	
Compact unit selection:	
Measured Values from Laboratory Test	
Ventilation	
Effective heat recovery efficiency η _{eff} (Test stand)	
Electric Efficiency (Test stand)	Wh/m ³
Heating	
Ambient Air Temperature T _{amb}	
Measured Thermal Power Heat Pump Heating P _{HP,Heating}	
Measured COP Heating COP _{heating}	
Domestic Hot Water	
Ambient Air Temperature T _{amb}	
Measured Thermal Power DHW Storage Heating-Up P _{DHW, Heating-Up}	
Measured Thermal Power DHW Storage Reload P _{DHW, Reload}	
Measured COP DHW Storage Heating-Up COP _{DHW, Heating-Up}	
Measured COP DHW Storage Reload COP _{DHW, Reload}	
Standby (inputs required only if different from storage reload)	
Ambient Air Temperature T _{amb}	
Measured Thermal Power Heat Pump Standby P _{HP,Standby}	
Measured COP Standby COP _{Standby}	
Specific heat loss storage incl. connections U * A _{Storage} (Test stand)	0%
Average Storage Temperature in Standby Mode T _{avg,standby} (Test stand)	°C
Heat pump priority	
separate heat pumps	
Room temperature (°C) 18	DHW Priority
Av. Ambient Temp. Heating P. (°C) 5	
Av. Ground Temp (°C) 11	
Efficiency SHX Exhaust Air Mixing η ⁺ _{SHX}	
Heat Recovery Efficiency SHX Exhaust Air Mixing (if applicable) η _{SHX,add} (Design Value)	0%
Volume Flow Rate of Added Exhaust Air (if applicable) V _{add} (Test stand)	m ³ /h
Hydraulic frost protection	
Heat supplied by direct electricity Q _{E,dr}	kWh/a
Space heat supplied by HP Q _{HP,Heating}	kWh/a
Winter DHW supplied by HP Q _{HP,DHW,Water}	0 kWh/a
Winter standby heat supplied by HP Q _{HP,Standby,Water}	kWh/a
Summer DHW supplied by HP Q _{HP,DHW,Summer}	0 kWh/a
Summer standby heat supplied by HP Q _{HP,Standby,Summer}	kWh/a
Performance Ratio of Heat Generator, DHW & Space Heating Annual Coefficient of Performance SPF _{H3}	
Final energy demand heat generation Q _{final}	kWh/a
Annual primary energy demand	kWh/(m ² a)
Annual CO ₂ -Equivalent Emissions	kg/a
	kg/(m ² a)
	kg/a
	kg/(m ² a)

incl. DHW Connection for Washing Machines & Dishwashers

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Sectic		Building type: School	
Treated Floor Area A _{TF,A}	719 m ²		
Covered fraction of space heating demand	(PE Value worksheet)	100%	
Space Heating Demand + Distribution Losses	Q _H +Q _{HS} (DHW+Distribution)	39339 kWh	
Solar contribution for space heating	η _{Solar, H} (SolarDHW worksheet)	0%	
Effective Annual heating demand	Q _{H,W} =Q _H *(1-η _{Solar, H})	39339 kWh	
Space Heating Demand without Distribution Losses	Q _H (Verification sheet)	39328 kWh	
Covered Fraction of DHW Demand	(PE Value worksheet)	100%	
Total Heating Demand of DHW system	Q _{DHW} (DHW+Distribution)	13329 kWh	
Solar contribution for DHW	η _{Solar, DHW} (SolarDHW worksheet)	0%	
Effective DHW Demand	Q _{DHW,W} =Q _{DHW} *(1-η _{Solar, DHW})	13329 kWh	
Additional selection only in the case of Natural Gas			
Boiler Type	(Project)	Low Temperature Boiler Gas	
Primary Energy factor	(Data worksheet)	1,1 kWh/kWh	
CO ₂ -Emissions Factor (CO ₂ -Equivalent)		250 g/kWh	
Useful heat provided	Q _{Use}	52667 kWh/a	
Max. Heating Power Required for Heating the Building	P _{BH} (Heating load worksheet)	31,56 kW	
Length of the Heating Period	t _{HP}	4655 h	
Length of DHW Heating Period	t _{DHW}	8760 h	
Use characteristic values entered (check if appropriate)?			
Project Data Standard Values Input field			
Design Output	P _{Nom} (Rating Plate)	32 kW	32 kW
Installation of Boiler (Outdoor: 0, Indoor: 1)		0	0
Input field			
Input Values (Oil and Gas Boiler)			
Boiler Efficiency at 30% Load	η _{10%} (Manufacturer)	91%	91%
Boiler Efficiency at Nominal Output	η _{100%} (Manufacturer)	91%	91%
Standby Heat Loss Boiler at 70 °C	q _{B,70} (Manufacturer)	1,1%	1,1%
Average Return Temperature Measured at 30% Load	θ _{30%} (Manufacturer)	40 °C	40
Input field			
Input Values (Biomass Heat Generator)			
Efficiency of Heat Generator in Basic Cycle	η _{GZ} (Manufacturer)		60%
Efficiency of Heat Generator in Constant Operation	η _{SO} (Manufacturer)		70%
Average Fraction of Heat Output Released to Heating Circuit	z _{IC,m} (Manufacturer)		0,4
Temperature Difference Betw. Power-On and Power-Off	Δθ (Manufacturer)		K
For Interior Installations: Area of Mechanical Room	A _{Install} (Project)		30 m ²
Useful heat output per basic cycle	Q _{N,GZ} (Manufacturer)		48,0 kWh
Average Power Output of the Heat Generator	Q _{N,m} (Manufacturer)		32,0 kW
Heat generator without pellets conveyor			kWh
Unit with regulation (no fan / no starting aid)			W
Heating energy demand for a basic machine cycle	Q _{HE,GZ} (Manufacturer)		0,98 kWh
Power consumption in steady state operation	P _{el,SB} (Manufacturer)		490 W
Input field			
Utilisation factor heat generator heating run	h _{H,gK} = η _g * η _K	91%	
Utilisation factor heat generator DHW run	h _{TW,gK} = η _{100%} / η _{TW,K}	88%	
Utilisation factor heat generator DHW & heating	h _{gK}	90%	
kWh/a kWh/(m ²)			
Final energy demand space heating	Q _{Final,HE} = Q _{H,W} * η _{H,gK}	43181	
Final energy demand DHW	Q _{Final,DHW} = Q _{DHW,W} * η _{TW,gK}	15166	
Total final energy demand	Q _{Final} = Q _{Final,HE} + Q _{Final,DHW}	58347	
Annual primary energy demand		64182	
Annual CO ₂ -Equivalent Emissions		14587 kg/a	kg/(m ²)
		81,1	
		89,2	
		20,3	

Building: Primary School 8 "Sveti Sveti Kiril I Metodi" - Se	Building type: School
Treated Floor Area A_{TFA} :	719 m ²
Covered fraction of space heating demand	(PE Value worksheet)
Annual heating demand kWh/a	Q_H (DHW+Distribution)
Solar contribution for space heating	$\eta_{Solar, H}$ (SolarDHW worksheet)
Effective Annual heating demand	$Q_{H,W} = Q_H * (1 - \eta_{Solar, H})$
Covered Fraction of DHW Demand	(PE Value worksheet)
DHW Demand	Q_{DHW} (DHW+Distribution)
Solar contribution for DHW	$\eta_{Solar, DHW}$ (SolarDHW worksheet)
Effective DHW Demand	$Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$
Heat source	None
Primary Energy factor	(Data worksheet)
CO ₂ -Emissions factor (CO ₂ -Equivalent)	(Data worksheet)
Utilisation factor of heat transfer station	ha,HX
Final energy demand heat generation	$Q_{final} = Q_{Use} * \epsilon_{a,DH}$
Annual primary energy demand	kWh/a
Annual CO ₂ -Equivalent Emissions	kWh/(m ² a)
	kg/a
	kg/(m ² a)

Table of Primary Energy Factors and CO₂-Equivalent Emissions Factors of Various Energy Carriers

Energy Type		Energy Carrier	PE (non-regenerative) kWh _{Prim} /kWh _{Final}	CO ₂ GEMIS 3.0 kg/kWh _{Final}
Fuel Source	1	None		
	2	Oil	1,1	0,31
	3	Natural Gas	1,1	0,25
	4	LPG	1,1	0,27
	5	Hard Coal	1,1	0,44
	6	Wood	0,2	0,05
Electricity	7	Electricity-Mix	2,6	0,68
	8	Electricity from Photovoltaics	0,7	0,25
District Heat	1	None	0	0
	2	Hard Coal CGS 70% PHC	0,8	0,24
	3	Hard Coal CGS 35% PHC	1,1	0,32
	4	Hard Coal HS 0% PHC	1,5	0,41
	5	Gas CGS 70% PHC	0,7	-0,07
	6	Gas CGS 35% PHC	1,1	0,13
Gas CGS	7	Gas HS 0% PHC	1,5	0,32
	8	Oil CGS 70% PHC	0,8	0,1
	9	Oil CGS 35% PHC	1,1	0,25
	10	Oil HS 0% PHC	1,5	0,41
Heating Oil-EL CGS	11	Oil HS 35% PHC	0,8	0,1
	12	Oil HS 0% PHC	1,5	0,41
	13	Oil HS 35% PHC	0,8	0,1

Data Source: DIN V 4701-10/GEMIS 4.14

Heat Generator		Selection of gas type	
Nr.	Type	Nr.	Type
1	None	1	Natural Gas
2	Improved gas condensing boi-ler	2	LPG
3	Improved oil condensing boi-ler	3	
4	Condensing boi-ler gas		
5	Condensing boi-ler oil		
6	Low Temperature Boi-ler Gas		
7	Low Temperature Boi-ler Oil		
8	Wood Log Burning (Direct and Indirect Release of Heat)		
9	Wood Pellet Burning (Direct and Indirect Release of Heat)		
10	Wood Pellet Burning (Only Indirect Release of Heat)		
11	Reserve		

Dishwashing	Washing
1	DHW Connection
2	Cold water connection

Clothes Drying		Availability	Electricity	Availability	Evaporation
1	Clothesline		1		1
2	Drying Closet (cold!)		1		1
3	Drying Closet (cold!) in Exhaust Air		0,9		0,9
4	Condensation Dryer		0,7		0
5	Electric Exhaust Air Dryer		1		1
6	Gas Exhaust Air Dryer		1		1

Cooking		Electric Fraction	Primärenergiefaktor	CO ₂ factor
1	Electricity	100%	2,6	0,68
2	Natural Gas	0%	1,1	0,25
3	LPG	0%	1,1	0,27