

B R I E F I N S T R U C T I O N S

Place your mouse here to see the PHPP help.

If no help appears when the mouse passes over cell B4, you can activate it by going into the Menu Bar Tools/Options/View, and under "Comments", select "Comment Indicator Only".

Passive House Verification: Meaning of Field Formats

Example	Field Format	Meaning
78,8	Courier New, blue, bold on yellow background	Input Field: Please enter the required value here
01ud triple-low-e-cr08	Arial Narrow, blue, bold on brown	Data entry field with drop down list
6619	Arial, black, standard on white background	Calculation field; please do not change
78,8	Courier New, purple, bold on white background	Field with references to another sheet - should not be changed.
126,0	Arial, black, large & bold on green background	Important result

Passive House Planning: Worksheet Directory

Worksheet name (to show/hide worksheets please use the separate 'Profile settings' tool)	Function	Brief Description	Required for the certification?
Verification	Building data; summary of results	Building description, selection of the calculation method, summary of results	yes
Overview	Overview of the specific data of the project entered	In-depth project description, overview of all results and input variables, specific details on building envelope, building services systems as well as general information.	no
Variants	Variant calculation	Input parameters and results for the variant calculations. Predefined fields for frequent entries, as well as user-defined area.	no
Comparison	Comparison between two variants	Comparison between two variants under the energy demand and economic viability perspective. Input of comparison configurations.	no
Climate	Climate Region Selection or Definition of User Data	Climate data for: Annual Heating, Windows, Heating Load, Heating, Summer, Cooling, Cooling Units, Cooling Load worksheets	yes
U-Values	Calculation of Standard building assembly U-Values	Heat transmission coefficient calculations in accordance with DIN EN ISO 6946.	yes
Areas	Areas summary	Building assembly Areas, Thermal Bridges, Treated Floor Area. Use exterior dimension references!	yes
Ground	Calculation of reduction factors against ground	More precise calculation of heat losses through the ground	if applicable
Components	Building component database	Database of certified, Passive House suitable components and entry of user-defined components	yes
Windows	Uw-Value Determination	Input of geometry, orientation, frame lengths, frame widths, Ug and U-values of the frame, and the thermal bridge heat loss coefficients of the connections; from these inputs, determine Uw and total radiation.	yes
Shading	Determination of shading coefficients	Input of shading parameters, e.g. balcony, neighbouring building, window reveal and calculating the shading factors	yes
Ventilation	Air Flow Rates, Exhaust/Supply Air Balancing, Pressurization Test Results	Sizing the ventilation system from extract and supply air requirements, infiltration air change rate and actual efficiency of heat recovery, input of pressurization test results	yes
Additional Vent	Design and planning of ventilation systems with diverse ventilation units	Extension of the Ventilation worksheet for dimensioning air flows, for special building uses and systems with various ventilation units	if used
Annual heating	Annual heating demand / Annual Method	Calculation of the annual space heating demand according to the energy balance method following EN 13790: Transmission + Ventilation · h (Solar Gains + Internal Gains)	no
Heating	Space heating demand calculation Monthly method according to EN 13790	Calculation procedure for the monthly method following EN 13790. Make appropriate selection in the Verification worksheet, if calculations should be performed following this procedure	yes
Heating Load	Building Heating Load Calculation	Calculation of the nominal heating load using a balance procedure for the design day: max transmission + max ventilation · η (minimum solar gains + internal heat gains)	yes
SummerVent	Determination of Summer Ventilation	Ventilation in cooling case and estimation of air flow rates for natural ventilation during the summer period	yes
Summer	Assessment of Summer Climate	Calculation of the frequency of overheating as a measure of summer comfort	yes
Cooling	Monthly Method for Cooling Demand	Annual useful cooling demand calculation	if present
Cooling units	Latent Cooling Energy	Calculation of the energy demand for dehumidification and choice of cooling method	if present
Cooling load	Building Cooling Load Calculation	Calculation of the daily average cooling load of the building	no
DHW+Distribution	Distribution losses; DHW Requirement and Losses	Heat loss calculation of the distribution systems (heating; DHW); calculation of the useful heat requirement of DHW and storage losses	yes
SolarDHW	Solar DHW Heating	Solar contribution calculation for DHW and space heating contribution	if solar panels are used
PV	Electricity generation by photovoltaic	Electricity generation calculation of PV system	no
Electricity	Electricity Demand for Dwellings	Calculation of the electricity demand of Passive Houses with residential use	yes
Use non-res	Patterns of non-residential Utilisation	Input or selection of utilisation patterns for planning of electricity demand and internal heat gains	no
Electricity non-res	Electricity Demand for non-residential Use	Calculation of the electricity demand for lighting, electric devices and kitchens for non-residential buildings	no
Aux Electricity	Auxiliary Electricity Demand	Calculation of auxiliary electricity and corresponding primary energy demand	yes
IG	Internal Heat Gains in Dwellings	Calculation of the internal heat gains based on the Electricity and Aux Electricity sheets.	no
IG non-res	Internal Heat Gains for non-residential Use	Calculation of the internal heat gains for non-residential buildings based on the Electricity non-res worksheet and the occupancy	no
PE-Value	Specific Primary Energy and CO ₂ Demands	Selection of heat generators, calculation of the specific primary energy and CO ₂ demands from the present results	yes
Compact	Efficiency of Heat Generator Compact Heat Pump Unit	Calculation of combined heat generation efficiency for heating and DHW only by means of a electric heat pump compact unit, considering the specific project boundary conditions.	if present
HP	Heat generation efficiency of the heat pump	Calculation of heat generation efficiency for one to two electric-run heat pumps, considering the specific project boundary conditions.	if present
HP Ground	Ground probe or ground collector in combination with a heat pump	Heat source calculation for a ground probe or horizontal subsoil heat exchanger for ground-coupled heat pumps, considering the specific project boundary conditions.	if present
Boiler	Efficiency of Heat Generator Boiler	For the calculation of the efficiency of heat generation with standard boilers (NT and calorific boilers) for the project given boundary conditions.	if present
District Heating	District Heat Transfer Station	Calculation of the final and primary energy demands (heat)	if present
Data	Database	Table of primary energy factors following [GEMIS] and database of EnEV (German energy efficiency regulation).	no

EnerPHit verification



Architecture:			
Street:			
Postcode/City:			
Energy consulting:			
Street:			
Postcode/City:			
Year of Construction:	2014	Interior temperature winter [C°]	20,0
Number of dwelling units:	1	Internal heat gains winter [W/m²]	2,8
Number of Occupants:	225,0	Interior temp. summer [C°]	25,0
Exterior vol. V _e :	6224,4 m³	IHG summer [W/m²]	2,8
		Spec. capacity [Wh/K per m² TFA]	204
		Mechanical cooling:	

Specific building demands with reference to the treated floor area					
	Treated floor area	1303,5 m²	Requirements	Fulfilled?*	
Space heating	Annual heating demand	250 kWh/(m²a)	25 kWh/(m²a)	no	
	Heating load	105 W/m²	-	-	
Space cooling	Overall specific space cooling demand	kWh/(m²a)	-	-	
	Cooling load	W/m²	-	-	
	Frequency of overheating (> 25 °C)	9,6 %	-	-	
Primary Energy	Heating, cooling, domestic hot water, auxiliary electricity, lighting, etc.	312 kWh/(m²a)	402 kWh/(m²a)	yes	
	DHW, space heating and auxiliary electricity	259 kWh/(m²a)	-	-	
	Specific primary energy reduction through solar electricity	kWh/(m²a)	-	-	
Airtightness	Pressurization test result n ₅₀	4,0 1/h	1 1/h	no	

* empty field: data missing; -: no requirement

<p>I confirm that the values given herein have been determined following the PHPP methodology and were determined based on the characteristics of the building. The PHPP calculations are attached to this application.</p>		EnerPHit building retrofit (acc. to heating demand)?	no
Name:		Company:	
Surname:		Issued on:	
			Signature

Basic data		
Building, name of the object	School "Tzanko Diustabanov"-Block A	
Street:	25 Hristo Smirnenski blv.	
Postcode/City:	Gabrovo	
Country:	Bulgaria	
Building type:		
Climate: region / climate data set		
Climate: degree days / altitude	User Data 74	User data - България 382
Building type / building status		
Context of urban development		
Building type / construction		
Building category, in terms of energy		
Year of construction / year of construction of existing building	2014	
Amount of dwelling units for residential use / non-residential use	Dwelling units P	13 225
Number of occupants standard / planned	m ² /P	6
Standard / design occupancy rate		
Home owner / client	Municipality of Gabrovo	
Architect		
Building services		
PHP/Energy balance		
Building physics		
Structural engineering		
Contractor / tradesperson / other (max. 5000 characters)		
Interior temperatures winter/summer	20	°C
IHG winter / summer	2,8	W/m ²
Type of certification	EnerPHit building retrofit (acc. to heating demand)	
Project certification / Certificate ID		
Certification body		
PHPPE-version / PHPP-registration number	Version 9.0 beta	
Characteristic value according to EnerPHit verification		
Treated floor area A _{TFA} / exterior volume V _e	1303,46	m ²
Space heating demand	6224,4	Requirement
Heating load residential	250	kWh/(m ² a)
Heating load Non-residential	105	kWh/(m ² a)
Frequency of overheating	10	%
Overall specific space cooling demand	Recommendation: < 10%	
Cooling load residential	105	kWh/(m ² a)
Cooling load non-residential	4,0	kWh/(m ² a)
Airtightness pressure air exchange rate test n₅₀	1	1/h
Total PE Value	402	kWh/(m ² a)
Heating, cooling, DHW, auxiliary electricity, lighting, electrical appliances	259	
Specific PE Demand - Mechanical System / CO ₂ -Equivalent	78	
Heating, DHW, auxiliary electricity (no lighting and electrical appliances)		
Solar power: Primary energy savings / CO ₂ emissions		

Average building quality		
	Specific Demand	Requirement
Average U-value of external insulation to outside air	1,84 W/(m²K)	-
Average U-value of external insulation to ground	2,01 W/(m²K)	-
Average U-value interior insulation to outside air	1,12 W/(m²K)	-
Average U-value interior insulation to ground	-0,05 W/(m²K)	-
Average U-value of thermal bridges ΔU	2,51 W/(m²K)	-
Average U-value windows	5,50 W/(m²K)	-
Average U-value of exterior doors		
Ventilation system eff. heat recovery efficiency	%	-

Building envelope and site		
Building envelope area A _{total} / treated floor area A _{TFA}	2901 m ²	1303
A/V-ratio / Envelope area use (A _{total} /A _{TFA})	0,47	2,23
Window area / Window area percentage	434 m ²	15,0%
Specific solar aperture / Passive solar heating mode	2,9%	22841
Building site area / built-up area		
Gross floor area BGF / Gross external volume BRI		
Floor space ratio / Amount of complete storeys		

Building description (max.5000 characters)

Opaque building components		
Exterior wall: U-value (average value) / area	1,33	W/(m²K)
Standard exterior wall: U-value / thickness		
Standard exterior wall: total area / area fraction		
Standard exterior wall: name / certified?		
Standard exterior wall: short description (materials, manufacturer, product name, special features)		
Exterior wall against ground: U-value (average value) / area		W/(m²K)
Standard exterior wall against ground: U-value / thickness		
Standard exterior wall against ground: area / area fraction		
Standard exterior wall against ground: name / certified?		
Standard exterior wall against ground: short description (materials, manufacturer, product name, special features)		
Roof / top floor ceiling: U-value (average value) / area	3,07	W/(m²K)
Standard roof / top floor ceiling: U-value / thickness		
Standard roof / top floor ceiling: area / area percentage		
Standard roof / top floor ceiling: name / certified?		
Standard roof / top floor ceiling: short description (materials, manufacturer, product name, special features)		

Floor slab / basement ceiling: U-value (average value) / area	2,01	W/(m ² K)	549,78
Standard floor slab / basement ceiling: U-value / thickness			0,0
Floor slab / basement ceiling standard: area / area fraction			
Standard floor slab / basement ceiling: name / certified?			
Standard floor slab / basement ceiling: short description (materials, manufacturer, product name, special features)			
 Thermal bridges: Y-value (Average value) / length	-0,241	W/(mK)	707,26
Thermal bridge free limit value / Complied?	0,01	W/(mK)	yes
Thermal bridges: short description (max.5000 letters) (additional notices, manufacturer, product name, materials, others)			

Windows / doors / shading systems		
windows/facades: U-value (average value) / area	2,51	W/(m²K)
window/facade frames: U-value (average value) / area	1,73	W/(m²K)
Glazing: U-value (Average value) / areas	2,90	W/(m²K)
Ψ-Value Glazing edge (average) / Ψ-Value Installation (average)	0,041	W/(mK)
Standard window frame: U-value / frame width		W/(m²K)
Standard window frame: window area / area percentage		W/(m²K)
Standard window frame: glass edge Ψ-value / installation Ψ-value		W/(mK)
Standard window frame: name, certified?		
Standard window frame: Short description (materials, manufacturer, product name, installation)		
Standard curtain wall facade: U-value / Frame width		W/(m²K)
Standard curtain wall facade: Facade area / Total area percentage		W/(m²K)
Standard curtain wall facade: Ψ-value glazing edge / Ψ-value installation		W/(mK)
Standard curtain wall facade: Description / Certified?		
Standard curtain wall facade: short description (materials, manufacturer, product name, installation)		
Standard glazing: U-value / g-value		W/(m²K)
Standard glazing: Facade area / Area ratio		W/(m²K)
Standard glazing: Description / Certified?		
Standard glazing: short description (description, manufacturer, product name, installation)		
Standard glazing 2: U-value / g-value		W/(m²K)
Standard glazing 2: Facade area / Area percentage		W/(m²K)
Standard glazing 2: Description / Certified?		
Standard glazing 2: short description (description, manufacturer, product name, installation)		
Roof lights / light domes: U-value / frame width		W/(m²K)
Roof lights / light domes: window area / area section		W/(m²K)
Roof lights / light domes: glazing U-value / g-value		W/(m²K)
Roof lights / light domes: Y-value glass edge / Installation Y-value		W/(mK)
Roof lights / light domes: name / certified?		
Roof lights / light domes: short description (materials, manufacturer, product name, installation situation)		
Exterior door: U-value (average value) / Area	5,50	W/(m²K)
Standard exterior door: door U-value / door U-value installed		W/(m²K)
Standard exterior door: frame U-value / door leaf U-value		W/(m²K)
Standard exterior door: door leaf thickness / frame width		mm
Standard exterior door: panel border Y-value / installation Y-value		W/(mK)
Standard exterior door: Name / certified?		
Standard exterior door: Short description (materials, manufacturer, product name, installation situation)		
Temporary sun protection: Type / Add. Reduction factor		5,97
Temporary sun protection: Area / Area ratio		
Shading reduction factors: orientation		
North	63	%
East	58	%
South	75	%
West	70	%
Horizontal	100	%
Reduction factor winter		
	68	
	70	
	64	
	83	
	100	
Summer reduction factor		

Ventilation		
Ventilation: Type of ventilation	Window ventilation only	
Calculated supply air demand / supply air per person	6'750	m ³ /h
Calculated extract air demand / Amount extract air rooms	0	m ³ /h
Design air flow rate (maximum) / Average value reference to maximum		m ³ /h
Average flow rate / Average air exchange		m ³ /h
Airtightness test pressure at n₅₀ / Air permeability q₅₀	4,00	1/h
Net air flow for pressurization test / Infiltration flow n _{V,Rest}		m ³
Ventilation unit: Description / Certified?		
Ventilation system: effective heat recovery efficiency / electrical efficiency		%
Ventilation system: Description (type of heat recovery, manufacturer, product name)		
Ventilation system: installation site / Temperature of mechanical services room		
Nominal width exterior or supply air / exhaust or extract air ducts		mm
Conductance ambient- or supply air duct / exhaust- or extract air duct		W/(mK)
Length ambient- or supply air duct / exhaust- or extract air duct		m
SHX: efficiency / effective heat recovery efficiency		%
HE defrosting / Defrosting at a minimum temperature of		0,00
Effective energy recovery efficiency ventilation / Humidity recovery		#WERT!
Ventilation system: Short description (installation site, ducts, silencers, others)		
Summer ventilation		
Summer base ventilation: ventilation type		
Air exchange via ventilation system with supply air:	0,00	
Air exchange via extract air system	0,00	
Window ventilation air exchange	0,46	
Night summer ventilation: Type of ventilation		
Night air exchange Window Night Ventilation, Manual	0,40	
Night air exchange mechanical, automatically Controlled ventilation	0,00	
Humidity differenceregulated		
Summer ventilation: short description (window opening profiles, night ventilation concepts, others)		
Cooling		
Max. indoor absolute humidity / Internal humidity sources	12,0	g/kg
Frequency of overheating / Overtemperature limit:	9,6	%
Mechanical cooling: Applied cooling units		
		kW
		kW
		kWh/(m ² a)
Mechanical cooling: Average annual coefficient of performance / Electricity demand		0,0
Mechanical cooling: Short description (unit, manufacturer, product name, installation site, installation)		

Heating and DHW			
DHW Demand	38,25	kWh/(m²a)	49863
Annual heating demand	250,68	kWh/(m²a)	326747
Direct electricity: contribution to space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
Direct electric heating / domestic hot water			
Final energy demand		kWh/(m²a)	
Direct electricity: short description (description, manufacturer, product name)			
Heat pump: covered fraction of space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
COP heat pump for heating / heat pump for DHW			
Final energy demand		kWh/(m²a)	
Compact unit: Short description (description, manufacturer, product name)			
Compact unit: covered fraction of space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
COP heat pump for heating / heat pump for DHW			
Final energy demand		kWh/(m²a)	
Compact unit: Short description (description, manufacturer, product name)			
Boiler: covered fraction of space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
Heat generator: building type / COP			
Final energy demand		kWh/(m²a)	
Boiler: short description (description, manufacturer, product name)			
District heating: Covered fraction of space heating / domestic hot water	100	%	100
PE value energy carrier / CO ₂ -emission factor	0,8	kWh/kWh	240
Heat source / Performance of heat generator	Hard Coal CGS 70% PHC		111,0
Final energy demand	320,7	kWh/(m²a)	
Compact unit: Short description (description, manufacturer, product name)			
Solarthermics			
Collector	7 Improved flat plate collector		
Collector area / Specific collector area	0,00	m ²	0,00
Deviation from north / Angle of inclination from the horizontal	180	°	45
Solarthermics: Short description (description, manufacturer, product name, installation location)			
Solar contribution to DHW	0,00	kWh/(m²a)	0
Solar contribution to space heating	0,00	kWh/(m²a)	0
Solar contribution total	0,00	kWh/(m²a)	0
Solar Storage	9 Simple solar storage		
PHOTOVOLTAIC			
Module technology	Amorph-Si		
Nominal current / Nominal voltage		A	
Nominal power / Number of modules	0,00	Wp	
Deviation from north / Angle of inclination from the horizontal		°	
Solarthermics: Short description (description, manufacturer, product name, installation location)			
Annual yield of PV modules		kWh/(m²a)	

Aux. electricity / Household electricity		
Aux Electricity		
Ventilation units / Electricity demand		
Heating system Devices / Electricity demand		973
DHW-system units / Electricity demand		321
Aux. Electricity solar devices / electr. demand		
Total aux. Electricity	0,99	kWh/(m²a) 1294,43
Household electricity		
Dishwasher / useful energy demand		16088
Washing machine units / Energy demand		14108
Clothes dryer unit / Energy demand		39277
Refrigerator, Freezer or combination unit / Useful energy demand		574
Cooking unit / energy demand		28125
Lighting		39150
Consumer Electronics		9900
Small appliances, etc.		11250
Other		
Total household electricity	121,58	kWh/(m²a) 158470,34
Economic data		
Total gross construction costs / contained VAT	€	
Building costs (cost group 300+400) / (cost group 200-700)	€	
Total gross construction costs per m ² BGF / per m ³ BRI	€/m ²	
Explanation building costs		
Fostering (Passivhaus, refurbishment, etc.)		
Explanation fostering		
Other		
Ecological aspects: rainwater utilization, etc.		
Material used: Regional products / Natural products		
Special features: first project in the country / first project used as		
Building awards		
Research project / funded project		
Description of research / funded project		
Other		

EnerPHit planning:

select active variants
>>

Results	Units
Annual heating demand	kwh/(m ² a)
Heating Load	W/m ²
Overall specific space cooling demand	kwh/(m ² a)
Cooling load	W/m ²
Frequency of overheating	%
Total primary energy demand	kwh/(m ² a)
Certifiable as EnerPHit building retrofit (acc. to heating demand)?	yes / no
<<	User defined
<<	Units

Input variables	Units
<< Assembly layers ('U-value')	
a Exterior roof insulation	W/(mK)
	mm
b New hydroinsulation	W/(mK)
	mm
c	W/(mK)
	mm
d Exterior roof insulation	W/(mK)
	mm
e New hydroinsulation	W/(mK)
	mm
f Cement	W/(mK)
	mm
g	W/(mK)
	mm
h Wall exterior insulation	W/(mK)
	mm
i New outside plaster	W/(mK)
	mm
j Stone	W/(mK)

		mm
k	Wall insulation Block A1	W/(mK)
		mm
l	New plaster lock A1	W/(mK)
		mm
m		W/(mK)
		mm
n	Basement insulation	W/(mK)
		mm
o		W/(mK)
		mm
p	Floor insulation on Block A connection	W/(mK)
		mm
q	New flooring	W/(mK)
		mm
r		W/(mK)
		mm
s		W/(mK)
		mm
t		W/(mK)
		mm
u		W/(mK)
		mm
v		W/(mK)
		mm
w		W/(mK)
		mm
x		W/(mK)
		mm
y		W/(mK)
		mm
z		W/(mK)
		mm

<< Radiation balance ('Areas')

<< Thermal bridges ('Areas')

<< Glazing and frames ('Window', 'Shading')

a	Wooden frame	
	Active variants:	
	g-Value: 0,77	Glazing
	U-Value: 2,8 W/(m ² K)	Frame
	<i>U-Value [W/(m²K]: Left: 1,6 Right: 1,6 Bottom: 1,6 Top: 1,6 Width [m]: Left: 0,14 Right: 0,14 Bottom: 0,14 Top: 0,14</i>	

	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
b	Wooden frame - shaded	
	Active variants:	
	g-Value: 0,77	Glazing
	U-Value: 2,8 W/(m ² K)	
	U-Value [W/(m ² K]: Left: 1,6 Right: 1,6 Bottom: 1,6 Top: 1,6	
	Width [m]: Left: 0,14 Right: 0,14 Bottom: 0,14 Top: 0,14	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
c	Wooden frame shaded door	
	Active variants:	
	g-Value: 0,77	Glazing
	U-Value: 2,8 W/(m ² K)	
	U-Value [W/(m ² K]: Left: 1,6 Right: 1,6 Bottom: 1,6 Top: 1,6	
	Width [m]: Left: 0,14 Right: 0,14 Bottom: 0,14 Top: 0,14	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
d	PVC frame	
	Active variants:	
	g-Value: 0,77	Glazing
	U-Value: 2,7 W/(m ² K)	
	U-Value [W/(m ² K]: Left: 1,8 Right: 1,8 Bottom: 1,8 Top: 1,8	
	Width [m]: Left: 0,14 Right: 0,14 Bottom: 0,14 Top: 0,14	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
a		

		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
e	Metal frame	
	Active variants:	
	g-Value: 0,87	Glazing
	U-Value: 5,8 W/(m ² K)	Frame
	U-Value [W/(m ² K]: Left: 5,5 Right: 5,5 Bottom: 5,5 Top: 5,5	
	Width [m]: Left: 0,14 Right: 0,14 Bottom: 0,14 Top: 0,14	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
f		
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
g		
	Glazing	
	Frame	

	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
h		
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
i		
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
j		
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
k		

		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
I		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
m		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
n		
		Glazing
		Frame

	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
o		
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
p		
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
q		
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
r		

		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
s		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
t		
		Glazing
		Frame
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
u		
		Glazing
		Frame

	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
v		
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
w		
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
x		
	Glazing	
	Frame	
	Window reveal depth	m
	Distance from glazing edge to reveal	m
	Overhang depth	m
	Distance of the upper edge of glazing to the overhang	m
	Reduction factor for temporary sun protection	%
y		

	Glazing
	Frame
Window reveal depth	m
Distance from glazing edge to reveal	m
Overhang depth	m
Distance of the upper edge of glazing to the overhang	m
Reduction factor for temporary sun protection	%
z	
	Glazing
	Frame
Window reveal depth	m
Distance from glazing edge to reveal	m
Overhang depth	m
Distance of the upper edge of glazing to the overhang	m
Reduction factor for temporary sun protection	%

<< Ventilation ('Ventilation', 'SummVent')

Ventilation type	select
Air Change Rate at press. Test (n_{50})	1/h
Design air flow rate (maximum)	m^3/h
Installation site of ventilation unit	Inside/Outside
Ventilation unit selection	select

Summer background ventilation to ensure adequate air quality

Air exchange via ventilation system with supply air:	1/h
HR/ER in summer (check one field only):	none
automatic bypass, controlled by temperature difference	check as appropriate
automatic bypass, controlled by enthalpy difference	check as appropriate
	always
Air exchange via extract air system	1/h
Specific power consumption (for extract air system)	Wh/m^3
Window ventilation air exchange	1/h

Additional summer ventilation for cooling

CALCULATION OF VARIANTS

Active

1-No measures	No measures	Block A: Roof ins. Block A1: Walls ins., Changing windows, shading, periferal ins.	Block A: Walls ins., Changing windows, shading Block A1: Roof ins. HVAC: Ventilation, Repearng heating	New heat source, new DHW system
1	1	2	3	4
250,1	250,1	188,6	24,2	24,2
105,1	105,1	80,2	16,1	16,1
9,6	9,6	9,1	8,2	8,2
312,4	312,4	257,8	128,8	124,0
no	no	no	yes	yes
Link	Link	Link	Link	Link

Value	1	2	3	4
0	0,035	0,035	0,035	0,035

0	0,035	0,035	0,035
0	300	300	300
0	0,17	0,17	0,17
0	0,06	0,06	0,06
0			
0			
0			
0	0,035	0,035	
0	300	300	
0	0,17	0,17	
0	0,06	0,06	
0	0,93	0,93	
0	100	100	
0			
0			
0			
0	0,032	0,032	
0	250	250	
0	0,87	0,87	
0	20	20	
0	1,06	1,06	

0			40	40
0		0,032	0,032	0,032
0		250	250	250
0		0,87	0,87	0,87
0		20	20	20
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				
0				

[Go to glazing list](#)

[Go to window frames list](#)

97ud Double glazing 4/30mm air/4	97ud Double glazing 4/30mm air/4	97ud Double glazing 4/30mm air/5	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer
54ud EXISTING: timber 68 mm	54ud EXISTING: timber 68 mm	54ud EXISTING: timber 68 mm	0081wi03 Rehau - REHAU GENEO PHZ - with Swissspacer V	0081wi03 Rehau - REHAU GENEO PHZ - with Swissspacer V

0,150	0,15	0,15	0,16	0,16
0,120	0,12	0,12	0,131	0,131
0,150	0,15	0,15	0,16	0,16
0,120	0,12	0,12	0,131	0,131
			60%	60%

[Go to glazing list](#)[Go to window frames list](#)

97ud Double glazing 4/30mm air/4	97ud Double glazing 4/30mm air/4	97ud Double glazing 4/30mm air/5	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer
54ud EXISTING: timber 68 mm	54ud EXISTING: timber 68 mm	54ud EXISTING: timber 68 mm	0081wi03 Rehau - REHAU GENEOPHZ - with Swissspacer V	0081wi03 Rehau - REHAU GENEOPHZ - with Swissspacer V
0,250	0,25	0,25	0,25	0,25
0,120	0,12	0,12	0,131	0,131
0,250	0,25	0,25	0,25	0,25
0,120	0,12	0,12	0,131	0,131
			60%	60%

[Go to glazing list](#)[Go to window frames list](#)

97ud Double glazing 4/30mm air/4	97ud Double glazing 4/30mm air/4	97ud Double glazing 4/30mm air/5	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer
54ud EXISTING: timber 68 mm	54ud EXISTING: timber 68 mm	54ud EXISTING: timber 68 mm	0251wi03 RAICO - FRAME+ 90 WB - with Swissspacer V	0251wi03 RAICO - FRAME+ 90 WB - with Swissspacer V
0,500	0,5	0,5	0,5	0,5
0,120	0,12	0,12	0,156	0,156
0,500	0,5	0,5	0,5	0,5
0,120	0,12	0,12	0,156	0,156

[Go to glazing list](#)[Go to window frames list](#)

94ud Double glazing 4/16mm air/4	94ud Double glazing 4/16mm air/4	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer
56ud EXISTING: synthetic before 1998	56ud EXISTING: synthetic before 1998	0081wi03 Rehau - REHAU GENEOPHZ - with Swissspacer V	0081wi03 Rehau - REHAU GENEOPHZ - with Swissspacer V	0081wi03 Rehau - REHAU GENEOPHZ - with Swissspacer V
0,150	0,15	0,25	0,25	0,25
0,140	0,14	0,131	0,131	0,131
0,150	0,15	0,25	0,25	0,25
0,140	0,14	0,131	0,131	0,131
		60%	60%	60%

[Go to glazing list](#)[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

92ud Single glazing	92ud Single glazing	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer	01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer
60ud EXISTING: metal, no thermal break, paint finish	60ud EXISTING: metal, no thermal break, paint finish	0251wi03 RAICO - FRAME+ 90 WB - with Swisspacer V	0251wi03 RAICO - FRAME+ 90 WB - with Swisspacer V	0251wi03 RAICO - FRAME+ 90 WB - with Swisspacer V
0,150	0,15	0,5	0,5	0,5
0,100	0,1	0,156	0,156	0,156
0,150	0,15	0,5	0,5	0,5
0,100	0,1	0,156	0,156	0,156

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

[Go to glazing list](#)

[Go to window frames list](#)

Window ventilation only	Window ventilation only	Window ventilation only	Balanced PH-Ventilation with HR	Balanced PH-Ventilation with HR
4,00	4	3	1	1
			Inside the thermal envelope	Inside the thermal envelope

[Go to ventilation units list](#)

0,00			0,31	0,31
			x	x
0,00			0,51	0,51
0,00			0,4	0,4
0,46	0,46	0,46	0,07	0,07

0,40	0 , 40	0 , 19	0 , 19	0 , 19
0,00				
0,00				

Basement insulation + LED Lighting				
5	6	7	8	9
24,1				
16,2				
8,4				
98,4				
yes				
Link	Link	Link		

5	6	7	8	9
---	---	---	---	---

0,035				
300				
0,17				
0,06				
0,035				
300				
0,17				
0,06				
0,93				
100				
0,032				
250				
0,87				
20				
1,06				

40				
0,032				
250				
0,87				
20				
0,041				
100				

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer				
0081wi03 Rehau - REHAU GENEO PHZ - with Swissspacer V				

0,16				
0,131				
0,16				
0,131				
60%				

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer				
0081wi03 Rehau - REHAU GENEOPHZ - with Swissspacer V				
0,25				
0,131				
0,25				
0,131				
60%				

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer				
0251wi03 RAICO - FRAME+ 90 WB - with Swissspacer V				
0,5				
0,156				
0,5				
0,156				

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer				
0081wi03 Rehau - REHAU GENEOPHZ - with Swissspacer V				
0,25				
0,131				
0,25				
0,131				
60%				

01ud 44 mm. triple glazing, 2 Low-E, air, alum.spacer				
0251wi03 RAICO - FRAME+ 90 WB - with Swissspacer V				
0 ,5				
0 ,156				
0 ,5				
0 ,156				

Balanced PH-Ventilation with HR				
1				
Inside the thermal envelope				

0,31				
x				
0,51				
0,4				
0,07				

0,19				

Selection of comparison configuration

Description	6-S2:Walls
Component type	Building assemblies ('U-Value')
Component	01ud Block A - plaster

Calculation of selected configuration

	Lower Efficiency	Hig Effici
Design according to variant	2-Block A: Roof ins.E	3-Block A:
U-Value	1,347	0,1
Minimal interior surface temperature	11,5	19
Design Temperature outside	-9,1	-9
Interior temperature	20,0	20
Normal surface thermal resistance	0,13	0,
Increased Heat Transfer Resistance	0,25	0,2
Minimal surface temperature unobstructed	14,8	19

Mould!

	Inves	
	Per m ² of component	Whole component
Area of component	1,00	1337
Investment costs less sum of financial support	10,38	13877
Annuity (capital costs)	0,56	748
		2,23

Energy (Space heating + c)

	Per m ² of TFA	Entire building	Per m ² of TFA
Area	1	1303	1
Annual heating demand	115,68	150786	24,25

Cooling + dehumidification demand

Electricity demand:

Auxiliary electricity for Heating	0,75	973	0,75
Auxiliary electricity ventilation winter	2,31	3009	2,31
Direct electric	0,00	0	0,00
HP	0,00	0	0,00
Compact heat pump unit	0,00	0	0,00
Auxiliary electricity ventilation summer	3,48	4533	3,48

Compressor cooling unit	0,00	0	0,00
-------------------------	------	---	------

Final energy demand:

Total electricity demand	6,53	8515	6,53
Gas	0,00	0	0,00
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	129,09	168267	27,62
Others	0,00	0	0,00

CO2-Emissions:

Total electricity demand	4,44	5790	4,44
Gas	0,00	0	0,00
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	40384,06	52639001	8639,21
Others	0,00	0	0,00

PE-demand

Total electricity	16,98	22138	16,98
Gas	0,00	0	0,00
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	134613,52	290152	28797,38
Others	0,00	0	0,00

Costs:

Total electricity	0,65	851	0,65
Gas	0,00	0	0,00
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	7,10	9255	1,52
Others	0,00	0	0,00
Total energy costs	7,75	10106	2,17
Maintenance costs	0,00	0	0,00

Final energy demand	142,16	185296	40,68
CO ₂ -Emissions	40388,50	52644791	8643,66
Primary energy demand	134630,50	312290	28814,36
Total cost space conditioning	7,75	10106	2,17

		Economi
Total annual costs	8,33	10854

Maximal economically viable additional i

Cost per kWh of s

<<

Boundary conditions

Interest rate + Inflation	Boundary
Nominal interest rate	6 ,50%
Inflation	1 ,53%
Period under consideration [a]	20

Electricity
Gas/Oil
Logs
Pellet
District heating
Others

z

E T W E E N T W O V A R I A N T S

ther ency	Difference / Savings / Profit
Walls ins.	
1,7	W/(m ² K)
1,2	°C
,1	°C
,0	°C
13	m ² K/W
25	m ² K/W
1,5	°C

Treatment		
Whole component	Per m ² of component	Whole component
1337	1,00	1337
55440	31,08	41563
2988	1,67	2240

Cooling + mech. ventilation)		
Entire building	Per m ² of component	Whole component
1303	1	1337
31608	89,12	119178

973	0,00	0
3009	0,00	0
0	0,00	0
0	0,00	0
0	0,00	0
4533	0,00	0

0	0,00	0	kWh/a
---	------	---	-------

8515	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
35997	98,91	132270	kWh/a
0	0,00	0	kWh/a

5790	0,00	0	kg/a
0	0,00	0	kg/a
0	0,00	0	kg/a
0	0,00	0	kg/a
0	0,00	0	kg/a
11260869	30940,88	41378133	kg/a
0	0,00	0	kg/a

22138	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
26917	196,84	263235	kWh/a
0	0,00	0	kWh/a

851	0,00	0	€/a
0	0,00	0	€/a
0	0,00	0	€/a
0	0,00	0	€/a
0	0,00	0	€/a
1980	5,44	7275	€/a
0	0,00	0	€/a
2831	5,44	7275	€/a
0	0,00	0	€/a

53026	98,91	132270	kWh/a
11266659	30940,88	41378133	kg/a
49055	196,84	263235	kWh/a
2831	5,58	7275	€/a

c viability			
5819	3,76	5035	€/a

investment costs	100,94	134991	€
aved final energy		1,7	Cent/kWh

conditions	
s [cent/kWh]	Period of use
10	Build. assemblies 50
6	Vent. system 25
3	Thermal bridges 50
4	Complete building 35
6	Windows 30
20	



Input: comparison configuration

Description	S1: Building	S1: Roof
Component type	Complete building	Building assemblies ('U-Value')
Component		10ud Roof type 2 direct to exterior wall
"Lower Efficiency" variant	1-No measures	1-No measures
Investment costs [€]	9274,80	8038,81
Annual maintenance costs [€/a]		
"Higher Efficiency" variant	2-Block A: Roof ins. Block A1: W	2-Block A: Roof ins. Block A1: W
Investment costs [€]	41269,17	17124,60
Annual maintenance costs [€/a]		
Financial support (present value) [€]		

Results (manual transfer)

3

4

5

S1: Walls A1	S1: Windows	S2: Building
Building assemblies ('U-Value')	Windows ('Window')	Complete building
11ud Block A - connection	d-PVC frame	- No additional input
1-No measures	1-No measures	2-Block A: Roof ins.Block A1: W
1235,99		17241,43
2-Block A: Roof ins.Block A1: Walls ins., Changing windows, Sh	3-Block A: Walls ins., Changing	
3441,66	14409,94	238849,27


9

10

Compl. Building	S4:Building
Complete building	Complete building
- No additional input	- No additional input
1-No measures	4-New heat source, new DHW system
0,00	0,00
5-Basement insulation + LED Li	5-Basement insulation + LED Lighting
298746,16	12378,38

EnerPHit planning:

CLIMATE DATA



Building: School "Tzanko Diustabanov"-Block A

Wedge-shaped building assemblies (tapered insulation),
unventilated air layers and unheated attics

> Auxiliary calculation to the right

Assembly No.	Building assembly description	Interior insulation?				
01ud	Block A - plaster	<input checked="" type="checkbox"/>				
Heat transfer resistance [m ² K/W]		interior R _{si} : 0,13				
		exterior R _{se} : 0,04				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Plaster in	0,700					20
2. Bricks	0,790					400
3. Plaster outside	0,870					30
4. EPS-F	0,000					0
5. Plaster	0,000					0
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total 45,0 cm
100%						
U-value supplement <input type="text"/> W/(m ² K)		U-Value: 1,347 W/(m ² K)				


Assembly No.	Building assembly description	Interior insulation?				
02ud	Block A - stone façade	<input checked="" type="checkbox"/>				
Heat transfer resistance [m ² K/W]		interior R _{si} : 0,13				
		exterior R _{se} : 0,04				
Area section 2	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Plaster in	0,700					20
2. Bricks	0,790					400
3. Plaster outside	0,870					20
4. Stone facede	1,060					40
5. EPS-F	0,000					0
6. Stone facede	0,000					0
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total 48,0 cm
100%						
U-value supplement <input type="text"/> W/(m ² K)		U-Value: 1,306 W/(m ² K)				


Assembly No.	Building assembly description	Interior insulation?				
03ud	Ground walls	<input checked="" type="checkbox"/>				
Heat transfer resistance [m ² K/W]		interior R _{si} : 0,13				
		exterior R _{se} : <input type="text"/>				
Area section 3	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Bitum	0,170					5
2. Concrete	1,630					550
3. Inside plaster	0,700					20
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total 57,5 cm
100%						
U-value supplement <input type="text"/> W/(m ² K)		U-Value: 1,903 W/(m ² K)				


Assembly No. Building assembly description					Interior insulation?		
04ud	Ground walls (heated basement)			<input checked="" type="checkbox"/>			
Heat transfer resistance [m^2K/W] interior R_{si} :		0,13					
exterior R_{se} :		<input type="text"/>					
Area section 4		λ [$W/(mK)$]	Area section 2 (optional)	λ [$W/(mK)$]	Area section 3 (optional)	λ [$W/(mK)$]	Thickness [mm]
1.	Bitum	0,170					5
2.	Concrete	1,630					200
3.	Inside plaster	0,700					20
4.							
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%		<input type="text"/>		<input type="text"/>		22,5	cm
U-value supplement <input type="text"/> W/(m ² K)				U-Value: 3,219		W/(m ² K)	

Assembly No. Building assembly description					Interior insulation?		
05ud	Floor (heated basement)			<input checked="" type="checkbox"/>			
Heat transfer resistance [m^2K/W] interior R_{si} :		0,17					
exterior R_{se} :		0,17					
Area section 5		λ [$W/(mK)$]	Area section 2 (optional)	λ [$W/(mK)$]	Area section 3 (optional)	λ [$W/(mK)$]	Thickness [mm]
1.	Mosaic	3,490					20
2.	Cement	0,930					30
3.	Concrete	2,100					200
4.	STONE embankment	3,500					250
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%		<input type="text"/>		<input type="text"/>		50,0	cm
U-value supplement <input type="text"/> W/(m ² K)				U-Value: 1,836		W/(m ² K)	

Assembly No. Building assembly description					Interior insulation?		
06ud	Floor (unheated basement)			<input checked="" type="checkbox"/>			
Heat transfer resistance [m^2K/W] interior R_{si} :		0,17					
exterior R_{se} :		0,17					
Area section 6		λ [$W/(mK)$]	Area section 2 (optional)	λ [$W/(mK)$]	Area section 3 (optional)	λ [$W/(mK)$]	Thickness [mm]
1.	Mosaic	3,490					20
2.	Cement	0,930					30
3.	Concrete	1,450					200
4.	Plaster	0,700					30
5.	EPS-F	0,000					0
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%		<input type="text"/>		<input type="text"/>		28,0	cm
U-value supplement <input type="text"/> W/(m ² K)				U-Value: 1,790		W/(m ² K)	

Assembly No. Building assembly description					Interior insulation?		
07ud	Floor slab on grade (mosaic)						
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,17				
exterior R _{se} :							
Area section 7		λ _i [W/(mK)]	Area section 2 (optional)	λ _i [W/(mK)]	Area section 3 (optional)	λ _i [W/(mK)]	Thickness [mm]
1. Mosaic		3,490					20
2. Cement		0,930					50
3. Concrete		1,450					150
4. Stone embankment		3,500					300
5. Floor insulation		0,000					0
6. New flooring		0,000					0
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						52,0	cm
U-value supplement  W/(m ² K)				U-Value: 2,389 W/(m ² K)			

Assembly No. Building assembly description					Interior insulation?		
08ud	Floor slab on grade (wood flooring)						
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,17				
exterior R _{se} :							
Area section 8		λ _i [W/(mK)]	Area section 2 (optional)	λ _i [W/(mK)]	Area section 3 (optional)	λ _i [W/(mK)]	Thickness [mm]
1. Wood		0,350					20
2. Cement		0,930					30
3. Concrete		1,450					200
4. Stone embankment		3,500					250
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						50,0	cm
U-value supplement  W/(m ² K)				U-Value: 2,133 W/(m ² K)			

Assembly No. Building assembly description					Interior insulation?		
09ud	Roof type 1 - unheated attic						
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,10				
exterior R _{se} :		0,10					
Area section 9		λ _i [W/(mK)]	Area section 2 (optional)	λ _i [W/(mK)]	Area section 3 (optional)	λ _i [W/(mK)]	Thickness [mm]
1. Suspended ceiling		0,210					8
2. Closed air		0,920					150
3. Concrete		2,100					120
4. Mineral wool		0,041					100
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						37,8	cm
U-value supplement  W/(m ² K)				U-Value: 0,345 W/(m ² K)			

EnerPHit planning:

U - V A L U E S O F B U I L D I N G E L E M E

Assembly No.	Building assembly description				Interior insulation?
10ud	Roof type 2 direct to external air				<input checked="" type="checkbox"/>
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,10		
		exterior R _{se} :	0,04		
Area section					
10	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
1. Plaster	0,700				
2. Concrete	2,100				
3. Cement	0,930				
4. Bitum	0,170				
5. XPS	0,000				
6. Hydroinsulation	0,000				
7.					
8.					
Percentage of sec. 1		Percentage of sec. 2	Percentage of sec. 3	Thickness [mm]	
100%		<input type="checkbox"/>	<input type="checkbox"/>	20	200
				30	5
				0	0
				Total	25,5 cm
U-value supplement <input type="checkbox"/> W/(m ² K)		U-Value: 3,072 W/(m ² K)			

Assembly No.	Building assembly description				Interior insulation?
11ud	Block A - connection				<input checked="" type="checkbox"/>
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,13		
		exterior R _{se} :	0,04		
Area section					
11	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
1. Plaster in	0,700				
2. Bricks	0,790				
3. Plaster outside	0,870				
4. EPS-F	0,000				
5. Plaster	0,000				
6.					
7.					
8.					
Percentage of sec. 1		Percentage of sec. 2	Percentage of sec. 3	Thickness [mm]	
100%		<input type="checkbox"/>	<input type="checkbox"/>	20	500
				30	0
				0	0
				Total	55,0 cm
U-value supplement <input type="checkbox"/> W/(m ² K)		U-Value: 1,155 W/(m ² K)			

Assembly No.	Building assembly description				Interior insulation?
12ud	Under unheated basement floor				<input checked="" type="checkbox"/>
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,17		
		exterior R _{se} :	<input type="checkbox"/>		
Area section					
12	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
1. Cement	0,930				
2. Concrete	1,450				
3. stone embankment	3,500				
4.					
5.					
6.					
7.					
8.					
Percentage of sec. 1		Percentage of sec. 2	Percentage of sec. 3	Thickness [mm]	
100%		<input type="checkbox"/>	<input type="checkbox"/>	20	150
				250	
				Total	42,0 cm
U-value supplement <input type="checkbox"/> W/(m ² K)		U-Value: 2,729 W/(m ² K)			

Assembly No.	Building assembly description				Interior insulation?
13ud	Block A - stone façade				<input checked="" type="checkbox"/>
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,13		

U - V A L U E S O F B U I L D I N G E L E M E

						exterior R _{se} : <input type="text" value="0,04"/>	
Area section 13		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.	Plaster in	<input type="text" value="0,700"/>					20
2.	Bricks	<input type="text" value="0,790"/>					500
3.	Plaster outside	<input type="text" value="0,870"/>					20
4.	Stone facade	<input type="text" value="1,060"/>					40
5.	EPS-F	<input type="text" value="0,000"/>					0
6.	Plaster	<input type="text" value="0,000"/>					0
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						58,0	cm
U-value supplement <input type="text"/> W/(m ² K)		U-Value: <input type="text" value="1,121"/> W/(m ² K)					

Assembly No. Building assembly description 14ud Block A connection roof direct to external air						Interior insulation? <input type="checkbox"/>	
Heat transfer resistance [m ² K/W]		interior R _{si} : <input type="text" value="0,10"/>					
exterior R _{se} : <input type="text" value="0,04"/>							
Area section 14		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.	Plaster	<input type="text" value="0,700"/>					20
2.	Concrete	<input type="text" value="1,630"/>					200
3.	Cement	<input type="text" value="0,930"/>					30
4.	Bitum	<input type="text" value="0,170"/>					5
5.	XPS	<input type="text" value="0,000"/>					0
6.	Armed_cement	<input type="text" value="0,000"/>					0
7.	Bitum	<input type="text" value="0,000"/>					0
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						25,5	cm
U-value supplement <input type="text"/> W/(m ² K)		U-Value: <input type="text" value="2,833"/> W/(m ² K)					

Assembly No. Building assembly description 15ud Roof type 2 direct to external air Connection						Interior insulation? <input type="checkbox"/>	
Heat transfer resistance [m ² K/W]		interior R _{si} : <input type="text" value="0,10"/>					
exterior R _{se} : <input type="text" value="0,04"/>							
Area section 15		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.	Plaster	<input type="text" value="0,700"/>					20
2.	Concrete	<input type="text" value="2,100"/>					200
3.	Cement	<input type="text" value="0,930"/>					30
4.	Bitum	<input type="text" value="0,170"/>					5
5.	Mineral wool	<input type="text" value="0,000"/>					0
6.	Hydroinsulation	<input type="text" value="0,000"/>					0
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						25,5	cm
U-value supplement <input type="text"/> W/(m ² K)		U-Value: <input type="text" value="3,072"/> W/(m ² K)					

Assembly No. Building assembly description 16ud						Interior insulation? <input type="checkbox"/>	
Heat transfer resistance [m ² K/W]		interior R _{si} : <input type="text"/>					
exterior R _{se} : <input type="text"/>							
Area section 16		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]

Secondary Calculation: Equivalent Thermal Conductivity of Still Air Spaces

Air Layer Thickness	<input type="text" value="50"/>	mm	Convective heat transfer
Direction of the thermal flow:	<input checked="" type="checkbox"/> Upwards		h_a 1,95 W/(m ² K)
	<input type="checkbox"/> Horizontal		Radiation heat transfer
	<input type="checkbox"/> Downwards		h_r 4,17 W/(m ² K)
Emissivity of surface 1	<input type="text" value="0,90"/>		equivalent thermal conductivity
Emissivity of surface 2	<input type="text" value="0,90"/>		λ <input type="text" value="0,31"/> W/(mK)

Secondary Calculation: Equivalent Thermal Conductivity of Still Air Spaces

Air Layer Thickness of the	<input type="text" value=""/>	mm	Convective heat transfer
	<input type="checkbox"/> Upwards		h_a W/(m ² K)
	<input type="checkbox"/> Horizontal		Radiation heat transfer
	<input type="checkbox"/> Downwards		h_r W/(m ² K)
Emissivity of surface 1	<input type="text" value=""/>		equivalent thermal conductivity
Emissivity of surface 3	<input type="text" value=""/>		λ <input type="text" value=""/> W/(mK)

Wedge-shaped layers (at an inclination of max. 5%)

(Calculation following EN 6946 Appendix C)

Assembly No. Building assembly description					
1a	Exemplary flat roof with wedge-shaped insulation				
Heat transfer resistance [$\text{m}^2\text{K}/\text{W}$]		interior R_{si} :	0,10		
		exterior R_{se} :	0,04		
A parallel assemblies layer					
Area section 1	λ [$\text{W}/(\text{mK})$]	Area section 2 (optional)	λ [$\text{W}/(\text{mK})$]	Area section 3 (optional)	λ [$\text{W}/(\text{mK})$]
1. Concrete Ceiling	2,100				
2. PS Rigid Foam	0,040				
3.					
4.					
5.					
6.					
7.					
8.					
Percentage of sec. 1		Percentage of sec. 2	Percentage of sec. 3		
100%					
U₀: 0,192 $\text{W}/(\text{m}^2\text{K})$					
R₀: 5,216 $(\text{m}^2\text{K})/\text{W}$					
B Wedge-Shaped Assembly Layer					
Area section 1	λ [$\text{W}/(\text{mK})$]	Area section 2 (optional)	λ [$\text{W}/(\text{mK})$]	Area section 3 (optional)	λ [$\text{W}/(\text{mK})$]
PS rigid foam insulation	0,040				
Percentage of sec. 2		Percentage of sec. 3	Thickness d ₁ [mm]		
			15,0 cm		
U₁: 0,267 $\text{W}/(\text{m}^2\text{K})$					
R₁: 3,750 $(\text{m}^2\text{K})/\text{W}$					
Rectangular Area U-Value: 0,144 $\text{W}/(\text{m}^2\text{K})$					
U-value of triangular area with the thickest point at the apex: 0,157 $\text{W}/(\text{m}^2\text{K})$					
U-value of triangular area with the thinnest point at the apex: 0,131 $\text{W}/(\text{m}^2\text{K})$					

Wedge-shaped layers (at an inclination of max. 5%)

(Calculation following EN 6946 Appendix C)

Assembly No. Building assembly description					
2a					
Heat transfer resistance [$\text{m}^2\text{K}/\text{W}$]		interior R_{si} :	<input type="text"/>	Total Width	
		exterior R_{se} :	<input type="text"/>		
A parallel assemblies layer					
Area section 1	$\lambda_1 [\text{W}/(\text{mK})]$	Area section 2 (optional)	$\lambda_2 [\text{W}/(\text{mK})]$	Area section 3 (optional)	$\lambda_3 [\text{W}/(\text{mK})]$
1.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
2.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
3.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
4.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
5.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
6.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
7.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
8.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
100%		<input type="text"/>		<input type="text"/>	
$U_0:$ <input type="text"/> $\text{W}/(\text{m}^2\text{K})$ $R_0:$ <input type="text"/> $(\text{m}^2\text{K})/\text{W}$					
B Wedge-Shaped Assembly Layer					
Area section 2 (optional)	$\lambda_2 [\text{W}/(\text{mK})]$	Area section 3 (optional)	$\lambda_3 [\text{W}/(\text{mK})]$	Thickness d_1 [mm]	
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	
Percentage of sec. 2		Percentage of sec. 3		Thickness d_1 [cm]	
<input type="text"/>		<input type="text"/>		<input type="text"/> cm	
$U_1:$ <input type="text"/> $\text{W}/(\text{m}^2\text{K})$ $R_1:$ <input type="text"/> $(\text{m}^2\text{K})/\text{W}$ Rectangular Area U-Value: <input type="text"/> $\text{W}/(\text{m}^2\text{K})$ U-value of triangular area with the thinnest point at the apex: <input type="text"/> $\text{W}/(\text{m}^2\text{K})$ U-value of triangular area with the thinnest point at the apex: <input type="text"/> $\text{W}/(\text{m}^2\text{K})$					

Non-conditioned attic

Building assembly description					
Roof					
Heat transfer resistance [m ² K/W]	interior R _{si} :	0,17	Exterior absorption coefficient	0,80	
	exterior R _{se} :	0,04	Exterior emissivity	0,93	
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
1. Corrugated galvanised irc 60,000					
2.					
3.					
4.					
5.					
6.					
7.					
8.					
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	Total
100%					0,3 cm
U-value supplement		W/(m ² K)		U-Value:	4,761 W/(m ² K)

Building assembly description					
Exterior attic wall					
Heat transfer resistance [m ² K/W]	interior R _{si} :	0,13	Exterior absorption coefficient	0,80	
	exterior R _{se} :	0,04	Exterior emissivity	0,93	
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
1. Interior plaster	0,350				
2. Masonry	1,100				
3. Exterior Render	0,800				
4.					
5.					
6.					
7.					
8.					
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	Total
100%					21,0 cm
U-value supplement		W/(m ² K)		U-Value:	2,519 W/(m ² K)

Building assembly description																														
Intermediate ceiling																														
Heat transfer resistance [m ² K/W] interior R _{si} : 0,17 exterior R _{se} : 0,17																														
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]																								
1. Wooden floor	0,130					22																								
2.																														
3.																														
4.																														
5.																														
6.																														
7.																														
8.																														
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total																								
83%		16,7%				2,2 cm																								
U-value supplement			U-Value: 1,964 W/(m ² K)																											
<table> <tr> <td>Attic area</td> <td colspan="2">emissivity in the attic</td> <td colspan="3">Air exchange in the attic</td> </tr> <tr> <td>Roof area</td> <td>200,0 m²</td> <td>Inner side of the roof / exterior wall</td> <td>0,93</td> <td>Air change rate</td> <td>0,20 1/h</td> </tr> <tr> <td>Area of exterior walls and attic</td> <td>200,0 m²</td> <td>Upper side of the interior ceiling</td> <td>0,93</td> <td>Volume</td> <td>200,0 m³</td> </tr> <tr> <td>Area of intermediate ceiling</td> <td>100,0 m²</td> <td></td> <td></td> <td></td> <td></td> </tr> </table>							Attic area	emissivity in the attic		Air exchange in the attic			Roof area	200,0 m ²	Inner side of the roof / exterior wall	0,93	Air change rate	0,20 1/h	Area of exterior walls and attic	200,0 m ²	Upper side of the interior ceiling	0,93	Volume	200,0 m ³	Area of intermediate ceiling	100,0 m ²				
Attic area	emissivity in the attic		Air exchange in the attic																											
Roof area	200,0 m ²	Inner side of the roof / exterior wall	0,93	Air change rate	0,20 1/h																									
Area of exterior walls and attic	200,0 m ²	Upper side of the interior ceiling	0,93	Volume	200,0 m ³																									
Area of intermediate ceiling	100,0 m ²																													
Equivalent value for the intermediate ceiling (to be linked to worksheets "Components" and "Areas")																														
U-Value:	2,732	Absorptivity:	0,780	Emissivity:	0,907																									
Total solar energy transmittance (informative): 0,085																														

AREAS DETERMINATION

Building: School "Tzanko Diustabanov"-Block A

Heating demand 250 kWh/(m²a)

Summary						Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit	Comment				
1	Treated Floor Area		1303,46	m ²	Treated floor area according to PHPP manual			10 months	12 months
2	North Windows	A	52,75	m ²		North Windows	2,457	3006	4602
3	East Windows	A	242,41	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the "Windows" worksheet.	East Windows	2,384	26390	44325
4	South Windows	A	36,89	m ²		South Windows	3,783	7765	8678
5	West Windows	A	101,73	m ²		West Windows	2,389	11692	19607
6	Horizontal Windows	A	0,00	m ²		Horizontal Windows			
7	Exterior Door	A	2,00	m ²	Please subtract area of door from respective building assembly	Exterior Door	5,500		
8	Exterior Wall - Ambient	A	1365,61	m ²	Temperature Zone "A" is ambient air.	Exterior Wall - Ambient	1,333	5880	9187
9	Exterior Wall - Ground	B	0,00	m ²	Temperature zone "B" is the ground.	Exterior Wall - Ground			
10	Roof/Ceiling - Ambient	A	549,78	m ²		Roof/Ceiling - Ambient	3,072	24117	34910
11	Floor slab / basement ceiling	B	549,78	m ²		Floor slab / basement ceiling	2,012		
12			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
13			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"	Factor for X			
14		X	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f, < 1):	75%			
						Thermal bridges - Overview	Ψ [W/(mK)]		
15	Thermal Bridges Ambient	A	597,06	m	Units in m	Thermal Bridges Ambient	-0,215		
16	Perimeter Thermal Bridges	P	110,20	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).	Perimeter Thermal Bridges	-0,380		
17	Thermal bridges FS/BC	B	0,00	m	Units in m	Thermal bridges FS/BC			
18	Partition Wall to Neighbour	I	70,07	m ²	No heat losses, only considered for the heating load calculation.	Partition Wall to Neighbour	1,347		
Total thermal envelope			2900,94	m²		Average Therm. Envelope	1,912		

[Go to building components list](#)

28				x (x	+	-) -	0,0	=								
29				x (x	+	-) -	0,0	=								
30				x (x	+	-) -	0,0	=								
31				x (x	+	-) -	0,0	=								
32				x (x	+	-) -	0,0	=								
33				x (x	+	-) -	0,0	=								
34				x (x	+	-) -	0,0	=								
35				x (x	+	-) -	0,0	=								
36				x (x	+	-) -	0,0	=								
37				x (x	+	-) -	0,0	=								
38				x (x	+	-) -	0,0	=								
39				x (x	+	-) -	0,0	=								
40				x (x	+	-) -	0,0	=								
41				x (x	+	-) -	0,0	=								
42				x (x	+	-) -	0,0	=								
43				x (x	+	-) -	0,0	=								
44				x (x	+	-) -	0,0	=								
45				x (x	+	-) -	0,0	=								
46				x (x	+	-) -	0,0	=								
47				x (x	+	-) -	0,0	=								
48				x (x	+	-) -	0,0	=								
49				x (x	+	-) -	0,0	=								
50				x (x	+	-) -	0,0	=								

Aend

AREAS DETERMINATION

Building: School "Tzanko Diustabanov"-Block A Heating demand 250 kWh/(m²a)

Summary						Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit	Comment				
1	Treated Floor Area		1303,46	m ²	Treated floor area according to PHPP manual				10 months
2	North Windows	A	52,75	m ²		North Windows	2,457	3006	4602
3	East Windows	A	242,41	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas. which is displayed in the "Windows" worksheet.	East Windows	2,384	26390	44325
4	South Windows	A	36,89	m ²		South Windows	3,783	7765	8678
5	West Windows	A	101,73	m ²		West Windows	2,389	11692	19607
6	Horizontal Windows	A	0,00	m ²		Horizontal Windows			
7	Exterior Door	A	2,00	m ²	Please subtract area of door from respective building assembly	Exterior Door	5,500		
8	Exterior Wall - Ambient	A	1365,61	m ²	Temperature Zone "A" is ambient air.	Exterior Wall - Ambient	1,333	5880	9187
9	Exterior Wall - Ground	B	0,00	m ²	Temperature zone "B" is the ground.	Exterior Wall - Ground			
10	Roof/Ceiling - Ambient	A	549,78	m ²		Roof/Ceiling - Ambient	3,072	24117	34910
11	Floor slab / basement ceiling	B	549,78	m ²		Floor slab / basement ceiling	2,012		
12			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
13			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"	Factor for X			
14		X	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f, < 1):	75%			
Thermal bridges - Overview									
15	Thermal Bridges Ambient	A	597,06	m	Units in m	Thermal Bridges Ambient	-0,215		
16	Perimeter Thermal Bridges	P	110,20	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).	Perimeter Thermal Bridges	-0,380		
17	Thermal bridges FS/BC	B	0,00	m	Units in m	Thermal bridges FS/BC			
18	Partition Wall to Neighbour	I	70,07	m ²	No heat losses, only considered for the heating load calculation.	Partition Wall to Neighbour	1,347		
Total thermal envelope						Average Therm. Envelope	1,912		

[Go to building components list](#)

Thermal Bridge Inputs											
Nr.	Thermal bridge description	Group Nr.	Assigned to group	Quan- ty	x (User deter- mined length [m]	Subtraction user- deter- mined length [m]) =	Length ℓ [m]	Input of thermal bridge heat loss coefficient W/(mK)	Ψ W/(mK)
1	Roof perimeter	15	Thermal Bridges Ambient	1	x (93,78	-) =	93,78	Roof perimeter	-1,207
2	Roof perimeter connectio	15	Thermal Bridges Ambient	1	x (25,40	-) =	25,40	Roof perimeter connection	-0,955
3	Basement perimeter	16	Perimeter Thermal Bridges	1	x (58,68	-) =	58,68	Basement perimeter	-0,767
4	Basement perimeter - win	16	Perimeter Thermal Bridges	1	x (20,10	-) =	20,10	Basement perimeter - windows	0,108
5	Basement ceiling correct	16	Perimeter Thermal Bridges	1	x (31,42	-) =	31,42	Basement ceiling correction	0,032
6	Roof to wall connection	15	Thermal Bridges Ambient	1	x (20,38	-) =	20,38	Roof to wall connection	0,431
7	Windows blinds	15	Thermal Bridges Ambient	1	x (228,75	-) =	228,75	Windows blinds	
8	Windows to walls	15	Thermal Bridges Ambient	1	x (228,75	-) =	228,75	Windows to walls	
9					x (-	-) =			
10					x (-	-) =			
11					x (-	-) =			
12					x (-	-) =			
13					x (-	-) =			
14					x (-	-) =			
15					x (-	-) =			
16					x (-	-) =			
17					x (-	-) =			
18					x (-	-) =			
19					x (-	-) =			
20					x (-	-) =			
21					x (-	-) =			
22					x (-	-) =			
23					x (-	-) =			
24					x (-	-) =			
25					x (-	-) =			
26					x (-	-) =			
27					x (-	-) =			
28					x (-	-) =			
29					x (-	-) =			
30					x (-	-) =			
31					x (-	-) =			

AREAS DETERMINATION

Building: School "Tzanko Diustabanov"-Block A Heating demand 250 kWh/(m²a)

Summary						Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit	Comment				
1	Treated Floor Area		1303,46	m ²	Treated floor area according to PHPP manual				10 months
2	North Windows	A	52,75	m ²		North Windows	2,457	3006	4602
3	East Windows	A	242,41	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas. which is displayed in the "Windows" worksheet.	East Windows	2,384	26390	44325
4	South Windows	A	36,89	m ²		South Windows	3,783	7765	8678
5	West Windows	A	101,73	m ²		West Windows	2,389	11692	19607
6	Horizontal Windows	A	0,00	m ²		Horizontal Windows			
7	Exterior Door	A	2,00	m ²	Please subtract area of door from respective building assembly	Exterior Door	5,500		
8	Exterior Wall - Ambient	A	1365,61	m ²	Temperature Zone "A" is ambient air.	Exterior Wall - Ambient	1,333	5880	9187
9	Exterior Wall - Ground	B	0,00	m ²	Temperature zone "B" is the ground.	Exterior Wall - Ground			
10	Roof/Ceiling - Ambient	A	549,78	m ²		Roof/Ceiling - Ambient	3,072	24117	34910
11	Floor slab / basement ceiling	B	549,78	m ²		Floor slab / basement ceiling	2,012		
12			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
13			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"	Factor for X			
14		X	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f, < 1):	75%			
Thermal bridges - Overview									
15	Thermal Bridges Ambient	A	597,06	m	Units in m	Thermal Bridges Ambient	-0,215		
16	Perimeter Thermal Bridges	P	110,20	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).	Perimeter Thermal Bridges	-0,380		
17	Thermal bridges FS/BC	B	0,00	m	Units in m	Thermal bridges FS/BC			
18	Partition Wall to Neighbour	I	70,07	m ²	No heat losses, only considered for the heating load calculation.	Partition Wall to Neighbour	1,347		
Total thermal envelope				2900,94	m ²	Average Therm. Envelope	1,912		

[Go to building components list](#)

32				x (-) =				
33				x (-) =				
34				x (-) =				
35				x (-) =				
36				x (-) =				
37				x (-) =				
38				x (-) =				
39				x (-) =				
40				x (-) =				
41				x (-) =				
42				x (-) =				
43				x (-) =				
44				x (-) =				
45				x (-) =				
46				x (-) =				
47				x (-) =				
48				x (-) =				
49				x (-) =				
50				x (-) =				
TBend								

A tool for thermal bridge conversion to exterior dimensions					
Description		Units	Window under	Windows above	
	Ψ Interior Dimensions	W/(mK)	0,110	0,103	
	Temperature Diff. TB	K	20,000	20,000	
Adjacent Area I	Temperature Diff. $\Delta\phi$ I	K	20,000	20,000	
	Exterior - Interior Dim. I	m	0,050	0,020	
	U-Value building assembly I	W/(m ² K)	0,790	0,790	
Adjacent Area II	Temperature Diff. $\Delta\phi$ II	K	20,000	20,000	
	Exterior - Interior Dim. II	m	0,390	0,370	
	U-Value building assembly II	W/(m ² K)	0,120	0,120	
	Ψ Exterior Dimensions	W/(mK)	0,024	0,043	

HEAT LOSSES THROUGH THE GROUND

Building part 1

Ground characteristics				Climate data	
Thermal conductivity	λ	2,0	W/(mK)	Av. Indoor Temp. Winter	T _i 20,0 °C
Heat capacity	p _c	2,0	MJ/(m ³ K)	Av. Indoor Temp. Summer	T _i 25,0 °C
Periodic Penetration Depth	δ	3,17	m	Average Ground Surface Temperature	T _{g,ave} 11,7 °C

Building data				U-value floor slab/basement ceiling	
Area of ground floor slab / basement ceiling	A	549,8	m ²	U _f	2,012 W/(m ² K)
Perimeter length	P	125,2	m	Thermal bridges floor slab/basement ceiling	Ψ_B *I 0,00 W/K
Charact. Dimension of floor slab	B'	8,78	m	U-value floor slab / basement ceiling incl. TB	U' _f 2,012 W/(m ² K)

Floor Slab Type (select only one)						
<input checked="" type="checkbox"/> Slab on Grade	Perimeter Insulation Width/Depth	D	0,30	m	Orientation of the Perimeter Ins.	
	Perimeter Insulation Thickness	d _n	0,20	m	(check only one field)	
	Conductivity perimeter insulation	λ_n	0,033	W/(mK)	horizontal	
					vertical <input checked="" type="checkbox"/>	
<input checked="" type="checkbox"/> Heated basement or floor slab completely / partially below ground level	Basement wall height below ground level	z		U-value below ground wall	U _{wB}	
					W/(m ² K)	
<input checked="" type="checkbox"/> Unheated basement	Height aboveground wall	h	1,25	m	U-value above ground wall	U _w
	Basement wall height below ground level	z	1,40	m	U-value below ground wall	U _{wB}
	Air Change Unheated Basement	n	0,20	h ⁻¹	U-value Basement Floor Slab	U _{fb}
	Air flow basement	V	770	m ³		2,729 W/(m ² K)
<input checked="" type="checkbox"/> Suspended Floor Above a Ventilated Crawl Space (at max. 0.5 m Below Ground)	U-value Crawl Space	U _{crawl}		Area of Ventilation Openings	εP	
	Height of crawl space wall	h		Wind Velocity at 10 m Height	v	
	U-value crawl space wall	U _w		Wind Shield factor	f _w	
					m ²	
					4,0 m/s	
					0,05	
<input checked="" type="checkbox"/> Additional Thermal Bridge Heat Losses at Perimeter	Phase shift	β		Steady-State Fraction	$\Psi_{P,stat}^* I$ -41,831 W/K	
			Months	Harmonic Fraction	$\Psi_{P,harm}^* I$ -41,831 W/K	

Groundwater correction					
Depth of the Groundwater Table	z _w	3,0	m	Groundwater Correction Factor	G _w 1,09558193 -
Groundwater flow rate	q _w	0,05	m/d		

Interim Results					
Phase shift	β	0,90	Months	Steady-state heat flow	Φ_{stat} 1701,4 W
Steady-state transmittance	L _s	204,49	W/K	Periodic Heat Flow	Φ_{harm} 443,3 W
Exterior Periodic transmittance	L _{pe}	71,46	W/K	Heat Losses During Heating Period	Q _{tot} 9737 kWh
Transmittance building	L ₀	1064,28	W/K		

Monthly Average temperatures in the ground for monthly method (building assembly 1)													
Month	1	2	3	4	5	6	7	8	9	10	11	12	Average value
Winter	17,7	17,6	17,8	18,0	18,4	18,8	19,1	19,2	19,0	18,8	18,4	18,0	18,4
Summer	21,8	21,7	21,8	22,1	22,5	22,8	23,1	23,2	23,1	22,8	22,4	22,0	22,4

Design ground temperature for 'Heating load' worksheet		17,6	For 'Cooling load' worksheet		23,2
			Reduction factor for 'Annual heating' worksheet		0,12

Total result (all building parts)					
Phase shift	β	0,90	Months	Steady-state heat flow	Φ_{stat} 1701,4 W
Steady-state transmittance	L _s	204,49	W/K	Periodic Heat Flow	Φ_{harm} 443,3 W
Exterior Periodic transmittance	L _{pe}	71,46	W/K	Heat Losses During Heating Period	Q _{tot} 9737 kWh
Transmittance building	L ₀	1064,28	W/K	Charact. Dimension of floor slab	B' 8,78 m

Monthly Average temperatures in the ground for monthly method (all building assemblies)													
Month	1	2	3	4	5	6	7	8	9	10	11	12	Average value
Winter	17,7	17,6	17,8	18,0	18,4	18,8	19,1	19,2	19,0	18,8	18,4	18,0	18,4
Summer	21,8	21,7	21,8	22,1	22,5	22,8	23,1	23,2	23,1	22,8	22,4	22,0	22,4

Design ground temperature for 'Heating load' worksheet		17,6	For 'Cooling load' worksheet		23,2
			Reduction factor for 'Annual heating' worksheet		0,12

P A S S I V E H O U S E - C O M P O N E N T S

Go to: [ARFAS](#)[Glazing](#)[Window frame](#)<http://www.passiv.de/komponentendatenbank/en-EN>[Ventilation units](#)[Compact units](#)

Building assemblies (U-values)

ID	Building system	Building assembly	1		
			Total thickness	U-Value	Interior insulation
Summary of the constructions calculated in 'U values' worksheet					
01ud	Block A - plaster	Block A - plaster	0,450	1,347	
02ud	Block A - stone façade	Block A - stone façade	0,480	1,306	
03ud	Ground walls	Ground walls	0,575	1,903	
04ud	Ground walls (heated basement)	Ground walls (heated basement)	0,225	3,219	
05ud	Floor (heated basement)	Floor (heated basement)	0,500	1,836	
06ud	Floor (unheated basement)	Floor (unheated basement)	0,280	1,790	
07ud	Floor slab on grade (mosaic)	Floor slab on grade (mosaic)	0,520	2,389	
08ud	Floor slab on grade (wood flooring)	Floor slab on grade (wood flooring)	0,500	2,133	
09ud	Roof type 1 - unheated attic	Roof type 1 - unheated attic	0,378	0,345	
10ud	Roof type 2 direct to external air	Roof type 2 direct to external air	0,255	3,072	
11ud	Block A - connection	Block A - connection	0,550	1,155	
12ud	Under unheated basement floor	Under unheated basement floor	0,420	2,729	
13ud	Block A - stone façade	Block A - stone façade	0,580	1,121	yes
14ud	Block A connection roof direct to exte	Block A connection roof direct to exte	0,255	2,833	
15ud	Roof type 2 direct to external air Conn	Roof type 2 direct to external air Conn	0,255	3,072	
16ud					
17ud					
18ud					
19ud					
20ud					
21ud					
22ud					
23ud					
24ud					
25ud					
26ud					
27ud					
28ud					
29ud					
30ud					
31ud					
32ud					
33ud					
34ud					
35ud					
36ud					
37ud					
38ud					
39ud					
40ud					
41ud					
42ud					
43ud					
44ud					
45ud					

Building assemblies (U-values)

ID	Building system	Building assembly	1	Total thickness	U-Value	Interior insulation
			m			
Summary of the constructions calculated in 'U values' worksheet						
46ud						
47ud						
48ud						
49ud						
50ud						
51ud						
52ud						
53ud						
54ud						
55ud						
56ud						
57ud						
58ud						
59ud						
60ud						
61ud						
62ud						
63ud						
64ud						
65ud						
66ud						
67ud						
68ud						
69ud						
70ud						
71ud						
72ud						
73ud						
74ud						
75ud						
76ud						
77ud						
78ud						
79ud						
80ud						
81ud						
82ud						
83ud	Brickwork 24 years old	Brickwork 24 years old	0,275	1,440		
84ud	Solid Brick 38-old	Solid Brick 38-old	0,415	1,640		
85ud	Half timbered 18-old	Half timbered 18-old	0,210	1,800		
86ud	Brickwork 30 years old	Brickwork 30 years old	0,335	1,230		

Building assemblies (U-values)

		1			
ID	Building system	Building assembly	Total thickness	U-Value	Interior insulation
	Summary of the constructions calculated in 'U values' worksheet		m	W/(m ² K)	-
97ud	Precast concrete-old	Precast concrete-old	0,275	1,300	
98ud	Wooden joist ceiling-old	Wooden joist ceiling-old	0,284	0,990	
99ud	Basement ceiling-old	Basement ceiling-old	0,242	1,230	

Glazing		Glazing		
ID	Description	g-Value	U _g -Value	
		W/(m ² K)		
01ud	44 mm. triple glazing, 2 Low-E, air, alum.spacer	0,51	0,70	
02ud				
03ud				
04ud				
05ud				
06ud				
07ud				
08ud				
09ud				
10ud				
11ud				
12ud				
13ud				
14ud				
15ud				
16ud				
17ud				
18ud				
19ud				
20ud				
21ud				
22ud				
23ud				
24ud				
25ud				
26ud				
27ud				
28ud				
29ud				
30ud				
31ud				
32ud				
33ud				
34ud				
35ud				
36ud				
37ud				
38ud				
39ud				
40ud				
41ud				
42ud				
43ud				
44ud				
45ud				
46ud				
47ud				
48ud				
49ud				
50ud				
51ud				

Glazing		Glazing	
ID	Description	g-Value	U _g -Value
			W/(m ² K)
52ud			
53ud			
54ud			
55ud			
56ud			
57ud			
58ud			
59ud			
60ud			
61ud			
62ud			
63ud			
64ud			
65ud			
66ud			
67ud			
68ud			
69ud			
70ud			
71ud			
72ud			
73ud			
74ud			
75ud			
76ud			
77ud			
78ud			
79ud			
80ud			
81ud			
82ud			
83ud			
84ud			
85ud			
86ud			
87ud			
88ud			
89ud			
90ud			
91ud			
92ud	Single glazing	0,87	5,80
93ud	Double glazing 4/12mm air/4	0,77	2,90
94ud	Double glazing 4/16mm air/4	0,77	2,70
95ud	Double glazing 4/20mm air/4	0,77	2,80
96ud	Double glazing 4/25mm air/4	0,77	2,80
97ud	Double glazing 4/30mm air/4	0,77	2,80
98ud	Triple glazing 4/10 air/4/10 air/4	0,70	2,00
99ud	Double low-e 4/16Argon90%/4 Epsilon=0.1	0,64	1,30

Window frames												Window frames											
	U _r -Value				Frame Width				Glazing edge thermal bridge				Installation thermal bridge				Curtain wall facades:						
ID	Description	left	right	bottom	above	left	right	bottom	above	$\Psi_{\text{Glazing edge left}}$	$\Psi_{\text{Glazing edge right}}$	$\Psi_{\text{Glazing edge bottom}}$	$\Psi_{\text{Glazing edge top}}$	$\Psi_{\text{Installation left}}$	$\Psi_{\text{Installation right}}$	$\Psi_{\text{Installation bottom}}$	$\Psi_{\text{Installation top}}$	$\chi_{\text{GC -value Glass carrier}}$					
		W/(m ² K)	W/(m ² K)	W/(m ² K)	W/(m ² K)	m	m	m	m	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/K					
01ud																							
02ud																							
03ud																							
04ud																							
05ud																							
06ud																							
07ud																							
08ud																							
09ud																							
10ud																							
11ud																							
12ud																							
13ud																							
14ud																							
15ud																							
16ud																							
17ud																							
18ud																							
19ud																							
20ud																							
21ud																							
22ud																							
23ud																							
24ud																							
25ud																							
26ud																							
27ud																							
28ud																							
29ud																							
30ud																							
31ud																							
32ud																							
33ud																							
34ud																							
35ud																							
36ud																							
37ud																							
38ud																							
39ud																							
40ud																							
41ud																							
42ud																							
43ud																							
44ud																							
45ud																							
46ud																							
47ud																							
48ud																							
49ud																							
50ud																							
51ud	PH-FRAMES: average thermal quality	0,75	0,75	0,75	0,75	0,140	0,140	0,140	0,140	0,040	0,040	0,040	0,040	0,040	0,040	0,040	0,040	0,040	W/K				

Ventilation units with heat recovery												
					Additional Device Data							
ID	Description	Heat recovery efficiency	Energy recovery value η_{FRG}	Electric efficiency	Entry area		External pressure per line	Fittings Δp_{intern}	Frost protection required	Noise protection		Additional info
	User defined area	%	%	Wh/m³	m³/h	m³/h	Pa	Pa		35 dB(A)	Supply air dB(A)	Extract air dB(A)
01ud	Tangra ventilation unit EVB 04 HiE	82%	0%	0,40	150	400	100	incl.	yes	—	57	57
02ud	Tangra ventilation unit EVB 06 HiE	82%	0%	0,40	250	600	100	incl.	yes	—	61	61
03ud	Tangra ventilation unit EVB 08 HiE	82%	0%	0,40	400	800			yes	—	61	61
04ud	Tangra ventilation unit EVB 10 HiE	82%	0%	0,40	500	1000			yes	—	61	61
05ud	Tangra ventilation unit EVB 12 HiE	82%	0%	0,40	750	1200			yes	—	68	68
06ud	Tangra ventilation unit EVB 16 HiE	82%	0%	0,40	800	1600			yes	—	68	68
07ud	Tangra ventilation unit EVB 20 HiE	82%	0%	0,40	1000	2000			yes	—	68	68
08ud												
09ud												
10ud												
11ud												
12ud												
13ud												
14ud												
15ud												
16ud												
17ud												
18ud												
19ud												
20ud												
21ud												
22ud												
23ud												
24ud												
25ud												
26ud												
27ud												
28ud												
29ud												
30ud												
31ud												
32ud												
33ud												
34ud												
35ud												
36ud												
37ud												
38ud												
39ud												
40ud												
41ud												
42ud												
43ud												
44ud												
45ud												
46ud												
47ud												
48ud												
49ud												
50ud												
51ud												

Ventilation units with heat recovery												
					Additional Device Data							
ID	Description	Heat recovery efficiency	Energy recovery value η_{FRG}	Electric efficiency	Entry area		External pressure per line	Fittings Δp_{intern}	Frost protection required	Noise protection		Additional info
	User defined area	%	%	Wh/m³	m³/h	m³/h	Pa	Pa		35 dB(A)	Supply air dB(A)	Extract air dB(A)
52ud												
53ud												
54ud												
55ud												
56ud												
57ud												
58ud												
59ud												
60ud												
61ud												
62ud												
63ud												
64ud												
65ud												
66ud												
67ud												
68ud												
69ud												
70ud												
71ud												
72ud												
73ud												
74ud												
75ud												
76ud												
77ud												
78ud												
79ud												
80ud												
81ud												
82ud												
83ud												
84ud												
85ud												
86ud												
87ud												
88ud												
89ud												
90ud												
91ud												
92ud												
93ud												
94ud												
95ud												
96ud												
97ud	Default	75%		0,45								
98ud	Extract air system	0%		0,25								
99ud	Compact unit to be chosen from 'Compact' worksheet											

					Window rough openings		installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge	Installation situation user-defined value for $\Psi_{\text{installed}}$ or '1': $\Psi_{\text{installed}}$ from worksheet 'Components' '0': in the case of abutting windows				Results U- and Ψ -values from 'Components' worksheet can be shown through clicking the '+' sign on the top edge of the sheet.						
Quantity	Description	Deviation from North	Angle of inclination from the horizontal	Orientation	Width	Height	Selection from worksheet 'Areas'	Selection from worksheet 'Components'	Selection from worksheet 'Components'	Perpendicular Radiation	Glazing	Frames (centre)	Ψ _{spacer (centre)}	left	right	bottom	above	Ψ _{Installation (Average)}	Window Area	Glazing Area	U-Value Window	Glazed fraction per window	Transmission-losses	Solar gains
		Degrees	Degrees		m	m	Sort: AS LIST	Sort: AS LIST		-	W/(m ² K)	W/(m ² K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m ²	m ²	W/(m ² K)	%	kWh/a	kWh/a

Quantity	Description	Deviation from North	Angle of Inclination from the Horizontal	Orientation	Glazing width	Glazing height	Glazing area	Height of the shading object	Horizontal distance	Window reveal depth	Distance from glazing edge to reveal	Overhang depth	Distance from upper glazing edge to overhang	Additional reduction factor winter shading	Additional reduction factor summer shading	Reduction factor z for temporary sun protection	Horizontal shading reduction factor	Reveal Shading Reduction Factor	Overhang shading reduction factor	Total shading reduction factor	Horizontal Shading Reduction Factor	Reveal Shading Reduction Factor	Overhang shading reduction factor	Total shading reduction factor	
1		270	90	West	0.77	1.42	1.1	6.95	13,00	0,50	0,120	0,50	0,12				64%	68%	84%	37%	70%	87%	88%	54%	
3		270	90	West	0.15	0.28	0.1	6.95	13,00	0,50	0,120	0,50	0,12				64%	41%	59%	15%	70%	71%	53%	26%	
1		270	90	West	0.57	0.17	0.1	6.95	13,00	0,50	0,120	0,50	0,12				64%	62%	52%	21%	70%	84%	45%	27%	
1		270	90	West	0.77	0.17	0.1	6.95	13,00	0,50	0,120	0,50	0,12				64%	68%	52%	23%	70%	87%	45%	28%	
1		270	90	West	0.57	0.17	0.1	6.95	13,00	0,50	0,120	0,50	0,12				64%	62%	52%	21%	70%	84%	45%	27%	
1	Corridor T7	270	90	West	0.42	1.17	0.5								100%	83%	94%	78%	100%	94%	98%	92%			
2		270	90	West	0.47	1.17	1.1								100%	84%	94%	79%	100%	94%	98%	92%			
1		270	90	West	0.42	1.17	0.5								100%	83%	94%	78%	100%	94%	98%	92%			
3	Lobby T8	0	90	North	0.62	0.72	1,3								100%	91%	92%	83%	100%	91%	97%	88%			
3		0	90	North	0.32	0.72	0.7								100%	86%	92%	80%	100%	87%	97%	84%			
3		0	90	North	0.62	0.72	1,3								100%	91%	92%	83%	100%	91%	97%	88%			
3		0	90	North	0.62	1.32	2,5								100%	91%	95%	86%	100%	91%	99%	89%			
3		0	90	North	0.32	1.32	1,3								100%	86%	95%	82%	100%	87%	99%	85%			
3		0	90	North	0.62	1.32	2,5								100%	91%	95%	86%	100%	91%	99%	89%			
1	Lobby T9	180	90	South	0.72	0.72	0,5								100%	93%	94%	88%	100%	91%	89%	81%			
1		180	90	South	0.47	0.72	0,3								100%	91%	94%	85%	100%	88%	89%	78%			
1		180	90	South	0.72	0.72	0,5								100%	93%	94%	88%	100%	91%	89%	81%			
1		180	90	South	0.72	1.32	1,0								100%	93%	96%	89%	100%	91%	95%	87%			
1		180	90	South	0.47	1.32	0,6								100%	91%	96%	87%	100%	88%	95%	84%			
1		180	90	South	0.72	1.32	1,0								100%	93%	96%	89%	100%	91%	95%	87%			
2	Lobby Door T10	180	90	South	0.72	0.72	1,0			0,15	0,100	1,00	0,080				100%	92%	64%	59%	100%	90%	24%	21%	
2		180	90	South	0.72	0.72	1,0			0,15	0,100	1,00	0,080				100%	92%	64%	59%	100%	90%	24%	21%	
2		180	90	South	0.72	1,32	1,9			0,15	0,100	1,00	1,080				100%	92%	89%	82%	100%	90%	69%	62%	
2		180	90	South	0.72	1,32	1,9			0,15	0,100	1,00	1,080				100%	92%	89%	82%	100%	90%	69%	62%	
2	solid	180	90	South	0.72	0.72	1,0			0,15	0,100	0,15	0,10	0%	0%		100%	92%	94%	0%	100%	90%	87%	0%	
2	solid	180	90	South	0.72	0.72	1,0			0,15	0,100	0,15	0,10	0%	0%		100%	92%	94%	0%	100%	90%	87%	0%	
1	Lobby T11	180	90	South	0.82	0.72	0,6			0,15	0,140	0,15	0,14				100%	93%	94%	88%	100%	92%	89%	82%	
2		180	90	South	0.47	0.72	0,7			0,15	0,140	0,15	0,14				100%	91%	94%	85%	100%	88%	89%	78%	
2		180	90	South	0.82	0.72	1,2			0,15	0,140	0,15	0,14				100%	93%	94%	88%	100%	92%	89%	82%	
1		180	90	South	0.82	0.72	0,6			0,15	0,140	0,15	0,14				100%	93%	94%	88%	100%	92%	89%	82%	
1		180	90	South	0.82	1,32	1,1			0,15	0,140	0,15	0,14				100%	93%	96%	90%	100%	92%	95%	87%	
2		180	90	South	0.47	1,32	1,2			0,15	0,140	0,15	0,14				100%	91%	96%	87%	100%	88%	95%	84%	
2		180	90	South	0.82	1,32	2,2			0,15	0,140	0,15	0,14				100%	93%	96%	90%	100%	92%	95%	87%	
1		180	90	South	0.82	1,32	1,1			0,15	0,140	0,15	0,14				100%	93%	96%	90%	100%	92%	95%	87%	

VENTILATION DATA

Building:

School "Tzanko Diustabanov"-Block A

Treated floor area A_{TFA}

m ²	1303
m	2,50
m ³	3259

(Areas worksheet)

Room Height h

Room ventilation volume ($A_{TFA} \cdot h$) = V_V

(Worksheet Annual heating)

Ventilation type

Please select

Window ventilation only

Infiltration air change rate

Wind protection coefficients e and f		
Coefficient e for screening class	Several side exposed	One side exposed
No screening	0,10	0,03
Moderate screening	0,07	0,02
High screening	0,04	0,01
Coefficient f	15	20

for annual demand: for Heating Load:

Wind protection coefficient, e

0,07	0,18
------	------

Wind protection coefficient, f

15	15
----	----

Air Change Rate at Press. Test

 n_{50}

1/h

4,00

Net Air Volume for
Press. Test V_{n50}

Air permeability q_{50} $\text{m}^3/(\text{hm}^2)$

for annual demand: for Heating Load:

Excess extract air

0,00	0,00
------	------

Infiltration air change rate

 $n_{V,\text{Rest}}$

1/h	
-----	--

Selection of ventilation data input - Results

The PHPP offers two methods for dimensioning the air quantities and choosing the ventilation unit. Fresh air or extract air quantities for residential buildings and parameters for ventilation system can be determined using the standard planning option in the 'Ventilation' sheet. The 'Additional Vent' sheet has been created for more complex ventilation systems and allows up to 10 different ventilation units. Furthermore, air quantities can be determined on a room-by-room or zone-by-zone basis. Please select your design method here.

Ventilation unit / Heat recovery efficiency design	Average		Extract air excess		Effective heat recovery		Specific power input		Heat recovery efficiency SHX	
	Air Exchange	Average Air Change Rate	(Extract air system)	efficiency	Energy recovery Unit	value	[W/m ³]	[%]	[W/m ³]	[-]
Standard design (Ventilation worksheet see below)	682	0,21	0,00				0,00		0,00	0,0%
Various vent. units, non residential (Worksheet Additional vent)										

SHX efficiency

 $\eta_{\text{SHX}} 0\%$

STANDARD INPUT FOR BALANCED VENTILATION

Ventilation dimensioning for systems with one ventilation unit

Calculation in sheet 'Additional Vent': Extended data input for balanced ventilation

Occupancy	m ² /P	6
Number of occupants	P	225,0
Supply air per person	m ³ (P/h)	30
Supply air requirement	m ³ /h	6750
Extract air rooms		Bathroom
Quantity	Kitchen	Bathroom (shower only)
Extract air requirement per room	60	40
Total Extract Air Requirement	m ³ /h	20
	m ³ /h	20
Design air flow rate (maximum)	m ³ /h	

Type of operation	Daily operation duration	Factors referenced to maximum	Air flow rate	Air change rate
			m ³ /h	1/h
maximum		1,00	#WERT!	#WERT!
Standard	24,0	0,77	#WERT!	#WERT!
Basic		0,54	#WERT!	#WERT!
Minimum		0,40	#WERT!	#WERT!
Average value		0,77	Average air flow rate (m ³ /h)	Average air change rate (1/h)

Selection of ventilation unit with heat recovery

Installation site of ventilation unit		No heat recovery. Please enter electrical efficiency data.
Ventilation unit selection	Sort: BY ID	
	Go to ventilation units list	
	Ψ	W/(mK)
		0,000
	m	
	Ψ	W/(mK)
		0,000
	m	
Temperature of mechanical services room (Enter only if the central unit is outside of the thermal envelope.)	°C	
	Room temperature (°C)	20
	Av. Ambient Temp. Heating P. (°C)	4,3
	Av. Ground Temp (°C)	11,7

Effective heat recovery efficiency $\eta_{HR,eff}$

Effective heat recovery efficiency subsoil heat exchanger
SHX efficiency η_{SHX}^{*SHX}
Heat recovery efficiency SHX η_{SHX}

Nominal width:	mm
Insul. Thickness:	mm
Reflective?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Thermal conductivity	W/(mK)
Nominal air flow rate	m ³ /h
$\Delta\vartheta$	16 K
Exterior duct diameter	0,000 m
Exterior diameter	0,000 m
α -Interior	0,00 W/(m ² K)
α -Surface	W/(m ² K)
Ψ-value	W/(mK)
Surface temperature difference	K

Nominal width:	mm
Insul. Thickness:	mm
Reflective?	yes <input checked="" type="checkbox"/> no <input type="checkbox"/>
Thermal conductivity	W/(mK)
Nominal air flow rate	m ³ /h
$\Delta\vartheta$	16 K
Exterior duct diameter	0,000 m
Exterior diameter	0,000 m
α -Interior	0,00 W/(m ² K)
α -Surface	W/(m ² K)
Ψ-value	W/(mK)
Surface temperature difference	K

EXTENDED DATA INPUT FOR BALANCED VENTILATION

Planning ventilation systems with multiple ventilation units

Building:

School "Tzanko Diustabakov"-Block A

Ventilation unit / Heat recovery efficiency design
 In Ventilation worksheet (standard design)
 In Additional Vent (this worksheet)

x	(Ventilation worksheet)
	(Additional vent.)

Treated Floor Area A_{TFA} m² 1303 (Areas worksheet)
 Room Height h m 2,50 (Worksheet Annual heating)
 Room air volume for ventilation ($A_{TFA} \cdot h$) = V_V m³ 3259 (Worksheet Annual heating)
 Number of Occupants P 225,0 (Ventilation worksheet)
 Room temperature °C 20 (Worksheet Annual heating)
 Average external temp. heating period °C 4,3 (Ventilation worksheet)
 Average ground temp. °C 11,7 (Ground worksheet)

Ventilation type Window ventilation only (Ventilation worksheet)

Results of ventilation design and unit selection:

Ventilation Unit no.	Description of the unit	Design		Average value / yr.		Air ch.rt.
		V_{SUP} m ³ /h	V_{ETA} m ³ /h	V_{SUP} m ³ /h	V_{ETA} m ³ /h	
1	Floor 1	1500	1500	160	160	---
2	Floor 2	1200	1200	128	128	---
3	Floor 3	1200	1200	128	128	---
4	Floor 4	1200	1200	128	128	---
5	Floor 5	1300	1300	139	139	---
6						---
7						---
8						---
9						---
10						---

Result for overall vent. syst.

6400	6400	682	682	0,21
------	------	-----	-----	------

Effective heat recovery efficiency	Energy recovery value	spec. Input power	Heat recov. efficiency SHX	Cross check
0%	0,40	0%	Please assign a ventilation unit	
0%	0,40	0%	Please assign a ventilation unit	
0%	0,40	0%	Please assign a ventilation unit	
0%	0,40	0%	Please assign a ventilation unit	
0%	0,40	0%	Please assign a ventilation unit	

No heat recovery. Irrelevant input				0%
------------------------------------	--	--	--	----

Recommendations for dimensioning air quantities

Use of low odour and low-emission building materials/ furnishings:

It is strongly recommended to use building materials that cause no or only little pollution instead of increasing the outdoor air volume flow in order to reduce preventable pollution. This holds true independently from the chosen approach for the air quality determination; emissions of all sources in the room should be considered, e.g. furniture, carpets and ventilation or air-conditioning unit.

Assessment of volume flow rates according to the number of persons

Also in non-residential buildings, the number of persons is fundamentally important for assessing the volume air flow rates. For good indoor air quality the amounts of 20 to 30 m³/h/person are completely sufficient. Higher outdoor air amounts may lead to excessively dry indoor air in winter. The air flow rates are specified by classification according to EN 13779. The classification must be agreed with the client in advance. IDA 3 is adequate for office buildings. IDA 4 has proven satisfactory for school buildings as purge ventilation is carried out during breaks anyway. For typical external air CO₂ concentrations of around 400-500 ppm, it is possible to comply even with 1500 ppm. Exceeding this figure temporarily is permissible.

Fresh air flow rates per person:

- Recommended for residential buildings: around 30 m³/(h person)
- Recommended for offices and similar uses: around 30 m³/(h person) (AMEV: 28 m³/(h person); EN 13779 / IDA 3: at least 24 m³/(h person))
- Recommended for schools and day care centres: 15 to 20 m³/(h person) (Source: Guidelines for energy-efficient educational buildings, Passive House Institute, 2010)
- Recommendation for sport halls: 60 m³/(h person) (DIN 18032-1)

Purging phase for intermittent ventilation operation

Due to the purge ventilation phase, the ventilation operation period is extended accordingly (utilisation time + purge ventilation phase). Please consider this for the ventilation design. Emissions have to be removed. Flushing the building prolongs the utilization time of the ventilation system (utilization time + flushing phase). Please consider this at design stage.

Design of air quantities

When ventilating the air quantities, please consider the design recommendations given above.

The ventilation operation period can be determined on the basis of the daily utilisation hours including purging phase if applicable. In addition, time periods with reduced ventilation requirements (operation modes) can be

Taken into account by means of reduction factors.

Room Nr.	Amount a	Room name	Assignment to ventilation unit	Area A m ²	Clear height h m	Room vol. A x h m ³	Volume flow per room V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{TRANS} m ³ /h	Air change rate per room n 1/h	Utilisation times d/h	d/week	weeks/yr	Reduction Red.1	Operation Red. 1	Reduction Red.2	Operation Red.2	Reduction Red.3	Operation Red.3	Cross check	Average volume flows V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{TRANS} m ³ /h	Average air change rate 1/h
1	1	Lobby	1	186	4,00	744	300	500		0,67	12	5	32	100%	15%	60%	15%	35%	70%		32	53	0,07	
2	1	Corridor L1	1	74	3,40	252		500	600	2,38	12	5	32	100%	15%	60%	15%	35%	70%			53	64	0,25
3	2	Classroom	1	45	3,40	152	400			2,64	12	5	32	100%	15%	60%	15%	35%	70%		85		0,28	
4	1	Classroom Sou	1	58	3,40	197	400			2,03	12	5	32	100%	15%	60%	15%	35%	70%		43		0,22	
5	1	Classroom sto	1	24	3,40	82		100		1,23	12	5	32	100%	15%	60%	15%	35%	70%			11		0,13
6	1	WC's level 1	1	13	3,40	44		200		4,52	12	5	32	100%	15%	60%	15%	35%	70%			21		0,48
7	1	WC's level 2	1	15	3,40	51		200		3,92	12	5	32	100%	15%	60%	15%	35%	70%			21		0,42
8	1	Corridor L2	2	64	3,40	216		600	600	2,78	12	5	32	100%	15%	60%	15%	35%	70%			64	64	0,30
9	2	Classroom 1	2	45	3,40	153	400			2,61	12	5	32	100%	15%	60%	15%	35%	70%		85		0,28	
10	1	Classroom Sou	2	58	3,40	197	400			2,03	12	5	32	100%	15%	60%	15%	35%	70%		43		0,22	
11	1	Classroom sto	2	24	3,40	82		100		1,23	12	5	32	100%	15%	60%	15%	35%	70%			11		0,13
12	1	WC's level 2	2	13	3,40	44		250		5,66	12	5	32	100%	15%	60%	15%	35%	70%			27		0,60
13	1	WC's level 3	2	15	3,40	51		250		4,90	12	5	32	100%	15%	60%	15%	35%	70%			27		0,52
14	1	Corridor L3	3	64	3,40	216		600	600	2,78	12	5	32	100%	15%	60%	15%	35%	70%			64	64	0,30
15	2	Classroom 1	3	45	3,40	153	400			2,61	12	5	32	100%	15%	60%	15%	35%	70%		85		0,28	
16	1	Classroom Sou	3	58	3,40	197	400			2,03	12	5	32	100%	15%	60%	15%	35%	70%		43		0,22	
17	1	Classroom sto	3	24	3,40	82		100		1,23	12	5	32	100%	15%	60%	15%	35%	70%			11		0,13
18	1	WC's level 2	3	13	3,40	44		250		5,66	12	5	32	100%	15%	60%	15%	35%	70%			27		0,60
19	1	WC's level 3	3	15	3,40	51		250		4,90	12	5	32	100%	15%	60%	15%	35%	70%			27		0,52
20	1	Corridor L4	4	64	3,40	216		600	600	2,78	12	5	32	100%	15%	60%	15%	35%	70%			64	64	0,30
21	2	Classroom 1	4	45	3,40	153	400			2,61	12	5	32	100%	15%	60%	15%	35%	70%		85		0,28	
22	1	Classroom Sou	4	58	3,40	197	400			2,03	12	5	32	100%	15%	60%	15%	35%	70%		43		0,22	
23	1	Classroom sto	4	24	3,40	82		100		1,23	12	5	32	100%	15%	60%	15%	35%	70%			11		0,13
24	1	WC's level 2	4	13	3,40	44		250		5,66	12	5	32	100%	15%	60%	15%	35%	70%			27		0,60
25	1	WC's level 3	4	15	3,40	51		250		4,90	12	5	32	100%	15%	60%	15%	35%	70%			27		0,52
26	1	Corridor L5	5	64	3,40	216		750	350	3,47	12	5	32	100%	15%	60%	15%	35%	70%			80	37	0,37
27	2	Classroom 1	5	45	3,40	153	400			2,61	12	5	32	100%	15%	60%	15%	35%	70%		85		0,28	
28	1	Classroom Sou	5	58	3,40	197	400			2,03	12	5	32	100%	15%	60%	15%	35%	70%		43		0,22	
29	1	Classroom sto	5	24	3,40	82		200		2,45	12	5	32	100%	15%	60%	15%	35%	70%			21		0,26
30	1	Cabinet	5	13	3,40	44	100			2,26	12	5	32	100%	15%	60%	15%	35%	70%			11		0,24
31	1	Storage room	5	17	3,40	58		350		6,06	12	5	32	100%	15%	60%	15%	35%	70%			37		0,65
32														100%	100%									
33														100%	100%									
34														100%	100%									

Additional lines: Please mark complete lines above, copy and paste multiple times

Ventilation unit selection

Up to 10 different ventilation units are considered. By changing the amount, identical units can be considered. The data from PHI certified ventilation units as well as the entry data lines for user data for other ventilation units can also be found in the worksheet "Components". When choosing to use a compact unit the standard design in the Ventilation worksheet has to be used.

[Go to ventilation units list](#)

Ventilation Unit no.	Quantity [-]	Description Ventilation units	Selection Unit type	Design vol. flow per unit m³/h	Entry area for volume flow rate from m³/h to m³/h	Electrical efficiency Wh/m³	Pressure loss calculation			Entry area per line		Cross check		Interior location (x)	Exterior location (x)	Heat recovery efficiency Unit effective [-]	Energy recovery value [-]	Frost protection necessary	Subsoil HX Effective-efficiency degree of heat recovery	U noise level < 35dB(A)	Noise protection adapter Supply air db(A)
							Δp_{duct} Pa	Δp_{duct} Pa	Δp_{intern} Pa	$\Delta p_{external}$ Pa	Δp_{intern} Pa	Pressure loss assessment duct network									

No heat recovery. Irrelevant input

		Change sorting type																		
1	1	Floor 1	06ud Tangra ventilation unit EVB 16 Hi	1500	800	1600	0,40	60	60	70	-	-	ok	x	0,82	80%	0%	yes	0%	n.a. 68
2	1	Floor 2	05ud Tangra ventilation unit EVB 12 Hi	1200	750	1200	0,40	55	55	60	-	-	ok	x	0,82	80%	0%	yes	0%	n.a. 68
3	1	Floor 3	05ud Tangra ventilation unit EVB 12 Hi	1200	750	1200	0,40	55	55	60	-	-	ok	x	0,82	81%	0%	yes	0%	n.a. 68
4	1	Floor 4	05ud Tangra ventilation unit EVB 12 Hi	1200	750	1200	0,40	55	55	60	-	-	ok	x	0,82	81%	0%	yes	0%	n.a. 68
5	1	Floor 5	06ud Tangra ventilation unit EVB 16 Hi	1300	800	1600	0,40	55	55	60	-	-	ok	x	0,82	81%	0%	yes	0%	n.a. 68
6																				
7																				
8																				
9																				
10																				

Data entries for duct sections between the ventilation unit and the thermal envelope

The duct sections between the ventilation unit and the thermal envelope should be as short as possible and should be well insulated, both for interior as for exterior location of the ventilation unit. These duct sections can be entered here. The heat losses of the overlying duct section will be considered for the effective heat recovery efficiency.

An entered duct section can also be used for multiple ventilation units.

If in the section "Ventilation unit - selection" in one line a ventilation unit is selected as multiple units (amount larger than 1 for identical units), then the corresponding duct sections may simply be entered (duct sections for one ventilation unit).

Temperature of the location of installation (only enter when at least one unit is installed outside of the thermal envelope)

Quantity	Cross check	Round duct ins. diameter mm	Rectangular duct Width mm	Insulation Thickness mm	Thermal conductivity W/(m K)	Reflective insulation duct (x)	Transmittance duct W/(m K)	Length of Supply air m	Ambient or Extract air Duct (1)	Exhaust or flow Duct (1)	Duct type	Design Volume rate	Vent. Unit 1	Vent. Unit 2	Allocation to ventilation units (when central unit applicable enter "1")								
1		315		150	0,033		0,292	4	1		Ambient air	1500	1										

1		315		150	0,033		0,292	15,5	1		Fortluft	1500	1										
1		315		150	0,033		0,291	4	1		Ambient air	1200		1									
1		315		150	0,033		0,291	11,9		1	Fortluft	1200		1									
1		315		150	0,033		0,291	4	1		Ambient air	1200		1									
1		315		150	0,033		0,291	8,3		1	Fortluft	1200		1									
1		315		150	0,033		0,291	4	1		Ambient air	1200		1									
1		315		150	0,033		0,291	4,7		1	Fortluft	1200		1									
1		315		150	0,033		0,291	4	1		Ambient air	1300		1									
1		315		150	0,033		0,291	1,1		1	Fortluft	1300		1									
												0											
												0											
												0											
												0											
												0											
												0											
												0											
												0											

Additional lines: Please mark complete lines above, copy and paste multiple times

EnerPHit planning: **SPECIFIC ANNUAL HEATING DEMAND (annual method)**

Climate: User data - Велико Търново РН1	Interior Temperature: 20,0 °C																																																																																																									
Building: School "Tzanko Diustabanov"-Block A	Building type: School																																																																																																									
	Treated Floor Area A _{TFA} : 1303,5 m ²																																																																																																									
<table border="1"> <thead> <tr> <th>Building assembly</th> <th>Temperature Zone</th> <th>Area m²</th> <th>U-Value W/(m²K)</th> <th>Temp. Factor f_t</th> <th>G_t kWh/a</th> <th>per m²</th> </tr> </thead> <tbody> <tr><td>Exterior Wall - Ambient</td><td>A</td><td>1365,6</td><td>1,333</td><td>*</td><td>1,00</td><td>135385</td></tr> <tr><td>Exterior Wall - Ground</td><td>B</td><td></td><td>*</td><td>0,12</td><td>=</td><td>103,87</td></tr> <tr><td>Roof/Ceiling - Ambient</td><td>A</td><td>549,8</td><td>3,072</td><td>*</td><td>1,00</td><td>=</td><td></td></tr> <tr><td>Floor slab / basement ceiling</td><td>B</td><td>549,8</td><td>2,012</td><td>*</td><td>0,12</td><td>=</td><td>96,39</td></tr> <tr><td></td><td>A</td><td></td><td>*</td><td>1,00</td><td>=</td><td>7,76</td></tr> <tr><td></td><td>A</td><td></td><td>*</td><td>1,00</td><td>=</td><td></td></tr> <tr><td></td><td>X</td><td></td><td>*</td><td>0,75</td><td>=</td><td></td></tr> <tr><td>Windows</td><td>A</td><td>433,8</td><td>2,513</td><td>*</td><td>1,00</td><td>=</td><td>62,20</td></tr> <tr><td>Exterior Door</td><td>A</td><td>2,0</td><td>5,500</td><td>*</td><td>1,00</td><td>=</td><td>0,63</td></tr> <tr><td>Exterior TB (length/m)</td><td>A</td><td>597,1</td><td>-0,215</td><td>*</td><td>1,00</td><td>=</td><td>-7,34</td></tr> <tr><td>Perimeter TB (length/m)</td><td>P</td><td>110,2</td><td>-0,380</td><td>*</td><td>0,12</td><td>=</td><td>-0,29</td></tr> <tr><td>Ground TB (length/m)</td><td>B</td><td></td><td>*</td><td>0,12</td><td>=</td><td>0,00</td></tr> <tr><td>Total of all building envelope areas</td><td></td><td>2900,9</td><td></td><td></td><td></td><td>KWh/(m²a)</td><td></td></tr> </tbody> </table>		Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Temp. Factor f _t	G _t kWh/a	per m ²	Exterior Wall - Ambient	A	1365,6	1,333	*	1,00	135385	Exterior Wall - Ground	B		*	0,12	=	103,87	Roof/Ceiling - Ambient	A	549,8	3,072	*	1,00	=		Floor slab / basement ceiling	B	549,8	2,012	*	0,12	=	96,39		A		*	1,00	=	7,76		A		*	1,00	=			X		*	0,75	=		Windows	A	433,8	2,513	*	1,00	=	62,20	Exterior Door	A	2,0	5,500	*	1,00	=	0,63	Exterior TB (length/m)	A	597,1	-0,215	*	1,00	=	-7,34	Perimeter TB (length/m)	P	110,2	-0,380	*	0,12	=	-0,29	Ground TB (length/m)	B		*	0,12	=	0,00	Total of all building envelope areas		2900,9				KWh/(m ² a)	
Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Temp. Factor f _t	G _t kWh/a	per m ²																																																																																																				
Exterior Wall - Ambient	A	1365,6	1,333	*	1,00	135385																																																																																																				
Exterior Wall - Ground	B		*	0,12	=	103,87																																																																																																				
Roof/Ceiling - Ambient	A	549,8	3,072	*	1,00	=																																																																																																				
Floor slab / basement ceiling	B	549,8	2,012	*	0,12	=	96,39																																																																																																			
	A		*	1,00	=	7,76																																																																																																				
	A		*	1,00	=																																																																																																					
	X		*	0,75	=																																																																																																					
Windows	A	433,8	2,513	*	1,00	=	62,20																																																																																																			
Exterior Door	A	2,0	5,500	*	1,00	=	0,63																																																																																																			
Exterior TB (length/m)	A	597,1	-0,215	*	1,00	=	-7,34																																																																																																			
Perimeter TB (length/m)	P	110,2	-0,380	*	0,12	=	-0,29																																																																																																			
Ground TB (length/m)	B		*	0,12	=	0,00																																																																																																				
Total of all building envelope areas		2900,9				KWh/(m ² a)																																																																																																				
Transmission heat losses Q _T																																																																																																										
<table border="1"> <thead> <tr> <th>Ventilation System:</th> <th>Effective Air Volume, V_v m³/h</th> <th>A_{TFA} m²</th> <th>Clear Room Height m</th> <th>Clear Room Volume m³</th> </tr> </thead> <tbody> <tr><td>Effective heat recovery efficiency of heat recovery</td><td>η_{eff} 0%</td><td>1303,5</td><td>*</td><td>2,50 = 3258,7</td></tr> <tr><td>Efficiency of Subsoil Heat Exchanger</td><td>η_{SHX} 0%</td><td></td><td></td><td></td></tr> <tr><td>Energetically Effective Air Exchange n_v</td><td>0,209</td><td>*</td><td>(1 - 0,00)</td><td>+ 0,046 = 0,256</td></tr> <tr><td>V_v m³</td><td>n_v 1/h</td><td>c_{Air} W/(m²K)</td><td>G_t kWh/a</td><td>per m²</td></tr> <tr><td>3258,7</td><td>*</td><td>0,256</td><td>*</td><td>0,33 * 74,4 = 20441</td></tr> <tr><td></td><td></td><td></td><td></td><td>15,7</td></tr> </tbody> </table>		Ventilation System:	Effective Air Volume, V _v m ³ /h	A _{TFA} m ²	Clear Room Height m	Clear Room Volume m ³	Effective heat recovery efficiency of heat recovery	η _{eff} 0%	1303,5	*	2,50 = 3258,7	Efficiency of Subsoil Heat Exchanger	η _{SHX} 0%				Energetically Effective Air Exchange n _v	0,209	*	(1 - 0,00)	+ 0,046 = 0,256	V _v m ³	n _v 1/h	c _{Air} W/(m ² K)	G _t kWh/a	per m ²	3258,7	*	0,256	*	0,33 * 74,4 = 20441					15,7																																																																						
Ventilation System:	Effective Air Volume, V _v m ³ /h	A _{TFA} m ²	Clear Room Height m	Clear Room Volume m ³																																																																																																						
Effective heat recovery efficiency of heat recovery	η _{eff} 0%	1303,5	*	2,50 = 3258,7																																																																																																						
Efficiency of Subsoil Heat Exchanger	η _{SHX} 0%																																																																																																									
Energetically Effective Air Exchange n _v	0,209	*	(1 - 0,00)	+ 0,046 = 0,256																																																																																																						
V _v m ³	n _v 1/h	c _{Air} W/(m ² K)	G _t kWh/a	per m ²																																																																																																						
3258,7	*	0,256	*	0,33 * 74,4 = 20441																																																																																																						
				15,7																																																																																																						
Ventilation heat losses Q _V																																																																																																										
<table border="1"> <thead> <tr> <th>Total heat losses Q_L</th> <th>Q_T kWh/a</th> <th>Q_V kWh/a</th> <th>Reduction Factor Night/Weekend Saving</th> <th>Q_L kWh/a</th> <th>Q_L kWh/(m²a)</th> </tr> </thead> <tbody> <tr><td>(343096 + 20441)</td><td></td><td></td><td>1,0</td><td>= 363537</td><td>278,9</td></tr> <tr><td>Orientation of the area</td><td>Reduction Factor See 'Windows' worksheet</td><td>g-Value (perp. radiation)</td><td>Area</td><td>Radiation HP</td><td></td></tr> <tr><td>1. North</td><td>0,26</td><td>*</td><td>52,75</td><td>*</td><td>122</td></tr> <tr><td>2. East</td><td>0,23</td><td>*</td><td>242,41</td><td>*</td><td>287</td></tr> <tr><td>3. South</td><td>0,33</td><td>*</td><td>36,89</td><td>*</td><td>432</td></tr> <tr><td>4. West</td><td>0,27</td><td>*</td><td>101,73</td><td>*</td><td>243</td></tr> <tr><td>5. Horizontal</td><td>0,00</td><td>*</td><td>0,00</td><td>*</td><td>400</td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td>0</td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td>kWh/(m²a)</td></tr> </tbody> </table>		Total heat losses Q _L	Q _T kWh/a	Q _V kWh/a	Reduction Factor Night/Weekend Saving	Q _L kWh/a	Q _L kWh/(m ² a)	(343096 + 20441)			1,0	= 363537	278,9	Orientation of the area	Reduction Factor See 'Windows' worksheet	g-Value (perp. radiation)	Area	Radiation HP		1. North	0,26	*	52,75	*	122	2. East	0,23	*	242,41	*	287	3. South	0,33	*	36,89	*	432	4. West	0,27	*	101,73	*	243	5. Horizontal	0,00	*	0,00	*	400						0						kWh/(m ² a)																																													
Total heat losses Q _L	Q _T kWh/a	Q _V kWh/a	Reduction Factor Night/Weekend Saving	Q _L kWh/a	Q _L kWh/(m ² a)																																																																																																					
(343096 + 20441)			1,0	= 363537	278,9																																																																																																					
Orientation of the area	Reduction Factor See 'Windows' worksheet	g-Value (perp. radiation)	Area	Radiation HP																																																																																																						
1. North	0,26	*	52,75	*	122																																																																																																					
2. East	0,23	*	242,41	*	287																																																																																																					
3. South	0,33	*	36,89	*	432																																																																																																					
4. West	0,27	*	101,73	*	243																																																																																																					
5. Horizontal	0,00	*	0,00	*	400																																																																																																					
					0																																																																																																					
					kWh/(m ² a)																																																																																																					
Available Solar Heat Gains Q _S																																																																																																										
<table border="1"> <thead> <tr> <th>Internal Heat Gains Q_I</th> <th>Length heating period kh/d</th> <th>Spec. Power q_i W/m²</th> <th>A_{TFA} m²</th> <th>Q_S + Q_I kWh/a</th> <th>Q_S + Q_I kWh/(m²a)</th> </tr> </thead> <tbody> <tr><td>0,024</td><td>*</td><td>189</td><td>*</td><td>2,80 * 1303,5 = 16570</td><td>12,7</td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td>Q_F / Q_L = 0,11</td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Utilisation Factor Heat Gains η_G</td><td colspan="4">(1 - (Q_F / Q_L)⁵) / (1 - (Q_F / Q_L)⁶) = 100%</td><td></td></tr> <tr><td>Heat Gains Q_G</td><td>η_G *</td><td>Q_F</td><td>= 39410</td><td></td><td>30,2</td></tr> <tr><td>Annual heating demand QH</td><td>Q_L - Q_G</td><td>= 324128</td><td></td><td>249</td><td></td></tr> <tr><td>Limiting value</td><td>KWh/(m²a)</td><td>25</td><td>Requirement met?</td><td>(Yes/No)</td><td>no</td></tr> </tbody> </table>		Internal Heat Gains Q _I	Length heating period kh/d	Spec. Power q _i W/m ²	A _{TFA} m ²	Q _S + Q _I kWh/a	Q _S + Q _I kWh/(m ² a)	0,024	*	189	*	2,80 * 1303,5 = 16570	12,7											Q _F / Q _L = 0,11								Utilisation Factor Heat Gains η _G	(1 - (Q _F / Q _L) ⁵) / (1 - (Q _F / Q _L) ⁶) = 100%					Heat Gains Q _G	η _G *	Q _F	= 39410		30,2	Annual heating demand QH	Q _L - Q _G	= 324128		249		Limiting value	KWh/(m ² a)	25	Requirement met?	(Yes/No)	no																																																			
Internal Heat Gains Q _I	Length heating period kh/d	Spec. Power q _i W/m ²	A _{TFA} m ²	Q _S + Q _I kWh/a	Q _S + Q _I kWh/(m ² a)																																																																																																					
0,024	*	189	*	2,80 * 1303,5 = 16570	12,7																																																																																																					
				Q _F / Q _L = 0,11																																																																																																						
Utilisation Factor Heat Gains η _G	(1 - (Q _F / Q _L) ⁵) / (1 - (Q _F / Q _L) ⁶) = 100%																																																																																																									
Heat Gains Q _G	η _G *	Q _F	= 39410		30,2																																																																																																					
Annual heating demand QH	Q _L - Q _G	= 324128		249																																																																																																						
Limiting value	KWh/(m ² a)	25	Requirement met?	(Yes/No)	no																																																																																																					

(This page displays the sums of the monthly method over the heating period)

Climate: Белико Търново PHI	Interior Temperature: 20 °C						
Building: School "Tzanko Diustabakov"-Block A	Building type: School						
Spec. Capacity: 204 Wh/(m²K)	Treated Floor Area A_{TFA} : 1303,5 m²						
		per m² Treated Floor Area					
Building assembly	Temperature Zone	Area m²	U-Value W/(m²K)	Month. Red. Fac.	G_t kWh/a	kWh/a	
Exterior Wall - Ambient	A	1365,6	* 1,333	* 1,00	* 87	= 158028	121,24
Exterior Wall - Ground	B		* 1,00	*	*	=	
Roof/Ceiling - Ambient	A	549,8	* 3,072	* 1,00	* 87	= 146659	112,52
Floor slab / basement ceiling	B	549,8	* 2,012	* 1,00	* 13	= 13997	10,74
	A			* 1,00	*	=	
	A			* 1,00	*	=	
	X			* 0,75	*	=	
Windows	A	433,8	* 2,513	* 1,00	* 87	= 94642	72,61
Exterior Door	A	2,0	* 5,500	* 1,00	* 87	= 955	0,73
Exterior TB (length/m)	A	597,1	* -0,215	* 1,00	* 87	= -11171	-8,57
Perimeter TB (length/m)	P	110,2	* -0,380	* 1,00	* 13	= -529	-0,41
Ground TB (length/m)	B			* 1,00	*	=	0,00
		Total	402580		308,9		

Transmission heat losses Q_T

Effective Air Volume V_v	A_{TFA} m²	Clear Room Height m			
	1303	* 2,50	= 3259		
$\eta_{V,system}$ 1/h	$\eta_{V,SIX}$	η_{HR}	$\eta_{V,Res}$ 1/h	$\eta_{V,equi,fraction}$ 1/h	
0,209	* (1- 0%) * (1- 0,00) + 0,046	= 0,256			
0,209	* 0%	* (1- 0,00)	= 0,000		
V_v m³	$\eta_{V,equi,fraction}$ 1/h	C_{Air} Wh/(m²K)	G_t kWh/a		
3259	* 0,256	* 0,33	* 87	= 23860	
Ventilation losses ambient Q_V	3259	* 0,000	* 0,33	* 61	= 0
Ventilation losses ground $Q_{V,e}$	3259				
		Total	23860		18,3

Ventilation heat losses Q_V

Q_T kWh/a	Q_V kWh/a	Reduction Factor Night/Weekend Saving	kWh/a	
(402580)	+ 23860)	* 1,0	= 426440	327,2

Total heat losses Q_L

Orientation of the area	Reduction Factor See 'Windows' worksheet	g-Value (perp. radiation)	Area	Global Radiation
North	0,26	* 0,77	* 52,7	* 284 = 3006
East	0,23	* 0,77	* 242,4	* 625 = 26390
South	0,33	* 0,81	* 36,9	* 780 = 7765
West	0,27	* 0,77	* 101,7	* 554 = 11692
Horizontal	0,00	* 0,00	* 0,0	* 959 = 0
Sum opaque areas				44824
		Total	93678	71,9


Available Solar Heat Gains Q_S

kh/d	Length Heat Period d/a	Spec. Power q_s W/m²	A_{TFA} m²	kWh/a	
0,024	* 303	* 2,8	* 1303,5	= 26541	20,4
Free Heat Q_F	$Q_S + Q_I$				
	= 120218			92,2	
Ratio Free Heat to Losses	Q_F / Q_L				
	= 0,28				
Utilisation Factor Heat Gains η_G					
Heat Gains Q_G					
Annual heating demand Q_H					
Limiting value	25 kWh/(m²a)				
		(Yes/No)	Requirement met?	NO	

Climate: Велико Търново RHI
 Building: School "Tzanko Diustabakov"-Block A

Interior Temperature: 20 °C
 Building type: School
 Treated Floor Area A_{TEFA} : 1303 m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heating Degree Hours - Exterior	15,7	12,6	11,3	7,3	3,4	0,7	-0,9	-0,6	3,3	7,0	10,5	15,1	85 kKh
Heating Degree Hours - Ground	1,7	1,6	1,7	1,4	1,2	0,9	-2,3	0,6	0,7	0,9	1,2	1,5	11 kKh
Losses - Exterior	74805	59855	53558	34651	16161	3422	-4069	-2982	15742	33192	49783	71804	405922 kWh
Losses - Ground	1800	1688	1776	1497	1242	914	-2467	663	731	985	1248	1588	11664 kWh
Sum spec. losses	58,8	47,2	42,5	27,7	13,4	3,3	-5,0	-1,8	12,6	26,2	39,1	56,3	320,4 kWh/m ²
Solar gains - North	148	201	296	392	508	572	540	466	339	254	159	138	4012 kWh
Solar gains - East	1512	1809	2639	3549	4083	4136	4297	3867	3254	2527	1541	1338	34554 kWh
Solar gains - South	607	677	846	896	856	806	866	926	956	906	647	567	9557 kWh
Solar gains - West	570	739	1224	1562	1899	1899	2005	1878	1520	1140	654	485	15576 kWh
Solar gains - Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0 kWh
Solar gains - Opaque	2133	2856	4489	6183	7488	7708	8079	7199	5636	4069	2380	1882	60103 kWh
Internal Heat Gains	2715	2453	2715	2628	2715	2628	2715	2715	2628	2715	2628	2715	31971 kWh
Sum spec. gains solar + internal	5,9	6,7	9,4	11,7	13,5	13,6	14,2	13,1	11,0	8,9	6,1	5,5	119,5 kWh/m ²
Utilisation Factor	100%	100%	100%	98%	79%	24%	100%	100%	85%	99%	100%	100%	59%
Annual heating demand	68920	52812	43151	21245	3496	13	0	0	4332	22681	43026	66266	325942 kWh
Spec. Heating Demand	52,9	40,5	33,1	16,3	2,7	0,0	0,0	0,0	3,3	17,4	33,0	50,8	250,1 kWh/m ²



Annual heating demand: Comparison

Monthly method

(Worksheet Heating) 325942 kWh/a

Annual method

(Worksheet Annual) 324128 kWh/a

250,1 kWh/(m²a) reference to treated floor area according to PHPP248,7 kWh/(m²a) reference to treated floor area according to PHPP

EnerPHit planning:

SPECIFIC SPACE HEATING LOAD

Building: School "Tzanko Diustabakov"-Block A	Building type: School
Climate (HL): Велико Търново РНІ	Treated Floor Area A _{TFA} : 1303,5 m ²

Building assembly	Temperature Zone	m ²	Design Temperature		Radiation: North Weather 1: -9,1 °C	South Weather 2: -4,6 °C	West Horizontal W/m ²	Horizontal W/m ²	Factor Always 1 (except 'X')	TempDiff 1 K	TempDiff 2 K	P _T 1 W	P _T 2 W
			North	East									
			Area	U-value W/(m ² K)									
1. Exterior Wall - Ambient	A	1365,6	*	1,333	*	*	1,00	29,1	or	24,6	=	52910	or 44719
2. Exterior Wall - Ground	B		*		*	*	1,00	2,4	or	2,4	=		or
3. Roof/Ceiling - Ambient	A	549,8	*	3,072	*	*	1,00	29,1	or	24,6	=	49103	or 41502
4. Floor slab / basement ceiling	B	549,8	*	2,012	*	*	1,00	2,4	or	2,4	=	2611	or 2611
5.	A		*		*	*	1,00	29,1	or	24,6	=		or
6.	A		*		*	*	1,00	29,1	or	24,6	=		or
7.	X		*		*	*	0,75	29,1	or	24,6	=		or
8. Windows	A	433,8	*	2,513	*	*	1,00	29,1	or	24,6	=	31687	or 26782
9. Exterior Door	A	2,0	*	5,500	*	*	1,00	29,1	or	24,6	=	320	or 270
10. Exterior TB (length/m)	A	597,1	*	-0,215	*	*	1,00	29,1	or	24,6	=	-3740	or -3161
11. Perimeter TB (length/m)	P	110,2	*	-0,380	*	*	1,00	2,4	or	2,4	=	-99	or -99
12. Ground TB (length/m)	B		*		*	*	1,00	2,4	or	2,4	=		or
13. House/DU Partition Wall	I	70,1	*	1,347	*	*	1,00	3,0	or	3,0	=	283	or 283

Transmission heat load P_T

$$\text{Total} = \boxed{133075} \text{ or } \boxed{112907}$$

Ventilation System:	Effective Air Volume, V _v	A _{TFA} m ²	Clear Room Height		Efficiency SHX	η _{SHX} 1 0%	η _{SHX} 2 0%
			m	m ³			
Heat recovery efficiency of the Heat Exchanger	η _{HR} 0%		2,50	=	3259		
Energetically Effective Air Exchange n _v	n _v 1/h	0,105	+	0,209	*(1- 0,00	Φ _{HR} 1/h	Φ _{HR} 1/h
V _v m ³	n _v 1/h	0,314	or	0,314	*	0,00	0,314
	C _{Air} Wh/(m ³ K)	0,33			*	29,1	or 24,6
							=

Ventilation heat load P_v

$$\boxed{9827} \text{ or } \boxed{8306}$$

Total heating load P_L

$$\boxed{142901} \text{ or } \boxed{121213}$$

Orientation of the area	Area m ²	g-Value (perp. radiation)	Reduction Factor (see 'Windows' worksheet)	Radiation 1 W/m ²	Radiation 2 W/m ²	P _T 1 W	P _T 2 W
1. North	52,7	*	0,8	*	19	=	201
2. East	242,4	*	0,8	*	49	=	2084
3. South	36,9	*	0,8	*	82	=	816
4. West	101,7	*	0,8	*	35	=	739
5. Horizontal	0,0	*	0,0	*	56	=	0

Solar heating power P_s

$$\boxed{3840} \text{ or } \boxed{2213}$$

Internal heating load P_i

$$\boxed{2086} \text{ or } \boxed{2086}$$

Heating power (gains) P_G

$$\boxed{5925} \text{ or } \boxed{4298}$$

$$\boxed{136976} \text{ or } \boxed{116915}$$

Heating load P_H

$$\boxed{136976} \text{ W}$$

Area specific space heating load PH / A_{TFA}

$$\boxed{105,1} \text{ W/m}^2$$

Input Max. Supply Air Temperature 52 °C	Supply Air Temperature Without Heating	θ _{Supply,Min} °C	θ _{Supply,Max} °C
Max. Supply Air Temperature θ _{Supply,Max} 52 °C		-9,1	-4,6

For comparison: heating load transportable by the supply Air. P_{Supply Air,Max}

$$= \boxed{13748} \text{ W specific: } \boxed{10,5} \text{ W/m}^2$$

(Yes/No)

Supply Air Heating Sufficient? no

SUMMER VENTILATION

Building: School "Tzanko Diustabanov"-Block A	Building type: School
Building volume: 3259 m ³	Heat recovery η _{HRV} : 0 %
Max. indoor absolute humidity: 12 g/kg	Energy recovery η _{ER} : 0 %
Internal humidity sources: 2 g/(m ² h)	Subsoil heat exchanger η [*] _{SHX} : 0 %

Results passive cooling		Results active cooling	
Frequency of overheating: 9,6%	at the overheating limit θ _{max} = 25 °C	Useful Cooling Demand: 10,3 kWh/(m ² a)	
Frequency of exceeded humidity: max. humidity: 11,7 g/kg		Dehumidification demand: 0,4 kWh/(m ² a)	

Summer background ventilation to ensure adequate air quality

Air exchange via ventilation system with supply 0,00 1/h	HRV/ERV in Summer (check only one field)
	None <input checked="" type="checkbox"/>
	automatic bypass, controlled by temperature difference <input type="checkbox"/>
	automatic bypass, controlled by enthalpy difference <input type="checkbox"/>
	always <input type="checkbox"/>
Air exchange via extract air system 0,00 1/h	Specific power consumption (for extract air system) 0,00 Wh/m ³
Window ventilation air exchange 0,46 1/h	

Effective air exchange

n _{V,system} 1/h	η [*] _{SHX}	η _{HR}	n _{V,equi,fraction} 1/h
exterior n _{V,e} without HR 0,000	*(1- 0%)*(1- 0,00)	= 0,000
Ground n _{L,g} without HR 0,000	*(1- 0%)	= 0,000	
	*	= 0,000	
0,000	0%	= 0,000	

Ventilation conductance

V _V m ³	n _{V,equi,fraction} 1/h	C _{Air} Wh/(m ² K)	
exterior H _{V,e} without HR 3259	*	0,33	= 0,0 W/K
3259	*	0,33	= 0,0 W/K
Ground H _{V,g} without HR 3259	*	0,33	= 0,0 W/K
3259	*	0,33	= 0,0 W/K
Infiltration, window, extract air system 3259	*	0,33	= 494,7 W/K
	0,460		

Additional Summer Ventilation for Cooling

Additional ventilation regulation
Minimum Acceptable Indoor Temperature **20,0** °C

Type of additional ventilation

Window Night Ventilation, Manual	Night ventilation value 0,40 1/h	
mechanical, automatically Controlled ventilation	Corresponding air change rate 0,00 1/h during operation, in addition to base air change Specific power consumption 0,00 Wh/m ³	Temperature difference 0,00 W/K Humidity difference x

Secondary Calculation: hygienic air exchange through window ventilation

Estimation for window air exchange to ensure sufficient air quality

Description

	Day GF	Day GF	Day GF			
Open duration [h/d]	2	3	1			

Climate Boundary Conditions

Temperature Diff Interior - Exterior	4	4	4			K
Wind Velocity	1	1	1			m/s

Window Group 1

Quantity	5	2	1			
Clear Width	2,15	2,40	1,90			m
Clear Height	2,05	2,60	2,50			m
Tilting window (check if appropriate)						
Opening Width (for tilting windows)						m

Window Group 2 (Cross Ventilation)

Quantity	5	2	2			
Clear Width	2,15	3,50	2,40			m
Clear Height	1,45	2,60	2,60			m
Tilting window (check if appropriate)						m
Opening Width (for Tilting Windows)						m

Difference in Height to Window 1

	0,13	0,30	0,07	0,00	0,00	0,00	Total
Result: air exchange	0,13	0,30	0,07	0,00	0,00	0,00	0,50 1/h

Secondary calculation: additional night ventilation for cooling

Air change value during additional window night ventilation

Description

	Night	Night				
Reduction Factor	100%	100%				

Climate Boundary Conditions

Temperature Diff Interior - Exterior	1	1	1	1	1	K
Wind Velocity	0	0	0	0	0	m/s

Window Group 1

Quantity	7	4				
Clear Width	2,15	2,40				m
Clear Height	2,05	2,60				m
Tilting window (check if appropriate)	x	x				
Opening Width (for Tilting Window)	0,060	0,060				m

Window Group 2 (Cross Ventilation)

Quantity	7	2				
Clear Width	2,15	3,50				m
Clear Height	1,45	2,60				m
Tilting window (check if appropriate)	x	x				
Opening Width (for Tilting Window)	0,060	0,060				m

Difference in Height to Window 1

	0,11	0,08	0,00	0,00	0,00	0,00	Total
Result: night ventilation values	0,11	0,08	0,00	0,00	0,00	0,00	0,19 1/h

SUMMER: PASSIVE COOLING


Climate: Велико Търново РНІ	Building type: School						
Building: School "Tzanko Diustabanov"-Block A	Treated Floor Area A_{TFA} : 1303,5 m ²						
Overtemperature limit: 25 °C	Building volume: 3259 m ³						
Nominal humidity: 12 g/kg	Internal humidity sources: 2,0 g/(m ³ h)						
Spec. Capacity: 204 Wh/(m ² h)							
Building assembly	Temperature Zone	Area	U-Value	Red. Factor $f_{T,SUMMER}$	H_{SUMMER} Heat Conductance		
1. Exterior Wall - Ambient	A	1365,6	* 1,333	* 1,00	= 1820,1		
2. Exterior Wall - Ground	B	549,8	* 3,072	* 1,00	= 1689,1		
3. Roof/Ceiling - Ambient	A	549,8	* 2,012	* 1,00	= 1106,1		
4. Floor slab / basement ceiling	B			* 1,00	=		
5.	A			* 1,00	=		
6.	A			* 1,00	=		
7.	X			* 0,75	=		
8. Windows	A	433,8	* 2,513	* 1,00	= 1090,0		
9. Exterior Door	A	2,0	* 5,500	* 1,00	= 11,0		
10. Exterior TB (length/m)	A	597,1	* -0,215	* 1,00	= -128,7		
11. Perimeter TB (length/m)	P	110,2	* -0,380	* 1,00	= -41,8		
12. Ground TB (length/m)	B			* 1,00	=		
					4481,6 W/K		
					1064,3 W/K		
Exterior Thermal Transmittance, $H_{T,e}$							
Ground Thermal Transmittance, $H_{T,g}$							
Summer Ventilation from 'SummVent' worksheet							
Ventilation unit conductance	Ventilation parameter	Summer ventilation regulation					
Exterior $H_{v,e}$	Temperature amplitude summer	11,2 K	HRV/ERV				
without HR	Minimum Acceptable Indoor Temperature	20,0 °C	None				
Ground $H_{v,g}$	Heat capacity air	0,33 Wh/(m ³ K)	Controlled by temperature				
without HR	Supply air exchange	0,00 1/h	Controlled by enthalpy				
Ventilation conductance, others	Ambient air exchange	0,46 1/h	always				
Exterior	Window night ventilation air exchange rate, manual @ 1K	0,40 1/h					
	Air change rate due to mechanical, automatically controlled ventilation	0,00 1/h	Controlled by temperature				
	Specific power consumption for	0,00 Wh/m ³	Controlled by humidity				
	η_{HR}						
	η_{ERV}						
	η^{SHX}						
Orientation of the area	Angle Factor Summer	Shading Factor Summer	Loss-Dirt	g-Value (perp. radiation)	Area	Portion of Glazing	Aperture
1. North	0,9	*	0,68	* 0,77	52,7 m ²	* 52%	= 12,1 m ²
2. East	0,9	*	0,70	* 0,77	242,4 m ²	* 48%	= 54,2 m ²
3. South	0,9	*	0,64	* 0,95	36,9 m ²	* 55%	= 9,0 m ²
4. West	0,9	*	0,83	* 0,95	101,7 m ²	* 48%	= 26,6 m ²
5. Horizontal	0,9	*	1,00	* 0,95	0,0 m ²	* 0%	= 0,0 m ²
6. Sum opaque areas							57,6 m ²
						Total 159,5	0,12
Solar Aperture							
Internal Heat Gains Q_i							
Frequency of Overheating $h_{\vartheta} \geq \vartheta_{max}$	9,6%	At the overheating limit $\vartheta_{max} = 25$ °C					
If the "frequency over 25°C" exceeds 10%, additional measures to protect against the heat during the summer are necessary.							
Daily internal temperature stroke	Transmission kWh/d	Ventilation kWh/d	Solar load kWh/d	1/k	Spec. Capacity Wh/(m ² h)	A_{TFA} m ²	
(602,3)	+ 118,0	+ 828,0) *	1000	/ (204) * 1303	= 5,8 K	

S P E C I F I C U S E F U L C O O L I N G D E M A N D

Climate: **Велико Търново РН1**
 Building: **School "Tzanko Diustabakov"-Block A**

Interior Temperature: **25** °C
 Building type: **School**
 Treated Floor Area A_{TFA} : **1303** m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heating Degree Hours - Exterior	19,4	15,9	14,9	10,8	7,1	4,3	2,8	3,1	6,9	10,7	14,0	18,8	129 kWh
Heating Degree Hours - Ground	5,4	4,9	5,4	5,0	4,9	4,5	1,4	4,3	4,3	4,6	4,8	5,2	55 kKh
Losses - Exterior	95614	78351	73546	53340	34732	20932	13734	14860	33727	52425	69075	92507	632845 kWh
Losses - Ground	5985	5471	5961	5538	5406	4931	1551	4804	4742	5138	5279	5765	60570 kWh
Losses summer ventilation	20197	16115	14503	9898	6054	3608	2603	2643	5925	9753	13697	19435	124431 kWh
Sum spec. heat losses	93,4	76,7	72,1	52,8	35,4	22,6	13,7	17,1	34,1	51,6	67,6	90,3	627,4 kWh/m ²
Solar load North	170	231	340	449	583	656	619	534	389	291	182	158	4602 kWh
Solar load East	1940	2321	3385	4553	5238	5306	5512	4961	4175	3241	1977	1717	44325 kWh
Solar load South	551	615	768	814	777	732	786	841	868	823	588	515	8678 kWh
Solar load West	717	930	1541	1966	2391	2391	2524	2365	1913	1435	824	611	19607 kWh
Solar load Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0 kWh
Solar load Opaque	2133	2856	4489	6183	7488	7708	8079	7199	5636	4069	2380	1882	60103 kWh
Internal Heat Gains	2715	2453	2715	2628	2715	2628	2715	2715	2628	2715	2628	2715	31971 kWh
Sum spec. loads solar + internal	6,3	7,2	10,2	12,7	14,7	14,9	15,5	14,3	12,0	9,6	6,6	5,8	129,9 kWh/m ²
Utilisation Factor Losses	7%	9%	14%	24%	41%	61%	65%	71%	35%	19%	10%	6%	19% 19%
Useful Cooling Energy Demand	0	1	7	58	408	1577	8520	2677	194	18	1	0	13461 kWh
Spec. Cooling Demand	0,0	0,0	0,0	0,0	0,3	1,2	6,5	2,1	0,1	0,0	0,0	0,0	10,3 kWh/m²
specif. dehumidification demand	0,0	0,0	0,0	0,0	0,0	0,0	0,2	0,1	0,0	0,0	0,0	0,0	0,4 kWh/m²
Sensible Fraction	100%	100%	100%	100%	100%	100%	96%	94%	100%	100%	100%	100%	96%



S P E C I F I C U S E F U L C O O L I N G D E M A N D

(This page displays the sums of the monthly method over the cooling period)

Climate: Велико Търново PHI

Building: School "Tzanko Diustabakov"-Block A

Building type: School

Treated Floor Area A_{TFA} : 1303,5 m²

Interior temperature summer: 25 °C

Nominal humidity: 12 g/kg

Spec. Capacity: 204 Wh/(m²K)Building volume: 3259 m³Internal humidity sources: 2,0 g/(m³)

Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Mon. Red. Fac.	G_i kWh/a	kWh/a	per m ² Treated Floor Area
1. Exterior Wall - Ambient	A	1365,6	*	1,333	*	129	= 234085
2. Exterior Wall - Ground	B	*	*	1,00	*	*	= 179,59
3. Roof/Ceiling - Ambient	A	549,8	*	3,072	*	129	= 217245
4. Floor slab / basement	c B	549,8	*	2,012	*	55	= 60570
5.	A	*	*	1,00	*	*	=
6.	A	*	*	1,00	*	*	=
7.	X	*	*	0,75	*	*	=
8. Windows	A	433,8	*	2,513	*	129	= 140192
9. Exterior Door	A	2,0	*	5,500	*	129	= 1415
10. Exterior TB (length/m)	A	597,1	*	-0,215	*	129	= -16548
11. Perimeter TB (length/m)	P	110,2	*	-0,380	*	129	= -5380
12. Ground TB (length/m)	B	*	*	1,00	*	129	= -4,13
			*	1,00	*	*	= 0,00
							KWh/(m ² a)
							Total 631579
							484,5

Transmission losses Q_T (negative: heat loads)

Total 631579

484,5

Summer Ventilation from 'SummVent' worksheet

Ventilation unit conductance	Ventilation parameter	Summer ventilation regulation
Exterior HV _a 0,0 W/K	Temperature amplitude summer 11,2 K	HRV/ERV
without HR 0,0 W/K	Minimum Acceptable Indoor Temperature 20,0 °C	None
Ground HV _a 0,0 W/K	Heat capacity air 0,33 Wh/(m ² K)	Controlled by temperature
without HR 0,0 W/K	Supply air exchange 0,00 1/h	Controlled by enthalpy
Ventilation conductance, others	Air mass exchange 0,46 1/h	always
Exterior 494,7 W/K	Window night ventilation air exchange rate, manual @ 1K 0,40 1/h	Additional ventilation
	Air change rate due to mechanical, automatically controlled 0,00 1/h	
	Specific power consumption for 0,00 Wh/m ³	
	η_{HR} 0%	
	η_{ERV} 0%	
	η_{SHX} 0%	

$n_{V,system}$	η_{SHX}	η_{HR}	$n_{V,Rest}$	$n_{V,equ,fraction}$
Effective Air Change Rate Ambient $n_{V,a}$ 0,000	*(1- 0%))*(1- 0,00)+ 0,000	0,460	= 0,460
Effective Air Change Rate Ground $n_{V,g}$ 0,000	*(1- 0%))*(1- 0,00)		= 0,000

V_V	$n_{V,equ,fraction}$	C_{Air}	G_i	kWh/a	kWh/(m ²)
3259	*	0,460	*	125	= 61837
3259	*	0,000	*	0	= 0
3259	*	0,677	*	171	= 124431

Total 186267 142,9

	Q_T	Q_V		
	kWh/a	kWh/a	= 817846	= 627,4

Orientation of the area	Reduction Factor	g-Value (perp. radiation)	Area	Global Radiation
1. North	0,30	*	52,7	379
2. East	0,29	*	242,4	818
3. South	0,30	*	36,9	960
4. West	0,34	*	101,7	738
5. Horizontal	0,40	*	0,0	1299
6. Sum opaque areas				60103

Total 137315 105,3

kWh/(m²a)

Internal Heat Gains Q_i	kh/d	Length Heat Period d/a	Spec. Power q _i W/m ²	A_{TFA} m ²	kWh/a	kWh/(m ²)
0,024	*	365	*	2,8	*	31971

Sum heat loads Q_F Total 169286 129,9kWh/a kWh/(m²)

Ratio of Losses to Free Heat Gains Q_L / Q_F	
	= 4,83

Utilisation Factor Heat Losses η_G = 19% kWh/a kWh/(m²) $\eta_G * Q_L = 155825$ 119,5 $Q_F - Q_{V,n} = 13461$ 10 kWh/a kWh/(m²)

Limiting value 15 (Yes/No) Requirement met? -

EnerPHit planning:

C O M P R E S S O R C O O L I N G U N I T S

Climate: Велико Търново РНІ
Building: School "Tzanko Diustabakov"-Block A
Interior temperature summer: 25,0 °C
Nominal humidity: 12,0 g/kg
Internal humidity sources: 2,0 g/(m²h)

Building type: school
Treated Floor Area A_{TFA} : 1303,5 m²
Mechanical cooling: 0,0
Air exchange via ventilation system with supply air: 0,0

Supply Air Cooling

check as appropriate

- On/Off Mode (check as appropriate)
- max. cooling capacity (sensible + latent)
- Temperature reduction dry
- Seasonal energy efficiency ratio

kW	
K	
2,0	

Recirculation Cooling

check as appropriate

- On/Off Mode (check as appropriate)
- max. cooling rate at nominal power
- Volume flow rate at nominal power
- Temperature reduction dry
- Variable volume flow (check if appropriate)
- Seasonal energy efficiency ratio

kW	
m³/h	
K	

Additional Dehumidification

check as appropriate

- Waste heat to room (please check if applicable)
- Seasonal energy efficiency ratio

--	--

Panel Cooling

check as appropriate

- Seasonal energy efficiency ratio

--

Useful cooling total

Cooling contribution by:

- Supply Air Cooling**
- Recirculation Cooling**
- Dehumidification**
- Remaining for Panel Cooling**

Total

sensible kWh/(m²a)	latent kWh/(m²a)	COP	Electricity Demand (kWh/a) kWh/(m²a)	Sensible Fraction
10,3	0,4	2,0	96%	
(<input type="text"/> + <input type="text"/>) / <input type="text"/>	/ <input type="text"/>	= <input type="text"/>		
(<input type="text"/> + <input type="text"/>) / <input type="text"/>	/ <input type="text"/>	= <input type="text"/>		
/ <input type="text"/>	/ <input type="text"/>	= <input type="text"/>		
0,0	0,0	0,0	0%	
0,0	0,0	0,0	0%	

Unsatisfied Demand


10,3	0,4
------	-----

Cooling demand covered?

(Yes/No)

COMPRESSOR COOLING UNITS**Humidity loads and humidity removal**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Internal humidity sources:	1,1	1,0	1,1	1,0	1,1	1,0	1,1	1,1	1,0	1,1	1,0	1,1	12
Infiltration/Window/Extract air system	-6,3	-5,6	-5,8	-4,5	-2,9	-1,3	-0,6	-0,9	-2,4	-3,8	-4,9	-6,2	-45
Supply air ventilation system	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Summer ventilation window	0,0	0,0	0,0	0,0	0,0	0,0	-0,3	0,0	0,0	0,0	0,0	0,0	0
Summer ventilation mechanically	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Total humidity load	0,0	0,0	0,0	0,0	0,0	0,0	0,1	0,1	0,0	0,0	0,0	0,0	0
Dehumidification by supply air cooling	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Dehumidification by circulation cooling	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Additional Dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Total dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Unnecessary dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0
Missing dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,2	0,1	0,0	0,0	0,0	0,0	0



COOLING LOAD

Building: School "Tzanko Diustabov"-Block A	Building type: School
Climate (HL): Велико Търново РНІ	Treated Floor Area A_{TFA} : 1303,5 m ²
Interior Temperature: 25 °C	Spec. Capacity: 204 Wh/m ²
Building volume: 3259 m ³	Nominal humidity: 12,0 g/kg
Radiation: North 92, East 197, South 185, West 197, Horizontal 349 W/m ²	Internal humidity sources: 2,0 g/kg
Temperature: Ambient Air Dew Point Sky	Weather 1: 28,1 °C 18,6 °C 16,5 °C
Weather 2: 24,5 °C 18,6 °C 18,6 °C	Ground Design Temp: 23,2 °C SHX 11,7 °C
Area U-Value Factor TempDiff 1 TempDiff 2 P_T 1 P_T 2	Building assembly Temperature Zone m ² W/(m²K) Always 1 (except "X") K K W W
1. Exterior Wall - Ambient A 1365,6 * 1,333 * 1,00 * 3,1 or -0,5 = 5697 or -855	2. Exterior Wall - Ground B * * 1,00 * -1,8 or -1,8 =
3. Roof/Ceiling - Ambient A 549,8 * 3,072 * 1,00 * 3,1 or -0,5 = 5287 or -794	4. Floor slab / basement ceiling B 549,8 * 2,012 * 1,00 * -1,8 or -1,8 = -1989 or -1989
5. A * * 1,00 * 3,1 or -0,5 =	6. A * * 1,00 * 3,1 or -0,5 =
7. X * * 0,75 * 3,1 or -0,5 =	8. Windows A 433,8 * 2,513 * 1,00 * 3,1 or -0,5 = 3412 or -512
9. Exterior Door A 2,0 * 5,500 * 1,00 * 3,1 or -0,5 = 34 or -5	10. Exterior TB (length/m) A 597,1 * -0,215 * 1,00 * 3,1 or -0,5 = -403 or 60
11. Perimeter TB (length/m) P 110,2 * -0,380 * 1,00 * -1,8 or -1,8 = 75 or 75	12. Ground TB (length/m) B * * 1,00 * -1,8 or -1,8 =
13. House/DU Partition Wall I 70,1 * 1,347 * 1,00 * 3,0 or 3,0 = 283 or 283	14. Radiation correction ambient air L _{ambien} W/K -379,1 * 3,1 or -0,5 = -1187 or 178
15. Radiation correction sky L _{sky} W/K 295,5 * -8,5 or -6,4 = -2503 or -1891	Total = 8707 or -5450
Transmission heat load P_T	Total = 8707 or -5450
V _v n _{v,equiv,fraction} n _{v,equiv,fraction} C _{Air} TempDiff 1 TempDiff 2 P_v 1 P_v 2	Ventilation load m ³ 1/h 1/h Wh/(m³K) K K W W
Exterior P _{V,o} 3259 * 0,460 or 0,460 * 0,33 * 3,1 or -0,5 = 1548 or -232	Ground PL,e 3259 * 0,000 or 0,000 * 0,33 * -13,3 or +13,3 = 0 or 0
Summer ventilation P _{L,s} 3259 * 0,000 or 0,000 * 0,33 * 0,0 or 0,0 = 0 or 0	Total = 1548 or -232
Ventilation heat load P_v	Total = 1548 or -232
Orientation of the area Area g-Value Reduction Factor Radiation 1 Radiation 2 P_T 1 P_T 2	Ventilation load m ² (perp. radiation) (see 'Windows' worksheet) W/m ² W/m ² W W
1. North 52,7 * 0,8 * 0,30 * 92 or 64 = 1117 or 771	2. East 242,4 * 0,8 * 0,29 * 198 or 179 = 10744 or 9709
3. South 36,9 * 0,8 * 0,30 * 185 or 237 = 1672 or 2138	4. West 101,7 * 0,8 * 0,34 * 197 or 159 = 5234 or 4212
5. Horizontal 0,0 * 0,0 * 0,40 * 349 or 269 = 0 or 0	Total = 15735 or 12595
Solar load P_s	Total = 34502 or 29426
Internal heating load P_i	Spec. Power A _{TFA} P_i 1 P_i 2
W/m ² m ² W W	
2,8 * * 1303 = 3650 or 3650	Total = 48407 or 27393
P_r + P_v + P_s + P_i	Total = 48407 or 27393
Cooling load P_c	Total = 48407 or 27393
Area specific cooling load P_c / A_{TFA}	Total = 37,1 W/m ²
Please enter the minimum supply air temperature: 3 °C Supply air temperature without cooling $\vartheta_{Supply,Min}$ °C	Spec. Power A _{TFA} P_i 1 P_i 2
W/m ² m ² W W	
2,8 * * 1303 = 3650 or 3650	Total = 48407 or 27393
For comparison: cooling load, transportable through the supply air P_{Supply/Max}	Spec. Power A _{TFA} P_i 1 P_i 2
W/m ² m ² W W	
0,0 * * 0,0 = 0 or 0	Total = 48407 or 27393
specific: 0,0	Air conditioning over the supply air possible? (yes/no) no
Daily internal temperature stroke	Attention: high daily temperature swings. The consideration of a daily average cooling load is not sufficient. If appropriate, improve solar shading!
Transmission Ventilation Solar load Time Spec. Capacity A _{TFA} P_i 1 P_i 2	W W W h/d Wh/(m²K) m ² W W
(8707,2 + 1548,3 + 34501,6) * 24 / (204 * 1303) = 4,0 K	1303 = 4,0 K
Dehumidification load from 'Cooling' worksheet	
Absolute humidity exterior air 13,4 or 13,4 g/kg Absolute humidity supply air 13,4 or 13,4 g/kg	
Ambient air mass flow 1769 or 1769 kg/h Supply air mass flow 0 or 0 kg/h	
Summer ventilation air mass flow 0 or 0 kg/h Humidity load, supply air 0 or 0 g/h	
Humidity load, outside air 2553 or 2553 g/h Humidity load, internal 2607 or 2607 g/h	
Enthalpy of vaporisation Wh/kg 707,639 / 1000 * 5160 or 5160 = 3652 or 3652	
Dehumidification load P_d	Total = 3652 or 3652
Area specific dehumidification load P_d / A_{TFA}	Total = 2,8 W/m ²
Monthly Average values	
	Jan Feb Mar Apr May Jun Jul Aug Sep Oct Nov Dec kWh/m ²
Spec. Cooling Demand 0,0 0,0 0,0 0,0 0,3 1,2 6,5 2,1 0,1 0,0 0,0 0,0	
Spec. dehumidification demand 0,0 0,0 0,0 0,0 0,0 0,0 0,2 0,1 0,0 0,0 0,0 0,0	
Sensible Fraction 100% 100% 100% 100% 100% 100% 96% 94% 100% 100% 100% 100%	
Minimum of sensible cooling load fraction occurred 100%	

HEAT DISTRIBUTION AND DHW SYSTEM

Building: School "Tzanko Diustabanov"-Block A

Interior Temperature:	20	°C
Building type:	School	
Treated Floor Area A_{TFK} :	1303	m ²
Occupancy:	225,0	Pers
Number of dwelling units:	1	
Annual heating demand q _{Heating} :	325942	kWh/a
Length of Heating Period:	189	d
Average heating load Pave:	71,8	kW
Marginal Utilisability of Additional Heat Gains:	100%	

Space Heat Distribution

Length of Distribution Pipes	L_H (Project)	
Heat Loss Coefficient per m Pipe	ψ (Project)	
Temperature of the Room Through Which the Pipes	ϑ_X Mechanical Room	
Design Flow Temperature	ϑ_{dist} Flow, Design Value	
Design system heating load	η_G	
Flow Temperature Control (check)	$P_{heating}$ (exist./calc.)	
Design Return Temperature	ϑ_R	$= 0.714^*(\vartheta_{dist}-20)+20$
Annual Heat Emission per m of Plumbing	Q^{*}_{HL}	$= Y (\vartheta_m-\vartheta_X) t_{heating} * 0.024$
Possible Utilization Factor of Released Heat	η_G	
Annual Losses	Q_{HL}	$= L_H \cdot q^{*}_{HL} \cdot (1-\eta_G)$
Specif. losses	q_{HL}	$= \sum Q_{HL} / A_{TFK}$
*Performance ratio of heat distribution	$e_{a,HL}$	$= (q_H + q_{HV}) / q_H$

Parts		
Warm region	Cold Region	Total
1	2	3
10,00	12,00	
0,362	0,362	
20	10,0	
55,0	56,0	
137,0	137,0	
x		
45,0	45,7	
30	67	
100%	0%	
0	806	0
806		kWh/a
0,6		kWh/(m ² a)
100%		-

DHW: Standard Useful Heat

DHW Consumption per Person and Day (60 °C)	V_{DHW} (Project or Average Value 25 Litres/P/d)	
Average Cold Water Temperature of the Supply	ϑ_{DW} Temperature of drinking water (Electricity worksheet)	
DHW Non-Electric Wash and Dish	Q_{DHW}	
Useful heat - DHW	q_{DHW}	$= Q_{DHW} / A_{TFK}$
Specif. useful heat - DHW		

3,0	Litre/Person/d
11,7	°C
0	kWh/va
13810	kWh/a
10,6	kWh/(m ² a)

DHW Distribution and Storage

Length of Circulation Pipes (Flow + Return)	L_{HS} (Project)	
Heat Loss Coefficient per m Pipe	ψ (Project)	
Temperature of the Room Through Which the Pipes	ϑ_X Mechanical Room	
Design Flow Temperature	ϑ_{dist} Flow, Design Value	
Daily circulation period of operation.	t_{circ} (Project)	
Design Return Temperature	ϑ_R	$= 0.875^*(\vartheta_{dist}-20)+20$
Circulation period of operation per year	t_{circ}	$= 365 t_{circ}$
Annual Heat Released per m of Pipe	q^{*}_Z	$= Y (\vartheta_m-\vartheta_X) t_{circ}$
Possible Utilization Factor of Released Heat	$\eta_{G,DHW}$	$= \eta_{heating}/365d * \eta_G$
Annual Heat Loss from Circulation Lines	Q_Z	$= L_{HS} \cdot q^{*}_Z \cdot (1-\eta_{G,DHW})$

Parts		
Warm region	Cold Region	Total
15,0	10,0	
0,780	0,780	
20	10,0	
60,0	60,0	
10,0	10,0	
55	55	
3650	3650	
107	135	
52%	0%	
772	1352	
2124		kWh/a

Total length of individual pipes

 L_U (Project)

m

Exterior pipe diameter

 $d_{U,Pipe}$ (Project)

m

Tap openings per person per day

m

Utilisation days per year

-

Heat loss per tap opening

d

Amount of tap openings per year

kWh/tap opening

Annual Heat Loss

Tap openings per year

Possible Utilization Factor of Released Heat

kWh/a

Annual Heat Loss of individual pipes

-

Average Heat Released from storage

W

Possible Utilization Factor of Released Heat

kWh/a

Annual Heat Losses from storage

kWh/a

Total heat losses of the DHW system

kWh/a

Specif. losses of the DHW system

kWh/(m²a)

Performance ratio DHW-distribution + storage

27,7

Total heating demand of DHW system

kWh/a

Totalspec. heating demand of DHW system

38,3

Secondary calculation: Ψ -values of plumbing

Nominal width:	25	mm
Insulation Thickness:	50	mm
Mirrored?	Yes	
	x	No
Thermal Conductivity	0,040	W/(mK)
Δθ	30 K	
Interior Pipe Diameter:	0,025 m	
Exterior Pipe Diameter	0,027 m	
Exterior Pipe Diameter	0,127 m	
α-Surface	6,08 W/(m²K)	
Ψ-Value	0,153 W/(mK)	
Surface Temperature Difference	1,886 K	

EnerPHit planning:

SOLAR THERMAL SYSTEM

Building: School "Tzanko Diustabanov"-Block A

Building type: School

Treated Floor Area A_{TFA}: 1303,5 m²**Solar fraction**

Heating Demand DHW

q_{gDHW} kWh/a

49863

(DHW+Distribution)

326747

(Worksheets Heating & DHW+Distribution)

Annual heating demand

Heating support (please check, if applicable)

DHW priority (check if appropriate)

Latitude:

43,1 °

(Worksheet Climate)

Collector: 7 Improved flat plate collector

Solar Collector Area

m²

0,00

Deviation from North

°

180

Angle of Inclination from the Horizontal

°

45

Height of the Collector Field

m

1,00

Height of Horizon

m

Horizontal Distance

m

Additional Reduction Factor Shading

r_{other}

Occupancy

Persons

225,0

Specific Collector Area

m²/Pers

0,0

Estimated solar DHW fraction**Estimated solar coverage for heating****Solar heat contribution total**

0%

kWh/a

0

kWh/a

0

kWh/(m²a)

0%

kWh/a

0

kWh/(m²a)

0

kWh/(m²a)**Secondary Calculation of Storage Losses**

Solar Storage: 9 Simple solar storage

Total storage volume

litre

500

Volume Standby Part (above)

litre

150

Volume Solar Part (below)

litre

350

Specific heat losses storage (total)

W/K

3,6

Typical Temperature DHW

°C

60

Room Temperature

°C

10

Storage heat losses (standby part only)


W

38

Total storage heat losses

W

180



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heating demand DHW-preparation	4235	3825	4235	4098	4235	4098	4235	4235	4098	4235	4098	4235	49863
Heating demand space heating	69090	52942	43257	21298	3505	14	0	0	4342	22737	43133	66430	326747
Heating demand	73325	56768	47492	25396	7739	4112	4235	4235	8441	26972	47231	70664	376610
Radiation on Tilted Collector Surface	0	0	0	0	0	0	0	0	0	0	0	0	0
Please enter: Solar production for DHW													0
Please enter: Solar production for heating													0
DHW heat demand covered by solar	0	0	0	0	0	0	0	0	0	0	0	0	0
Heating demand covered by solar	0	0	0	0	0	0	0	0	0	0	0	0	0
Heating demand covered by solar	0	0	0	0	0	0	0	0	0	0	0	0	0
Solar fraction	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-

Hit planning:

PHOTOVOLTAIC SYSTEM

Building: School "Tzanko Diustabanov"-Block A

Building type: school

Climate: Велико Търново РНІ

Information from the module data sheet

Technology Amorph-Si

Nominal current
Nominal voltage
Nominal power
Temperature coefficient short-circuit current
Temperature coefficient open-circuit voltage

I_{MPP0}
 U_{MPP0}
 P_n
 α
 β

A
V
W_p
%/K
%/K

Further specifications

Latitude:
Number of modules
Deviation from North
Angle of inclination from the horizontal
Height of module array
Height of horizon
Horizontal distance
Additional Reduction Factor Shading
Efficiency of the inverter


n_M
 h_{Hori}
 a_{Hori}
 r_{other}
 η_{HRV}

43,1
°
°
°
m
m
m
g/kWh

(Worksheet Climate)

Annual yield of the inverter
Annual losses due to shading
PE value (non-renewable)
CO₂-equivalent emission value

kWh
kWh
g/kWh



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Solar radiation on tilted surface	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	kWh/m²/a
Ambient temperature	-1	2	5	10	16	20	22	22	16	11	6	0	°C
total monthly generation	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	kWh/month
Losses due to shading situation	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	kWh/a

E L E C T R I C I T Y D E M A N D

Building: School "Tzanko Diustabakov"-Block A

Calculation in worksheet 'Electricity non-res'!

Column Nr.	Households			Solar fraction of DHW Laundry&Dish			Prim. Energy Factors:			
	1 HH	225,0 P	1303 m ²	Marginal Performance Ratio DHW	111%	Marginal Performance Ratio Heating	Electricity	2,6 kWh/kWh	Natural Gas	1,1 kWh/kWh
Application	Used ? (1/0)	Within the Thermal Envelope? (1/0)	Norm Demand	Utilization Factor	Frequency	Reference Quantity	Useful Energy (kWh/a)	Electric Fraction		
Dishwashing	1	1	1,10 kWh/Use	*	1,00	*	65 /P*a	16088 * 100% = 16088	16088	41828
Cold water connection				*	1,00	*	57 /P*a	14108 * 100% = 14108	14108	36680
Clothes washing	1	1	1,10 kWh/Use	*	1,00	*	57 /P*a	39277 * 100% = 39277	39277	102119
Cold water connection				*	0,60	*	57 /P*a	0 * 100% = 0	0	0
Clothes drying with:	1	1	3,50 kWh/Use	Residual dampness	0,88	*	57 /P*a	285 * 100% = 285	285	740
Condensation Dryer				*	0,60	*	57 /P*a	289 * 100% = 289	289	752
Energy consumed by evaporation	0	1	3,13 kWh/Use	*	1,00	*	365 d/a	0 * 100% = 0	0	0
Refrigerating	1	1	0,78 kWh/d	*	0,90	*	365 d/a	28125 * 100% = 28125	28125	73125
Freezing	1	0	0,88 kWh/d	*	1,00	*	365 d/a	0 * 100% = 0	0	0
or combination	0	1	1,00 kWh/d	*	1,00	*	500 /P*a	1294 * 100% = 1294	1294	0
Cooking with:	1	1	0,25 kWh/Use	Percentage CFLs	0%	*	1,00 kh/(P*a)	39150 * 100% = 39150	39150	101790
Electricity				*	1,00	*	1,00 kh/(P*a)	9900 * 100% = 9900	9900	25740
Lighting	1	1	60 W	*	1,00	*	1,00 kh/(P*a)	11250 * 100% = 11250	11250	29250
Consumer electronics	1	1	80 W	*	1,00	*	1,00 kh/(P*a)	0 * 100% = 0	0	3366
Small appliances, etc.	1	1	50 kWh/a	*	1,00	*	1,00 kh/(P*a)	0 * 100% = 0	0	0
Total aux. electricity							0	0	0	0
Other:							0	0	0	0
Total							159765 kWh	0 kWh	0 kWh	415388
Specific Demand							122,6 kWh/(m ² a)	0,0 kWh/(m ² a)	0,0 kWh/(m ² a)	318,7
Recommended maximum value							18			50

UTILISATION non-residential Use

Building: School "Tzanko Diustabakov"-Block A

Latitude [°]: 43

	Periods of utilisation and operation													Lighting	Illumination Level [lux]	Height of utilisation level (0,8 or 0,0 m)	Relative Absenteism	Part Use Factor of Building Operating Period for Lighting	Average Occupancy [m²/Pers.]
	Begin Utilisation [h]	End Utilisation [h]	Daily Utilisation Hours [h/d]	Annual Utilisation Days [da]	Annual Utilisation Hours [h/a]	Annual Utilisation Hours During Daytime [h/a]	Annual Utilisation Hours During Nighttime [h/a]	Daily operating hours of heating	Daily operating hours of ventilation										
1 Classroom	7,5	18	11	180	1890	1803	87	13	13					300	0,8	0,8	0,25	0,9	3,0
2 Corridors	7,5	18	11	180	1890	1803	87	13	13					100	0,0	0,0	0,80	1,0	
3 Lobbies	7,5	18	11	180	1890	1803	87	13	13					200	0,0	0,0	0,80	1,0	
4 Computer room	7,5	18	11	180	1890	1803	87	13	13					300	0,8	0,8	0,30	0,4	2,0
5 Bookstore	9,0	18	9	180	1620	1534	86	11	11					300	0,8	0,8	0,90	1,0	
6 Canteen	10,0	16	6	180	990	990	0	8	8					100	0,8	0,8	0,80	0,4	
7 Kitchen	10,0	16	6	180	990	990	0	8	8					100	0,8	0,8	0,80	0,4	
8 Stairs	7,5	18	11	180	1890	1803	87	13	13					100	0,0	0,0	0,80	1,0	
9 WC, Sanitary	7,5	18	11	180	1890	1803	87	13	13					200	0,8	0,8	0,90	1,0	
10 Teacher offices	7,5	18	11	180	1890	1803	87	13	13					300	0,8	0,8	0,30	0,7	10,0
11			0	0	0	0	0	2	2						0,8				
12			0	0	0	0	0	2	2						0,8				
13			0	0	0	0	0	2	2						0,8				
14			0	0	0	0	0	2	2						0,8				
15			0	0	0	0	0	2	2						0,8				
16			0	0	0	0	0	2	2						0,8				
17			0	0	0	0	0	2	2						0,8				
18			0	0	0	0	0	2	2						0,8				
19			0	0	0	0	0	2	2						0,8				
20			0	0	0	0	0	2	2						0,8				
21 Single Office	7	18	11	250	2750	2543	207	13						500	0,8	0,8	0,30	0,70	10,00
22 Group Office	7	18	11	250	2750	2543	207	13						500	0,8	0,8	0,30	0,70	
23 Open-Plan Office	7	18	11	250	2750	2543	207	13						500	0,8	0,8	0,00	1,00	15,00
24 Meeting	7	18	11	250	2750	2543	207	13						500	0,8	0,8	0,50	1,00	2,00
25 Counter Area	7	18	11	250	2750	2543	207	13						200	0,8	0,8	0,00	1,00	
26 Retail	8	20	12	300	3600	2999	601	14						300	0,8	0,8	0,00	1,00	7,00
27 Classroom	8	15	7	200	1400	1398	2	9						300	0,8	0,8	0,25	0,90	2,00
28 University Auditorium	8	18	10	150	1500	1409	91	12						500	0,8	0,8	0,25	0,70	0,75
29 Bedroom	0	24	24	365	8760	4407	4353	24						300	0,8	0,8	0,00	0,50	
30 Hotel Room	21	8	11	365	4015	755	3260	24						200	0,8	0,8	0,25	0,30	
31 Canteen	8	15	7	250	1750	1748	2	9						200	0,8	0,8	0,00	1,00	
32 Restaurant	10	0	14	300	4200	2404	1796	16						200	0,8	0,8	0,00	1,00	1,50
33 Kitchen Non-Residential	10	23	13	300	3900	2404	1496	15						500	0,8	0,8	0,00	1,00	
34 Kitchen, Storage, Preparation	7	23	16	300	3900	2404	1496	15						300	0,8	0,8	0,50	1,00	
35 WC, Sanitary	7	18	11	250	2750	2543	207	13						200	0,8	0,8	0,90	1,00	
36 Other Habitable Rooms	7	18	11	250	2750	2543	207	13						300	0,8	0,8	0,50	1,00	
37 Secondary Areas	7	18	11	250	2750	2543	207	13						100	0,8	0,8	0,90	1,00	
38 Circulation Area	7	18	11	250	2750	2543	207	13						100	0,0	0,0	0,80	1,00	
39 Storage, Services	7	18	11	250	2750	2543	207	13						100	0,8	0,8	0,98	1,00	
40 Server Room	0	24	24	365	8760	4407	4353	24						500	0,8	0,8	0,50	0,50	
41 Workshop	7	16	9	250	2250	2192	58	11						500	0,8	0,8	0,00	1,00	
42 Theatre Auditorium	19	23	4	250	1001	55	946	6						200	0,8	0,8	0,00	1,00	
43 Theatre Foyer	19	23	4	250	1001	55	946	6						300	0,8	0,8	0,50	1,00	
44 Theatre Stage	13	23	10	250	2500	1253	1247	12						1000	0,8	0,8	0,00	0,60	
45 Fair, Congress	13	18	5	150	1350	1260	90	11						300	0,8	0,8	0,50	1,00	
46 Exhibition	10	18	8	250	2001	1850	151	24						200	0,8	0,8	0,00	1,00	
47 Library Reading Room	8	20	12	300	3600	2999	601	14						500	0,8	0,8	0,00	1,00	
48 Open Access Library	8	20	12	300	3600	2999	601	14						200	0,8	0,8	0,00	1,00	
49 Library Repository	8	20	12	300	3600	2999	601	14						100	0,8	0,8	0,90	1,00	
50 Gymnasium	8	23	15	300	4500	3002	1498	17						300	0,8	0,8	0,30	1,00	
51 Parking Garage	7	18	11	250	2750	2543	207	0						75	0,0	0,0	0,95	1,00	
52 Public Parking Garage	9	0	15	365	5475	3290	2185	0						75	0,0	0,0	0,80	1,00	

E L E C T R I C I T Y D E M A N D Non-Residential Use

Building: School "Tzanko Diustabancov"-Block A

Treated Floor Area A _{TFR} :	1303,5	m ²
Auxiliary Electricity Demand:	1294,4	kWh/a
Primary Energy factors:		
Electricity:	2,6	kWh/kWh
Natural gas:	1,1	kWh/kWh
Energy Carrier for DHW:		
Solar fraction of DHW:	0%	
Marginal Performance Ratio DHW:		

Window Properties (from Windows worksheet):

	Shading	Dirt Factor	Non-Perpendicular Radiation	Glazing Fraction
North	0,63	0,95	0,85	0,52
East	0,58		0,48	
South	0,75		0,55	
West	0,70		0,48	

Lighting / non-residential	Percentage of treated floor area	Facade with Windows				
		Room Category	Nominal Illuminance Level	Deviation from North	Orientation	Light Transmission Glazing
Room / Zone		Room Depth	Room Width	Room Height	Lintel Height	Window Width
		2	15			
Lobby	6%	3	Lobbies	200	0 North	69%
Lobby	6%	3	Lobbies	200	180 South	69%
Corridors	22%	2	Corridors	100	270 West	69%
Classroom east orient	30%	1	Classroom	300	90 East	69%
Classroom south orient	19%	1	Classroom	300	180 South	69%
Classroom south orient	8%	1	Classroom	300	180 South	69%
WC's	9%	9	WC, Sanitary	200	90 East	69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%
						69%

Room Geometry: Input of a Typical Room or Room by Room

Room Depth	Room Width	Room Height	Lintel Height	Window Width
3	3	3	3	3

Input Warning

Daylight Utilisation

User Data: Installed Lighting Power (Standard)


Installed Lighting Power (Standard)

Lighting Control

With motion?

9	1410,0	1270,3	16,2	3302,9
	1410,0	1270,3	16,2	3302,9
	1410,0	2975,9	10,4	7737,3
	1566,0	9601,9	24,6	24964,9
	1566,0	6081,2	24,6	15811,1
	1566,0	2560,5	24,6	6657,3
	1350,0	1824,4	15,6	4743,5
	0,0	0,0	0,0	
	0,0	0,0	0,0	
	0,0	0,0	0,0	
	0,0	0,0	0,0	
	0,0	0,0	0,0	
	0,0	0,0	0,0	
	0,0	0,0	0,0	
	0,0	0,0	0,0	
	0,0	0,0	0,0	
	0,0	0,0	0,0	

Primary Energy Demand (kWh/a)
kWh/a



Office Equipment												Electricity Demand (kWh/a)		Primary Energy Demand (kWh/a)	
Room Category	Room Category	In the thermal envelope? (1/0)	Existing/Planned? (1/0)	Quantity	Power Rating (W)	Utilisation Hours per Year (h/a)	relative absenteeism	Duration of Utilisation in Energy Saving Mode (h/a)	Useful Energy (kWh/a)						
PC 1	4 Computer room	1	1	*	0	* (756 * 0,3)	18		0			0,0		0	
PC in Energy Saving Mode	4 Computer room	1	1	*	0	* (756 * 0,3)	18		0			0,0		0	
Monitor 1	4 Computer room	1	1	*	0	* (756 * 0,3)	18		0			0,0		0	
Monitor in Energy Saving Mode	4 Computer room	1	1	*	0	* (756 * 0,3)	18		0			0,0		0	
PC 2	10 Teacher offices	1	1	*	2	* (1323 * 0,3)	18		0			101,9		265	
PC in Energy Saving Mode	10 Teacher offices	1	1	*	2	* (1323 * 0,3)	18		0			1,6		4	
Monitor 2	10 Teacher offices	1	1	*	2	* (1323 * 0,3)	18		0			37,0		96	
Monitor in Energy Saving Mode	10 Teacher offices	1	1	*	2	* (1323 * 0,3)	18		0			1,2		3	
Copier	10 Teacher offices	1	1	*	1	* (1890 * 0,3)	18		0			75,6		197	
Copier in Energy Saving Mode	10 Teacher offices	1	1	*	1	* (1890 * 0,3)	18		0			51,0		133	
Printer		0	0	*	0	* (0 * 0)	18		0			0,0		0	
Printer in Energy Saving Mode		0	0	*	0	* (0 * 0)	18		0			0,0		0	
Server		0	0	*	0	* (0 * 0)	18		0			0,0		0	
Server in Energy Saving Mode		0	0	*	0	* (0 * 0)	18		0			0,0		0	
Telephone System		1	1	*	1	* (94 * 0,3)	18		0			823,4		2141	
Hand Dryer (WC)				*					0			0,0		0	
				*					0			0,0		0	
				*					0			0,0		0	
Kitchen / Aux. Electricity	Predominant Utilisation Pattern of Building	In the thermal envelope? (1/0)	Existing/Planned? (1/0)	Utilisation Days per Year (da)	Number of Meals per Utilisation Day	Norm Consumption	Useful Energy (kWh/a)	Non-Electric Fraction	Electric Fraction	Additional demand	Marginal Performance Ratio	Solar Fraction	Other Primary Energy Demand (kWh/a)	Electricity Demand (kWh/a)	Primary Energy Demand (kWh/a)
Cooking				*	0	* (0,25 * 0,3)	0					0		0,0	0
Electricity				*	0	* (0,25 * 0,3)	0					0		0,0	0
Dishwashing				*	0	* (0,10 * 0,3)	0					0		0,0	0
DHW connection				*	365							0		0,0	0
Refrigerating												0,0		0,0	0
Total Auxiliary Electricity												1294		1294,4	3366
Total												27971 kWh		27971 kWh/a	72724 kWh/a
Specific Demand												0,0		21 kWh/(m²a)	56 kWh/(m²a)

EnerPHit planning:

AUXILIARY ELECTRICITY

Building: School "Tzanko Diustabanov"-Block A												
Treated Floor Area Heating period Air Volume Dwelling Units Enclosed Volume	1303 189 3259 1 6224	m ² d m ³ HH m ³	Operation Vent. System Winter Operation Vent. System Summer Air Change Rate Defrosting HX from	4,54 4,22 0,21 2,0	kh/a kh/a h ⁻¹ °C	Primary Energy factor - Electricity Annual Space Heating Demand Boiler Rated Power DHW System Heating Demand Design Flow Temperature	2,60 250 137 49863 55	kWh/kWh kWh/(m ² a) kW kWh/a °C				
Column Nr.	1	2	3	4	5	6	7	8	9	10	11	12
Application	Used ? (1/0)	Within the Thermal Envelope ? (1/0)	Norm Demand	Utilization Factor	Period of Operation	Reference Size	Electricity Demand (kWh/a)	Available as Interior Heat	Used During Time Period (kh/a)	Internal heat source Winter (W)	Internal heat source Summer (W)	Primary Energy Demand (kWh/a)
<u>Ventilation System</u>												
Winter Ventilation	0	0,00	Wh/m ³	* 0,21	h ⁻¹	* 4,5 kh/a	* 3259 m ³	= 0	considered in heat recovery efficiency	0	0	0
Defroster HX	0	1	W	* 1,00	kh/a	* 0,6	= 0	* 1,0 / 4,54 = 0	0	0	0	0
Summer Ventilation	0	1,00	Wh/m ³	* 0,00	h ⁻¹	* 4,2 kh/a	* 3259 m ³	= 0	* 1,0 / 4,22 = 0	0	0	0
Additional ventilation summer	0	1,00	0,00	Wh/m ³	* 0,00	h ⁻¹	* 4,2 kh/a	* 3259 m ³	= 0 * 1,0 / 4,22 =	0	0	0
<u>Heating System</u>												
Enter the Rated Power of the pump												
Circulation Pump	1	1	W	* 214	W	* 1,0	* 4,5 kh/a	* 1	= 973 * 1,0 / 4,54 = 214	214	2530	2530
Boiler Electricity Consumption at 30% Load												
Aux. Energy - Heat. Boiler	0	0	W	* 159	W	* 1,00	* 0,00 kh/a	* 1	= 0 * 1,0 / 4,54 = 0	0	0	0
Aux. Energy - Wood fired/pellet boiler	0	0	W	0	W	Data entries in Boiler worksheet. Auxiliary energy demand including possible drinking water prod.	0	* 1,0 / 4,54 = 0	0	0	0	0
<u>DHW system</u>												
Enter average power consumption of pump												
Circulation Pump	1	43	W	* 1,00	W	* 7,5 kh/a	* 1	= 321 * 0,5 / 8,76 = 0	0	0	836	836
Enter the Rated Power of the pump												
Storage Load Pump DHW	162	W	* 1,00	W	* 0,4 kh/a	* 1	= 0 * 1,0 / 4,54 = 0	0	0	0	0	0
Boiler Electricity Consumption at 100% Load												
DHW Boiler Aux. Energy	0	0	W	* 477	W	* 1,00	* 0,0 kh/a	* 1	= 0 * 1,0 / 4,54 = 0	0	0	0
Enter the Rated Power of the Solar DHW pump												
Solar Aux Electricity	0	130	W	* 1,00	W	* 1,8 kh/a	* 1	= 0 * 0,5 / 8,76 = 0	0	0	0	0
<u>Misc. Aux. Electricity</u>												
Misc. Aux. Electricity	0	0	kWh/a	* 1,00	W	* 1,0	* 1,0 HH	= 0 * 1,0 / 8,76 = 0	0	0	0	0
Total								1294		214	0	3366
Specific Demand	kWh/(m ² a)	divided by treated floor area:								1,0		2,6

INTERNAL HEAT GAINS

Building: School "Tzanko Diustabakov"-Block A

Calculation in worksheet 'IHG non-res'!

Utilisation Pattern: School 2,80 W/m²Type of Values Used: Standard 18,63 W/m² in summerNo data input necessary 1,34 W/m²[Go to utilisation pattern selection](#)

Calculation Internal Heat Household Column Nr.	1 Application	2 Existing (1/0), or number of people	3 Persons Living Area	4 Norm Consumption	5 Utilization Factor	6 Frequency	7 Heating Demand Heating period	8 Included in Electricity Balance?	9 Availability	10 Used During Time Period (kh/a)	Internal heat source Winter (W)
Dishwashing	1	1	225,0 P 1303 m ²	1,1 kWh/Use	1,00	65 /(P^* a)	16088 *	0,30	/ 8,76	=	551
Clothes Washing	1	1		1,1 kWh/Use	1,00	57 /(P^* a)	14108 *	0,30	/ 8,76	=	483
Clothes drying with: Condensation Dryer	1	1		3,5 kWh/Use	0,88	57 /(P^* a)	39277 0	0,70	/ 8,76	=	3139
Energy consumed by evaporation	0	1		0,0 kWh/Use	-3,1	57 /(P^* a)	0	0,80	/ 8,76	=	0
Refrigerating	1	1		0,8 kWh/d	0,60	365 d/a	285 *	0,00	/ 8,76	=	33
Freezing or combination	1	0		0,9 kWh/d	0,90	365 d/a	289 *	1,00	/ 8,76	=	0
Cooking	1	1		1,0 kWh/d	1,00	365 d/a	0	1,00	/ 8,76	=	0
Lighting	1	1		60,0 W	1,00	500 /(P^* a)	28125 *	0,50	/ 8,76	=	1605
Consumer Electronics	1	1		80,0 W	1,00	2,9 kh/(P^* a)	39150 *	1,00	/ 8,76	=	4469
Household Appliances/Other	1	1		50,0 kWh	1,00	0,55 kh/(P^* a)	9900 *	1,00	/ 8,76	=	1130
Auxiliary Appliances (cf. Aux Electricity Sheet)						1,0 /(P^* a)	11250 *	1,00	/ 8,76	=	1284
Other Applications (cf. Electricity Sheet)	0	0,0						0	/ 8,76	=	214
Persons	225	1	80,0 W/P	1,00		8,76 kh/a	0	*			0
Cold Water	225	1	-4,0 W/P	1,00		8,76 kh/a	157680 *	0,55	/ 8,76	=	9900
DHW - circulation	1	1	182,8 W	1,00		8,76 kh/a	1601 *	1,00	/ 8,76	=	-905
DHW - individual pipes	1	1	7889,4 W	1,00		8,76 kh/a	69111 *	1,00	/ 8,76	=	183
DHW - storage	1	1	150,0 W	1,00		8,76 kh/a	1314 *	1,00	/ 8,76	=	7889
Evaporation	225	1	-25,0 W/P	1,00		8,76 kh/a	-49275 *	1,00	/ 8,76	=	150
Total											16278 W
Specific Demand											12,49 W/m ²
Heat Available From Internal Sources											56,7 kWh/(m ² a)
							189,2 d/a				

EnerPHit planning:

INTERNAL HEAT GAINS non-residential Use

Building: School "Tzanko Diustabakov"-Block A

Utilisation Pattern: School

2,80 W/m²

Type of Values Used: Standard

No data input necessary

Calculation Internal Heat		Persons: 225,0 Treated floor area: 1303,46 m ²		P	Heating period: 189,17 d/a		Room Temperature: 20 °C Internal Heat Gains Aux. Electricity: 214,3 W								
Column Nr.	Persons	Select	Utilisation Pattern	Select	Activity of Persons	Number of Occupants	Floor Area of Utilisation Zone (m ²)	Average Occupancy (Persons / m ²)	Heat emitted per person (W)	Utilisation Hours per Year [h/a]	Relative Presence	Used in Time Span (h/a)	Average Heat Emitted by Persons (W)		
Persons A	1 Classroom	1	<= 10 yr., sitting 3 >10 yr., standing or light work	1 Planning with occupancy 1 Planning with occupancy	{ 205 }* or { 20 }	{ 205 }* or { 20 }	27	0,3333333333	60 * 1890 * 0,75 / 8760 = 1990	9 * 1890 * 0,75 / 8760 = 324	18	0,75 / 8760 = 0	0,75 / 8760 = 0		
Persons B	1 Classroom	1	Invalid data input	Enter occupancy or floor area	{ 20 }* or { 0 }	{ 20 }* or { 0 }	100 * 1890 * 0,75 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0	0,75 / 8760 = 0	0,75 / 8760 = 0		
Persons C			Invalid data input	Enter occupancy or floor area	{ 0 }* or { 0 }	{ 0 }* or { 0 }	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0	0,75 / 8760 = 0	0,75 / 8760 = 0		
Persons D			Invalid data input	Enter occupancy or floor area	{ 0 }* or { 0 }	{ 0 }* or { 0 }	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0	0,75 / 8760 = 0	0,75 / 8760 = 0		
Persons E			Invalid data input	Enter occupancy or floor area	{ 0 }* or { 0 }	{ 0 }* or { 0 }	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0	0,75 / 8760 = 0	0,75 / 8760 = 0		
Persons F			Invalid data input	Enter occupancy or floor area	{ 0 }* or { 0 }	{ 0 }* or { 0 }	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0	0,75 / 8760 = 0	0,75 / 8760 = 0		
Persons G			Invalid data input	Enter occupancy or floor area	{ 0 }* or { 0 }	{ 0 }* or { 0 }	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0 * 0 * 0 * 1,00 / 8760 = 0	0	0,75 / 8760 = 0	0,75 / 8760 = 0		
Evaporation (person specific)						143 *									
Lighting / Equipment / Aux. Electricity															
Lighting															
Office Applications (Within Therm. Envelope)															
Cooking (Within Therm. Envelope)															
Dishwashing (Within Therm. Envelope)															
Cooling (Within Therm. Envelope)															
Other (Within Therm. Envelope)															
Auxiliary Appliances (See Aux Electricity Worksheet)															
Heat loss due to cold water (calculation from column AJ)	on/off (1 / 0)														
Cold Water Due to Flushing WC															
Total															
Specific Demand															
Heat Available From Internal Sources															
Preprogramm Utilisation Pattern of Building (Data transferred from Electricity non-res worksheet; Input Kitchen)		Number of WCs (user data)		Amount of WCs: Standard values for schools are used (X)		Number of WCs (calculation value)		DT: Cold Water Temp. - Room Temp. [K]		Occupied Days per Year [d/a]		Loss daytime [W]		Loss Nighttime [W]	
0	2			0	-8	0	-8	0	0	0	0	1,00 / 365 = 0	1,00 / 365 = 0	Average Power Cold Water W	
														5574	
														4,3	
														19	
										189 d/a					

PRIMARY ENERGY VALUE

Building: School "Tzanko Diustabakov"-Block A		Building type: School
Treated Floor Area A _{FA} :	1303	m ²
Space Heating Demand incl. Distribution:	251	kWh/(m ² a)
Useful cooling demand incl. dehumidification:		kWh/(m ² a)
Final Energy	Primary Energy	Emissions CO ₂ -Equivalent
kWh/(m ² a)	kWh/(m ² a)	kg/(m ² a)
Electricity Demand (without Heat Pump)		PE Value CO ₂ -Emissions Factor (CO ₂ -Equivalent)
Covered Fraction of Space Heating Demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	2,6 680
Direct Electric Heating Q _{H,de}	0,0	0,0 0,0
Hot water, direct electric (without DHW wash&dish) Q _{DHW,de} (DHW+Distribution, SolarDHW)	0,0	0,0 0,0
Electric Post heating DHW Wash&Dish (Electricity, SolarDHW)	0,0	0,0 0,0
Electricity demand lighting/auxiliary tools/kitchen Q _{EHH} (Electricity worksheet)	20,5	53,2 13,9
Electricity Demand - Auxiliary Electricity	1,0	2,6 0,7
Total electricity demand (without heat pump)	21,5	55,8 14,6
Heat pump		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of Space Heating Demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	2,6 680
Energy Carrier - Supplementary Heating	Electricity	2,6 680
Annual coefficient of performance of heat pump 1 (heating / heating&DHW) SPF _{H-1} (HP worksheet)	0%	kWh/kWh g/kWh
Annual coefficient of performance of heat pump 2 (DHW) SPF _{H-1} (HP worksheet)	0%	2,6 680
Heat generation efficiency (excl. DHW wash&dish) (HP worksheet)	0,0	0,0 0,0
Heat generation efficiency (incl. DHW wash&dish) (HP worksheet)	0,0	0,0 0,0
Electricity Demand Heat Pump (without DHW Wash&Dish) Q _{HP} (HP worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (HP worksheet)	0,0	0,0 0,0
Total electricity demand heat pump	0,0	0,0 0,0
Compact Heat Pump Unit		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	2,6 680
Energy Carrier - Supplementary Heating	Electricity	2,6 680
COP Heat Pump Heating SPF _{H-1} (Compact worksheet)	0,0	0,0 0,0
COP Heat Pump DHW SPF _{H-1} (Compact worksheet)	0,0	0,0 0,0
Heat generation efficiency (excl. DHW wash&dish) (Compact worksheet)	0,0	0,0 0,0
Heat generation efficiency (incl. DHW wash&dish) (Compact worksheet)	0,0	0,0 0,0
Electricity Demand Heat Pump (without DHW Wash&Dish) Q _{HP} (Compact worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (Compact worksheet)	0,0	0,0 0,0
Total Compact Unit	0,0	0,0 0,0
Boiler		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	2,6 250
Boiler Type (Boiler worksheet)	0%	0,0 0,0
Performance Ratio of Heat Generator (Boiler worksheet)	0%	0,0 0,0
Annual Energy Demand (without DHW Wash&Dish) (Boiler worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (Electricity worksheet)	0,0	0,0 0,0
Total heating oil/gas/wood	0,0	0,0 0,0
District Heat		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	100%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	100%	0,8 240
Heat source Hard Coal CGS 70% PHC	111%	0,0 0,0
Performance Ratio of Heat Generator (District heating worksheet)	320,7	256,6 77,0
Heating Demand District Heat (without DHW Wash&Dish) (District heating worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (Electricity worksheet)	320,7	256,6 77,0
Total district heat	320,7	256,6 77,0
Other		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	0,2 55
Heat source Wood	0%	0,0 0,0
Performance Ratio of Heat Generator (Project)	0%	0,0 0,0
Annual Energy Demand, Space Heating (Project)	0,0	0,0 0,0
Annual Energy Demand, DHW (without DHW Wash&Dish) (Electricity worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (Electricity worksheet)	0,0	0,0 0,0
Non-Electric Demand Cooking/Drying (Gas) (Electricity worksheet)	0,0	0,0 0,0
Total - Other	0,0	0,0 0,0
Cooling with Electric Heat Pump		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of Cooling Demand (Project)	100%	kWh/kWh g/kWh
Heat source Electricity	0,0	0,0 0,0
Seasonal energy efficiency ratio cooling	0,0	0,0 0,0
Energy Demand Space Cooling	0,0	0,0 0,0
Heating, cooling, DHW, auxiliary electricity, lighting, electrical appliances	342,2	312,4 91,6
Total PE Value	312,4	kWh/(m ² a) 680
Total emissions CO₂-Equivalent	91,6	kg/(m ² a) (Yes/No)
Primary Energy Requirement		402 kWh/(m ² a) yes
Heating, DHW, auxiliary electricity (no lighting and electrical appliances)	321,7	259,2 77,6
Specific PE Demand - Mechanical System	259,2	kWh/(m ² a)
Total emissions CO₂-Equivalent	77,6	kg/(m ² a)
Solar electricity		PE-Value (Generation) CO ₂ -Emission Factor
Planned Annual Electricity Generation (Worksheet PV)	kWh/a	kWh/kWh g/kWh
Specific Demand		
PE Value: conservation by solar electricity		
Saved CO ₂ emissions through solar electricity		

EnerPHit planning:

HEAT PUMP

Building: School "Tzanko Diustabanov"-Block A	Building type: School
Climate: Велико Търново PHI	Treated Floor Area A_{TFA} : 1303 m ²
Covered fraction of space heating demand (PE Value worksheet)	
$Q_{H,W} + Q_{HL}$: (DHW+Distribution)	
$\eta_{Solar, H}$ (SolarDHW worksheet)	
$Q_{H,W} = Q_H * (1 - \eta_{Solar, H})$	
0% kWh/a	
326747 kWh/a	
0%	
0 kWh/a	
Covered Fraction of DHW Demand (PE Value worksheet)	
Q_{DHW} (DHW+Distribution)	
$\eta_{Solar, DHW}$ (SolarDHW worksheet)	
$Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$	
0% kWh/a	
49230 kWh/a	
0%	
0 kWh/a	
1 Heating & DHW	
Heating	
Selection of HP: None	Heat source:
Selection of distribution system	θ_{design} (DHW+Distribution)
Design distribution temperature	P_{nom}
Nominal Power of distribution system	P_{nom}
Radiator exponent	n
Heating storage	$U * A_{Storage}$
Specific heat losses storage	Inside or outside of the thermal envelope
Storage location in thermal envelope	(DHW+Distribution)
Room temperature (Storage location: outside of thermal envelope)	θ_{snk}
Sink temperature of heat pump for heating	θ_{snk}
No W/K	
Outside °C	
10,00 °C	
61,50 °C	
Ambient air °C	
60,00 °C	
Outside W/K	
2,5 °C	
10,00 °C	
Type of backup heater	Electr. immersion heater
$\Delta\theta$ of Electric flow type heater	5,0 K
In case of one heat pump with functionality: Heating & DHW	
Same heat pump's sink temperature for Heating and for DHW	
Heat Pump Priority	(Manufacturer, Techn. Data)
Yes	
DHW priority	
Control	
Control strategy	On / off
Heating	
Depth (horizontal / vertical) ground heat exchanger	z
Power of pump for ground heat exchanger	P_{pump}
50,0 m	
0,05 kW	

EnerPHit planning:

HEAT PUMP

0

Heating Heat pump: <input type="text"/>	Source: <input type="text"/>	θ_source °C	θ_sink °C	Heating capacity kW	COP																																																																																										
<table border="1"> <tr><td>Test Point 1</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 2</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 3</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 4</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 5</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 6</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 7</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 8</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 9</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 10</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 11</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 12</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 13</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 14</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 15</td><td></td><td></td><td></td><td></td><td></td></tr> </table>						Test Point 1						Test Point 2						Test Point 3						Test Point 4						Test Point 5						Test Point 6						Test Point 7						Test Point 8						Test Point 9						Test Point 10						Test Point 11						Test Point 12						Test Point 13						Test Point 14						Test Point 15					
Test Point 1																																																																																															
Test Point 2																																																																																															
Test Point 3																																																																																															
Test Point 4																																																																																															
Test Point 5																																																																																															
Test Point 6																																																																																															
Test Point 7																																																																																															
Test Point 8																																																																																															
Test Point 9																																																																																															
Test Point 10																																																																																															
Test Point 11																																																																																															
Test Point 12																																																																																															
Test Point 13																																																																																															
Test Point 14																																																																																															
Test Point 15																																																																																															
Temperature difference in sink		$\Delta\theta_{\text{Sink}}$	<input type="text"/> K																																																																																												

DHW Heat pump: <input type="text"/>	Source: <input type="text"/>	θ_source °C	θ_sink °C	Heating capacity kW	COP																																																																																										
<table border="1"> <tr><td>Test Point 1</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 2</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 3</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 4</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 5</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 6</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 7</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 8</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 9</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 10</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 11</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 12</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 13</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 14</td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>Test Point 15</td><td></td><td></td><td></td><td></td><td></td></tr> </table>						Test Point 1						Test Point 2						Test Point 3						Test Point 4						Test Point 5						Test Point 6						Test Point 7						Test Point 8						Test Point 9						Test Point 10						Test Point 11						Test Point 12						Test Point 13						Test Point 14						Test Point 15					
Test Point 1																																																																																															
Test Point 2																																																																																															
Test Point 3																																																																																															
Test Point 4																																																																																															
Test Point 5																																																																																															
Test Point 6																																																																																															
Test Point 7																																																																																															
Test Point 8																																																																																															
Test Point 9																																																																																															
Test Point 10																																																																																															
Test Point 11																																																																																															
Test Point 12																																																																																															
Test Point 13																																																																																															
Test Point 14																																																																																															
Test Point 15																																																																																															
Temperature difference in sink		$\Delta\theta_{\text{Sink}}$	<input type="text"/> K																																																																																												

Electrical energy consumption of pump (groundwater / ground)	Q_{pump}	<input type="text"/> kWh/a
Energy by Direct Electricity	$Q_{E,\text{dir}}$	<input type="text"/> kWh/a
Space heat supplied by HP	$Q_{\text{HP},\text{Heating}}$	<input type="text"/> kWh/a
Winter DHW supplied by HP	$Q_{\text{HP,DHW,Winter}}$	<input type="text"/> kWh/a
Summer DHW supplied by HP	$Q_{\text{HP,DHW,Summer}}$	<input type="text"/> kWh/a
Space heating supplied by HP without storage losses	$Q_{\text{HP,Heating}}$	<input type="text"/> kWh/a
Winter DHW supplied by HP without storage losses	$Q_{\text{HP,DHW,Winter}}$	<input type="text"/> kWh/a
Summer DHW supplied by HP without storage losses	$Q_{\text{HP,DHW,Summer}}$	<input type="text"/> kWh/a
Electrical consumption of HP	$Q_{e,\text{HP}}$	<input type="text"/> kWh/a
Seasonal performance factor of Heat Pump	SPF_{H-1}	1. HP: Heating or heating & DHW
Seasonal Performance factor of System	SPF_{H-3}	2. HP: Domestic hot water
Heat generation efficiency DHW & heating		<input type="text"/> kWh/(m²a)
Final electrical energy demand heat generation	Q_{final}	<input type="text"/> kg/a
Annual primary energy demand		<input type="text"/> kg/(m²a)
Annual CO ₂ -Equivalent Emissions		<input type="text"/>

EnerPHit planning:

HP Ground (Ground probes / Ground collectors)

<p>Building: School "Tzanko Diustabakov"-Block A</p> <p>Climate: Велико Търново PHI</p>	<p>Building type: School</p> <p>Treated Floor Area A_{TFA}: 1303 m²</p>																																
Ground probes																																	
<p>Probe field configuration (HP worksheet)</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td style="background-color: orange;">A</td><td>Individual probe</td></tr> <tr><td>H</td><td>50 m</td></tr> <tr><td>B</td><td>m</td></tr> <tr><td>z</td><td>25 m</td></tr> </table> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td style="background-color: orange;">A</td><td>Double-U</td></tr> <tr><td>R_b</td><td>m</td></tr> <tr><td>R_i</td><td>m</td></tr> <tr><td>R_a</td><td>m</td></tr> <tr><td>BU</td><td>m</td></tr> <tr><td>R_{i2}</td><td>m</td></tr> <tr><td>R_{o2}</td><td>m</td></tr> <tr><td>λ_R</td><td>W/(mK)</td></tr> <tr><td>λ_F</td><td>W/(mK)</td></tr> <tr><td>t_p</td><td>#DIV/0! d</td></tr> <tr><td>R_a</td><td>Km/W</td></tr> <tr><td>R_b</td><td>Km/W</td></tr> </table>		A	Individual probe	H	50 m	B	m	z	25 m	A	Double-U	R_b	m	R_i	m	R_a	m	BU	m	R_{i2}	m	R_{o2}	m	λ_R	W/(mK)	λ_F	W/(mK)	t_p	#DIV/0! d	R_a	Km/W	R_b	Km/W
A	Individual probe																																
H	50 m																																
B	m																																
z	25 m																																
A	Double-U																																
R_b	m																																
R_i	m																																
R_a	m																																
BU	m																																
R_{i2}	m																																
R_{o2}	m																																
λ_R	W/(mK)																																
λ_F	W/(mK)																																
t_p	#DIV/0! d																																
R_a	Km/W																																
R_b	Km/W																																
<p>Ground</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td style="background-color: orange;">J</td><td>0</td></tr> <tr><td>ρ_E</td><td>0 kg/m³</td></tr> <tr><td>c_{pE}</td><td>0 J/(kgK)</td></tr> <tr><td>λ_E</td><td>0,0 W/(mK)</td></tr> <tr><td>a_E</td><td>#DIV/0! m/s²</td></tr> <tr><td>ΔT_G</td><td>0,022 K/m</td></tr> </table>		J	0	ρ_E	0 kg/m ³	c_{pE}	0 J/(kgK)	λ_E	0,0 W/(mK)	a_E	#DIV/0! m/s ²	ΔT_G	0,022 K/m																				
J	0																																
ρ_E	0 kg/m ³																																
c_{pE}	0 J/(kgK)																																
λ_E	0,0 W/(mK)																																
a_E	#DIV/0! m/s ²																																
ΔT_G	0,022 K/m																																
<p>Brine</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td style="background-color: orange;">E</td><td>0</td></tr> <tr><td>ρ_s</td><td>0 kg/m³</td></tr> <tr><td>η_s</td><td>0 kg/(ms)</td></tr> <tr><td>c_{ps}</td><td>0 J/(kgK)</td></tr> <tr><td>λ_s</td><td>0 W/(mK)</td></tr> <tr><td>m_s</td><td>kg/s</td></tr> </table>		E	0	ρ_s	0 kg/m ³	η_s	0 kg/(ms)	c_{ps}	0 J/(kgK)	λ_s	0 W/(mK)	m_s	kg/s																				
E	0																																
ρ_s	0 kg/m ³																																
η_s	0 kg/(ms)																																
c_{ps}	0 J/(kgK)																																
λ_s	0 W/(mK)																																
m_s	kg/s																																
<p>Operation type</p> <p>Waste heat of active cooling to ground probe? Please check, if applicable.</p> <p><input checked="" type="checkbox"/></p>																																	
<p>Heat pump operation duration</p> <p>Specific heat extraction rate as an annual average</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td>q_{ex}</td><td>h/a</td></tr> <tr><td>H/R_b</td><td>W/m</td></tr> <tr><td colspan="2"><input checked="" type="checkbox"/> W/K</td></tr> </table>		q_{ex}	h/a	H/R_b	W/m	<input checked="" type="checkbox"/> W/K																											
q_{ex}	h/a																																
H/R_b	W/m																																
<input checked="" type="checkbox"/> W/K																																	
Ground collectors																																	
<table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td>r_i</td><td>0,013 m</td></tr> <tr><td>r_a</td><td>0,016 m</td></tr> <tr><td>λ_t</td><td>0,420 W/(mK)</td></tr> <tr><td>z_{pipe}</td><td>50 m</td></tr> <tr><td>z_{gw}</td><td>m</td></tr> <tr><td>D</td><td>0,4 m</td></tr> <tr><td>z_{gw}</td><td>80 m²</td></tr> <tr><td>Base area</td><td>20,1 m²</td></tr> <tr><td>Pipe outer surface</td><td></td></tr> <tr><td>Pipe length</td><td>200,0 m</td></tr> </table>		r_i	0,013 m	r_a	0,016 m	λ_t	0,420 W/(mK)	z_{pipe}	50 m	z_{gw}	m	D	0,4 m	z_{gw}	80 m ²	Base area	20,1 m ²	Pipe outer surface		Pipe length	200,0 m												
r_i	0,013 m																																
r_a	0,016 m																																
λ_t	0,420 W/(mK)																																
z_{pipe}	50 m																																
z_{gw}	m																																
D	0,4 m																																
z_{gw}	80 m ²																																
Base area	20,1 m ²																																
Pipe outer surface																																	
Pipe length	200,0 m																																
<p>Brine</p> <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td style="background-color: orange;">E</td><td>0</td></tr> <tr><td>ρ_s</td><td>0 kg/m³</td></tr> <tr><td>η_s</td><td>0 kg/(ms)</td></tr> <tr><td>c_{ps}</td><td>0 J/(kgK)</td></tr> <tr><td>λ_s</td><td>0 W/(mK)</td></tr> <tr><td>m_s</td><td>0,5 kg/s</td></tr> </table>		E	0	ρ_s	0 kg/m ³	η_s	0 kg/(ms)	c_{ps}	0 J/(kgK)	λ_s	0 W/(mK)	m_s	0,5 kg/s																				
E	0																																
ρ_s	0 kg/m ³																																
η_s	0 kg/(ms)																																
c_{ps}	0 J/(kgK)																																
λ_s	0 W/(mK)																																
m_s	0,5 kg/s																																
<p>Specific heat extraction rate</p> <p>q_{ex} W/m²</p> <p>$U * A$ W/K</p>																																	
Climate <table border="1" style="margin-left: auto; margin-right: auto;"> <tr><td>Period duration</td><td>365 d</td></tr> <tr><td>Average ground surface temperature</td><td>T_m0 11,7 °C</td></tr> <tr><td>Surface temperature amplitude</td><td>$T1$ 11,4 °C</td></tr> <tr><td>Phase shifting surface</td><td>t_{k2} 31 d</td></tr> </table>		Period duration	365 d	Average ground surface temperature	T_m0 11,7 °C	Surface temperature amplitude	$T1$ 11,4 °C	Phase shifting surface	t_{k2} 31 d																								
Period duration	365 d																																
Average ground surface temperature	T_m0 11,7 °C																																
Surface temperature amplitude	$T1$ 11,4 °C																																
Phase shifting surface	t_{k2} 31 d																																

HP Ground (Ground probes / Ground collectors)

Ground characteristics		Thermal conductivity [W/(mK)]	Density [kg/m³]	Heat capacity [J/(kg K)]	Heat capacity [MJ/(m³ K)]	Temperature conductivity [10⁻⁷ m²/s]	Source
A	Sand, 9% moisture	0,980	1440	1507	2,170	4,520	[Neiß 1977]
B	Sand, 13% moisture	1,500	1600	1800	2,880	5,210	[Neiß 1977]
C	Ground, coarse gravel	0,520	2000	1840	3,680	1,410	[VDI 1984]
D	Loam, 36% moisture	2,300	1650	2847	4,700	4,900	[Neiß 1977]
E	Clay	1,280	1500	880	1,320	9,700	[VDI 1984]
F	Clay / Silt	2,200	2550	882	2,250	9,780	[VDI 2000]
G	Slate	2,100	2700	870	2,350	8,940	[VDI 2000]
H	Silt	1,500	1920	2938	5,640	2,660	[ISO 13370]
I	Rock	3,500	2500	2500	6,250	5,600	[ISO 13370]
J							

Properties of the brine		Temperature [°C]	Density [kg/m³]	Heat capacity [J/(kg K)]	Thermal conductivity [W/(mK)]	Dynamic viscosity [kg/(ms)]
A	Ethylene glycol 25%	2	1052	3950	0,480	0,0052
B	Potassium carbonate	2	1265	2941	0,544	0,0031
C	Potassium formate	2	1226	3190	0,534	0,00237
D	Water	2	997	4190	0,590	0,001307
E						

Result ground probe calculation	
Month	Borehole Temperature °C
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	

COMPACT UNIT WITH EXHAUST AIR HEAT PUMP

Calculation based on measured values of the laboratory evaluation for component certification

Building: School "Tzanko Blustabakov"-Block A	Building type: School
Treated Floor Area A_{IFA} :	1303 m ²
Covered fraction of space heating demand (PE Value worksheet)	0%
Space Heating Demand + Distribution Losses $Q_{H,HP} + Q_{DHW}$ (DHW+Distribution)	326747 kWh
Solar contribution for space heating $\eta_{Solar, H}$ (SolarDHW worksheet)	0%
Effective Annual heating demand $Q_{H,W} = Q_H * (1 - \eta_{Solar, H})$	0 kWh
Covered Fraction of DHW Demand (PE Value worksheet)	0%
Total Heating Demand of DHW system Q_{DHW} (DHW+Distribution)	49863 kWh
Solar contribution for DHW $\eta_{Solar, DHW}$ (SolarDHW worksheet)	0%
Effective DHW Demand $Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$	0 kWh
Sort: AS LIST	
Go to list of compact units	
Invalid selection: for the time being compact HP units or combined HPs can ONLY be considered as single units, meaning they can ONLY be calculated with the 'Ventilation' worksheet (please check the	
Compact unit selection:	
Measured Values from Laboratory Test	
Ventilation	
Effective heat recovery efficiency η_{eff} (Test stand)	
Electric Efficiency (Test stand)	Wh/m ³
Heating	
Ambient Air Temperature T_{amb}	
Measured Thermal Power Heat Pump Heating $P_{HP,Heating}$	kW
Measured COP Heating $COP_{Heating}$	-
Domestic Hot Water	
Ambient Air Temperature T_{amb}	
Measured Thermal Power DHW Storage Heating-Up $P_{DHW, Heating-Up}$	kW
Measured Thermal Power DHW Storage Reload $P_{DHW, Reload}$	kW
Measured COP DHW Storage Heating-Up $COP_{DHW, Heating-Up}$	-
Measured COP DHW Storage Reload $COP_{DHW, Reload}$	-
Standby (inputs required only if different from storage reload)	
Ambient Air Temperature T_{amb}	
Measured Thermal Power Heat Pump Standby $P_{HP,Standby}$	kW
Measured COP Standby $COP_{Standby}$	-
Specific heat loss storage incl. connections $U * A_{Storage}$ (Test stand)	W/K
Average Storage Temperature in Standby Mode $T_{avg,Standby}$ (Test stand)	°C
Heat pump priority	
separate heat pumps	
Room temperature (°C) Av. Ambient Temp. Heating P. (°C) Av. Ground Temp (°C)	20 4 12
η^*_{SHX}	
Efficiency SHX Exhaust Air Mixing $\eta_{SHX,add}$ (Design Value)	0%
Heat Recovery Efficiency SHX Exhaust Air Mixing (if applicable) V_{add} (Test stand)	m ³ /h
Volume Flow Rate of Added Exhaust Air (if applicable)	
Hydraulic frost protection	
Heat supplied by direct electricity $Q_{E,dr}$	kWh/a
Space heat supplied by HP $Q_{HP,Heating}$	kWh/a
Winter DHW supplied by HP $Q_{HP,DHW,Water}$	0 kWh/a
Winter standby heat supplied by HP $Q_{HP,Standby,Water}$	kWh/a
Summer DHW supplied by HP $Q_{HP,DHW,Summer}$	0 kWh/a
Summer standby heat supplied by HP $Q_{HP,Standby,Summer}$	kWh/a
Performance Ratio of Heat Generator, DHW & Space Heating	
Annual Coefficient of Performance SPF_{H3}	
Final energy demand heat generation Q_{final}	kWh/a
Annual primary energy demand	kWh/(m ² a)
Annual CO ₂ -Equivalent Emissions	kg/a
	kg/(m ² a)
	kWh/a
	kWh/(m ² a)
	kg/a
	kg/(m ² a)

incl. DHW Connection for Washing Machines & Dishwashers

49863 kWh
0%
0 kWh

Building: School "Tzanko Diustabanov"-Block A		Building type: School																																																																																					
Treated Floor Area $A_{TF,A}$	1303 m ²																																																																																						
Covered fraction of space heating demand	(PE Value worksheet)	0%																																																																																					
Space Heating Demand + Distribution Losses	$Q_{HS} + Q_{DHW}$ (DHW+Distribution)	326747 kWh																																																																																					
Solar contribution for space heating	$\eta_{Solar, HS}$ (SolarDHW worksheet)	0%																																																																																					
Effective Annual heating demand	$Q_{HS,W} = Q_{HS} * (1 - \eta_{Solar, HS})$	0 kWh																																																																																					
Space Heating Demand without Distribution Losses	Q_{HS} (Verification sheet)	325942 kWh																																																																																					
Covered Fraction of DHW Demand	(PE Value worksheet)	0%																																																																																					
Total Heating Demand of DHW system	Q_{DHW} (DHW+Distribution)	49863 kWh																																																																																					
Solar contribution for DHW	$\eta_{Solar, DHW}$ (SolarDHW worksheet)	0%																																																																																					
Effective DHW Demand	$Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$	0 kWh																																																																																					
Additional selection only in the case of Natural Gas																																																																																							
Boiler Type	(Project)	None	Natural Gas																																																																																				
Primary Energy factor	(Data worksheet)		kWh/kWh																																																																																				
CO ₂ -Emissions Factor (CO ₂ -Equivalent)		250 g/kWh																																																																																					
Useful heat provided	Q_{Use}		kWh/a																																																																																				
Max. Heating Power Required for Heating the Building	P_{BH} (Heating load worksheet)	136.98 kW																																																																																					
Length of the Heating Period	t_{HP}	4540 h																																																																																					
Length of DHW Heating Period	t_{DHW}	8760 h																																																																																					
Use characteristic values entered (check if appropriate)?																																																																																							
<table border="1"> <thead> <tr> <th>Project Data</th> <th>Standard Values</th> <th>Input field</th> </tr> </thead> <tbody> <tr> <td>Design Output</td> <td>P_{Nom} (Rating Plate)</td> <td>137 kW</td> </tr> <tr> <td>Installation of Boiler (Outdoor: 0, Indoor: 1)</td> <td></td> <td>0</td> </tr> <tr> <td colspan="3">Input Values (Oil and Gas Boiler)</td> </tr> <tr> <td>Boiler Efficiency at 30% Load</td> <td>$\eta_{10\%}$ (Manufacturer)</td> <td>60%</td> </tr> <tr> <td>Boiler Efficiency at Nominal Output</td> <td>$\eta_{100\%}$ (Manufacturer)</td> <td>70%</td> </tr> <tr> <td>Standby Heat Loss Boiler at 70 °C</td> <td>$q_{B,70}$ (Manufacturer)</td> <td>0,4</td> </tr> <tr> <td>Average Return Temperature Measured at 30% Load</td> <td>$\vartheta_{30\%}$ (Manufacturer)</td> <td>60 °C</td> </tr> <tr> <td colspan="3">Input Values (Biomass Heat Generator)</td> </tr> <tr> <td>Efficiency of Heat Generator in Basic Cycle</td> <td>η_{GZ} (Manufacturer)</td> <td>60%</td> </tr> <tr> <td>Efficiency of Heat Generator in Constant Operation</td> <td>η_{SO} (Manufacturer)</td> <td>70%</td> </tr> <tr> <td>Average Fraction of Heat Output Released to Heating Circuit</td> <td>$Z_{IC,m}$ (Manufacturer)</td> <td>0,4</td> </tr> <tr> <td>Temperature Difference Betw. Power-On and Power-Off</td> <td>$\Delta\vartheta$ (Manufacturer)</td> <td>30 K</td> </tr> <tr> <td>For Interior Installations: Area of Mechanical Room</td> <td>$A_{Install}$ (Project)</td> <td>0 m²</td> </tr> <tr> <td>Useful heat output per basic cycle</td> <td>$Q_{N,GZ}$ (Manufacturer)</td> <td>205,5 kWh</td> </tr> <tr> <td>Average Power Output of the Heat Generator</td> <td>$Q_{N,m}$ (Manufacturer)</td> <td>137,0 kW</td> </tr> <tr> <td>Heat generator without pellets conveyor</td> <td></td> <td></td> </tr> <tr> <td>Unit with regulation (no fan / no starting aid)</td> <td></td> <td></td> </tr> <tr> <td>Heating energy demand for a basic machine cycle</td> <td>$Q_{HE,GZ}$ (Manufacturer)</td> <td>0 kWh</td> </tr> <tr> <td>Power consumption in steady state operation</td> <td>$P_{el,SB}$ (Manufacturer)</td> <td>0 W</td> </tr> <tr> <td>Utilisation factor heat generator heating run</td> <td>$h_{H,gK} = \eta_g * \eta_K$</td> <td>0%</td> </tr> <tr> <td>Utilisation factor heat generator DHW run</td> <td>$h_{TW,gK} = \eta_{100\%} / \eta_{g,TW}$</td> <td>0%</td> </tr> <tr> <td>Utilisation factor heat generator DHW & heating</td> <td>h_{gK}</td> <td>0%</td> </tr> <tr> <td>Final energy demand space heating</td> <td>$Q_{Final, HE} = Q_{HS,W} * \epsilon_{H,gK}$</td> <td>0 kWh/a</td> </tr> <tr> <td>Final energy demand DHW</td> <td>$Q_{Final, DHW} = Q_{DHW,W} * \epsilon_{TW,gK}$</td> <td>0 kWh/(m²a)</td> </tr> <tr> <td>Total final energy demand</td> <td>$Q_{Final} = Q_{Final,DHW} + Q_{Final,HE}$</td> <td>0,0 kg/a</td> </tr> <tr> <td>Annual primary energy demand</td> <td></td> <td>0 kg/(m²a)</td> </tr> <tr> <td>Annual CO₂-Equivalent Emissions</td> <td></td> <td>0,0 kg/a</td> </tr> </tbody> </table>				Project Data	Standard Values	Input field	Design Output	P_{Nom} (Rating Plate)	137 kW	Installation of Boiler (Outdoor: 0, Indoor: 1)		0	Input Values (Oil and Gas Boiler)			Boiler Efficiency at 30% Load	$\eta_{10\%}$ (Manufacturer)	60%	Boiler Efficiency at Nominal Output	$\eta_{100\%}$ (Manufacturer)	70%	Standby Heat Loss Boiler at 70 °C	$q_{B,70}$ (Manufacturer)	0,4	Average Return Temperature Measured at 30% Load	$\vartheta_{30\%}$ (Manufacturer)	60 °C	Input Values (Biomass Heat Generator)			Efficiency of Heat Generator in Basic Cycle	η_{GZ} (Manufacturer)	60%	Efficiency of Heat Generator in Constant Operation	η_{SO} (Manufacturer)	70%	Average Fraction of Heat Output Released to Heating Circuit	$Z_{IC,m}$ (Manufacturer)	0,4	Temperature Difference Betw. Power-On and Power-Off	$\Delta\vartheta$ (Manufacturer)	30 K	For Interior Installations: Area of Mechanical Room	$A_{Install}$ (Project)	0 m ²	Useful heat output per basic cycle	$Q_{N,GZ}$ (Manufacturer)	205,5 kWh	Average Power Output of the Heat Generator	$Q_{N,m}$ (Manufacturer)	137,0 kW	Heat generator without pellets conveyor			Unit with regulation (no fan / no starting aid)			Heating energy demand for a basic machine cycle	$Q_{HE,GZ}$ (Manufacturer)	0 kWh	Power consumption in steady state operation	$P_{el,SB}$ (Manufacturer)	0 W	Utilisation factor heat generator heating run	$h_{H,gK} = \eta_g * \eta_K$	0%	Utilisation factor heat generator DHW run	$h_{TW,gK} = \eta_{100\%} / \eta_{g,TW}$	0%	Utilisation factor heat generator DHW & heating	h_{gK}	0%	Final energy demand space heating	$Q_{Final, HE} = Q_{HS,W} * \epsilon_{H,gK}$	0 kWh/a	Final energy demand DHW	$Q_{Final, DHW} = Q_{DHW,W} * \epsilon_{TW,gK}$	0 kWh/(m ² a)	Total final energy demand	$Q_{Final} = Q_{Final,DHW} + Q_{Final,HE}$	0,0 kg/a	Annual primary energy demand		0 kg/(m ² a)	Annual CO ₂ -Equivalent Emissions		0,0 kg/a
Project Data	Standard Values	Input field																																																																																					
Design Output	P_{Nom} (Rating Plate)	137 kW																																																																																					
Installation of Boiler (Outdoor: 0, Indoor: 1)		0																																																																																					
Input Values (Oil and Gas Boiler)																																																																																							
Boiler Efficiency at 30% Load	$\eta_{10\%}$ (Manufacturer)	60%																																																																																					
Boiler Efficiency at Nominal Output	$\eta_{100\%}$ (Manufacturer)	70%																																																																																					
Standby Heat Loss Boiler at 70 °C	$q_{B,70}$ (Manufacturer)	0,4																																																																																					
Average Return Temperature Measured at 30% Load	$\vartheta_{30\%}$ (Manufacturer)	60 °C																																																																																					
Input Values (Biomass Heat Generator)																																																																																							
Efficiency of Heat Generator in Basic Cycle	η_{GZ} (Manufacturer)	60%																																																																																					
Efficiency of Heat Generator in Constant Operation	η_{SO} (Manufacturer)	70%																																																																																					
Average Fraction of Heat Output Released to Heating Circuit	$Z_{IC,m}$ (Manufacturer)	0,4																																																																																					
Temperature Difference Betw. Power-On and Power-Off	$\Delta\vartheta$ (Manufacturer)	30 K																																																																																					
For Interior Installations: Area of Mechanical Room	$A_{Install}$ (Project)	0 m ²																																																																																					
Useful heat output per basic cycle	$Q_{N,GZ}$ (Manufacturer)	205,5 kWh																																																																																					
Average Power Output of the Heat Generator	$Q_{N,m}$ (Manufacturer)	137,0 kW																																																																																					
Heat generator without pellets conveyor																																																																																							
Unit with regulation (no fan / no starting aid)																																																																																							
Heating energy demand for a basic machine cycle	$Q_{HE,GZ}$ (Manufacturer)	0 kWh																																																																																					
Power consumption in steady state operation	$P_{el,SB}$ (Manufacturer)	0 W																																																																																					
Utilisation factor heat generator heating run	$h_{H,gK} = \eta_g * \eta_K$	0%																																																																																					
Utilisation factor heat generator DHW run	$h_{TW,gK} = \eta_{100\%} / \eta_{g,TW}$	0%																																																																																					
Utilisation factor heat generator DHW & heating	h_{gK}	0%																																																																																					
Final energy demand space heating	$Q_{Final, HE} = Q_{HS,W} * \epsilon_{H,gK}$	0 kWh/a																																																																																					
Final energy demand DHW	$Q_{Final, DHW} = Q_{DHW,W} * \epsilon_{TW,gK}$	0 kWh/(m ² a)																																																																																					
Total final energy demand	$Q_{Final} = Q_{Final,DHW} + Q_{Final,HE}$	0,0 kg/a																																																																																					
Annual primary energy demand		0 kg/(m ² a)																																																																																					
Annual CO ₂ -Equivalent Emissions		0,0 kg/a																																																																																					

Building: School "Tzanko Diustabakov"-Block A	Building type: School
	Treated Floor Area A_{TFP} : 1303 m ²
Covered fraction of space heating demand	(PE Value worksheet)
Annual heating demand kWh/a	Q_H (DHW+Distribution)
Solar contribution for space heating	$\eta_{Solar, H}$ (SolarDHW worksheet)
Effective Annual heating demand	$Q_{H,W} = Q_H * (1 - \eta_{Solar, H})$ 326747 kWh
Covered Fraction of DHW Demand	(PE Value worksheet)
DHW Demand	Q_{DHW} (DHW+Distribution)
Solar contribution for DHW	$\eta_{Solar, DHW}$ (SolarDHW worksheet)
Effective DHW Demand	$Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$ 49863 kWh
Heat source	Hard Coal COS 70% PHC
Primary Energy factor	(Data worksheet) 0,8 kWh/kWh
CO ₂ -Emissions factor (CO ₂ -Equivalent)	(Data worksheet) 240 g/kWh
Utilisation factor of heat transfer station	ha,HX 111%
Final energy demand heat generation	418037 kWh/a
Annual primary energy demand	320,7 kWh/(m ² a)
Annual CO ₂ -Equivalent Emissions	334430 kg/a
	256,6 kg/(m ² a)
	100329 kg/a
	77,0 kg/(m ² a)

Table of Primary Energy Factors and CO₂-Equivalent Emissions Factors of Various Energy Carriers

Energy Type		Energy Carrier	PE (non-regenerative) kWh _{Prim} /kWh _{Final}	CO ₂ GEMIS 3.0 kg/kWh _{Final}
Fuel Source	1	None		
	2	Oil	1,1	0,31
	3	Natural Gas	1,1	0,25
	4	LPG	1,1	0,27
	5	Hard Coal	1,1	0,44
	6	Wood	0,2	0,05
Electricity	7	Electricity-Mix	2,6	0,68
	8	Electricity from Photovoltaics	0,7	0,25
District Heat	1	None	0	0
	2	Hard Coal CGS 70% PHC	0,8	0,24
	3	Hard Coal CGS 35% PHC	1,1	0,32
	4	Hard Coal HS 0% PHC	1,5	0,41
	5	Gas CGS 70% PHC	0,7	-0,07
	6	Gas CGS 35% PHC	1,1	0,13
Gas CGS	7	Gas HS 0% PHC	1,5	0,32
	8	Oil CGS 70% PHC	0,8	0,1
	9	Oil CGS 35% PHC	1,1	0,25
	10	Oil HS 0% PHC	1,5	0,41

Data Source: DIN V 4701-10/GEMIS 4.14

Heat Generator	Selection of gas type
Nr.	Type
1	None
2	Improved gas condensing boiler
3	Improved oil condensing boiler
4	Condensing boiler gas
5	Condensing boiler oil
6	Low Temperature Boiler Gas
7	Low Temperature Boiler Oil
8	Wood Log Burning (Direct and Indirect Release of Heat)
9	Wood Pellet Burning (Direct and Indirect Release of Heat)
10	Wood Pellet Burning (Only Indirect Release of Heat)
11	Reserve
	Nr.
	Type
	1 Natural Gas
	2 LPG
	3

Dishwashing	Washing
1	DHW Connection
2	Cold water connection

Clothes Drying	Availability Electricity	Availability Evaporation
1 Clothesline	1	1
2 Drying Closet (cold!)	1	1
3 Drying Closet (cold!) in Exhaust Air	0,9	0,9
4 Condensation Dryer	0,7	0
5 Electric Exhaust Air Dryer	1	1
6 Gas Exhaust Air Dryer	1	1

Cooking	Electric Fraction	Primärenergiefaktor	CO ₂ factor
1 Electricity	100%	2,6	0,68
2 Natural Gas	0%	1,1	0,25
3 LPG	0%	1,1	0,27