

BRIEF INSTRUCTIONS

Place your mouse here to see the PHPP help.

If no help appears when the mouse passes over cell B4, you can activate it by going into the Menu Bar Tools/Options/View, and under "Comments", select "Comment Indicator Only".

Passive House Verification: Meaning of Field Formats

Example	Field Format	Meaning
78,8	Courier New, blue, bold on yellow background	Input Field: Please enter the required value here
01ud triple-low-e-cr08	Arial Narrow, blue, bold on brown	Data entry field with drop down list
6619	Arial, black, standard on white background	Calculation field; please do not change
78,8	Courier New, purple, bold on white background	Field with references to another sheet - should not be changed.
126,0	Arial, black, large & bold on green background	Important result

Passive House Planning: Worksheet Directory

Worksheet name (to show/hide worksheets please use the separate 'Profile settings' tool)	Function	Brief Description	Required for the certification?
Verification	Building data; summary of results	Building description, selection of the calculation method, summary of results	yes
Overview	Overview of the specific data of the project entered	In-depth project description, overview of all results and input variables, specific details on building envelope, building services systems as well as general information.	no
Variants	Variant calculation	Input parameters and results for the variant calculations. Predefined fields for frequent entries, as well as user-defined area.	no
Comparison	Comparison between two variants	Comparison between two variants under the energy demand and economic viability perspective. Input of comparison configurations.	no
Climate	Climate Region Selection or Definition of User Data	Climate data for: Annual Heating, Windows, Heating Load, Heating, Summer, Cooling, Cooling Units, Cooling Load worksheets	yes
U-Values	Calculation of Standard building assembly U-Values	Heat transmission coefficient calculations in accordance with DIN EN ISO 6946.	yes
Areas	Areas summary	Building assembly Areas, Thermal Bridges, Treated Floor Area. Use exterior dimension references!	yes
Ground	Calculation of reduction factors against ground	More precise calculation of heat losses through the ground	if applicable
Components	Building component database	Database of certified, Passive House suitable components and entry of user-defined components	yes
Windows	Uw-Value Determination	Input of geometry, orientation, frame lengths, frame widths, Ug and U-values of the frame, and the thermal bridge heat loss coefficients of the connections; from these inputs, determine Uw and total radiation.	yes
Shading	Determination of shading coefficients	Input of shading parameters, e.g. balcony, neighbouring building, window reveal and calculating the shading factors	yes
Ventilation	Air Flow Rates, Exhaust/Supply Air Balancing, Pressurization Test Results	Sizing the ventilation system from extract and supply air requirements, infiltration air change rate and actual efficiency of heat recovery, input of pressurization test results	yes
Additional Vent	Design and planning of ventilation systems with diverse ventilation units	Extension of the Ventilation worksheet for dimensioning air flows, for special building uses and systems with various ventilation units	if used
Annual heating	Annual heating demand / Annual Method	Calculation of the annual space heating demand according to the energy balance method following EN 13790: Transmission + Ventilation · h (Solar Gains + Internal Gains)	no
Heating	Space heating demand calculation Monthly method according to EN 13790	Calculation procedure for the monthly method following EN 13790. Make appropriate selection in the Verification worksheet, if calculations should be performed following this procedure	yes
Heating Load	Building Heating Load Calculation	Calculation of the nominal heating load using a balance procedure for the design day: max transmission + max ventilation · η (minimum solar gains + internal heat gains)	yes
SummerVent	Determination of Summer Ventilation	Ventilation in cooling case and estimation of air flow rates for natural ventilation during the summer period	yes
Summer	Assessment of Summer Climate	Calculation of the frequency of overheating as a measure of summer comfort	yes
Cooling	Monthly Method for Cooling Demand	Annual useful cooling demand calculation	if present
Cooling units	Latent Cooling Energy	Calculation of the energy demand for dehumidification and choice of cooling method	if present
Cooling load	Building Cooling Load Calculation	Calculation of the daily average cooling load of the building	no
DHW+Distribution	Distribution losses; DHW Requirement and Losses	Heat loss calculation of the distribution systems (heating; DHW); calculation of the useful heat requirement of DHW and storage losses	yes
SolarDHW	Solar DHW Heating	Solar contribution calculation for DHW and space heating contribution	if solar panels are used
PV	Electricity generation by photovoltaic	Electricity generation calculation of PV system	no
Electricity	Electricity Demand for Dwellings	Calculation of the electricity demand of Passive Houses with residential use	yes
Use non-res	Patterns of non-residential Utilisation	Input or selection of utilisation patterns for planning of electricity demand and internal heat gains	no
Electricity non-res	Electricity Demand for non-residential Use	Calculation of the electricity demand for lighting, electric devices and kitchens for non-residential buildings	no
Aux Electricity	Auxiliary Electricity Demand	Calculation of auxiliary electricity and corresponding primary energy demand	yes
IG	Internal Heat Gains in Dwellings	Calculation of the internal heat gains based on the Electricity and Aux Electricity sheets.	no
IG non-res	Internal Heat Gains for non-residential Use	Calculation of the internal heat gains for non-residential buildings based on the Electricity non-res worksheet and the occupancy	no
PE-Value	Specific Primary Energy and CO ₂ Demands	Selection of heat generators, calculation of the specific primary energy and CO ₂ demands from the present results	yes
Compact	Efficiency of Heat Generator Compact Heat Pump Unit	Calculation of combined heat generation efficiency for heating and DHW only by means of a electric heat pump compact unit, considering the specific project boundary conditions.	if present
HP	Heat generation efficiency of the heat pump	Calculation of heat generation efficiency for one to two electric-run heat pumps, considering the specific project boundary conditions.	if present
HP Ground	Ground probe or ground collector in combination with a heat pump	Heat source calculation for a ground probe or horizontal subsoil heat exchanger for ground-coupled heat pumps, considering the specific project boundary conditions.	if present
Boiler	Efficiency of Heat Generator Boiler	For the calculation of the efficiency of heat generation with standard boilers (NT and calorific boilers) for the project given boundary conditions.	if present
District Heating	District Heat Transfer Station	Calculation of the final and primary energy demands (heat)	if present
Data	Database	Table of primary energy factors following [GEMIS] and database of EnEV (German energy efficiency regulation).	no

EnerPHit verification



Building:	Primary School 3 "Tzanko Diustabakov" -		
Street:	25 Hristo Smirnenski blv.		
Postcode/City:	Gabrovo		
Country:	Bulgaria		
Building type:	School		
Climate:	Велико Търново PHI		
Altitude of building site (in [m] above sea level):	382		
Home owner/client:	Municipality of Gabrovo		
Street:	3 Vazrazhdane square		
Postcode/City:	Gabrovo		
Architecture:			
Street:			
Postcode/City:			
Energy consulting:			
Street:			
Postcode/City:			
Year of Construction:	2014	Interior temperature winter [C°]	18,0
Number of dwelling units:	1	Internal heat gains winter [W/m²]	2,8
Number of Occupants:	50,0	Interior temp. summer [C°]	24,0
Exterior vol. V _e :	6224,4 m³	IHG summer [W/m²]	2,8
		Spec. capacity [Wh/K per m² TFA]	204
		Mechanical cooling:	x

Specific building demands with reference to the treated floor area					
		Treated floor area	848,4 m²	Requirements	Fulfilled?*
Space heating	Annual heating demand	46 kWh/(m²a)	25 kWh/(m²a)	no	-
	Heating load	26 W/m²	-	-	-
Space cooling	Overall specific space cooling demand	0 kWh/(m²a)	-	-	-
	Cooling load	14 W/m²	-	-	-
	Frequency of overheating (> 24 °C)	%	-	-	-
Primary Energy	Heating, cooling, domestic hot water, auxiliary electricity, lighting, plant	128 kWh/(m²a)	158 kWh/(m²a)	yes	-
	DHW, space heating and auxiliary electricity	100 kWh/(m²a)	-	-	-
	Specific primary energy reduction through solar electricity	kWh/(m²a)	-	-	-
Airtightness	Pressurization test result n ₅₀	2,0 1/h	1 1/h	no	-

* empty field: data missing; -: no requirement

I confirm that the values given herein have been determined following the PHPP methodology and were determined based on the characteristics of the building. The PHPP calculations are attached to this application.		EnerPHit building retrofit (acc. to heating demand)?	no
Name:		Company:	
Surname:		Issued on:	
			Signature

Basic data		
Building, name of the object	Primary School 3 "Tzanko Diustabanov" - Section 25 Hristo Smirnenski blv.	
Street:	Gabrovo	
Postcode/City:	Bulgaria	
Country:		
Building type:		
Climate: region / climate data set	User Data	
Climate: degree days / altitude	74	kKh/a 382
Building type / building status		
Context of urban development		
Building type / construction		
Building category, in terms of energy		
Year of construction / year of construction of existing building	2014	
Amount of dwelling units for residential use / non-residential use	Dwelling units	
Number of occupants standard / planned	8	
Standard / design occupancy rate	50	
Home owner / client	m²/P	
Architect	17	
Building services		
PHP/Energy balance		
Building physics		
Structural engineering		
Contractor / tradesperson / other (max. 5000 characters)		
Interior temperatures winter/summer	18	°C 24
IHG winter / summer	2,8	W/m ² 2,8
Type of certification	EnerPHit building retrofit (acc. to heating demand)	
Project certification / Certificate ID		
Certification body		
PHPPEdition / PHPP-registration number	Version 9.0 beta	
Characteristic value according to EnerPHit verification		
Treated floor area A _{TFA} / exterior volume V _e	848,4	m ² 6224,4
Space heating demand	Specific Demand	
Heating load residential	46	kWh/(m ² a)
Heating load Non-residential	26	kWh/(m ² a)
Frequency of overheating		
Overall specific space cooling demand	0	%
Cooling load residential	0	kWh/(m ² a)
Cooling load non-residential	26	kWh/(m ² a)
Airtightness pressure air exchange rate test n ₅₀	2,0	1/h
Total PE Value	128	kWh/(m ² a) 158
Heating, cooling, DHW, auxiliary electricity, lighting, electrical appliances		
Specific PE Demand - Mechanical System / CO ₂ -Equivalent	100	kWh/(m ² a) 27
Heating, DHW, auxiliary electricity (no lighting and electrical appliances)		
Solar power: Primary energy savings / CO ₂ emissions		
Requirement		
25		
-		
1		
158		
27		

Average building quality		Specific Demand	Requirement
Average U-value of external insulation to outside air	0,12	W/(m²K)	-
Average U-value of external insulation to ground	1,98	W/(m²K)	-
Average U-value interior insulation to outside air	0,11	W/(m²K)	-
Average U-value interior insulation to ground		W/(m²K)	-
Average U-value of thermal bridges ΔU	0,01	W/(m²K)	-
Average U-value windows	2,64	W/(m²K)	-
Average U-value of exterior doors	0,80	W/(m²K)	-
Ventilation system eff. heat recovery efficiency	81,00	%	-

Building envelope and site			
Building envelope area A _{total} / treated floor area A _{TFA}	2606	m ²	848
A/V-ratio / Envelope area use (A _{total} /A _{TFA})	0,42		3,07
Window area / Window area percentage	198	m ²	7,6%
Specific solar aperture / Passive solar heating mode	1,6%		11409
Building site area / built-up area		m ²	
Gross floor area BGF / Gross external volume BRI		m ²	
Floor space ratio / Amount of complete storeys			

Building description (max.5000 characters)

Opaque building components		
Exterior wall: U-value (average value) / area	0,13	W/(m²K)
Standard exterior wall: U-value / thickness		
Standard exterior wall: total area / area fraction		
Standard exterior wall: name / certified?		
Standard exterior wall: short description (materials, manufacturer, product name, special features)		
Exterior wall against ground: U-value (average value) / area		W/(m²K)
Standard exterior wall against ground: U-value / thickness		
Standard exterior wall against ground: area / area fraction		
Standard exterior wall against ground: name / certified?		
Standard exterior wall against ground: short description (materials, manufacturer, product name, special features)		
Roof / top floor ceiling: U-value (average value) / area	0,11	W/(m²K)
Standard roof / top floor ceiling: U-value / thickness		
Standard roof / top floor ceiling: area / area percentage		
Standard roof / top floor ceiling: name / certified?		
Standard roof / top floor ceiling: short description (materials, manufacturer, product name, special features)		

Floor slab / basement ceiling: U-value (average value) / area	1,98	W/(m ² K)	910,21
Standard floor slab / basement ceiling: U-value / thickness			0,0
Floor slab / basement ceiling standard: area / area fraction			
Standard floor slab / basement ceiling: name / certified?			
Standard floor slab / basement ceiling: short description (materials, manufacturer, product name, special features)			
 Thermal bridges: Y-value (Average value) / length	0,037	W/(mK)	327,07
Thermal bridge free limit value / Complied?	0,01	W/(mK)	no
Thermal bridges: short description (max.5000 letters) (additional notices, manufacturer, product name, materials, others)			

Windows / doors / shading systems			
windows/facades: U-value (average value) / area	2,64	W/(m²K)	197,98
window/facade frames: U-value (average value) / area	2,25	W/(m²K)	95,25
Glazing: U-value (Average value) / areas	2,55	W/(m²K)	102,73
Ψ-Value Glazing edge (average) / Ψ-Value Installation (average)	0,039	W/(mK)	0,076
Standard window frame: U-value / frame width		W/(m²K)	
Standard window frame: window area / area percentage		W/(m²K)	
Standard window frame: glass edge Ψ-value / installation Ψ-value		W/(mK)	
Standard window frame: name, certified?			
Standard window frame: Short description (materials, manufacturer, product name, installation)			
Standard curtain wall facade: U-value / Frame width		W/(m²K)	
Standard curtain wall facade: Facade area / Total area percentage		W/(m²K)	
Standard curtain wall facade: Ψ-value glazing edge / Ψ-value installation		W/(mK)	
Standard curtain wall facade: Description / Certified?			
Standard curtain wall facade: short description (materials, manufacturer, product name, installation)			
Standard glazing: U-value / g-value		W/(m²K)	
Standard glazing: Facade area / Area ratio		W/(m²K)	
Standard glazing: Description / Certified?			
Standard glazing: short description (description, manufacturer, product name, installation)			
Standard glazing 2: U-value / g-value		W/(m²K)	
Standard glazing 2: Facade area / Area percentage		W/(m²K)	
Standard glazing 2: Description / Certified?			
Standard glazing 2: short description (description, manufacturer, product name, installation)			
Roof lights / light domes: U-value / frame width		W/(m²K)	
Roof lights / light domes: window area / area section		W/(m²K)	
Roof lights / light domes: glazing U-value / g-value		W/(m²K)	
Roof lights / light domes: Y-value glass edge / Installation Y-value		W/(mK)	
Roof lights / light domes: name / certified?			
Roof lights / light domes: short description (materials, manufacturer, product name, installation situation)			
Exterior door: U-value (average value) / Area	0,80	W/(m²K)	3,00
Standard exterior door: door U-value / door U-value installed		W/(m²K)	
Standard exterior door: frame U-value / door leaf U-value		W/(m²K)	
Standard exterior door: door leaf thickness / frame width		mm	
Standard exterior door: panel border Y-value / installation Y-value		W/(mK)	
Standard exterior door: Name / certified?			
Standard exterior door: Short description (materials, manufacturer, product name, installation situation)			
Temporary sun protection: Type / Add. Reduction factor		W/(m²K)	7,29
Temporary sun protection: Area / Area ratio		W/(m²K)	
Shading reduction factors: orientation			
North	68	%	78
East	70	%	39
South	67	%	41
West	60	%	48
Horizontal	100	%	100
Reduction factor winter			Summer reduction factor

Ventilation		
Ventilation: Type of ventilation	Balanced PH-Ventilation with HR	
Calculated supply air demand / supply air per person	1500	m³/h
Calculated extract air demand / Amount extract air rooms	0	m³/h
Design air flow rate (maximum) / Average value reference to maximum		m³/h
Average flow rate / Average air exchange		m³/h
Airtightness test pressure at n_{50} / Air permeability q_{50}	2,00	1/h
Net air flow for pressurization test / Infiltration flow $n_{V,Rest}$		m³
Ventilation unit: Description / Certified?		
Ventilation system: effective heat recovery efficiency / electrical efficiency		%
Ventilation system: Description (type of heat recovery, manufacturer, product name)		
Ventilation system: installation site / Temperature of mechanical services room	Inside the thermal envelope	
Nominal width exterior or supply air / exhaust or extract air ducts		mm
Conductance ambient- or supply air duct / exhaust- or extract air duct		W/(mK)
Length ambient- or supply air duct / exhaust- or extract air duct		m
SHX: efficiency / effective heat recovery efficiency		%
HE defrosting / Defrosting at a minimum temperature of		0,00
Effective energy recovery efficiency ventilation / Humidity recovery	yes	2,00
		0,0
Ventilation system: Short description (installation site, ducts, silencers, others)		

Summer ventilation		
Summer base ventilation: ventilation type		
Air exchange via ventilation system with supply air:	Without heat recovery	0,63
Air exchange via extract air system		0,00
Window ventilation air exchange		0,19
Night summer ventilation: Type of ventilation		
Night air exchange Window Night Ventilation, Manual		0,19
Night air exchange mechanical, automatically Controlled ventilation	Humidity differenceregulated	0,63
Summer ventilation: short description (window opening profiles, night ventilation concepts, others)		

Cooling		
Max. indoor absolute humidity / Internal humidity sources	12,0	g/kg
Mechanical cooling: sensible / latent	0,3	kWh/(m²a)
Mechanical cooling: Applied cooling units		
Supply Air Cooling: max. cooling capacity / energy efficiency ratio	5,0	kW
Supply Air Cooling:cyclical operation		kW
	0,0	
		kWh/(m²a)
Mechanical cooling: Average annual coefficient of performance / Electricity demand	2,0	
Mechanical cooling: Short description (unit, manufacturer, product name, installation site, installation)		

Heating and DHW			
DHW Demand	30,11	kWh/(m ² a)	25541
Annual heating demand	46,47	kWh/(m ² a)	39424
Direct electricity: contribution to space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
Direct electric heating / domestic hot water			
Final energy demand		kWh/(m ² a)	
Direct electricity: short description (description, manufacturer, product name)			
Heat pump: covered fraction of space heating / domestic hot water	70	%	60
PE value energy carrier / CO ₂ -emission factor	2,6	kWh/kWh	680
COP heat pump for heating / heat pump for DHW	1,9		
Final energy demand	23,5	kWh/(m ² a)	
Compact unit: Short description (description, manufacturer, product name)			
Compact unit: covered fraction of space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
COP heat pump for heating / heat pump for DHW			
Final energy demand		kWh/(m ² a)	
Compact unit: Short description (description, manufacturer, product name)			
Boiler: covered fraction of space heating / domestic hot water		%	
PE value energy carrier / CO ₂ -emission factor		kWh/kWh	
Heat generator: building type / COP			
Final energy demand		kWh/(m ² a)	
Boiler: short description (description, manufacturer, product name)			
District heating: Covered fraction of space heating / domestic hot water	30	%	40
PE value energy carrier / CO ₂ -emission factor	0,8	kWh/kWh	240
Heat source / Performance of heat generator	Hard Coal CGS 70% PHC		105,0
Final energy demand	20,4	kWh/(m ² a)	
Compact unit: Short description (description, manufacturer, product name)			
Solarthermics			
Collector	7 Improved flat plate collector		
Collector area / Specific collector area	28,00	m ²	0,56
Deviation from north / Angle of inclination from the horizontal	180	°	26
Solarthermics: Short description (description, manufacturer, product name, installation location)			
Solar contribution to DHW	11,65	kWh/(m ² a)	39
Solar contribution to space heating	6,25	kWh/(m ² a)	13
Solar contribution total	17,90	kWh/(m ² a)	23
Solar Storage	9 Simple solar storage		
PHOTOVOLTAIC			
Module technology	Amorph-Si		
Nominal current / Nominal voltage		A	
Nominal power / Number of modules	0,00	Wp	
Deviation from north / Angle of inclination from the horizontal		°	
Solarthermics: Short description (description, manufacturer, product name, installation location)			
Annual yield of PV modules		kWh/(m ² a)	

Aux. electricity / Household electricity		
Aux Electricity		
Ventilation units / Electricity demand		5870
Heating system Devices / Electricity demand		973
DHW-system units / Electricity demand		321
Aux. Electricity solar devices / electr. demand		227
Total aux. Electricity	8,71	kWh/(m²a)
		7391,52
Household electricity		
Dishwasher / useful energy demand		3575
Washing machine units / Energy demand		3135
Clothes dryer unit / Energy demand		8728
Refrigerator, Freezer or combination unit / Useful energy demand		574
Cooking unit / energy demand		6250
Lighting		8700
Consumer Electronics		2200
Small appliances, etc.		2500
Other		
Total household electricity	42,03	kWh/(m²a)
		35661,91
Economic data		
Total gross construction costs / contained VAT	€	
Building costs (cost group 300+400) / (cost group 200-700)	€	
Total gross construction costs per m ² BGF / per m ³ BRI	€/m ²	
Explanation building costs		
Fostering (Passivhaus, refurbishment, etc.)		
Explanation fostering		
Other		
Ecological aspects: rainwater utilization, etc.		
Material used: Regional products / Natural products		
Special features: first project in the country / first project used as		
Building awards		
Research project / funded project		
Description of research / funded project		
Other		

EnerPHit planning:

select active variants
>>

Results	Units
Annual heating demand	kwh/(m ² a)
Heating Load	W/m ²
Overall specific space cooling demand	kwh/(m ² a)
Cooling load	W/m ²
Frequency of overheating	%
Total primary energy demand	kwh/(m ² a)
Certifiable as EnerPHit building retrofit (acc. to heating demand)?	yes / no
<< User defined	Units

Input variables	Units
<< Assembly layers ('U-value')	
<< Radiation balance ('Areas')	
<< Thermal bridges ('Areas')	
<< Glazing and frames ('Window', 'Shading')	
<< Ventilation ('Ventilation', 'SummVent')	
<< Heat generator ('PE-value')	

Direct electricity Heat pump Passive House compact unit with supply air ventilation pump	Fraction of annual heating demand Fraction of domestic warm water
	Selection HP Fraction of annual heating demand Fraction of domestic warm water
	Selection of device Fraction of annual heating demand Fraction of domestic warm water

Boiler (gas, oil & wood)	Selection of boiler
	Fraction of annual heating demand
	Fraction of domestic warm water
District Heating	Selection of heat source
	Fraction of annual heating demand
	Fraction of domestic warm water
Other	Efficiency
	Fraction of annual heating demand
	Fraction of domestic warm water

<< Compressor cooling unit ('Cooling units')

<< User defined

	Description	Units
1	Door U-Value	W/m2K
2	Heat Loss Coefficient heating	W/mK
3	Heat Loss Coefficient DHW	W/mK
4	Average Heat Released from storage	W
5	Solar Collector Area	m2
6	Utilisation factor of heat transfer station	%
7	Summer Ventilation, additional ventilation summer	0/1
8	Defroster HX	0/1
9	Lighting (Changing MHL to LED)	W/m2
10	Mechanical cooling:	x
11	Perimeter Insulation Width/Depth	m
12	Perimeter Insulation Thickness	m
13		
14		
15		
16		
17		
18		
19		
20		
21		
22		
23		
24		
25		
26		
27		

CALCULATION OF VARIANTS

Active

4-New energy source (only Block C), DHW solar panels, LED lightings		No measures	Block C: Wall ins. Block C1: wall ins. windows changing HVAC: ventilation	Roof ins.	New energy source (only Block C), DHW solar panels, LED lightings
4	1	2	3	4	
46,3	121,3	96,4	46,3	46,3	
26,1	68,6	47,6	26,1	26,1	
0,4				0,4	
14,0				14,0	
	7,9	0,9	0,1		
127,9	196,5	193,9	151,9	127,9	
no	no	no	no	no	
Link	Link	Link	Link	Link	
Value	1	2	3	4	

0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
Daikin Altherma 16 kW	None	None	None	Daikin Altherma 16 kW
70%	0%	0%	0%	70%
60%	0%	0%	0%	60%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%

None	None	None	None	None
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
Hard Coal CGS 70% PHC	Hard Coal CGS 70% PHC			
30%	100%	100%	100%	30%
40%	100%	100%	100%	40%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%

Change aluminium windows (15 years)				
5	6	7	8	9
22,5				
15,7		52,5	52,5	
0,3				
11,6				
93,4				
yes				
Link	Link	Link	Link	
5	6	7	8	9

0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
Daikin Altherma 16 kW	Daikin Altherma 16 kW	None	None	None
70%	70%	0%	0%	0%
60%	60%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%

None	None	None	None	None
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
Hard Coal CGS 70% PHC	Hard Coal CGS 70% PHC	None	None	None
30%	30%	0%	0%	0%
40%	40%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%
0%	0%	0%	0%	0%

Selection of comparison configuration

Description	4-S1: Windows
Component type	Windows ('Window')
Component	f-PVC frame North

Calculation of selected configuration

	Lower Efficiency	Hig Effici
Design according to variant	1-No measures	2-Block C:
Uw--Value	2,523	1,00
Minimal interior surface temperature	-	-
	Uncomfortable!	
	Inves	
	Per m ² of component	Whole component
Area of component	1,00	18
Investment costs less sum of financial support	0,00	0
Annuity (capital costs)	0,00	0
	21,21	

Energy (Space heating + c)

	Per m ² of TFA	Entire building	Per m ² of TFA
Area	1	848	1
Annual heating demand	98,30	83396	96,40
Cooling + dehumidification demand			

Electricity demand:

Auxiliary electricity for Heating	1,15	973	1,15
Auxiliary electricity ventilation winter	1,73	1467	1,73
Direct electric	0,00	0	0,00
HP	0,00	0	0,00
Compact heat pump unit	0,00	0	0,00
Auxiliary electricity ventilation summer	2,66	2256	2,66
Compressor cooling unit	0,00	0	0,00

Final energy demand:

Total electricity demand	5,53	4696	5,53
Gas	0,00	0	0,00
Oil	0,00	0	0,00

Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	103,54	87843	101,54
Others	0,00	0	0,00

CO2-Emissions:

Total electricity demand	3,76	3193	3,76
Gas	0,00	0	0,00
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	21082,38	17886292	20675,59
Others	0,00	0	0,00

PE-demand

Total electricity	14,39	12209	14,39
Gas	0,00	0	0,00
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	82,83	102	39,16
Others	0,00	0	0,00

Costs:

Total electricity	1,38	1174	1,38
Gas	0,00	0	0,00
Oil	0,00	0	0,00
Logs	0,00	0	0,00
Pellet	0,00	0	0,00
District Heat	13,46	11420	13,20
Others	0,00	0	0,00
Total energy costs	14,84	12594	14,58
Maintenance costs	0,00	0	0,00

Final energy demand	114,61	97234	112,61
CO ₂ -Emissions	21086,14	17889485	20679,36
Primary energy demand	97,22	12311	53,55
Total cost space conditioning	14,84	12594	14,58

Total annual costs	14,84	12594	Economical
			15,04


Maximal economically viable additional investment
Cost per kWh of space heating

<<

Boundary conditions

Boundary	
Interest rate + Inflation	Energy price

Nominal interest rate	6 , 50%	Electricity
Inflation	1 , 53%	Gas/Oil
Period under consideration [a]	20	Logs Pellet District heating Others



z

E T W E E N T W O V A R I A N T S

her ency	Difference / Savings / Profit
-------------	----------------------------------

Wall ins.

037

-

Uncomfortable!

W/(m²K)

°C

tment

Whole component	Per m ² of component	Whole component
18	1,00	18
6015	329,95	6015
387	21,21	387

m²
€
€/a

(cooling + mech. ventilation)

Entire building	Per m ² of component	Whole component
848	1	18
81782	88,55	1614

m²
kWh/a
kWh/a

973	0,00	0
1467	0,00	0
0	0,00	0
0	0,00	0
0	0,00	0
2256	0,00	0
0	0,00	0

kWh/a
kWh/a
kWh/a
kWh/a
kWh/a
kWh/a
kWh/a

4696	0,00	0
0	0,00	0
0	0,00	0

kWh/a
kWh/a
kWh/a

0	0,00	0	kWh/a
0	0,00	0	kWh/a
86148	92,97	1695	kWh/a
0	0,00	0	kWh/a

3193	0,00	0	kg/a
0	0,00	0	kg/a
0	0,00	0	kg/a
0	0,00	0	kg/a
0	0,00	0	kg/a
17541173	18930,31	345118	kg/a
0	0,00	0	kg/a

12209	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
0	0,00	0	kWh/a
10	5,05	92	kWh/a
0	0,00	0	kWh/a

1174	0,00	0	€/a
0	0,00	0	€/a
0	0,00	0	€/a
0	0,00	0	€/a
0	0,00	0	€/a
11199	12,09	220	€/a
0	0,00	0	€/a
12373	12,09	220	€/a
0	0,00	0	€/a

95539	92,97	1695	kWh/a
17544366	18930,31	345118	kg/a
12219	5,05	92	kWh/a
12373	0,26	220	€/a

c viability		
12760	-9,12	-166
investment costs	188,04	3428
saved final energy	22,8	Cent/kWh

conditions	
s [cent/kWh]	Period of use

25	Build. assemblies	50	a
9	Vent. system	25	a
5	Thermal bridges	50	a
7	Complete building	35	a
13	Windows	30	a
20			



Input: comparison configuration

Description	S1:Building	S1: Walls C
Component type	Complete building	Building assemblies ('U-Value')
Component	- No additional input	01ud Block C - plaster
"Lower Efficiency" variant	1-No measures	1-No measures
Investment costs [€]	8340,03	4176,73
Annual maintenance costs [€/a]		
"Higher Efficiency" variant	2-Block C: Wall ins. Block C1: w	2-Block C: Wall ins. Block C1: w
Investment costs [€]	45262,71	17575,70
Annual maintenance costs [€/a]		
Financial support (present value) [€]		

Results (manual transfer)

3	4	5
S1: Walls C1	S1: Windows	S1: Ventilation
Building assemblies ('U-Value')	Windows ('Window')	Ventilation system ('Ventilation')
02ud Block C - plaster external	f-PVC frame North	- No additional input
1-No measures	1-No measures	1-No measures
1241,08	0,00	2922,22
2-Block C: Wall ins. Block C1: w	2-Block C: Wall ins. Block C1: w	2-Block C: Wall ins. Block C1: w
4227,51	6015,25	14747,38
		400

6	7	8
S2:Roof C	S2:Roof C1	S3:Building
Building assemblies ('U-Value')	Building assemblies ('U-Value')	Complete building
11ud Roof Gym direct to external	10ud Roof dressingrooms direct - No additional input	
2-Block C: Wall ins. Block C1: w 4214,16	2-Block C: Wall ins. Block C1: w 3782,54	3-Roof ins. 0,00
3-Roof ins.	3-Roof ins.	4-New energy source (only Bloc
45754,92	10041,80	34026,47


9

10

Comp. Renovation	S4:Alumin.wind
Complete building	Complete building
- No additional input	- No additional input
1-No measures	4-New energy source (only Block C), DHW solar panels, LED lightings
16336 , 73	0 , 00
5-Change aluminium windows (5-Change aluminium windows (15 years)
184086 , 73	48489 , 53

EnerPHit planning:

CLIMATE DATA





DHW solar panels, LED lightings


Building: Primary School 3 "Tzanko Diustabanov" - Section A




Wedge-shaped building assemblies (tapered insulation),

unventilated air layers and unheated attics

> Auxiliary calculation to the right

Assembly No.	Building assembly description	Interior insulation?					
01ud	Block C - plaster						
Heat transfer resistance [m ² K/W] interior R _{si} : 0,13 exterior R _{se} : 0,04							
1.	Plaster in	0,700	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
2.	Aereted concret	0,210					20
3.	Plaster outside	0,870					250
4.	EPS-F	0,032					20
5.	Plaster	0,870					200
6.							20
7.							
8.							
		Percentage of sec. 1 100%	Percentage of sec. 2	Percentage of sec. 3			Total 51,0 cm
		 W/(m ² K)	U-Value: 0,130 W/(m ² K)				


Assembly No.	Building assembly description	Interior insulation?					
02ud	Block C - plaster external insulation						
Heat transfer resistance [m ² K/W] interior R _{si} : 0,13 exterior R _{se} : 0,04							
1.	Plaster in	0,700	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
2.	Aereted concret	0,210					20
3.	Plaster outside	0,870					250
4.	EPS-F	0,032					20
5.	Plaster	0,870					200
6.							20
7.							
8.							
		Percentage of sec. 1 100%	Percentage of sec. 2	Percentage of sec. 3			Total 51,0 cm
		 W/(m ² K)	U-Value: 0,130 W/(m ² K)				



Assembly No.	Building assembly description	Interior insulation?					
03ud							
Heat transfer resistance [m ² K/W] interior R _{si} : 0,13 exterior R _{se} :							
1.	Area section 3	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
2.							
3.							
4.							
5.							
6.							
7.							
8.							
		Percentage of sec. 1 100%	Percentage of sec. 2	Percentage of sec. 3			Total cm
		 W/(m ² K)	U-Value:  W/(m ² K)				



Assembly No.	Building assembly description					Interior insulation?		
04ud						<input type="checkbox"/>		
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,13					
		exterior R _{se} :						
Area section 4	λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]
1.								
2.								
3.								
4.								
5.								
6.								
7.								
8.								
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total		
100%								cm
U-value supplement <input type="text"/> W/(m ² K)				U-Value: <input type="text"/> W/(m ² K)				

Assembly No.	Building assembly description					Interior insulation?		
05ud						<input type="checkbox"/>		
Heat transfer resistance [m ² K/W]		interior R _{si} :	<input type="text"/>					
		exterior R _{se} :	<input type="text"/>					
Area section 5	λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]
1.								
2.								
3.								
4.								
5.								
6.								
7.								
8.								
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total		
100%								cm
U-value supplement <input type="text"/> W/(m ² K)				U-Value: <input type="text"/> W/(m ² K)				

Assembly No.	Building assembly description					Interior insulation?		
06ud						<input type="checkbox"/>		
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,17					
		exterior R _{se} :	0,17					
Area section 6	λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]
1.								
2.								
3.								
4.								
5.								
6.								
7.								
8.								
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total		
100%								cm
U-value supplement <input type="text"/> W/(m ² K)				U-Value: <input type="text"/> W/(m ² K)				

Assembly No. Building assembly description					Interior insulation?		
07ud	Floor slab on grade (tiles)						
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,17				
exterior R _{se} :							
Area section 7		λ _i [W/(mK)]	Area section 2 (optional)	λ _i [W/(mK)]	Area section 3 (optional)	λ _i [W/(mK)]	Thickness [mm]
1. Tiles		3,490					20
2. Cement		0,930					50
3. Concrete		2,100					150
4. Stone embankment		3,500					300
5. Floor insulation		0,000					0
6. New flooring		0,000					0
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	52,0 cm
100%							
U-value supplement  W/(m ² K)				U-Value: 2,586 W/(m ² K)			

Assembly No. Building assembly description					Interior insulation?		
08ud	Floor slab on grade (Gym)						
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,17				
exterior R _{se} :							
Area section 8		λ _i [W/(mK)]	Area section 2 (optional)	λ _i [W/(mK)]	Area section 3 (optional)	λ _i [W/(mK)]	Thickness [mm]
1. Wood		0,350					20
2. Air closed		0,160					30
3. Cement		0,930					30
4. Concrete		2,100					100
5. Stone embankment		3,500					250
6. Mineral wool		0,000					0
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	43,0 cm
100%							
U-value supplement  W/(m ² K)				U-Value: 1,767 W/(m ² K)			

Assembly No. Building assembly description					Interior insulation?		
09ud							
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,10				
exterior R _{se} :		0,10					
Area section 9		λ _i [W/(mK)]	Area section 2 (optional)	λ _i [W/(mK)]	Area section 3 (optional)	λ _i [W/(mK)]	Thickness [mm]
1.							
2.							
3.							
4.							
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	cm
100%							
U-value supplement  W/(m ² K)				U-Value:  W/(m ² K)			

EnerPHit planning:

U - V A L U E S O F B U I L D I N G E L E M E

Assembly No.	Building assembly description					Interior insulation?																																																						
10ud	Roof dressingrooms direct to external air					<input checked="" type="checkbox"/>																																																						
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,10																																																									
		exterior R _{se} :	0,04																																																									
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 5px;"> <tr> <th style="width: 10%;">Area section</th> <th style="width: 10%;">λ [W/(mK)]</th> <th style="width: 10%;">Area section 2 (optional)</th> <th style="width: 10%;">λ [W/(mK)]</th> <th style="width: 10%;">Area section 3 (optional)</th> <th style="width: 10%;">λ [W/(mK)]</th> </tr> <tr> <td>1. Plaster</td> <td>0,700</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2. Concrete</td> <td>2,100</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>3. Cement</td> <td>0,930</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4. Bitum</td> <td>0,170</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>5. Mineral wool</td> <td>0,041</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>6. XPS</td> <td>0,035</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>7. Hydroinsulation</td> <td>0,170</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>8.</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>						Area section	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	1. Plaster	0,700					2. Concrete	2,100					3. Cement	0,930					4. Bitum	0,170					5. Mineral wool	0,041					6. XPS	0,035					7. Hydroinsulation	0,170					8.						Thickness [mm]
Area section	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]																																																							
1. Plaster	0,700																																																											
2. Concrete	2,100																																																											
3. Cement	0,930																																																											
4. Bitum	0,170																																																											
5. Mineral wool	0,041																																																											
6. XPS	0,035																																																											
7. Hydroinsulation	0,170																																																											
8.																																																												
						20																																																						
						200																																																						
						30																																																						
						5																																																						
						40																																																						
						300																																																						
						5																																																						
						Total																																																						
						60,0 cm																																																						
U-value supplement				U-Value:	0,101	W/(m ² K)																																																						

Assembly No.	Building assembly description					Interior insulation?																																																						
11ud	Roof Gym direct to external air					<input checked="" type="checkbox"/>																																																						
						yes																																																						
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,10																																																									
		exterior R _{se} :	0,04																																																									
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 5px;"> <tr> <th style="width: 10%;">Area section</th> <th style="width: 10%;">λ [W/(mK)]</th> <th style="width: 10%;">Area section 2 (optional)</th> <th style="width: 10%;">λ [W/(mK)]</th> <th style="width: 10%;">Area section 3 (optional)</th> <th style="width: 10%;">λ [W/(mK)]</th> </tr> <tr> <td>1. Sandwich panel (poliure)</td> <td>0,041</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2. Wood</td> <td>0,350</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>3. Hydroinsulation</td> <td>0,170</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4. Tiles</td> <td>0,990</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>5. Mineral wool</td> <td>0,041</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>6.</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>7.</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>8.</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>						Area section	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	1. Sandwich panel (poliure)	0,041					2. Wood	0,350					3. Hydroinsulation	0,170					4. Tiles	0,990					5. Mineral wool	0,041					6.						7.						8.						Thickness [mm]
Area section	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]																																																							
1. Sandwich panel (poliure)	0,041																																																											
2. Wood	0,350																																																											
3. Hydroinsulation	0,170																																																											
4. Tiles	0,990																																																											
5. Mineral wool	0,041																																																											
6.																																																												
7.																																																												
8.																																																												
						50																																																						
						30																																																						
						5																																																						
						30																																																						
						300																																																						
						Total																																																						
						41,5 cm																																																						
U-value supplement				U-Value:	0,113	W/(m ² K)																																																						

Assembly No.	Building assembly description					Interior insulation?																																																						
12ud	Under unheated basement floor					<input checked="" type="checkbox"/>																																																						
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,17																																																									
		exterior R _{se} :																																																										
<table border="1" style="width: 100%; border-collapse: collapse; margin-bottom: 5px;"> <tr> <th style="width: 10%;">Area section</th> <th style="width: 10%;">λ [W/(mK)]</th> <th style="width: 10%;">Area section 2 (optional)</th> <th style="width: 10%;">λ [W/(mK)]</th> <th style="width: 10%;">Area section 3 (optional)</th> <th style="width: 10%;">λ [W/(mK)]</th> </tr> <tr> <td>12. Cement</td> <td>0,930</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2. Concrete</td> <td>1,450</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>3. stone embankment</td> <td>3,500</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4.</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>5.</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>6.</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>7.</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>8.</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>						Area section	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	12. Cement	0,930					2. Concrete	1,450					3. stone embankment	3,500					4.						5.						6.						7.						8.						Thickness [mm]
Area section	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]																																																							
12. Cement	0,930																																																											
2. Concrete	1,450																																																											
3. stone embankment	3,500																																																											
4.																																																												
5.																																																												
6.																																																												
7.																																																												
8.																																																												
						20																																																						
						150																																																						
						250																																																						
						Total																																																						
						42,0 cm																																																						
U-value supplement				U-Value:	2,729	W/(m ² K)																																																						

Assembly No.	Building assembly description					Interior insulation?
13ud	Block A - stone façade					<input checked="" type="checkbox"/>
						yes
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,13			
		exterior R _{se} :				

EnerPHit planning:

U - V A L U E S O F B U I L D I N G E L E M E

Building assembly description							
exterior R_{se} : 0,04							
Area section		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.	Plaster in	0,700					20
2.	Bricks	0,790					500
3.	Plaster outside	0,870					20
4.	Stone facade	1,060					40
5.	EPS-F	0,000					0
6.	Plaster	0,000					0
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						58,0	cm
U-value supplement W/(m ² K)		U-Value: 1,121 W/(m ² K)					

Building assembly description							
Assembly No. 14ud Block A connection roof direct to external air							
Interior insulation? 							
Heat transfer resistance [m ² K/W] interior R_{si} : 0,10							
exterior R_{se} : 0,04							
Area section		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.	Plaster	0,700					20
2.	Concrete	1,630					200
3.	Cement	0,930					30
4.	Bitum	0,170					5
5.	Closed air	0,870					20
6.	Mineral wool	0,032					200
7.	Suspended ceiling	0,032					200
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%						67,5	cm
U-value supplement W/(m ² K)		U-Value: 0,078 W/(m ² K)					

Building assembly description							
Assembly No. 15ud							
Interior insulation? 							
Heat transfer resistance [m ² K/W] interior R_{si} : 							
exterior R_{se} : 							
Area section		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1.							
2.							
3.							
4.							
5.							
6.							
7.							
8.							
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%							cm
U-value supplement W/(m ² K)		U-Value: W/(m ² K)					

Building assembly description							
Assembly No. 16ud							
Interior insulation? 							
Heat transfer resistance [m ² K/W] interior R_{si} : 							
exterior R_{se} : 							
Area section		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
16							

EnerPHit planning:

U - V A L U E S O F B U I L D I N G E L E M E N T S

1.									
2.									
3.									
4.									
5.									
6.									
7.									
8.									
Percentage of sec. 1 100%									
					Percentage of sec. 2	Percentage of sec. 3	Percentage of sec. 3	Total	cm
					U-value supplement <input type="text"/> W/(m ² K)		U-Value: <input type="text"/> W/(m ² K)		

Assembly No. Building assembly description								
17ud						Interior insulation?		
		Heat transfer resistance [m ² K/W]		interior R _{si} :	<input type="text"/>			
				exterior R _{se} :	<input type="text"/>			
Area section								
17		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
1.								
2.								
3.								
4.								
5.								
6.								
7.								
8.								
Percentage of sec. 1 100%								
					Percentage of sec. 2	Percentage of sec. 3	Percentage of sec. 3	
					U-value supplement <input type="text"/> W/(m ² K)		U-Value: <input type="text"/> W/(m ² K)	

Assembly No. Building assembly description								
18ud						Interior insulation?		
		Heat transfer resistance [m ² K/W]		interior R _{si} :	<input type="text"/>			
				exterior R _{se} :	<input type="text"/>			
Area section								
18		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
1.								
2.								
3.								
4.								
5.								
6.								
7.								
8.								
Percentage of sec. 1 100%								
					Percentage of sec. 2	Percentage of sec. 3	Percentage of sec. 3	
					U-value supplement <input type="text"/> W/(m ² K)		U-Value: <input type="text"/> W/(m ² K)	

Assembly No. Building assembly description								
19ud						Interior insulation?		
		Heat transfer resistance [m ² K/W]		interior R _{si} :	<input type="text"/>			
				exterior R _{se} :	<input type="text"/>			
Area section								
19		λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
1.								
2.								
3.								
4.								

EnerPHit planning:

U - V A L U E S O F B U I L D I N G E L E M E N T S

5.									
6.									
7.									
8.									
Percentage of sec. 1 100%				Percentage of sec. 2			Percentage of sec. 3		Total
									cm
U-value supplement				U-Value:			W/(m ² K)		

Assembly No. Building assembly description								Interior insulation?	
20ud								<input type="checkbox"/>	
Heat transfer resistance [m ² K/W]		interior R _{si} :							
exterior R _{se} :									
Area section 20		λ [W/(mK)]	Area section 2 (optional)		λ [W/(mK)]	Area section 3 (optional)		λ [W/(mK)]	Thickness [mm]
1.									
2.									
3.									
4.									
5.									
6.									
7.									
8.									
Percentage of sec. 1 100%				Percentage of sec. 2			Percentage of sec. 3		Total
									cm
U-value supplement				U-Value:			W/(m ² K)		

Secondary Calculation: Equivalent Thermal Conductivity of Still Air Spaces

Air Layer Thickness	50	mm	Convective heat transfer	
Direction of the thermal flow:	x	Upwards	h_a	1,95 W/(m ² K)
		Horizontal	Radiation heat transfer	
		Downwards	h_r	4,17 W/(m ² K)
Emissivity of surface 1	0,90		equivalent thermal conductivity	
Emissivity of surface 2	0,90		λ	0,31 W/(mK)

Secondary Calculation: Equivalent Thermal Conductivity of Still Air Spaces

Air Layer Thickness of the	30	mm	Convective heat transfer	
		Upwards	h_a	0,833333 W/(m ² K)
		Horizontal	Radiation heat transfer	
	x	Downwards	h_r	4,34 W/(m ² K)
Emissivity of surface 1	0,92		equivalent thermal conductivity	
Emissivity of surface 3	0,92		λ	0,16 W/(mK)

Wedge-shaped layers (at an inclination of max. 5%)

(Calculation following EN 6946 Appendix C)

Assembly No. Building assembly description					
1a	Exemplary flat roof with wedge-shaped insulation				
Heat transfer resistance [$\text{m}^2\text{K}/\text{W}$]		interior R_{si} :	0,10		
		exterior R_{se} :	0,04		
A parallel assemblies layer					
Area section 1	λ [$\text{W}/(\text{mK})$]	Area section 2 (optional)	λ [$\text{W}/(\text{mK})$]	Area section 3 (optional)	λ [$\text{W}/(\text{mK})$]
1. Concrete Ceiling	2,100				
2. PS Rigid Foam	0,040				
3.					
4.					
5.					
6.					
7.					
8.					
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
100%					
U₀: 0,192 W/(m²K)					
R₀: 5,216 (m²K)/W					
B Wedge-Shaped Assembly Layer					
Area section 1	λ [$\text{W}/(\text{mK})$]	Area section 2 (optional)	λ [$\text{W}/(\text{mK})$]	Area section 3 (optional)	λ [$\text{W}/(\text{mK})$]
PS rigid foam insulation	0,040				
Percentage of sec. 2		Percentage of sec. 3		Thickness d ₁ [mm]	
				150 cm	
U₁: 0,267 W/(m²K)					
R₁: 3,750 (m²K)/W					
Rectangular Area U-Value: 0,144 W/(m²K)					
U-value of triangular area with the thickest point at the apex: 0,157 W/(m²K)					
U-value of triangular area with the thinnest point at the apex: 0,131 W/(m²K)					

Wedge-shaped layers (at an inclination of max. 5%)

(Calculation following EN 6946 Appendix C)

Assembly No. Building assembly description					
2a					
Heat transfer resistance [$\text{m}^2\text{K}/\text{W}$]		interior R_{si} :	<input type="text"/>		
exterior R_{se} :		<input type="text"/>			
A parallel assemblies layer					
Area section 1	$\lambda_1 [\text{W}/(\text{mK})]$	Area section 2 (optional)	$\lambda_2 [\text{W}/(\text{mK})]$	Area section 3 (optional)	$\lambda_3 [\text{W}/(\text{mK})]$
1.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
2.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
3.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
4.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
5.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
6.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
7.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
8.	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
100%		<input type="text"/>		<input type="text"/>	
Total <input type="text"/> cm					
$U_0:$ <input type="text"/> $\text{W}/(\text{m}^2\text{K})$ $R_0:$ <input type="text"/> $(\text{m}^2\text{K})/\text{W}$					
B Wedge-Shaped Assembly Layer					
Area section 2 (optional)	$\lambda_2 [\text{W}/(\text{mK})]$	Area section 3 (optional)	$\lambda_3 [\text{W}/(\text{mK})]$	Thickness d_1 [mm]	
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	
Percentage of sec. 2		Percentage of sec. 3		Thickness d_1 [cm]	
<input type="text"/>		<input type="text"/>		<input type="text"/> cm	
$U_1:$ <input type="text"/> $\text{W}/(\text{m}^2\text{K})$ $R_1:$ <input type="text"/> $(\text{m}^2\text{K})/\text{W}$ Rectangular Area U-Value: <input type="text"/> $\text{W}/(\text{m}^2\text{K})$ U-value of triangular area with the thinnest point at the apex: <input type="text"/> $\text{W}/(\text{m}^2\text{K})$ U-value of triangular area with the thinnest point at the apex: <input type="text"/> $\text{W}/(\text{m}^2\text{K})$					

Non-conditioned attic

Building assembly description									
Roof									
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,17	Exterior absorption coefficient	0,80				
exterior R _{se} :		0,04	Exterior emissivity		0,93				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]				
1. Corrugated galvanised irc 60,000									
2.									
3.									
4.									
5.									
6.									
7.									
8.									
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3					
100%									
U-value supplement		W/(m ² K)		U-Value: 4,761 W/(m ² K)					
Thickness [mm]									
3									
Building assembly description									
Exterior attic wall									
Heat transfer resistance [m ² K/W]		interior R _{si} :	0,13	Exterior absorption coefficient	0,80				
exterior R _{se} :		0,04	Exterior emissivity		0,93				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]				
1. Interior plaster	0,350								
2. Masonry	1,100								
3. Exterior Render	0,800								
4.									
5.									
6.									
7.									
8.									
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3					
100%									
U-value supplement		W/(m ² K)		U-Value: 2,519 W/(m ² K)					
Thickness [mm]									
15									
175									
20									

Building assembly description						
Intermediate ceiling						
Heat transfer resistance [m ² K/W] interior R _{si} : 0,17 exterior R _{se} : 0,17						
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
1. Wooden floor	0,130					22
2.						
3.						
4.						
5.						
6.						
7.						
8.						
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
83%		16,7%				2,2 cm
U-value supplement			U-Value: 1,964 W/(m ² K)			
Attic area			emissivity in the attic		Air exchange in the attic	
Roof area	200,0	m ²	Inner side of the roof / exterior wall	0,93	Air change rate	0,20 1/h
Area of exterior walls and attic	200,0	m ²	Upper side of the interior ceiling	0,93	Volume	200,0 m ³
Area of intermediate ceiling	100,0	m ²				
Equivalent value for the intermediate ceiling (to be linked to worksheets "Components" and "Areas")						
U-Value:	2,732	Absorptivity:	0,780	Emissivity:	0,907	
Total solar energy transmittance (informative): 0,085						

AREAS DETERMINATION

Building: Primary School 3 "Tzanko Diustabanov" - Sector Heating demand 46 kWh/(m²a)

Summary										Building assembly overview		Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit	Comment									
1	Treated Floor Area		846,40	m ²	Treated floor area according to PHPP manual					North Windows	2,390	3416	6098	9 months
2	North Windows	A	58,20	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the "Windows" worksheet.					East Windows	2,353	1546	1046	
3	East Windows	A	12,52	m ²						South Windows	2,818	13898	10153	
4	South Windows	A	100,80	m ²						West Windows	2,618	1231	1467	
5	West Windows	A	26,46	m ²						Horizontal Windows				
6	Horizontal Windows	A	0,00	m ²										
7	Exterior Door	A	3,00	m ²	Please subtract area of door from respective building assembly					Exterior Door	0,800			
8	Exterior Wall - Ambient	A	539,24	m ²	Temperature Zone "A" is ambient air.					Exterior Wall - Ambient	0,130	75	207	
9	Exterior Wall - Ground	B	0,00	m ²	Temperature zone "B" is the ground.					Exterior Wall - Ground				
10	Roof/Ceiling - Ambient	A	955,36	m ²						Roof/Ceiling - Ambient	0,110	782	1413	
11	Floor slab / basement ceiling	B	910,21	m ²						Floor slab / basement ceiling	1,977			
12			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"									
13			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"					Factor for X				
14		X	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f, < 1):					75%				
										Thermal bridges - Overview	Ψ [W/(mK)]			
15	Thermal Bridges Ambient	A	203,27	m	Units in m					Thermal Bridges Ambient	0,081			
16	Perimeter Thermal Bridges	P	123,80	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).					Perimeter Thermal Bridges	-0,036			
17	Thermal bridges FS/BC	B	0,00	m	Units in m					Thermal bridges FS/BC				
18	Partition Wall to Neighbour	I	0,00	m ²	No heat losses, only considered for the heating load calculation.					Partition Wall to Neighbour				
Total thermal envelope			2605,79	m ²						Average Therm. Envelope	0,964			

Area input													Sort: AS LIST				Go to building components list				
Area Nr.	Building assembly description	Group Nr.	Assigned to group	Quantity	x (a [m]	x	b [m]	+ User-Determined [m ²]	- User Subtraction [m ²]	- Subtraction window areas [m ²]) = Area [m ²]	Selection of building element assembly / certified building system	U-Value [W/(m ² K)]	Deviation from North	Angle of inclination from the horizontal	Orientation	Reduction factor shading	Exterior absorptivity	Exterior emissivity	
	Treated floor area	1	Treated Floor Area	1	x (x		+ 846,40	-		= 846,4									
	North Windows	2	North Windows	1	x (x		+ 58,20	-		= 58,2	From 'Windows' worksheet	2,390							
	East Windows	3	East Windows	1	x (x		+ 12,52	-		= 12,5	From 'Windows' worksheet	2,353							
	South Windows	4	South Windows	1	x (x		+ 100,80	-		= 100,8	From 'Windows' worksheet	2,818							
	West Windows	5	West Windows	1	x (x		+ 26,46	-		= 26,5	From 'Windows' worksheet	2,618							
	Horizontal Windows	6	Horizontal Windows	1	x (x		+ 0,00	-		= 0,0	From 'Windows' worksheet	0,000							
	Exterior Door	7	Exterior Door	1	x (1,20	x	2,50	+	-		= 3,0	U-value exterior door:	0,800							
1	North facade 1	8	Exterior Wall - Ambient	1	x (6,50	x	3,30	+	-		= 17,2	02ud Block C - plaster external insul	0,130	0	90	North	0,70	0,40	0,90	
2	East facade 1	8	Exterior Wall - Ambient	1	x (1,50	x	3,30	+	-		= 5,0	02ud Block C - plaster external insul	0,130	90	90	East	0,70	0,40	0,90	
3	North facade 2	8	Exterior Wall - Ambient	1	x (12,60	x	3,30	+	-		= 31,6	02ud Block C - plaster external insul	0,130	0	90	North	0,70	0,40	0,90	
4	North-west facade 1	8	Exterior Wall - Ambient	1	x (6,40	x	3,30	+	-		= 17,1	02ud Block C - plaster external insul	0,130	315	90	West	0,70	0,40	0,90	
5	North-east facade 1	8	Exterior Wall - Ambient	1	x (10,90	x	6,00	+	-		= 31,8	01ud Block C - plaster	0,130	45	90	North	0,70	0,40	0,90	
6	North-west facade 2	8	Exterior Wall - Ambient	1	x (18,15	x	6,00	+	-		= 108,9	01ud Block C - plaster	0,130	315	90	West	0,70	0,40	0,90	
7	South-west facade 1	8	Exterior Wall - Ambient	1	x (36,35	x	6,00	+	-		= 117,3	01ud Block C - plaster	0,130	225	90	South	0,70	0,40	0,90	
8	South-east facade 1	8	Exterior Wall - Ambient	1	x (18,15	x	6,00	+	-		= 108,9	01ud Block C - plaster	0,130	135	90	East	0,70	0,40	0,90	
9	North-east facade 2	8	Exterior Wall - Ambient	1	x (6,05	x	6,00	+	-		= 25,9	02ud Block C - plaster external insul	0,130	45	90	North	0,70	0,40	0,90	
10	South-east facade 2	8	Exterior Wall - Ambient	1	x (1,00	x	2,70	+	-		= 3,6	01ud Block C - plaster	0,130	135	90	East	0,70	0,40	0,90	
11	Circle south part	8	Exterior Wall - Ambient	1	x (2,70	x	2,70	+	-		= 0,0	0,3	01ud Block C - plaster	0,130	180	90	South	0,70	0,40	0,90
12	Circle east part	8	Exterior Wall - Ambient	1	x (2,70	x	2,70	+	-		= 0,0	0,3	01ud Block C - plaster	0,130	90	90	East	0,70	0,40	0,90
13	Circle north part	8	Exterior Wall - Ambient	1	x (2,70	x	2,70	+	-		= 0,0	0,3	01ud Block C - plaster	0,130	0	90	North	0,70	0,40	0,90
14	North-west facade 3	8	Exterior Wall - Ambient	1	x (15,90	x	2,70	+	-		= 42,9	01ud Block C - plaster	0,130	45	90	North	0,70	0,40	0,90	
15	North-west facade 3	8	Exterior Wall - Ambient	1	x (2,80	x	2,70	+	-		= 7,6	01ud Block C - plaster	0,130	315	90	West	0,70	0,40	0,90	
16	South-west facade 2	8	Exterior Wall - Ambient	1	x (23,00	x	1,00	+	-		= 21,9	01ud Block C - plaster	0,130	315	90	West	0,70	0,40	0,90	
17	Roof 1	10	Roof/Ceiling - Ambient	1	x (19,70	x	18,93	+ 335,92	-		= 0,0	= 708,7	11ud Roof Gym direct to external air	0,113	0	0	Hor	0,40	0,80	0,90
18	Roof 2	10	Roof/Ceiling - Ambient	1	x (x		+ 262,88	- 16,26		= 0,0	= 246,6	10ud Roof dressingrooms direct to e	0,101	0	0	Hor	0,40	0,95	0,90
19	Floor 1	11	Floor slab / basement ceiling	1	x (18,15	x	36,35	+ 17,63	-		= 0,0	= 677,4	08ud Floor slab on grade (Gym)	1,767						
20	Floor 2	11	Floor slab / basement ceiling	1	x (x		+ 250,46	- 17,63		= 0,0	= 232,8	07ud Floor slab on grade (tiles)	2,586						
21	South-east facade 2	8	Exterior Wall - Ambient	1	x (2,00	x	0,48	+	-		= 0,5	= 0,4	01ud Block C - plaster	0,130	135	90	East	0,70	0,40	0,90
22	North-west facade 2	8	Exterior Wall - Ambient	1	x (2,00	x	0,48	+	-		= 0,5	= 0,4	01ud Block C - plaster	0,130	315	90	West	0,70	0,40	0,90
23	South-east facade 3	8	Exterior Wall - Ambient	1	x (3,20	x	3,30	+	-		= 8,4	= 2,2	02ud Block C - plaster external insul	0,130	135	90	East	0,70	0,40	0,90
24					x (x		+	-		= 0,0	=								
25					x (x		+	-		= 0,0	=								
26					x (x		+	-		= 0,0	=								
27					x (x		+	-		= 0,0	=								

AREAS DETERMINATION

Building: Primary School 3 "Tzanko Diustabakov" - Sector Heating demand 46 kWh/(m²a)

46 kWh/(m²a)

Summary							Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit	Comment					
1	Treated Floor Area		848,40	m ²	Treated floor area according to PHPP manual				9 months	8 months
2	North Windows	A	58,20	m ²			North Windows	2,390	3416	6098
3	East Windows	A	12,52	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the "Windows" worksheet.		East Windows	2,353	1546	1046
4	South Windows	A	100,80	m ²			South Windows	2,818	13898	10153
5	West Windows	A	26,46	m ²			West Windows	2,618	1231	1467
6	Horizontal Windows	A	0,00	m ²			Horizontal Windows			
7	Exterior Door	A	3,00	m ²	Please subtract area of door from respective building assembly		Exterior Door	0,800		
8	Exterior Wall - Ambient	A	539,24	m ²	Temperature Zone "A" is ambient air.		Exterior Wall - Ambient	0,130	75	207
9	Exterior Wall - Ground	B	0,00	m ²	Temperature zone "B" is the ground.		Exterior Wall - Ground			
10	Roof/Ceiling - Ambient	A	955,36	m ²			Roof/Ceiling - Ambient	0,110	782	1413
11	Floor slab / basement ceiling	B	910,21	m ²			Floor slab / basement ceiling	1,977		
12			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"					
13			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"		Factor for X			
14		X	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f, < 1):		75%			
							Thermal bridges - Overview	Ψ [W/(mK)]		
15	Thermal Bridges Ambient	A	203,27	m	Units in m		Thermal Bridges Ambient	0,081		
16	Perimeter Thermal Bridges	P	123,80	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).		Perimeter Thermal Bridges	-0,036		
17	Thermal bridges FS/BC	B	0,00	m	Units in m		Thermal bridges FS/BC			
18	Partition Wall to Neighbour	I	0,00	m ²	No heat losses, only considered for the heating load calculation.		Partition Wall to Neighbour			
Total thermal envelope			2605,79	m ²			Average Therm. Envelope	0,964		

[Go to building components list](#)

28			x (x	+	-) -	0,0	=	
29			x (x	+	-) -	0,0	=	
30			x (x	+	-) -	0,0	=	
31			x (x	+	-) -	0,0	=	
32			x (x	+	-) -	0,0	=	
33			x (x	+	-) -	0,0	=	
34			x (x	+	-) -	0,0	=	
35			x (x	+	-) -	0,0	=	
36			x (x	+	-) -	0,0	=	
37			x (x	+	-) -	0,0	=	
38			x (x	+	-) -	0,0	=	
39			x (x	+	-) -	0,0	=	
40			x (x	+	-) -	0,0	=	
41			x (x	+	-) -	0,0	=	
42			x (x	+	-) -	0,0	=	
43			x (x	+	-) -	0,0	=	
44			x (x	+	-) -	0,0	=	
45			x (x	+	-) -	0,0	=	
46			x (x	+	-) -	0,0	=	
47			x (x	+	-) -	0,0	=	
48			x (x	+	-) -	0,0	=	
49			x (x	+	-) -	0,0	=	
50			x (x	+	-) -	0,0	=	

Aend

AREAS DETERMINATION

Building: Primary School 3 "Tzanko Diustabanov" - Sector Heating demand 46 kWh/(m²a)

Summary						Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit	Comment				
1	Treated Floor Area		848,40	m ²	Treated floor area according to PHPP manual			9 months	8 months
2	North Windows	A	58,20	m ²		North Windows	2,390	3416	6098
3	East Windows	A	12,52	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas. which is displayed in the "Windows" worksheet.	East Windows	2,353	1546	1046
4	South Windows	A	100,80	m ²		South Windows	2,818	13898	10153
5	West Windows	A	26,46	m ²		West Windows	2,618	1231	1467
6	Horizontal Windows	A	0,00	m ²		Horizontal Windows			
7	Exterior Door	A	3,00	m ²	Please subtract area of door from respective building assembly	Exterior Door	0,800		
8	Exterior Wall - Ambient	A	539,24	m ²	Temperature Zone "A" is ambient air.	Exterior Wall - Ambient	0,130	75	207
9	Exterior Wall - Ground	B	0,00	m ²	Temperature zone "B" is the ground.	Exterior Wall - Ground			
10	Roof/Ceiling - Ambient	A	955,36	m ²		Roof/Ceiling - Ambient	0,110	782	1413
11	Floor slab / basement ceiling	B	910,21	m ²		Floor slab / basement ceiling	1,977		
12			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
13			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"	Factor for X			
14		X	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f, < 1):	75%			
						Thermal bridges - Overview	Ψ [W/(mK)]		
15	Thermal Bridges Ambient	A	203,27	m	Units in m	Thermal Bridges Ambient	0,081		
16	Perimeter Thermal Bridges	P	123,80	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).	Perimeter Thermal Bridges	-0,036		
17	Thermal bridges FS/BC	B	0,00	m	Units in m	Thermal bridges FS/BC			
18	Partition Wall to Neighbour	I	0,00	m ²	No heat losses, only considered for the heating load calculation.	Partition Wall to Neighbour			
Total thermal envelope			2605,79	m ²		Average Therm. Envelope	0,964		

[Go to building components list](#)

Thermal Bridge Inputs											
Nr.	Thermal bridge description	Group Nr.	Assigned to group	Quantity	x (User determined length [m]	Subtraction user-determined length [m]	=	Length ℓ [m]	Input of thermal bridge heat loss coefficient W/(mK)	Ψ W/(mK)
1	Roof_connection	15	Thermal Bridges Ambient	1	x (34,13	-) =	34,13	Roof_connection	0,072
2	Roof_con.-wall_Gym	15	Thermal Bridges Ambient	1	x (33,37	-) =	33,37	Roof_con.-wall_Gym	0,025
3	Roof_to_wall_Gym	15	Thermal Bridges Ambient	1	x (112,77	-) =	112,77	Roof_to_wall_Gym	0,097
4	Roof_to_roof_windows	15	Thermal Bridges Ambient	1	x (23,00	-) =	23,00	Roof_to_roof_windows	0,097
5	Floor_Gym	16	Perimeter Thermal Bridges	1	x (90,20	-) =	90,20	Floor_Gym	-0,036
6	Floor_Dressrooms	16	Perimeter Thermal Bridges	1	x (33,60	-) =	33,60	Floor_Dressrooms	-0,036
7					x (-	-) =			
8					x (-	-) =			
9					x (-	-) =			
10					x (-	-) =			
11					x (-	-) =			
12					x (-	-) =			
13					x (-	-) =			
14					x (-	-) =			
15					x (-	-) =			
16					x (-	-) =			
17					x (-	-) =			
18					x (-	-) =			
19					x (-	-) =			
20					x (-	-) =			
21					x (-	-) =			
22					x (-	-) =			
23					x (-	-) =			
24					x (-	-) =			
25					x (-	-) =			
26					x (-	-) =			
27					x (-	-) =			
28					x (-	-) =			
29					x (-	-) =			
30					x (-	-) =			
31					x (-	-) =			

AREAS DETERMINATION

Building: Primary School 3 "Tzanko Diustabanov" - Sector Heating demand 46 kWh/(m²a)

Summary						Building assembly overview	Average U-Value [W/(m²K)]	Radiation-gains heating season	Radiation-load cooling period [kWh/a]
Group Nr.	Area group	Temp.-zone	Area	Unit	Comment				
1	Treated Floor Area		848,40	m ²	Treated floor area according to PHPP manual				9 months
2	North Windows	A	58,20	m ²		North Windows	2,390	3416	6098
3	East Windows	A	12,52	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas. which is displayed in the "Windows" worksheet.	East Windows	2,353	1546	1046
4	South Windows	A	100,80	m ²		South Windows	2,818	13898	10153
5	West Windows	A	26,46	m ²		West Windows	2,618	1231	1467
6	Horizontal Windows	A	0,00	m ²		Horizontal Windows			
7	Exterior Door	A	3,00	m ²	Please subtract area of door from respective building assembly	Exterior Door	0,800		
8	Exterior Wall - Ambient	A	539,24	m ²	Temperature Zone "A" is ambient air.	Exterior Wall - Ambient	0,130	75	207
9	Exterior Wall - Ground	B	0,00	m ²	Temperature zone "B" is the ground.	Exterior Wall - Ground			
10	Roof/Ceiling - Ambient	A	955,36	m ²		Roof/Ceiling - Ambient	0,110	782	1413
11	Floor slab / basement ceiling	B	910,21	m ²		Floor slab / basement ceiling	1,977		
12			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
13			0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"	Factor for X			
14		X	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f, < 1):	75%			
Thermal bridges - Overview									
15	Thermal Bridges Ambient	A	203,27	m	Units in m	Thermal Bridges Ambient	0,081		
16	Perimeter Thermal Bridges	P	123,80	m	Units in m; temperature zone "P" is perimeter (see Ground worksheet).	Perimeter Thermal Bridges	-0,036		
17	Thermal bridges FS/BC	B	0,00	m	Units in m	Thermal bridges FS/BC			
18	Partition Wall to Neighbour	I	0,00	m ²	No heat losses, only considered for the heating load calculation.	Partition Wall to Neighbour			
Total thermal envelope						Average Therm. Envelope	0,964		

[Go to building components list](#)

32				x (-) =				
33				x (-) =				
34				x (-) =				
35				x (-) =				
36				x (-) =				
37				x (-) =				
38				x (-) =				
39				x (-) =				
40				x (-) =				
41				x (-) =				
42				x (-) =				
43				x (-) =				
44				x (-) =				
45				x (-) =				
46				x (-) =				
47				x (-) =				
48				x (-) =				
49				x (-) =				
50				x (-) =				
TBend								

A tool for thermal bridge conversion to exterior dimensions				
Description		Units	Example	
	Ψ Interior Dimensions	W/(mK)	0,027	
	Temperature Diff. TB	K	30,000	
Adjacent Area I	Temperature Diff. $\Delta\phi$ I	K	30,000	
	Exterior - Interior Dim. I	m	0,400	
	U-Value building assembly I	W/(m ² K)	0,138	
Adjacent Area II	Temperature Diff. $\Delta\phi$ II	K	30,000	
	Exterior - Interior Dim. II	m	0,300	
	U-Value building assembly II	W/(m ² K)	0,110	
	Ψ Exterior Dimensions	W/(mK)	-0,061	

HEAT LOSSES THROUGH THE GROUND

Building part 1

Ground characteristics				Climate data	
Thermal conductivity	λ	2,0	W/(mK)	Av. Indoor Temp. Winter	T _i 18,0 °C
Heat capacity	p _c	2,0	MJ/(m ³ K)	Av. Indoor Temp. Summer	T _i 24,0 °C
Periodic Penetration Depth	δ	3,17	m	Average Ground Surface Temperature	T _{g,ave} 11,7 °C

Building data				U-value floor slab/basement ceiling	
Area of ground floor slab / basement ceiling	A	910,2	m ²	U _f	1,977 W/(m ² K)
Perimeter length	P	123,8	m	Thermal bridges floor slab/basement ceiling	Ψ_B *I 0,00 W/K
Charact. Dimension of floor slab	B'	14,71	m	U-value floor slab / basement ceiling incl. TB	U' _f 1,977 W/(m ² K)

Floor Slab Type (select only one)					
<input checked="" type="checkbox"/> Slab on Grade	Perimeter Insulation Width/Depth	D	0,40	m	Orientation of the Perimeter Ins.
	Perimeter Insulation Thickness	d _n	0,20	m	(check only one field)
	Conductivity perimeter insulation	λ_n	0,033	W/(mK)	horizontal
					vertical <input checked="" type="checkbox"/>
<input checked="" type="checkbox"/> Heated basement or floor slab completely / partially below ground level	Basement wall height below ground level	z		U-value below ground wall	U _{wB}
					W/(m ² K)
<input checked="" type="checkbox"/> Unheated basement	Height aboveground wall	h		U-value above ground wall	U _w
	Basement wall height below ground level	z		U-value below ground wall	U _{wB}
	Air Change Unheated Basement	n		U-value Basement Floor Slab	U _{IB}
	Air flow basement	V			W/(m ² K)
<input checked="" type="checkbox"/> Suspended Floor Above a Ventilated Crawl Space (at max. 0.5 m Below Ground)	U-value Crawl Space	U _{Crawl}		Area of Ventilation Openings	εP
	Height of crawl space wall	h		Wind Velocity at 10 m Height	v
	U-value crawl space wall	U _w		Wind Shield factor	f _w
					m ²
					m/s
					0,05
Additional Thermal Bridge Heat Losses at Perimeter					
Phase shift	β		Months	Steady-State Fraction	$\Psi_{P,stat}^* I$ -4,457 W/K
				Harmonic Fraction	$\Psi_{P,harm}^* I$ -4,457 W/K

Groundwater correction					
Depth of the Groundwater Table	z_w	3,0	m	Groundwater Correction Factor	G _w #DIV/0! -
Groundwater flow rate	q _w	0,05	m/d		

Interim Results					
Phase shift	β	0,90	Months	Steady-state heat flow	Φ_{stat} 1586,8 W
Steady-state transmittance	L _s	251,07	W/K	Periodic Heat Flow	Φ_{harm} 625,2 W
Exterior Periodic transmittance	L _{pe}	100,94	W/K	Heat Losses During Heating Period	Q _{tot} 10042 kWh
Transmittance building	L ₀	1794,63	W/K		

Monthly Average temperatures in the ground for monthly method (building assembly 1)													
Month	1	2	3	4	5	6	7	8	9	10	11	12	Average value
Winter	16,6	16,5	16,6	16,8	17,1	17,5	17,7	17,8	17,7	17,4	17,1	16,8	17,1
Summer	21,7	21,6	21,7	22,0	22,3	22,6	22,8	22,9	22,8	22,6	22,3	21,9	22,3

Design ground temperature for 'Heating load' worksheet	16,5	For 'Cooling load' worksheet	22,9
Reduction factor for 'Annual heating' worksheet	0,09		

Total result (all building parts)					
Phase shift	β	0,90	Months	Steady-state heat flow	Φ_{stat} 1586,8 W
Steady-state transmittance	L _s	251,07	W/K	Periodic Heat Flow	Φ_{harm} 625,2 W
Exterior Periodic transmittance	L _{pe}	100,94	W/K	Heat Losses During Heating Period	Q _{tot} 10042 kWh
Transmittance building	L ₀	1794,63	W/K	Charact. Dimension of floor slab	B' 14,71 m

Monthly Average temperatures in the ground for monthly method (all building assemblies)													
Month	1	2	3	4	5	6	7	8	9	10	11	12	Average value
Winter	16,6	16,5	16,6	16,8	17,1	17,5	17,7	17,8	17,7	17,4	17,1	16,8	17,1
Summer	21,7	21,6	21,7	22,0	22,3	22,6	22,8	22,9	22,8	22,6	22,3	21,9	22,3

Design ground temperature for 'Heating load' worksheet	16,5	For 'Cooling load' worksheet	22,9
Reduction factor for 'Annual heating' worksheet	0,09		

P A S S I V E H O U S E - C O M P O N E N T SGo to: [AREAS](#)[Glazing](#)[Window frame](#)<http://www.passiv.de/komponentendatenbank/en-EN>[Ventilation units](#)[Compact units](#)**Building assemblies (U-values)**

ID	Building system	Building assembly	1		
			Total thickness	U-Value	Interior insulation
		Summary of the constructions calculated in 'U values' worksheet	m	W/(m²K)	-
01ud	Block C - plaster	Block C - plaster	0,510	0,130	
02ud	Block C - plaster external insulation	Block C - plaster external insulation	0,510	0,130	
03ud					
04ud					
05ud					
06ud					
07ud	Floor slab on grade (tiles)	Floor slab on grade (tiles)	0,520	2,586	
08ud	Floor slab on grade (Gym)	Floor slab on grade (Gym)	0,430	1,767	
09ud					
10ud	Roof dressingrooms direct to external a	Roof dressingrooms direct to external a	0,600	0,101	

Glazing		Glazing	
ID	Description	g-Value	U _g -Value
			W/(m ² K)
01ud	44 mm. triple glazing, 2 Low-E, air, alum.spacer	0,51	0,70
02ud			
03ud			
04ud			
05ud			
06ud			
07ud			
08ud			
09ud			
10ud			

Window frames															Window frames			
	Description	U _r -Value				Frame Width				Glazing edge thermal bridge				Installation thermal bridge				Curtain wall facades:
ID		left	right	bottom	above	left	right	bottom	above	Ψ _{Glazing edge left}	Ψ _{Glazing edge right}	Ψ _{Glazing edge bottom}	Ψ _{Glazing edge top}	Ψ _{Installation left}	Ψ _{Installation right}	Ψ _{Installation bottom}	Ψ _{Installation top}	
		W/(m ² K)	W/(m ² K)	W/(m ² K)	W/(m ² K)	m	m	m	m	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/K	
01ud	EXISTING: metal, thermal break	2,40	2,40	2,40	2,40	0,140	0,140	0,140	0,140	0,040	0,040	0,040	0,040	0,088	0,088	0,088	0,088	
02ud	EXISTING: synthetic before 1998	1,80	1,80	1,80	1,80	0,140	0,140	0,140	0,140	0,050	0,050	0,050	0,050	0,088	0,088	0,088	0,088	
03ud	VEKA AG ALPHALINE 90 MD	0,97	0,97	0,97	0,97	0,118	0,118	0,118	0,118	0,030	0,030	0,030	0,030	0,040	0,040	0,040	0,040	
04ud																		
05ud																		
06ud																		
07ud																		
08ud																		
09ud																		
10ud																		

Ventilation units with heat recovery												
					Additional Device Data							
ID	Description	Heat recovery efficiency	Energy recovery value η_{FRG}	Electric efficiency	Entry area		External pressure per line	Fittings Δp_{intern}	Frost protection required	Noise protection		Additional info
	User defined area	%	%	Wh/m³	m³/h	m³/h	Pa	Pa		35 dB(A)	Supply air dB(A)	Extract air dB(A)
01ud	Tangra ventilation unit EVB 04 HiE	82%	0%	0,40	150	400	100	incl.	yes	—	57	57
02ud	Tangra ventilation unit EVB 06 HiE	82%	0%	0,40	250	600	100	incl.	yes	—	61	61
03ud	Tangra ventilation unit EVB 08 HiE	82%	0%	0,40	400	800			yes	—	61	61
04ud	Tangra ventilation unit EVB 10 HiE	82%	0%	0,40	500	1000			yes	—	61	61
05ud	Tangra ventilation unit EVB 12 HiE	82%	0%	0,40	750	1200			yes	—	68	68
06ud	Tangra ventilation unit EVB 16 HiE	82%	0%	0,40	800	1600			yes	—	68	68
07ud	Tangra ventilation unit EVB 20 HiE	82%	0%	0,40	1000	2000			yes	—	68	68
08ud												
09ud												
10ud												

REDUCTION FACTOR SOLAR RADIATION, WINDOW U-VALUE

Building: Primary School 3 "Tzanko Diustabakov" - Section A								Annual heating demand:	46	kWh/(m²a)	Heating degree hours:													
Climate:	User data - Велико Търново РНІ					g-Value	Solar radiation reduction factor	Window area	Window U-Value	Glazing area	Average global radiation	Transmission losses	Heat gains solar radiation											
Window area orientation	Global radiation (cardinal points)	Shading	Dirt	Non-perpendicular incident radiation	Glazing fraction			m ²	W/(m ² K)	m ²	kWh/(m ² a)	kWh/a	kWh/a											
maximum:	kWh/(m ² a)	0,75	0,95	0,85	0,541	0,70	0,30	58,20	2,39	31,48	142	65,3	9085	1718										
North	122	0,68	0,95	0,85	0,541	0,70	0,28	12,52	2,35	6,20	368	1924	901											
East	240	0,70	0,95	0,85	0,495	0,70	0,28	100,80	2,82	53,29	370	18547	8168											
South	432	0,67	0,95	0,85	0,529	0,77	0,28	26,46	2,62	11,76	151	4524	622											
West	243	0,60	0,95	0,85	0,445	0,72	0,22	0,00	0,00	0,00	400	0	0											
jhtin	Horizontal	400	1,00	0,95	0,85	0,000	0,00	0,00	0,00	0,00	400	34080	11409											
Total or Average Value for All Windows.								0,74	0,28	197,98	2,64	102,73	11409											
Go to glazing list								Go to window frames list							Results									
								user-defined value for $\Psi_{\text{installed}}$ or '1': $\Psi_{\text{installed}}$ from worksheet 'Components' '0': in the case of abutting windows							U- and Ψ -values from 'Components' worksheet can be shown through clicking the '+' sign on the top edge of the sheet.									
Quantity	Description	Deviation from North	Angle of inclination from the horizontal	Orientation	Width	Height	Selection from worksheet 'Areas'	Selection from worksheet 'Components'	Perpendicular Radiation	Glazing	Frames (centre)	Ψ_{spacer} (centre)	left	right	bottom	above	$\Psi_{\text{Installation (Average)}}$	Window Area	Glazing Area	U-Value Window	Glazed fraction per window	Transmission-losses	Solar gains	
		Degrees	Degrees		m	m	Sort: AS LIST	Sort: AS LIST	-	W/(m ²)	W/(m ² K)	W/(mK)	W/(mK) or 1/0	W/(mK)	W/(mK)	W/(mK)	m ²	m ²	W/(m ² K)	%	kWh/a	kWh/a		
2	Type 1 North	0	90	North	0,600	1,440	1-North facade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al3ud VEKA AG ALPHALINE 90 MD	0,51	0,70	0,97	0,030	1	0	1	1	0,040	1,7	0,88	1,06	51%	120	36	
2		0	90	North	0,600	1,440	1-North facade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al3ud VEKA AG ALPHALINE 90 MD	0,51	0,70	0,97	0,030	0	1	1	1	0,040	1,7	0,88	1,06	51%	120	36	
1	Type 2 North	0	90	North	0,900	0,900	1-North facade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al3ud VEKA AG ALPHALINE 90 MD	0,51	0,70	0,97	0,030	1	1	1	1	0,040	0,8	0,44	1,10	54%	58	18	
5	Type 3 North	0	90	North	1,050	0,950	3-North facade 2	01ud 44 mm. triple glazing, 2 Low-E, air, al3ud VEKA AG ALPHALINE 90 MD	0,51	0,70	0,97	0,030	1	0	1	1	0,040	5,0	2,91	1,03	58%	334	122	
5		0	90	North	1,050	0,950	3-North facade 2	01ud 44 mm. triple glazing, 2 Low-E, air, al3ud VEKA AG ALPHALINE 90 MD	0,51	0,70	0,97	0,030	0	1	1	1	0,040	5,0	2,91	1,03	58%	334	122	
2	Type 3 North-west	315	90	West	1,050	0,950	4-North-west facade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al3ud VEKA AG ALPHALINE 90 MD	0,51	0,70	0,97	0,030	1	0	1	1	0,040	2,0	1,16	1,03	58%	134	59	
2		315	90	West	1,050	0,950	4-North-west facade 1	01ud 44 mm. triple glazing, 2 Low-E, air, al3ud VEKA AG ALPHALINE 90 MD	0,51	0,70	0,97	0,030	0	1	1	1	0,040	2,0	1,16	1,03	58%	134	59	
2	Type 4 North-east	45	90	North	0,800	1,500	5-North-east facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	1	0	0	1	0,088	2,4	1,27	2,90	53%	454	76
2		45	90	North	0,800	1,500	5-North-east facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	0	1	0,088	2,4	1,27	2,90	53%	454	76
2		45	90	North	0,800	1,500	5-North-east facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	0	1	0,088	2,4	1,27	2,90	53%	454	76
2		45	90	North	0,800	1,500	5-North-east facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	0	1	0,088	2,4	1,27	2,90	53%	454	76
10		45	90	North	0,800	1,500	5-North-east facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	0	1	0,088	12,0	6,34	2,79	53%	2183	378
10		45	90	North	0,800	1,500	5-North-east facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	0	0	1	0,088	12,0	6,34	2,79	53%	2183	378
6	Type 4 South-west	225	90	South	0,800	1,500	7-South-west facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	1	0	0	1	0,088	7,2	3,81	2,90	53%	1362	583
6		225	90	South	0,800	1,500	7-South-west facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	0	1	0,088	7,2	3,81	2,90	53%	1362	583
6		225	90	South	0,800	1,500	7-South-west facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	1	0	1	0	0,088	7,2	3,81	2,90	53%	1362	583
30		225	90	South	0,800	1,500	7-South-west facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	0	1	0	0,088	36,0	19,03	2,79	53%	6550	2917
30		225	90	South	0,800	1,500	7-South-west facade 1	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	0	0	1	0,088	36,0	19,03	2,79	53%	6550	2917
1	Type 5 South-west	45	90	North	0,800	1,850	9-North-east facade 2	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	1	0	1	1	0,088	1,5	0,82	2,94	55%	284	50
5		45	90	North	0,800	1,850	9-North-east facade 2	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	0	1	1	0,088	7,4	4,08	2,83	55%	1367	249
1		45	90	North	0,800	1,850	9-North-east facade 2	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	1	1	0,088	1,5	0,82	2,94	55%	284	50
1	Door	135	90	East	0,800	1,800	23-South-east facade 3	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	1	0	0	1	0,088	1,4	0,79	2,89	55%	272	123
1		135	90	East	0,800	1,000	23-South-east facade 3	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	0	1	0,088	0,8	0,37	2,91	47%	152	54
1		135	90	East	1,600	0,900	23-South-east facade 3	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	1	0	0	0	0,088	1,4	0,62	2,79	57%	262	133
1		135	90	East	1,600	0,900	23-South-east facade 3	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	0	0	0	0,000	1,4	0,62	2,74	57%	257	133
1		135	90	East	1,600	1,000	23-South-east facade 3	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	0	0	0,088	1,6	0,95	2,79	59%	292	158
1		135	90	East	0,600	0,900	23-South-east facade 3	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	1	0	1	0	0,088	0,5	0,20	2,93	37%	103	25
1		135	90	East	0,600	0,900	23-South-east facade 3	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	0	1	0,088	0,5	0,20	2,78	37%	98	25
1		135	90	East	0,600	1,000	23-South-east facade 3	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	1	0	0,088	0,6	0,23	2,93	38%	115	30
2	Type 6 South-east	135	90	East	0,600	0,800	10-South-east facade 2	01ud 44 mm. triple glazing, 2 Low-E, air, al3ud VEKA AG ALPHALINE 90 MD	0,51	0,70	0,97	0,030	1	1	0	1	0,040	1,0	0,41	1,15	43%	72	48	
2		135	90	East	0,600	1,600	10-South-east facade 2	01ud 44 mm. triple glazing, 2 Low-E, air, al3ud VEKA AG ALPHALINE 90 MD	0,51	0,70	0,97	0,030	1	1	0	0	0,040	1,9	0,99	1,07	52%	134	122	
2		135	90	East	0,600	1,600	10-South-east facade 2	01ud 44 mm. triple glazing, 2 Low-E, air, al3ud VEKA AG ALPHALINE 90 MD	0,51	0,70	0,97	0,030	1	1	1	0	0,040	0,7	0,26	1,19	37%	56	30	
1	Roof triangle	135	90	East	1,160	0,450	21-South-east facade 2	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	1	1	1	1	0,088	0,5	0,15	3,22	29%	110	19
1	Roof triangle	315	90	West	1,160	0,450	23-North-west facade 2	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	1	1	1	1	0,088	0,5	0,15	3,22	29%	110	7
1	Roof	315	90	West	0,700	0,950	16-South-west facade 2	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	1	1	1	1	0,088	0,7	0,28	3,01	42%	131	15
31	Roof	315	90	West	0,700	0,950	16-South-west facade 2	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	0	1	1	0,088	20,6	8,72	2,89	42%	3885	466
1	Roof	315	90	West	0,700	0,950	16-South-west facade 2	97ud Double glazing 430mm air/7	01ud EXISTING: metal, thermal break	0,77	2,80	2,40	0,040	0	1	1	1	0,088	0,7	0,28	3,01	42%	131</	

CALCULATING SHADING FACTORS

Climate: User data - Велико Търново PHI
 Building: Primary School 3 "Tzanko Diustabov" - Section A
 Latitude: 43,086 °

Orientation	Glazing area	Reduction factor winter	Summer reduction factor
			r_s
North	31,48	68%	78%
East	6,20	70%	39%
South	53,29	67%	41%
West	11,76	60%	48%
Horizontal	0,00	100%	100%

Space heating demand: 46,3 kWh/(m²a)
 Useful Cooling Demand: 0,3 kWh/(m²a)
 Frequency of overheating: 0,1%

8

Quantity	Description	Deviation from North	Angle of inclination from the horizontal	Orientation	Horizon		Reveal		Overhang		Winter						Summer					
					m	m	m	m	m	m	%	%	%	%	%	%	%	%	%	%	%	
					h_{glz}	h_{glz}	h_{horiz}	d_{horiz}	d_{reveal}	d_{over}	$r_{other,w}$	$r_{other,s}$	z	r_s	r_s	r_s	r_s	r_s	r_s	r_s		
2	Type 1 North	0	90	North	0,36	1,20	0,9		0,16	0,11	0,16	0,13		100%	86%	94%	81%	100%	86%	98%	85%	
2		0	90	North	0,36	1,20	0,9		0,16	0,13	0,16	0,13		100%	86%	94%	81%	100%	86%	98%	85%	
1	Type 2 North	0	90	North	0,56	0,66	0,4		0,16	0,131	0,16	0,13		100%	90%	91%	82%	100%	90%	95%	86%	
5	Type 3 North	0	90	North	0,81	0,71	2,9		0,16	0,131	0,16	0,13		100%	92%	91%	84%	100%	92%	96%	88%	
5		0	90	North	0,81	0,71	2,9		0,16	0,131	0,16	0,13		100%	92%	91%	84%	100%	92%	96%	88%	
2	Type 3 North-w	315	90	West	0,81	0,71	1,2		0,16	0,131	0,16	0,13		100%	90%	91%	82%	100%	94%	96%	90%	
2		315	90	West	0,81	0,71	1,2		0,16	0,131	0,16	0,13		100%	90%	91%	82%	100%	94%	96%	90%	
2	Type 4 North-e	45	90	North	0,52	1,22	1,3		0,35	0,120	0,35	0,12		100%	74%	87%	64%	100%	83%	92%	76%	
2		45	90	North	0,52	1,22	1,3		0,35	0,120	0,35	0,12		100%	74%	87%	64%	100%	83%	92%	76%	
2		45	90	North	0,52	1,22	1,3		0,35	0,120	0,35	0,12		100%	74%	87%	64%	100%	83%	92%	76%	
10		45	90	North	0,52	1,22	6,3		0,35	0,120	0,35	0,12		100%	74%	87%	64%	100%	83%	92%	76%	
10		45	90	North	0,52	1,22	6,3		0,35	0,120	0,35	0,12		100%	74%	87%	64%	100%	83%	92%	76%	
6	Type 4 South-w	225	90	South	0,52	1,22	3,8		0,35	0,120	0,35	0,12		60%	100%	75%	89%	67%	100%	82%	84%	41%
6		225	90	South	0,52	1,22	3,8		0,35	0,120	0,35	0,12		60%	100%	75%	89%	67%	100%	82%	84%	41%
6		225	90	South	0,52	1,22	3,8		0,35	0,120	0,35	0,12		60%	100%	75%	89%	67%	100%	82%	84%	41%
30		225	90	South	0,52	1,22	19,0		0,35	0,120	0,35	0,12		60%	100%	75%	89%	67%	100%	82%	84%	41%
30		225	90	South	0,52	1,22	19,0		0,35	0,120	0,35	0,12		60%	100%	75%	89%	67%	100%	82%	84%	41%
1	Type 5 South-w	45	90	North	0,52	1,57	0,8		0,35	0,120	0,35	0,12		100%	74%	90%	66%	100%	83%	94%	78%	
5		45	90	North	0,52	1,57	4,1		0,35	0,120	0,35	0,12		100%	74%	90%	66%	100%	83%	94%	78%	
1		45	90	North	0,52	1,57	0,8		0,35	0,120	0,35	0,12		100%	74%	90%	66%	100%	83%	94%	78%	
1	Door	135	90	East	0,52	1,52	0,8		0,35	0,120	0,35	0,12		60%	100%	75%	91%	68%	100%	82%	85%	43%
1		135	90	East	0,52	0,72	0,4		0,35	0,120	0,35	0,12		60%	100%	75%	84%	63%	100%	82%	85%	35%
1		135	90	East	1,32	0,62	0,8		0,35	0,120	0,35	0,12		60%	100%	86%	82%	71%	100%	90%	67%	36%
1		135	90	East	1,32	0,62	0,8		0,35	0,120	0,35	0,12		60%	100%	86%	82%	71%	100%	90%	67%	36%
1		135	90	East	1,32	0,72	1,0		0,35	0,120	0,35	0,12		60%	100%	86%	84%	73%	100%	90%	71%	39%
1		135	90	East	0,32	0,62	0,2		0,35	0,120	0,35	0,12		60%	100%	68%	82%	56%	100%	77%	67%	31%
1		135	90	East	0,32	0,62	0,2		0,35	0,120	0,35	0,12		60%	100%	68%	82%	56%	100%	77%	67%	31%
1		135	90	East	0,32	0,72	0,2		0,35	0,120	0,35	0,12		60%	100%	68%	84%	57%	100%	77%	71%	33%
2	Type 6 South e	135	90	East	0,36	0,56	0,4		0,16	0,131	0,16	0,13		60%	100%	85%	91%	77%	100%	89%	89%	47%
2		135	90	East	0,36	1,36	1,0		0,16	0,131	0,16	0,13		60%	100%	85%	95%	81%	100%	89%	97%	52%
2		135	90	East	0,36	0,36	0,3		0,16	0,131	0,16	0,13		60%	100%	85%	88%	75%	100%	89%	82%	44%
1	Roof triangle	135	90	East	0,88	0,17	0,1		0,35	0,120	0,35	0,12		60%	100%	82%	67%	55%	100%	87%	42%	22%
1	Roof triangle	315	90	West	0,88	0,17	0,1		0,35	0,120	0,35	0,12		60%	100%	81%	64%	52%	100%	88%	60%	53%
1	Roof	315	90	West	0,42	0,67	0,3		0,35	0,120	0,35	0,12		60%	100%	71%	81%	57%	100%	81%	83%	40%
31	Roof	315	90	West	0,42	0,67	0,7		0,35	0,120	0,35	0,12		60%	100%	71%	81%	57%	100%	81%	83%	40%
1	Roof	315	90	West	0,42	0,67	0,3		0,35	0,120	0,35	0,12		60%	100%	71%	81%	57%	100%	81%	83%	40%

VENTILATION DATA

Building:

Primary School 3 "Tzanko Diustabanov" - Section A

Treated floor area A_{TFA}	m ²	848	(Areas worksheet)
Room Height h	m	2,50	
Room ventilation volume ($A_{TFA} \cdot h$) =	m ³	2121	(Worksheet Annual heating)

Ventilation type

Please select

Balanced PH-Ventilation with HR

Infiltration air change rate

Wind protection coefficients e and f		
Coefficient e for screening class	Several side exposed	One side exposed
No screening	0,10	0,03
Moderate screening	0,07	0,02
High screening	0,04	0,01
Coefficient f	15	20
Wind protection coefficient, e	for annual demand:	for Heating Load:
	0,07	0,18
Wind protection coefficient, f	15	15
Air Change Rate at Press. Test	n ₅₀	Net Air Volume for Press. Test V _{n50} m ³
	1/h	2,00
Excess extract air	for annual demand:	for Heating Load:
	0,00	0,00
Infiltration air change rate	n _{V,Rest}	1/h

Selection of ventilation data input - Results

The PHPP offers two methods for dimensioning the air quantities and choosing the ventilation unit. Fresh air or extract air quantities for residential buildings and parameters for ventilation system can be determined using the standard planning option in the 'Ventilation' sheet. The 'Additional Vent' sheet has been created for more complex ventilation systems and allows up to 10 different ventilation units. Furthermore, air quantities can be determined on a room-by-room or zone-by-zone basis. Please select your design method here.

Ventilation unit / Heat recovery efficiency design	(Ventilation worksheet see below)	Average	Extract air	Effective heat	Specific	Heat
		Air	Average	excess	recovery	power
Standard design	(Ventilation worksheet see below)	Exchange m ³ /h	Air Change Rate 1/h	(Extract air system) 1/h	efficiency Unit [-]	value [-]
<input checked="" type="checkbox"/> Various vent. units, non residential	(Worksheet Additional vent)	808	0,38	0,00	81,0%	0,0%

SHX efficiency η_{SHX} 0 %

STANDARD INPUT FOR BALANCED VENTILATION

Ventilation dimensioning for systems with one ventilation unit

Calculation in sheet 'Additional Vent': Extended data input for balanced ventilation

Occupancy		17
Number of occupants	P	50,0
Supply air per person	m³/(P·h)	30
Supply air requirement	m³/h	1500
Extract air rooms		Bathroom
Quantity	Kitchen	Bathroom (shower only)
Extract air requirement per room	60	40
Total Extract Air Requirement	m³/h	20
	m³/h	20
Design air flow rate (maximum)	m³/h	

Type of operation	Daily operation duration	Factors referenced to maximum	Air flow rate	Air change rate
			m³/h	1/h
maximum		1,00	#WERT!	#WERT!
Standard	24,0	0,77	#WERT!	#WERT!
Basic		0,54	#WERT!	#WERT!
Minimum		0,40	#WERT!	#WERT!
Average value		0,77	Average air flow rate (m³/h)	Average air change rate (1/h)

Selection of ventilation unit with heat recovery

Installation site of ventilation unit	inside the thermal envelope	Heat recovery?	
Ventilation unit selection	Sort: BY ID	Heat recovery efficiency Unit η_{HR}	Specific power input [Wh/m³]
	Go to ventilation units list	Energy recovery η_{ERV}	Application range [m³/h]
Conductance value of exterior air duct Ψ	W/(mK)	0,000	See calculation below
Length of exterior air duct	m		
Conductance value of exhaust air duct Ψ	W/(mK)	0,000	See calculation below
Length of exhaust air duct	m		
Temperature of mechanical services room (Enter only if the central unit is outside of the thermal envelope.)	°C		Room temperature (°C) Av. Ambient Temp. Heating P. (°C) Av. Ground Temp (°C)
Effective heat recovery efficiency	$\eta_{HR,eff}$		18 4,3 11,7

Effective heat recovery efficiency subsoil heat exchanger

SHX efficiency	η_{SHX}
Heat recovery efficiency SHX	0 %

Secondary calculation

Ψ -value supply or ambient air duct

Nominal width:	mm
Insul. Thickness:	mm
Reflective?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Thermal conductivity	W/(mK)
Nominal air flow rate	m³/h
$\Delta\vartheta$	14 K
Exterior duct diameter	0,000 m
Exterior diameter	0,000 m
α -Interior	0,00 W/(m²K)
α -Surface	W/(m²K)
Ψ -value	W/(mK)
Surface temperature difference	K

Secondary calculation

Ψ -value extract or exhaust air duct

Nominal width:	mm
Insul. Thickness:	mm
Reflective?	yes <input checked="" type="checkbox"/> no <input type="checkbox"/>
Thermal conductivity	W/(mK)
Nominal air flow rate	m³/h
$\Delta\vartheta$	14 K
Exterior duct diameter	0,000 m
Exterior diameter	0,000 m
α -Interior	0,00 W/(m²K)
α -Surface	W/(m²K)
Ψ -value	W/(mK)
Surface temperature difference	K

EXTENDED DATA INPUT FOR BALANCED VENTILATION

Planning ventilation systems with multiple ventilation units

Building:

Primary School 3 "Tzanko Diustabanov" - Section A

- Ventilation unit / Heat recovery efficiency design
 - In Ventilation worksheet (standard design)
 - In Additional Vent (this worksheet)

Treated Floor Area A_{TFA}
Room Height h
Room air volume for ventilation ($A_{TFA} \cdot h$) = V_v
Number of Occupants
Room temperature
Average external temp. heating period
Average ground temp.

Ventilation type

Balanced PH-Ventilation with HR (Ventilation worksheet)

Results of ventilation design and unit selection:

Ventilation Unit no.	Description of the unit	Design		Average value / yr.		
		V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{SUP} m ³ /h	V _{ETA} m ³ /h	Air ch.rt 1/h
1	Floor 1	420	420	63	63	---
2	Floor 2	2000	2000	745	745	---
3						---
4						---
5						---
6						---
7						---
8						---
9						---
10						---

Result for overall vent. syst.

2420	2420	808	808	0,38
------	------	-----	-----	------

Effective heat recovery efficiency	Energy recovery value	spec. Input power	Heat recov. efficiency SHX	Cross check
77%	0%	0,40	0%	
81%	0%	0,40	0%	
81%	0%	0,40	0%	

Recommendations for dimensioning air quantities

Use of low odour and low-emission building materials/ furnishings:

It is strongly recommended to use building materials that cause no or only little pollution instead of increasing the outdoor air volume flow in order to reduce preventable pollution. This holds true independently from the chosen approach for the air quality determination; emissions of all sources in the room should be considered, e.g. furniture, carpets and ventilation or air-conditioning units.

Assessment of volume flow rates according to the number of persons

Also in non-residential buildings, the number of persons is fundamentally important for assessing the volume air flow rates. For good indoor air quality the amounts of 20 to 30 m³/h/person are completely sufficient. Higher outdoor air amounts may lead to excessively dry indoor air in winter. The air flow rates are specified by classification according to EN 13779. The classification must be agreed with the client in advance. IDA 3 is adequate for office buildings. IDA 4 has proven satisfactory for school buildings as purge ventilation is carried out during breaks anyway. For typical external air CO₂ concentrations of around 400-500 ppm, it is possible to comply even with 1500 ppm. Exceeding this figure temporarily is permissible.

Fresh air flow rates per person:

- Recommended for residential buildings: around 30 m³/h (person)
 - Recommended for offices and similar uses: around 30 m³/h (person) (AMEV: 28 m³/h (person); EN 13779 / IDA 3: at least 24 m³/h (person))
 - Recommended for schools and day care centres: 15 to 20 m³/h (person) (Source: Guidelines for energy-efficient educational buildings, Passive House Institute, 2010)
 - Recommendation for sport halls: 60 m³/h (person) (DIN 18032-1)

Purging phase for intermittent ventilation operation

Due to the purge ventilation phase, the ventilation operation period is extended accordingly (utilisation time + purge ventilation phase). Please consider this for the ventilation design. Emulsions have to be removed. Elushing the building prolongs the utilisation time of the ventilation system (utilisation time + flushing phase). Please consider this at design stage.

Design of air quantities

When designing the air quantities, please consider the design recommendations given above.

The ventilation operation period can be determined on the basis of the daily utilisation hours including purging phase if applicable. In addition, time periods with reduced ventilation requirements (operation modes) can be

Taken into account by means of reduction factors.

Room Nr.	Amount a	Room name	Assignment to ventilation unit	Area A m ²	Clear height h m	Room vol. A x h m ³	Volume flow per room V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{TRANS} m ³ /h	Air change rate per room n 1/h	Utilisation times h/d	d/week d	weeks/yr Weeks	Reduction Red.1	Operation Red. 1	Reduction Red.2	Operation Red.2	Reduction Red.3	Operation Red.3	Cross check	Average volume flows V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{TRANS} m ³ /h	Average air change rate 1/h
1	2	Teacher office	1	13,5	3,00	41	50	10		1,23	12	7	32	100%	15%	60%	15%	35%	70%		15	3		0,18
2	1	Dressing room	1	36	3,00	108	160			1,48	12	7	32	100%	15%	60%	15%	35%	70%		24			0,22
3	1	Dressing room	1	27	3,00	81	140			1,73	12	7	32	100%	15%	60%	15%	35%	70%		21			0,26
4	2	Showers, batl	1	9	3,00	27		100		3,70	12	7	32	100%	15%	60%	15%	35%	70%					0,55
5	1	Corridor	1	62,87	3,00	189	20	150		0,80	12	7	32	100%	15%	60%	15%	35%	70%		3	22		0,12
6	1	Gym-storage	1	25,47	3,00	76		50		0,65	12	7	32	100%	15%	60%	15%	35%	70%			7		0,10
7	1	Gym	2	630,76	8,00	5046	1600	2000		0,40	15	7	50	100%	30%	60%	30%	35%	40%		596	745		0,15
8	1	Tribune	2	46,79	3,00	140	400			2,85	15	7	50	100%	30%	60%	30%	35%	40%		149			1,06
9	1	Stairs	1	9,08	8,00	73		50		0,69	12	7	32	100%	15%	60%	15%	35%	70%			7		0,10
10														100%	100%									
11														100%	100%									
12														100%	100%									
13														100%	100%									
14														100%	100%									
15														100%	100%									
16														100%	100%									
17														100%	100%									
18														100%	100%									
19														100%	100%									
20														100%	100%									
21														100%	100%									
22														100%	100%									
23														100%	100%									
24														100%	100%									
25														100%	100%									
26														100%	100%									
27														100%	100%									
28														100%	100%									
29														100%	100%									
30														100%	100%									
31														100%	100%									
32														100%	100%									
33														100%	100%									
34														100%	100%									

Additional lines: Please mark complete lines above, copy and paste multiple times

808	808	---	0,14
-----	-----	-----	------

Ventilation unit selection

Up to 10 different ventilation units are considered. By changing the amount, identical units can be considered. The data from PHI certified ventilation units as well as the entry data lines for user data for other ventilation units can also be found in the worksheet "Components". When choosing to use a compact unit the standard design in the Ventilation worksheet has to be used.

[Go to ventilation units list](#)

Ventilation Unit no.	Quantity [-]	Description Ventilation units	Selection Unit type	Design vol. flow per unit m³/h	Entry area for volume flow rate from m³/h to m³/h	Electrical efficiency Wh/m³	Pressure loss calculation			Entry area per line ΔP _{external} Pa	Subtraction ΔP _{internal} Pa	Cross check		Interior location (x)	Exterior location (x)	Heat recovery efficiency Unit [-]	Energy recovery effective [-]	Frost protection necessary	Subsoil HX Effective- efficiency degree	Efficiency of heat recovery	U noise level < 35dB(A)	Noise protection Supply air db(A)
							ODA-SUP ΔP _{duct} Pa	ETA-EHA ΔP _{duct} Pa	Additional ΔP _{internal} Pa			Pressure loss assessment duct network										
1	1	Floor 1	02ud Tangra ventilation unit EVB 06 Hi	420	250	600	0,40	65	65	75	100	-	Probably too high	x		0,82	77%	0%	yes	0%	n.a.	61
2	1	Floor 2	07ud Tangra ventilation unit EVB 20 Hi	2000	1000	2000	0,40	60	60	70	-	-	ok	x		0,82	81%	0%	yes	0%	n.a.	68

[Change sorting type](#)

1	1	Floor 1	02ud Tangra ventilation unit EVB 06 Hi	420	250	600	0,40	65	65	75	100	-	Probably too high	x		0,82	77%	0%	yes	0%	n.a.	61
2	1	Floor 2	07ud Tangra ventilation unit EVB 20 Hi	2000	1000	2000	0,40	60	60	70	-	-	ok	x		0,82	81%	0%	yes	0%	n.a.	68
3																						
4																						
5																						
6																						
7																						
8																						
9																						
10																						

Data entries for duct sections between the ventilation unit and the thermal envelope

The duct sections between the ventilation unit and the thermal envelope should be as short as possible and should be well insulated, both for interior as for exterior location of the ventilation unit. These duct sections can be entered here. The heat losses of the overlying duct section will be considered for the effective heat recovery efficiency.

An entered duct section can also be used for multiple ventilation units.

If in the section "Ventilation unit - selection" in one line a ventilation unit is selected as multiple units (amount larger than 1 for identical units), then the corresponding duct sections may simply be entered (duct sections for one ventilation unit).

Temperature of the location of installation (only enter when at least one unit is installed outside of the thermal envelope)

Quantity	Cross check	Round duct ins. diameter mm	Rectangular duct Width mm	Height mm	Insulation Thickness mm	Thermal conductivity W/(m K)	Reflective insulation duct (x)	Transmittance duct W/(m K)	Length of Supply air m	Ambient or Extract air Duct (1)	Exhaust or flow Duct (1)	Duct type	Design Volume rate	Vent. Unit 1	Vent. Unit 2	Allocation to ventilation units (when central unit applicable enter "1")							
																Vent. Unit 3	Vent. Unit 4	Vent. Unit 5	Vent. Unit 6	Vent. Unit 7	Vent. Unit 8	Vent. Unit 9	Vent. Unit 10
1		315			150	0,033		0,278	6	1		Ambient air	420	1									
1		315			150	0,033		0,278	12,2		1	Fortluft	420	1									
1		315			150	0,033		0,295	3	1		Ambient air	2000		1								
1		315			150	0,033		0,295	8,6		1	Fortluft	2000		1								
1		315			150	0,033			3	1		Ambient air	0		1								
1		315			150	0,033			5		1	Fortluft	0		1								

Additional lines: Please mark complete lines above, copy and paste multiple times

EnerPHit planning: **SPECIFIC ANNUAL HEATING DEMAND (annual method)**


Climate: User data - Велико Търново РН1	Interior Temperature: 18,0 °C																																																																																																																																																																																																																																																																															
Building: Primary School 3 "Tzanko Diustabanov" - Section A	Building type: School																																																																																																																																																																																																																																																																															
Treated Floor Area A _{TFA} : 848,4 m ²	per m ²																																																																																																																																																																																																																																																																															
<table border="1"> <thead> <tr> <th>Building assembly</th> <th>Temperature Zone</th> <th>Area m²</th> <th>U-Value W/(m²K)</th> <th>Temp. Factor f_t</th> <th>G_t kWh/a</th> <th>kWh/a</th> <th>Treated Floor Area</th> </tr> </thead> <tbody> <tr><td>Exterior Wall - Ambient</td><td>A</td><td>539,2</td><td>* 0,130</td><td>* 1,00</td><td>* 65,3</td><td>= 4580</td><td>5,40</td></tr> <tr><td>Exterior Wall - Ground</td><td>B</td><td></td><td>* 0,09</td><td>* 0,09</td><td></td><td></td><td></td></tr> <tr><td>Roof/Ceiling - Ambient</td><td>A</td><td>955,4</td><td>* 0,110</td><td>* 1,00</td><td>* 65,3</td><td>= 6873</td><td>8,10</td></tr> <tr><td>Floor slab / basement ceiling</td><td>B</td><td>910,2</td><td>* 1,977</td><td>* 0,09</td><td>* 65,3</td><td>= 10067</td><td>11,87</td></tr> <tr><td></td><td>A</td><td></td><td></td><td>* 1,00</td><td></td><td></td><td></td></tr> <tr><td></td><td>X</td><td></td><td></td><td>* 1,00</td><td></td><td></td><td></td></tr> <tr><td>Windows</td><td>A</td><td>198,0</td><td>* 2,636</td><td>* 0,75</td><td>* 65,3</td><td>= 34080</td><td>40,17</td></tr> <tr><td>Exterior Door</td><td>A</td><td>3,0</td><td>* 0,800</td><td>* 1,00</td><td>* 65,3</td><td>= 157</td><td>0,18</td></tr> <tr><td>Exterior TB (length/m)</td><td>A</td><td>203,3</td><td>* 0,081</td><td>* 1,00</td><td>* 65,3</td><td>= 1075</td><td>1,27</td></tr> <tr><td>Perimeter TB (length/m)</td><td>P</td><td>123,8</td><td>* -0,036</td><td>* 0,09</td><td>* 65,3</td><td>= -25</td><td>-0,03</td></tr> <tr><td>Ground TB (length/m)</td><td>B</td><td></td><td></td><td>* 0,09</td><td></td><td></td><td>0,00</td></tr> <tr> <td>Total of all building envelope areas</td> <td></td> <td>2605,8</td> <td></td> <td></td> <td></td> <td></td> <td>KWh/(m²a)</td> </tr> <tr> <td>Transmission heat losses Q_T</td> <td></td> <td></td> <td></td> <td></td> <td>Total 56807</td> <td></td> <td>67,0</td> </tr> <tr> <td colspan="2"> <table border="1"> <thead> <tr> <th>Ventilation System:</th> <th>A_{TFA} m²</th> <th>Clear Room Height m</th> <th>m³</th> </tr> </thead> <tbody> <tr><td>Effective Air Volume, V_v</td><td>848,4</td><td>* 2,50</td><td>= 2121,0</td></tr> <tr><td>η_{eff} 81%</td><td></td><td></td><td></td></tr> <tr><td>Efficient heat recovery of heat recovery</td><td></td><td></td><td></td></tr> <tr><td>Efficiency of Subsoil Heat Exchanger η_{SHX} 0%</td><td></td><td></td><td></td></tr> <tr><td>Energetically Effective Air Exchange n_v 0,381</td><td>* (1 - 0,81)</td><td>+ 0,046</td><td>= 0,119</td></tr> <tr> <td>V_v m³</td> <td>n_v 1/h</td> <td>c_{Air} W/(m²K)</td> <td>G_t kWh/a</td> </tr> <tr> <td>2121,0</td> <td>* 0,119</td> <td>* 0,33</td> <td>* 65,3 = 5419</td> <td>kWh/a</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>KWh/(m²a)</td> </tr> <tr> <td>Ventilation heat losses Q_V</td> <td></td> <td></td> <td></td> <td></td> <td>6,4</td> <td></td> </tr> <tr> <td>Total heat losses Q_L</td> <td>(Q_T + Q_V)</td> <td>Reduction Factor Night/Weekend Saving 1,0</td> <td></td> <td></td> <td>62226</td> <td>KWh/(m²a) 73,3</td> </tr> <tr> <td>Orientation of the area</td> <td>Reduction Factor See 'Windows' worksheet</td> <td>g-Value (perp. radiation)</td> <td>Area</td> <td>Radiation HP</td> <td></td> <td></td> </tr> <tr> <td>1. North</td> <td>0,30</td> <td>* 0,70</td> <td>* 58,20</td> <td>* 142 = 1718</td> <td></td> <td></td> </tr> <tr> <td>2. East</td> <td>0,28</td> <td>* 0,70</td> <td>* 12,52</td> <td>* 368 = 901</td> <td></td> <td></td> </tr> <tr> <td>3. South</td> <td>0,28</td> <td>* 0,77</td> <td>* 100,80</td> <td>* 370 = 8168</td> <td></td> <td></td> </tr> <tr> <td>4. West</td> <td>0,22</td> <td>* 0,72</td> <td>* 26,46</td> <td>* 151 = 622</td> <td></td> <td></td> </tr> <tr> <td>5. Horizontal</td> <td>0,00</td> <td>* 0,00</td> <td>* 0,00</td> <td>* 400 = 0</td> <td></td> <td></td> </tr> <tr> <td>Available Solar Heat Gains Q_S</td> <td></td> <td></td> <td></td> <td></td> <td>Total 11409</td> <td>13,4</td> </tr> <tr> <td>Internal Heat Gains Q_I</td> <td>kh/d 0,024</td> <td>Length heating period d/a 189</td> <td>Spec. Power q_i W/m² 2,80</td> <td>A_{TFA} m² 848,4</td> <td>= 10785</td> <td>KWh/(m²a) 12,7</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Q_S + Q_I = 22194</td> <td>KWh/(m²a) 26,2</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Ratio of Free Heat to Losses Q_F / Q_L = 0,36</td> <td></td> </tr> <tr> <td>Utilisation Factor Heat Gains η_G</td> <td></td> <td></td> <td></td> <td></td> <td>(1 - (Q_F / Q_L)⁵) / (1 - (Q_F / Q_L)⁶) = 100%</td> <td>KWh/a KWh/(m²a)</td> </tr> <tr> <td>Heat Gains Q_G</td> <td></td> <td></td> <td></td> <td></td> <td>η_G * Q_F = 22111</td> <td>26,1</td> </tr> <tr> <td>Annual heating demand QH</td> <td></td> <td></td> <td></td> <td></td> <td>Q_L - Q_G = 40115</td> <td>47</td> </tr> <tr> <td></td> <td>Limiting value 25</td> <td></td> <td></td> <td></td> <td>Requirement met? (Yes/No)</td> <td>no</td> </tr> </tbody></table> </td></tr></tbody></table>		Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Temp. Factor f _t	G _t kWh/a	kWh/a	Treated Floor Area	Exterior Wall - Ambient	A	539,2	* 0,130	* 1,00	* 65,3	= 4580	5,40	Exterior Wall - Ground	B		* 0,09	* 0,09				Roof/Ceiling - Ambient	A	955,4	* 0,110	* 1,00	* 65,3	= 6873	8,10	Floor slab / basement ceiling	B	910,2	* 1,977	* 0,09	* 65,3	= 10067	11,87		A			* 1,00					X			* 1,00				Windows	A	198,0	* 2,636	* 0,75	* 65,3	= 34080	40,17	Exterior Door	A	3,0	* 0,800	* 1,00	* 65,3	= 157	0,18	Exterior TB (length/m)	A	203,3	* 0,081	* 1,00	* 65,3	= 1075	1,27	Perimeter TB (length/m)	P	123,8	* -0,036	* 0,09	* 65,3	= -25	-0,03	Ground TB (length/m)	B			* 0,09			0,00	Total of all building envelope areas		2605,8					KWh/(m ² a)	Transmission heat losses Q _T					Total 56807		67,0	<table border="1"> <thead> <tr> <th>Ventilation System:</th> <th>A_{TFA} m²</th> <th>Clear Room Height m</th> <th>m³</th> </tr> </thead> <tbody> <tr><td>Effective Air Volume, V_v</td><td>848,4</td><td>* 2,50</td><td>= 2121,0</td></tr> <tr><td>η_{eff} 81%</td><td></td><td></td><td></td></tr> <tr><td>Efficient heat recovery of heat recovery</td><td></td><td></td><td></td></tr> <tr><td>Efficiency of Subsoil Heat Exchanger η_{SHX} 0%</td><td></td><td></td><td></td></tr> <tr><td>Energetically Effective Air Exchange n_v 0,381</td><td>* (1 - 0,81)</td><td>+ 0,046</td><td>= 0,119</td></tr> <tr> <td>V_v m³</td> <td>n_v 1/h</td> <td>c_{Air} W/(m²K)</td> <td>G_t kWh/a</td> </tr> <tr> <td>2121,0</td> <td>* 0,119</td> <td>* 0,33</td> <td>* 65,3 = 5419</td> <td>kWh/a</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>KWh/(m²a)</td> </tr> <tr> <td>Ventilation heat losses Q_V</td> <td></td> <td></td> <td></td> <td></td> <td>6,4</td> <td></td> </tr> <tr> <td>Total heat losses Q_L</td> <td>(Q_T + Q_V)</td> <td>Reduction Factor Night/Weekend Saving 1,0</td> <td></td> <td></td> <td>62226</td> <td>KWh/(m²a) 73,3</td> </tr> <tr> <td>Orientation of the area</td> <td>Reduction Factor See 'Windows' worksheet</td> <td>g-Value (perp. radiation)</td> <td>Area</td> <td>Radiation HP</td> <td></td> <td></td> </tr> <tr> <td>1. North</td> <td>0,30</td> <td>* 0,70</td> <td>* 58,20</td> <td>* 142 = 1718</td> <td></td> <td></td> </tr> <tr> <td>2. East</td> <td>0,28</td> <td>* 0,70</td> <td>* 12,52</td> <td>* 368 = 901</td> <td></td> <td></td> </tr> <tr> <td>3. South</td> <td>0,28</td> <td>* 0,77</td> <td>* 100,80</td> <td>* 370 = 8168</td> <td></td> <td></td> </tr> <tr> <td>4. West</td> <td>0,22</td> <td>* 0,72</td> <td>* 26,46</td> <td>* 151 = 622</td> <td></td> <td></td> </tr> <tr> <td>5. Horizontal</td> <td>0,00</td> <td>* 0,00</td> <td>* 0,00</td> <td>* 400 = 0</td> <td></td> <td></td> </tr> <tr> <td>Available Solar Heat Gains Q_S</td> <td></td> <td></td> <td></td> <td></td> <td>Total 11409</td> <td>13,4</td> </tr> <tr> <td>Internal Heat Gains Q_I</td> <td>kh/d 0,024</td> <td>Length heating period d/a 189</td> <td>Spec. Power q_i W/m² 2,80</td> <td>A_{TFA} m² 848,4</td> <td>= 10785</td> <td>KWh/(m²a) 12,7</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Q_S + Q_I = 22194</td> <td>KWh/(m²a) 26,2</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Ratio of Free Heat to Losses Q_F / Q_L = 0,36</td> <td></td> </tr> <tr> <td>Utilisation Factor Heat Gains η_G</td> <td></td> <td></td> <td></td> <td></td> <td>(1 - (Q_F / Q_L)⁵) / (1 - (Q_F / Q_L)⁶) = 100%</td> <td>KWh/a KWh/(m²a)</td> </tr> <tr> <td>Heat Gains Q_G</td> <td></td> <td></td> <td></td> <td></td> <td>η_G * Q_F = 22111</td> <td>26,1</td> </tr> <tr> <td>Annual heating demand QH</td> <td></td> <td></td> <td></td> <td></td> <td>Q_L - Q_G = 40115</td> <td>47</td> </tr> <tr> <td></td> <td>Limiting value 25</td> <td></td> <td></td> <td></td> <td>Requirement met? (Yes/No)</td> <td>no</td> </tr> </tbody></table>		Ventilation System:	A _{TFA} m ²	Clear Room Height m	m ³	Effective Air Volume, V _v	848,4	* 2,50	= 2121,0	η _{eff} 81%				Efficient heat recovery of heat recovery				Efficiency of Subsoil Heat Exchanger η _{SHX} 0%				Energetically Effective Air Exchange n _v 0,381	* (1 - 0,81)	+ 0,046	= 0,119	V _v m ³	n _v 1/h	c _{Air} W/(m ² K)	G _t kWh/a	2121,0	* 0,119	* 0,33	* 65,3 = 5419	kWh/a					KWh/(m ² a)	Ventilation heat losses Q _V					6,4		Total heat losses Q _L	(Q _T + Q _V)	Reduction Factor Night/Weekend Saving 1,0			62226	KWh/(m ² a) 73,3	Orientation of the area	Reduction Factor See 'Windows' worksheet	g-Value (perp. radiation)	Area	Radiation HP			1. North	0,30	* 0,70	* 58,20	* 142 = 1718			2. East	0,28	* 0,70	* 12,52	* 368 = 901			3. South	0,28	* 0,77	* 100,80	* 370 = 8168			4. West	0,22	* 0,72	* 26,46	* 151 = 622			5. Horizontal	0,00	* 0,00	* 0,00	* 400 = 0			Available Solar Heat Gains Q _S					Total 11409	13,4	Internal Heat Gains Q _I	kh/d 0,024	Length heating period d/a 189	Spec. Power q _i W/m ² 2,80	A _{TFA} m ² 848,4	= 10785	KWh/(m ² a) 12,7													Q _S + Q _I = 22194	KWh/(m ² a) 26,2						Ratio of Free Heat to Losses Q _F / Q _L = 0,36		Utilisation Factor Heat Gains η _G					(1 - (Q _F / Q _L) ⁵) / (1 - (Q _F / Q _L) ⁶) = 100%	KWh/a KWh/(m ² a)	Heat Gains Q _G					η _G * Q _F = 22111	26,1	Annual heating demand QH					Q _L - Q _G = 40115	47		Limiting value 25				Requirement met? (Yes/No)	no
Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Temp. Factor f _t	G _t kWh/a	kWh/a	Treated Floor Area																																																																																																																																																																																																																																																																									
Exterior Wall - Ambient	A	539,2	* 0,130	* 1,00	* 65,3	= 4580	5,40																																																																																																																																																																																																																																																																									
Exterior Wall - Ground	B		* 0,09	* 0,09																																																																																																																																																																																																																																																																												
Roof/Ceiling - Ambient	A	955,4	* 0,110	* 1,00	* 65,3	= 6873	8,10																																																																																																																																																																																																																																																																									
Floor slab / basement ceiling	B	910,2	* 1,977	* 0,09	* 65,3	= 10067	11,87																																																																																																																																																																																																																																																																									
	A			* 1,00																																																																																																																																																																																																																																																																												
	X			* 1,00																																																																																																																																																																																																																																																																												
Windows	A	198,0	* 2,636	* 0,75	* 65,3	= 34080	40,17																																																																																																																																																																																																																																																																									
Exterior Door	A	3,0	* 0,800	* 1,00	* 65,3	= 157	0,18																																																																																																																																																																																																																																																																									
Exterior TB (length/m)	A	203,3	* 0,081	* 1,00	* 65,3	= 1075	1,27																																																																																																																																																																																																																																																																									
Perimeter TB (length/m)	P	123,8	* -0,036	* 0,09	* 65,3	= -25	-0,03																																																																																																																																																																																																																																																																									
Ground TB (length/m)	B			* 0,09			0,00																																																																																																																																																																																																																																																																									
Total of all building envelope areas		2605,8					KWh/(m ² a)																																																																																																																																																																																																																																																																									
Transmission heat losses Q _T					Total 56807		67,0																																																																																																																																																																																																																																																																									
<table border="1"> <thead> <tr> <th>Ventilation System:</th> <th>A_{TFA} m²</th> <th>Clear Room Height m</th> <th>m³</th> </tr> </thead> <tbody> <tr><td>Effective Air Volume, V_v</td><td>848,4</td><td>* 2,50</td><td>= 2121,0</td></tr> <tr><td>η_{eff} 81%</td><td></td><td></td><td></td></tr> <tr><td>Efficient heat recovery of heat recovery</td><td></td><td></td><td></td></tr> <tr><td>Efficiency of Subsoil Heat Exchanger η_{SHX} 0%</td><td></td><td></td><td></td></tr> <tr><td>Energetically Effective Air Exchange n_v 0,381</td><td>* (1 - 0,81)</td><td>+ 0,046</td><td>= 0,119</td></tr> <tr> <td>V_v m³</td> <td>n_v 1/h</td> <td>c_{Air} W/(m²K)</td> <td>G_t kWh/a</td> </tr> <tr> <td>2121,0</td> <td>* 0,119</td> <td>* 0,33</td> <td>* 65,3 = 5419</td> <td>kWh/a</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td>KWh/(m²a)</td> </tr> <tr> <td>Ventilation heat losses Q_V</td> <td></td> <td></td> <td></td> <td></td> <td>6,4</td> <td></td> </tr> <tr> <td>Total heat losses Q_L</td> <td>(Q_T + Q_V)</td> <td>Reduction Factor Night/Weekend Saving 1,0</td> <td></td> <td></td> <td>62226</td> <td>KWh/(m²a) 73,3</td> </tr> <tr> <td>Orientation of the area</td> <td>Reduction Factor See 'Windows' worksheet</td> <td>g-Value (perp. radiation)</td> <td>Area</td> <td>Radiation HP</td> <td></td> <td></td> </tr> <tr> <td>1. North</td> <td>0,30</td> <td>* 0,70</td> <td>* 58,20</td> <td>* 142 = 1718</td> <td></td> <td></td> </tr> <tr> <td>2. East</td> <td>0,28</td> <td>* 0,70</td> <td>* 12,52</td> <td>* 368 = 901</td> <td></td> <td></td> </tr> <tr> <td>3. South</td> <td>0,28</td> <td>* 0,77</td> <td>* 100,80</td> <td>* 370 = 8168</td> <td></td> <td></td> </tr> <tr> <td>4. West</td> <td>0,22</td> <td>* 0,72</td> <td>* 26,46</td> <td>* 151 = 622</td> <td></td> <td></td> </tr> <tr> <td>5. Horizontal</td> <td>0,00</td> <td>* 0,00</td> <td>* 0,00</td> <td>* 400 = 0</td> <td></td> <td></td> </tr> <tr> <td>Available Solar Heat Gains Q_S</td> <td></td> <td></td> <td></td> <td></td> <td>Total 11409</td> <td>13,4</td> </tr> <tr> <td>Internal Heat Gains Q_I</td> <td>kh/d 0,024</td> <td>Length heating period d/a 189</td> <td>Spec. Power q_i W/m² 2,80</td> <td>A_{TFA} m² 848,4</td> <td>= 10785</td> <td>KWh/(m²a) 12,7</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Q_S + Q_I = 22194</td> <td>KWh/(m²a) 26,2</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Ratio of Free Heat to Losses Q_F / Q_L = 0,36</td> <td></td> </tr> <tr> <td>Utilisation Factor Heat Gains η_G</td> <td></td> <td></td> <td></td> <td></td> <td>(1 - (Q_F / Q_L)⁵) / (1 - (Q_F / Q_L)⁶) = 100%</td> <td>KWh/a KWh/(m²a)</td> </tr> <tr> <td>Heat Gains Q_G</td> <td></td> <td></td> <td></td> <td></td> <td>η_G * Q_F = 22111</td> <td>26,1</td> </tr> <tr> <td>Annual heating demand QH</td> <td></td> <td></td> <td></td> <td></td> <td>Q_L - Q_G = 40115</td> <td>47</td> </tr> <tr> <td></td> <td>Limiting value 25</td> <td></td> <td></td> <td></td> <td>Requirement met? (Yes/No)</td> <td>no</td> </tr> </tbody></table>		Ventilation System:	A _{TFA} m ²	Clear Room Height m	m ³	Effective Air Volume, V _v	848,4	* 2,50	= 2121,0	η _{eff} 81%				Efficient heat recovery of heat recovery				Efficiency of Subsoil Heat Exchanger η _{SHX} 0%				Energetically Effective Air Exchange n _v 0,381	* (1 - 0,81)	+ 0,046	= 0,119	V _v m ³	n _v 1/h	c _{Air} W/(m ² K)	G _t kWh/a	2121,0	* 0,119	* 0,33	* 65,3 = 5419	kWh/a					KWh/(m ² a)	Ventilation heat losses Q _V					6,4		Total heat losses Q _L	(Q _T + Q _V)	Reduction Factor Night/Weekend Saving 1,0			62226	KWh/(m ² a) 73,3	Orientation of the area	Reduction Factor See 'Windows' worksheet	g-Value (perp. radiation)	Area	Radiation HP			1. North	0,30	* 0,70	* 58,20	* 142 = 1718			2. East	0,28	* 0,70	* 12,52	* 368 = 901			3. South	0,28	* 0,77	* 100,80	* 370 = 8168			4. West	0,22	* 0,72	* 26,46	* 151 = 622			5. Horizontal	0,00	* 0,00	* 0,00	* 400 = 0			Available Solar Heat Gains Q _S					Total 11409	13,4	Internal Heat Gains Q _I	kh/d 0,024	Length heating period d/a 189	Spec. Power q _i W/m ² 2,80	A _{TFA} m ² 848,4	= 10785	KWh/(m ² a) 12,7													Q _S + Q _I = 22194	KWh/(m ² a) 26,2						Ratio of Free Heat to Losses Q _F / Q _L = 0,36		Utilisation Factor Heat Gains η _G					(1 - (Q _F / Q _L) ⁵) / (1 - (Q _F / Q _L) ⁶) = 100%	KWh/a KWh/(m ² a)	Heat Gains Q _G					η _G * Q _F = 22111	26,1	Annual heating demand QH					Q _L - Q _G = 40115	47		Limiting value 25				Requirement met? (Yes/No)	no																																																																																																																		
Ventilation System:	A _{TFA} m ²	Clear Room Height m	m ³																																																																																																																																																																																																																																																																													
Effective Air Volume, V _v	848,4	* 2,50	= 2121,0																																																																																																																																																																																																																																																																													
η _{eff} 81%																																																																																																																																																																																																																																																																																
Efficient heat recovery of heat recovery																																																																																																																																																																																																																																																																																
Efficiency of Subsoil Heat Exchanger η _{SHX} 0%																																																																																																																																																																																																																																																																																
Energetically Effective Air Exchange n _v 0,381	* (1 - 0,81)	+ 0,046	= 0,119																																																																																																																																																																																																																																																																													
V _v m ³	n _v 1/h	c _{Air} W/(m ² K)	G _t kWh/a																																																																																																																																																																																																																																																																													
2121,0	* 0,119	* 0,33	* 65,3 = 5419	kWh/a																																																																																																																																																																																																																																																																												
				KWh/(m ² a)																																																																																																																																																																																																																																																																												
Ventilation heat losses Q _V					6,4																																																																																																																																																																																																																																																																											
Total heat losses Q _L	(Q _T + Q _V)	Reduction Factor Night/Weekend Saving 1,0			62226	KWh/(m ² a) 73,3																																																																																																																																																																																																																																																																										
Orientation of the area	Reduction Factor See 'Windows' worksheet	g-Value (perp. radiation)	Area	Radiation HP																																																																																																																																																																																																																																																																												
1. North	0,30	* 0,70	* 58,20	* 142 = 1718																																																																																																																																																																																																																																																																												
2. East	0,28	* 0,70	* 12,52	* 368 = 901																																																																																																																																																																																																																																																																												
3. South	0,28	* 0,77	* 100,80	* 370 = 8168																																																																																																																																																																																																																																																																												
4. West	0,22	* 0,72	* 26,46	* 151 = 622																																																																																																																																																																																																																																																																												
5. Horizontal	0,00	* 0,00	* 0,00	* 400 = 0																																																																																																																																																																																																																																																																												
Available Solar Heat Gains Q _S					Total 11409	13,4																																																																																																																																																																																																																																																																										
Internal Heat Gains Q _I	kh/d 0,024	Length heating period d/a 189	Spec. Power q _i W/m ² 2,80	A _{TFA} m ² 848,4	= 10785	KWh/(m ² a) 12,7																																																																																																																																																																																																																																																																										
					Q _S + Q _I = 22194	KWh/(m ² a) 26,2																																																																																																																																																																																																																																																																										
					Ratio of Free Heat to Losses Q _F / Q _L = 0,36																																																																																																																																																																																																																																																																											
Utilisation Factor Heat Gains η _G					(1 - (Q _F / Q _L) ⁵) / (1 - (Q _F / Q _L) ⁶) = 100%	KWh/a KWh/(m ² a)																																																																																																																																																																																																																																																																										
Heat Gains Q _G					η _G * Q _F = 22111	26,1																																																																																																																																																																																																																																																																										
Annual heating demand QH					Q _L - Q _G = 40115	47																																																																																																																																																																																																																																																																										
	Limiting value 25				Requirement met? (Yes/No)	no																																																																																																																																																																																																																																																																										

(This page displays the sums of the monthly method over the heating period)						
Climate: Белико Търново PHI	Interior Temperature: 18 °C					
Building: Primary School 3 "Tzankov Diustabakov" - Section A	Building type: School					
Spec. Capacity: 204 Wh/(m²K)	Treated Floor Area A_{TFA} : 848,4 m²					
Building assembly	Temperature Zone	Area m²	U-Value W/(m²K)	Month. Red. Fac.	G_t kWh/a	per m² Treated Floor Area
Exterior Wall - Ambient	A	539,2	* 0,130	* 1,00	* 72 = 5022	5,92
Exterior Wall - Ground	B		* 1,00	*	=	
Roof/Ceiling - Ambient	A	955,4	* 0,110	* 1,00	* 72 = 7535	8,88
Floor slab / basement ceiling	B	910,2	* 1,977	* 1,00	* 7 = 12411	14,63
	A				=	
	A				=	
	X					
Windows	A	198,0	* 2,636	* 1,00	* 72 = 37362	44,04
Exterior Door	A	3,0	* 0,800	* 1,00	* 72 = 172	0,20
Exterior TB (length/m)	A	203,3	* 0,081	* 1,00	* 72 = 1179	1,39
Perimeter TB (length/m)	P	123,8	* -0,036	* 1,00	* 7 = -31	-0,04
Ground TB (length/m)	B				=	0,00
Total						63650
						75,0
Transmission heat losses Q_T						
	Effective Air Volume V_v	A_{TFA} m²	Clear Room Height m	m^3		
		848	* 2,50	= 2121		
	$\eta_{V,system}$ 1/h	$\eta_{V,SIX}$	η_{HR}	$\eta_{V,Res}$ 1/h	$\eta_{V,equi,fraction}$ 1/h	
Effective Air Change Rate Ambient $n_{v,a}$	0,381	* (1- 0%) * (1- 0,81) + 0,046	= 0,119			
Effective Air Change Rate Ground $n_{v,g}$	0,381	* 0% * (1- 0,81)	= 0,000			
Ventilation losses ambient Q_V	V_v m³	$\eta_{V,equi,fraction}$ 1/h	C_{Air} W/(m²K)	G_t kWh/a	kWh/a	kWh/(m²a)
Ventilation losses ground $Q_{V,e}$	2121	* 0,119	* 0,33	* 72 = 5941	7,0	
Total					5941	7,0
Ventilation heat losses Q_V						
	Q_T kWh/a	Q_V kWh/a	Reduction Factor Night/Weekend Saving	kWh/a	kWh/(m²a)	
Total heat losses Q_L	(63650) + (5941) * 1,0 = 69591			69591	82,0	
Orientation of the area	Reduction Factor See 'Windows' worksheet	g-Value (perp. radiation)	Area m^2	$kWh/(m²a)$	kWh/a	
North	0,30	* 0,70	* 58,2	* 282 = 3416		
East	0,28	* 0,70	* 12,5	* 632 = 1546		
South	0,28	* 0,77	* 100,8	* 630 = 13898		
West	0,22	* 0,72	* 26,5	* 298 = 1231		
Horizontal	0,00	* 0,00	* 0,0	* 787 = 0		
Sum opaque areas					1862	
Total					21953	25,9
Available Solar Heat Gains Q_S						
	kh/d	Length Heat. Period d/a	Spec. Power q_s W/m²	A_{TFA} m²	kWh/a	kWh/(m²a)
Internal Heat Gains Q_I	0,024	* 273	* 2,8	* 848,4 = 15564	18,3	
Free Heat Q_F				$Q_S + Q_I = 37517$	44,2	
Ratio Free Heat to Losses				$Q_F / Q_L = 0,54$		
Utilisation Factor Heat Gains η_G				= 81% kWh/a		
Heat Gains Q_G				$\eta_G * Q_F = 30313$	35,7	
Annual heating demand Q_H				$Q_L - Q_G = 39278$	46	
Limiting value				(Yes/No)		
				Requirement met?	NO	

Climate: Велико Търново RHI
 Building: Primary School 3 "Tzanko Diustabakov" - Section A

Interior Temperature: 18 °C
 Building type: School
 Treated Floor Area A_{TFA}: 848 m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heating Degree Hours - Exterior	14,2	11,1	9,6	5,6	1,6	-1,0	-2,7	-2,5	1,6	5,3	8,9	13,6	65 kWh
Heating Degree Hours - Ground	1,1	1,0	1,1	0,9	0,6	0,4	0,2	0,2	0,2	0,4	0,7	0,9	8 kWh
Losses - Exterior	11332	8901	7663	4482	1293	-824	-2157	-1977	1297	4247	7150	10845	52252 kWh
Losses - Ground	1934	1836	1903	1529	1150	705	428	329	443	781	1172	1633	13842 kWh
Sum spec. losses	15,6	12,7	11,3	7,1	2,9	-0,1	-2,0	-1,9	2,1	5,9	9,8	14,7	77,9 kWh/m ²
Solar gains - North	190	256	404	598	773	845	825	690	497	341	191	167	5776 kWh
Solar gains - East	121	138	185	223	235	231	244	235	219	188	126	110	2255 kWh
Solar gains - South	1076	1249	1715	1917	2013	1926	2072	2120	2005	1762	1180	981	20017 kWh
Solar gains - West	64	91	154	204	266	281	283	254	188	134	75	55	2048 kWh
Solar gains - Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0 kWh
Solar gains - Opaque	106	144	225	310	376	389	407	362	282	203	119	94	3020 kWh
Internal Heat Gains	1767	1596	1767	1710	1767	1710	1767	1767	1710	1767	1710	1767	20810 kWh
Sum spec. gains solar + internal	3,9	4,1	5,2	5,8	6,4	6,3	6,6	6,4	5,8	5,2	4,0	3,7	63,6 kWh/m ²
Utilisation Factor	100%	100%	99%	91%	45%	100%	100%	100%	35%	89%	99%	100%	50%
Annual heating demand	9943	7270	5161	1511	22	0	0	0	5	1121	4940	9305	39278 kWh
Spec. Heating Demand	11,7	8,6	6,1	1,8	0,0	0,0	0,0	0,0	0,0	1,3	5,8	11,0	46,3 kWh/m ²



Annual heating demand: Comparison

Monthly method

(Worksheet Heating) 39278 kWh/a

Annual method

(Worksheet Annual) 40115 kWh/a

(Worksheet Heating) 46,3 kWh/(m²a) reference to treated floor area according to PHPP(Worksheet Annual) 47,3 kWh/(m²a) reference to treated floor area according to PHPP

SPECIFIC SPACE HEATING LOAD

Building: Primary School 3 "Tzanko Diustabakov" - Section A
 Building type: School
 Climate (HL): Велико Търново РНІ
 Treated Floor Area A_{TFA} : 848,4 m²
 Interior Temperature: 18 °C

Weather 1:	Design Temperature		Radiation: North		South		West		Horizontal		W/m ²
	-9,1	°C	19	39	82	35	56	W/m ²			
Weather 2:	-4,6		°C	16	23	40	24	36	W/m ²		
Ground Design Temp.:	16,5	°C	Area	U-value	Factor Always 1 (except 'X')	TempDiff 1	TempDiff 2	P _{T 1}	P _{T 2}		
Building assembly	Temperature Zone	m ²	W/(m ² K)		K	K		W	W		
1. Exterior Wall - Ambient	A	539,2	*	0,130	1,00	27,1	22,6	= 1899	= 1583		
2. Exterior Wall - Ground	B	*	*	*	1,00	1,5	1,5	=	=		
3. Roof/Ceiling - Ambient	A	955,4	*	0,110	1,00	27,1	22,6	= 2849	= 2375		
4. Floor slab / basement ceiling	B	910,2	*	1,977	1,00	1,5	1,5	= 2738	= 2738		
5.		*	*	*	1,00	27,1	22,6	=	=		
6.	A	*	*	*	1,00	27,1	22,6	=	=		
7.	X	*	*	*	0,75	27,1	22,6	=	=		
8. Windows	A	198,0	*	2,636	1,00	27,1	22,6	= 14127	= 11778		
9. Exterior Door	A	3,0	*	0,800	1,00	27,1	22,6	= 65	= 54		
10. Perimeter TB (length/m)	A	203,3	*	0,081	1,00	27,1	22,6	= 446	= 372		
11. Perimeter TB (length/m)	P	123,8	*	-0,036	1,00	1,5	1,5	= -7	= -7		
12. Ground TB (length/m)	B	*	*	*	1,00	1,5	1,5	=	=		
13. House/DU Partition Wall	I	*	*	*	1,00	1,0	1,0	=	=		

Transmission heat load P_T

Total	=	22117	or	18894
-------	---	-------	----	-------

Ventilation System:	A_{TFA}		Clear Room Height		Efficiency SHX	$\eta_{SHX\ 1}$	$\eta_{SHX\ 2}$
	Effective Air Volume, V _v	m ²	m	m ³			
		848,4	*	2,50	= 2121		
Heat recovery efficiency of the Heat Exchanger	η_{HR}	81%	Heat Recovery Efficiency SHX	0%	Efficiency SHX	0%	0%
Energetically Effective Air Exchange n _v	n _{v,Res} (Heating Load)	1/h	n _{v,system}	1/h	Φ_{HR}	Φ_{HR}	
	0,105	+	0,381	*	(1 - 0,81)	0,177	1/h
Ventilation heat load P _v	V _v	m ³	n _v	1/h	Φ_{HR}	Φ_{HR}	1/h
	2121,0	*	0,177	or 0,177	0,81	= 0,177	0,177

Total heating load P_L

P _T + P _v	=	25477	or	21696
---------------------------------	---	-------	----	-------

Orientation of the area	Area m ²	g-Value (perp. radiation)	Reduction Factor (see 'Windows' worksheet)	Radiation 1 W/m ²	Radiation 2 W/m ²	P _{T 1} W	P _{T 2} W
1. North	58,2	*	0,7	0,30	22	= 265	= 202
2. East	12,5	*	0,7	0,28	67	= 165	= 83
3. South	100,8	*	0,8	0,28	65	= 1426	= 763
4. West	26,5	*	0,7	0,22	20	= 83	= 73
5. Horizontal	0,0	*	0,0	0,40	56	= 0	= 0

Solar heating power P_s

Total	=	1939	or	1121
-------	---	------	----	------

Internal heating load P _i	Spec. Power W/m ²	A_{TFA} m ²	P _{i 1} W	P _{i 2} W
	1,6	*	= 1357	= 1357

Heating power (gains) P_G

P _T + P _i	=	3296	or	2478
P _L - P _G	=	22181	or	19218

Heating load P_H

=	22181	W
---	-------	---

Area specific space heating load PH / A_{TFA}

=	26,1	W/m ²
---	------	------------------

Input Max. Supply Air Temperature 52 °C
 Max. Supply Air Temperature $\dot{v}_{Supply,Max}$ 52 °C
 Supply Air Temperature Without Heating
 $\dot{v}_{Supply,Min}$ 12,9 °C
 13,7 °C

For comparison: heating load transportable by the supply Air. P_{Supply Air,Max}

= 10435 W specific: 12,3 W/m²

(Yes/No)
Supply Air Heating Sufficient? **no**

SUMMER VENTILATION

Building: Primary School 3 "Tzanko Diustabanov" - Section panels	Building type: School
Building volume: 2121 m ³	Heat recovery η _{HRV} : 81%
Max. indoor absolute humidity: 12 g/kg	Energy recovery η _{ER} : 0%
Internal humidity sources: 2 g/(m ² h)	Subsoil heat exchanger η [*] _{SHX} : 0%

Results passive cooling		Results active cooling	
Frequency of overheating: 0,1%	at the overheating limit θ _{max} = 24 °C	Useful Cooling Demand: 0,3 kWh/(m ² a)	
Frequency of exceeded humidity: 0,0%	max. humidity: 11,5 g/kg	Dehumidification demand: 0,1 kWh/(m ² a)	

Summer background ventilation to ensure adequate air quality

Air exchange via ventilation system with supply 0,63 1/h	HRV/ERV in Summer (check only one field)
	None <input checked="" type="checkbox"/>
	automatic bypass, controlled by temperature difference <input type="checkbox"/>
	automatic bypass, controlled by enthalpy difference <input type="checkbox"/>
	always <input type="checkbox"/>
Air exchange via extract air system 0,00 1/h	Specific power consumption (for extract air system) 0,00 Wh/m ³
Window ventilation air exchange 0,19 1/h	

Effective air exchange

	n _{V,system} 1/h	η [*] _{SHX}	η _{HR}	n _{V,equi,fraction} 1/h
exterior n _{V,e} without HR	0,630	*(1- 0%)*(1- 0,81	= 0,120
Ground n _{L,g} without HR	0,630	*(1- 0%)*(1- 0,81	= 0,630
	0,630	* 0%		= 0,000
				= 0,000

Ventilation conductance

	V _V m ³	n _{V,equi,fraction} 1/h	c _{Air} Wh/(m ² K)	
exterior H _{V,e} without HR	2121	* 0,120	* 0,33	= 83,8 W/K
Ground H _{V,g} without HR	2121	* 0,630	* 0,33	= 441,0 W/K
Infiltration, window, extract air system	2121	* 0,000	* 0,33	= 0,0 W/K
	2121	* 0,000	* 0,33	= 0,0 W/K
		* 0,190	* 0,33	= 133,0 W/K

Additional Summer Ventilation for Cooling

Additional ventilation regulation
Minimum Acceptable Indoor Temperature **18,0** °C

Type of additional ventilation

Window Night Ventilation, Manual	Night ventilation value 0,19 1/h		
mechanical, automatically Controlled ventilation	Corresponding air change rate 0,63 1/h during operation, in addition to base air change Specific power consumption 0,40 Wh/m ³	Temperature difference 0,40 K	Controlled by (please choose) <input checked="" type="checkbox"/>

Secondary Calculation: hygienic air exchange through window ventilation

Estimation for window air exchange to ensure sufficient air quality

Description

Open duration [h/d]

	Day GF	Day GF	Day GF			
Open duration [h/d]	2	2	12			

Climate Boundary Conditions

Temperature Diff Interior - Exterior
Wind Velocity

4	4	4				K
1	1	1				m/s

Window Group 1

Quantity

Clear Width

Clear Height

Tilting window (check if appropriate)

Opening Width (for tilting windows)

2	3	6				m
0,60	1,00	1,85				m
1,44	0,95	1,50				m
x	x	x				m
0,055	0,055	0,055				m

Window Group 2 (Cross Ventilation)

Quantity

Clear Width

Clear Height

Tilting window (check if appropriate)

Opening Width (for Tilting Windows)

1	1	3				m
1,05	1,05	1,85				m
2,00	2,00	1,50				m
x	x	x				m
0,055		0,055				m

Difference in Height to Window 1

Result: air exchange

0,03	0,03	0,12	0,00	0,00	0,00	Total 0,19 1/h
------	------	------	------	------	------	----------------

Secondary calculation: additional night ventilation for cooling

Air change value during additional window night ventilation

Description

Reduction Factor

	Night	Night	Night			
Reduction Factor	100%	100%	100%			

Climate Boundary Conditions

Temperature Diff Interior - Exterior
Wind Velocity

1	1	1	1	1	1	K
0	0	0	0	0	0	m/s

Window Group 1

Quantity

Clear Width

Clear Height

Tilting window (check if appropriate)

Opening Width (for Tilting Window)

2	1	4				m
1,85	1,85	1,00				m
1,50	1,50	0,95				m
x	x	x				m
0,055	0,055	0,055				m

Window Group 2 (Cross Ventilation)

Quantity

Clear Width

Clear Height

Tilting window (check if appropriate)

Opening Width (for Tilting Window)

2	1	3				m
1,85	1,85	1,85				m
1,50	1,50	1,50				m
x	x	x				m
0,055	0,055	0,055				m

Difference in Height to Window 1

Result: night ventilation values

0,03	0,02	0,13	0,00	0,00	0,00	Total 0,19 1/h
------	------	------	------	------	------	----------------

SUMMER: PASSIVE COOLING


Climate: Велико Търново РНІ	Building type: School				
Building: Primary School 3 "Tzanko Diustabakov" - Section A	Treated Floor Area A_{TFA} : 848,4 m ²				
Overtemperature limit: 24 °C	Building volume: 2121 m ³				
Nominal humidity: 12 g/kg	Internal humidity sources: 2,0 g/(m ³ h)				
Spec. Capacity: 204 Wh/(m ² K)					
Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Red. Factor $f_{T,SUMMER}$	H_{SUMMER} Heat Conductance
1. Exterior Wall - Ambient	A	539,2	* 0,130	* 1,00	= 70,1
2. Exterior Wall - Ground	B	955,4	* 0,110	* 1,00	= 105,2
3. Roof/Ceiling - Ambient	A	910,2	* 1,977	* 1,00	= 1799,1
4. Floor slab / basement ceiling	B			* 1,00	=
5.	A			* 1,00	=
6.	A			* 1,00	=
7.	X			* 0,75	=
8. Windows	A	198,0	* 2,636	* 1,00	= 521,9
9. Exterior Door	A	3,0	* 0,800	* 1,00	= 2,4
10. Exterior TB (length/m)	A	203,3	* 0,081	* 1,00	= 16,5
11. Perimeter TB (length/m)	P	123,8	* -0,036	* 1,00	= -4,5
12. Ground TB (length/m)	B			* 1,00	=
					716,1 W/K
					1794,6 W/K
Exterior Thermal Transmittance, $H_{T,e}$					
Ground Thermal Transmittance, $H_{T,g}$					
Summer Ventilation from 'SummVent' worksheet					
Ventilation unit conductance		Ventilation parameter		Summer ventilation regulation	
Exterior $H_{v,e}$	83,8 W/K	Temperature amplitude summer	11,2 K	HRV/ERV	x
without HR	441,0 W/K	Minimum Acceptable Indoor Temperature	18,0 °C	None	
Ground $H_{v,g}$	0,0 W/K	Heat capacity air	0,33 Wh/(m ³ K)	Controlled by temperature	
without HR	0,0 W/K	Supply air exchange	0,63 1/h	Controlled by enthalpy	
Ventilation conductance, others		Ambient air exchange	0,19 1/h	always	
Exterior	133,0 W/K	Window night ventilation air exchange rate, manual @ 1K	0,19 1/h		
		Air change rate due to mechanical, automatically controlled ventilation	0,63 1/h	Controlled by temperature	
		Specific power consumption for	0,40 Wh/m ³	Controlled by humidity	x
		η_{HR}	81%		
		η_{ERV}	0%		
		η^{SHX}	0%		
Orientation of the area	Angle Factor Summer	Shading Factor Summer	Loss-Dirt	g-Value (perp. radiation)	Area m ²
1. North	0,9	*	0,78	* 0,95	* 58,2
2. East	0,9	*	0,39	* 0,95	* 12,5
3. South	0,9	*	0,41	* 0,95	* 100,8
4. West	0,9	*	0,48	* 0,95	* 26,5
5. Horizontal	0,9	*	1,00	* 0,95	* 0,0
6. Sum opaque areas				* 0,00	
					54%
					49%
					53%
					44%
					0%
					0,0
					2,8
					Total 37,0
Solar Aperture					
Internal Heat Gains Q_I					
Frequency of Overheating $h_{\vartheta} \geq \vartheta_{max}$ 0,1% At the overheating limit $\vartheta_{max} = 24$ °C					
If the "frequency over 25°C" exceeds 10%, additional measures to protect against the heat during the summer are necessary.					
Daily internal temperature stroke					
Transmission kWh/d	1/k	Ventilation kWh/d	Solar load kWh/d	Spec. Capacity Wh/(m ² K)	A_{TFA} m ²
(96,2) + 142,6 + 150,7) * 1000 / (204 * 848) = 2,3 K					

S P E C I F I C U S E F U L C O O L I N G D E M A N D

Climate: Велико Търново РНІ
 Building: Primary School 3 "Tzanko Diustabakov" - Section A

Interior Temperature: 24 °C
 Building type: School
 Treated Floor Area A_{TFA} : 848 m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heating Degree Hours - Exterior	18,7	15,2	14,1	9,9	6,1	3,3	1,8	2,0	6,0	9,8	13,3	18,1	118 kKh
Heating Degree Hours - Ground	5,5	5,1	5,5	5,2	5,1	4,7	4,7	4,6	4,6	4,9	5,0	5,4	60 kKh
Losses - Exterior	23900	19435	17987	12686	7744	4157	2194	2484	7575	12508	17000	23124	150795 kWh
Losses - Ground	9969	9094	9939	9305	9184	8478	8460	8361	8217	8814	8947	9668	108436 kWh
Losses summer ventilation	14250	11432	10362	7098	4224	2293	1395	1446	4140	6990	9792	13737	87161 kWh
Sum spec. heat losses	56,7	47,1	45,1	34,3	24,9	17,6	14,2	14,5	23,5	33,4	42,1	54,8	408,3 kWh/m ²
Solar load North	232	314	496	733	948	1036	1012	846	609	419	234	204	7083 kWh
Solar load East	72	82	110	133	140	137	145	140	130	112	75	66	1341 kWh
Solar load South	704	816	1121	1253	1316	1259	1355	1386	1311	1152	772	641	13086 kWh
Solar load West	53	75	128	170	221	234	235	211	156	111	62	46	1703 kWh
Solar load Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0 kWh
Solar load Opaque	106	144	225	310	376	389	407	362	282	203	119	94	3020 kWh
Internal Heat Gains	1767	1596	1767	1710	1767	1710	1767	1767	1710	1767	1710	1767	20810 kWh
Sum spec. loads solar + internal	3,5	3,6	4,5	5,1	5,6	5,6	5,8	5,6	4,9	4,4	3,5	3,3	55,4 kWh/m ²
Utilisation Factor Losses	6%	8%	10%	15%	23%	32%	39%	38%	21%	13%	8%	6%	14%
Useful Cooling Energy Demand	0	0	0	1	4	19	185	39	3	0	0	0	252 kWh
Spec. Cooling Demand	0,0	0,0	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,0	0,0	0,3 kWh/m ²
spec. dehumidification demand	0,0	0,0	0,0	0,0	0,0	0,0	0,1	0,0	0,0	0,0	0,0	0,0	0,1 kWh/m ²
Sensible Fraction	100%	100%	100%	100%	100%	100%	70%	100%	100%	100%	100%	100%	76%



S P E C I F I C U S E F U L C O O L I N G D E M A N D

(This page displays the sums of the monthly method over the cooling period)

Climate: Велико Търново PHI

Building: Primary School 3 "Tzanko Diustabakov" - Section A

Building type: School

Treated Floor Area A_{TFA} : 848,4 m²

Interior temperature summer: 24 °C

Building volume: 2121 m³

Nominal humidity: 12 g/kg

Internal humidity sources: 2,0 g/(m³)Spec. Capacity: 204 Wh/(m²K)

Building assembly	Temperature Zone	Area m ²	U-Value W/(m ² K)	Mon. Red. Fac.	G_i kWh/a	kWh/a	per m ² Treated Floor Area
1. Exterior Wall - Ambient	A	539,2	*	0,130	*	1,00	= 3715
2. Exterior Wall - Ground	B	*	*	1,00	*	=	
3. Roof/Ceiling - Ambient	A	955,4	*	0,110	*	1,00	= 5574
4. Floor slab / basement	c B	910,2	*	1,977	*	1,00	= 70757
5.	A	*	*	1,00	*	*	
6.	A	*	*	1,00	*	*	
7.	X	*	*	0,75	*	*	
8. Windows	A	198,0	*	2,636	*	1,00	= 27640
9. Exterior Door	A	3,0	*	0,800	*	1,00	= 127
10. Exterior TB (length/m)	A	203,3	*	0,081	*	1,00	= 872
11. Perimeter TB (length/m)	P	123,8	*	-0,036	*	1,00	= -236
12. Ground TB (length/m)	B	*	*	1,00	*	1,00	= 0,00

Transmission losses Q_T (negative: heat loads)

Total 108449 127,8

Summer Ventilation from SummVent worksheet

Ventilation unit conductance	Ventilation parameter	Summer ventilation regulation
Exterior $H_{v,e}$ 83,8 W/K	Temperature amplitude summer 11,2 K	HRV/ERV
without HR 441,0 W/K	Minimum Acceptable Indoor Temperature 18,0 °C	None *
Ground $H_{v,g}$ 0,0 W/K	Heat capacity air 0,33 Wh/(m ² K)	Controlled by temperature
without HR 0,0 W/K	Supply air exchange 0,63 1/h	Controlled by enthalpy
Ventilation conductance, others	Ambient air exchange 0,19 1/h	always
Exterior 133,0 W/K	Window night ventilation air exchange rate, manual @ 1K 0,19 1/h	Additional ventilation
	Air change rate due to mechanical, automatically controlled 0,63 1/h	
	Specific power consumption for 0,40 Wh/m ³	
	η_{HR} 81%	
	η_{ERV} 0%	
	η_{SHX} 0%	

Hygienic air change	$n_{V,system}$ 1/h	η_{HSX} *(1- 0%)	η_{HR} *(1- 0,00%)	$n_{V,Rest}$ 1/h	$n_{V,equ,fraction}$ 1/h
Effective Air Change Rate Ambient $n_{v,a}$ 0,630	*	*(1- 0%))*(1- 0,00%)	+ 0,190	= 0,820
Effective Air Change Rate Ground $n_{v,g}$ 0,630	*	*(1- 0%))*(1- 0,00%)	= 0,000	

	V_V m ³	$n_{V,equ,fraction}$ 1/h	C_{Air} Wh/(m ² K)	G_i kWh/a	kWh/a	kWh/(m ²)
Ventilation losses ambient Q_V 2121	*	0,820	*	0,33	= 29644	34,9
Ventilation losses ground $Q_{V,e}$ 2121	*	0,000	*	0,33	= 0	0,0
Heat losses summer ventilation 2121	*	0,882	*	0,33	= 37948	44,7

Total 67592 79,7

Total heat losses Q_L	Q_T kWh/a	Q_V kWh/a	Q_L kWh/a	Q_L kWh/(m ²)
	108449	+ 67592	= 176041	207,5

Orientation of the area	Reduction Factor	g-Value (perp. radiation)	Area m ²	Global Radiation kWh/(m ² a)	kWh/a
1. North	0,36	*	0,70	58,2	= 6098
2. East	0,17	*	0,70	12,5	= 1046
3. South	0,19	*	0,77	100,8	= 10153
4. West	0,18	*	0,72	26,5	= 1467
5. Horizontal	0,40	*	0,00	0,0	= 0
6. Sum opaque areas				1113	= 2556

Total 21320 25,1

Internal Heat Gains Q_i	kh/d	Length Heat Period d/a	Spec. Power q _i W/m ²	A_{TFA} m ²	kWh/a	kWh/(m ²)
	0,024	*	245	*	2,8	= 13968

Sum heat loads Q_F Q_s + Q_i = 35288 41,6Ratio of Losses to Free Heat Gains Q_L / Q_F = 4,99Utilisation Factor Heat Losses η_G = 20% kWh/a kWh/(m²)Useful heat losses Q_{V,n} η_G * Q_L = 35036 41,3Useful Cooling Demand Q_K Q_F - Q_{V,n} = 252 0

Limiting value 15 (Yes/No) Requirement met? -

EnerPHit planning:

C O M P R E S S O R C O O L I N G U N I T S

Climate:	Велико Търново РНІ
DHW solar p	Building: Primary School 3 "Tzanko Diustabanov" - Section
Interior temperature summer:	24,0 °C
Nominal humidity:	12,0 g/kg
Internal humidity sources:	2,0 g/(m²h)

Treated Floor Area A_{TFA} :**848,4 m²**

Mechanical cooling:

x

Air exchange via ventilation system with supply air:

0,6

Supply Air Cooling

check as appropriate

- On/Off Mode (check as appropriate)
- max. cooling capacity (sensible + latent)
- Temperature reduction dry
- Seasonal energy efficiency ratio

5,0	kW
11,0	K
3,0	

Recirculation Cooling

check as appropriate

- On/Off Mode (check as appropriate)
- max. cooling capacity (sensible + latent)
- Volume flow rate at nominal power
- Temperature reduction dry
- Variable volume flow (check if appropriate)
- Seasonal energy efficiency ratio

0,0	kW
0,0	m ³ /h
	K
1,0	

Additional Dehumidification

check as appropriate

- Waste heat to room (please check if applicable)
- Seasonal energy efficiency ratio

1,0

Panel Cooling

check as appropriate

- Seasonal energy efficiency ratio

1,0

Useful cooling total

Cooling contribution by:

- Supply Air Cooling**
- Recirculation Cooling**
- Dehumidification**
- Remaining for Panel Cooling**

Total

sensible kWh/(m ² a)	latent kWh/(m ² a)	COP	Electricity Demand (kWh/a) kWh/(m ² a)	Sensible Fraction
0,3	0,1			76%
(0,3 + 0,0) / 3,0 = 0,1				100%
(0,0 + 0,0) / 1,0 = 0,0				0%
	0,1 / 1,0 = 0,1			0%
0,0				100%
(0,3 + 0,1) / 2,0 = 0,2				76%

Unsatisfied Demand


0,0	0,0
------------	------------

Cooling demand covered? **yes**

(Yes/No)

COMPRESSOR COOLING UNITS**Humidity loads and humidity removal**

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Internal humidity sources:	1,1	1,0	1,1	1,0	1,1	1,0	1,1	1,1	1,0	1,1	1,0	1,1	12	kWh/m ²
Infiltration/Window/Extract air system	-2,6	-2,3	-2,4	-1,9	-1,2	-0,5	-0,3	-0,4	-1,0	-1,6	-2,0	-2,5	-19	kWh/m ²
Supply air ventilation system	-8,7	-7,7	-7,9	-6,2	-4,0	-1,7	-0,8	-1,3	-3,3	-5,3	-6,7	-8,5	-62	kWh/m ²
Summer ventilation window	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Summer ventilation mechanically	0,0	0,0	0,0	0,0	0,0	0,0	-0,1	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Total humidity load	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Dehumidification by supply air cooling	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh
Dehumidification by circulation cooling	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh
Additional Dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh
Total dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh
Unnecessary dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh
Missing dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,1	0,0	0,0	0,0	0,0	0,0	0	kWh



EnerPHit planning: C O O L I N G L O A D

Building: Primary School 3 "Tzanko Diustabanov" - Section A Climate (HL): Велико Търново РНІ					Building type: School Treated Floor Area A _{TFA} : 848,4 m ² Interior Temperature: 24 °C Building volume: 2121 m ³ Spec. Capacity: 204 Wh/m ²					
Temperature: Ambient Air Dew Point Sky Weather 1: 28,1 °C 18,6 16,5 °C Weather 2: 24,5 °C 18,6 18,6 °C Ground Design Temp.: 22,9 °C SHX 11,7 °C					Radiation: North East South West Horizontal 92 197 185 197 349 W/m ² 64 159 237 159 269 W/m ²					
Nominal humidity: 12,0 g/kg Internal humidity sources: 2,0 g/kg					Building assembly Temperature Zone Area U-Value Factor TempDiff 1 TempDiff 2 P _T 1 P _T 2 m ² W/(mK) Always 1 (except 'X') K K W W					
1. Exterior Wall - Ambient A 539,2 * 0,130 * 1,00 * 4,1 or 0,5 = 290 or 37 2. Exterior Wall - Ground B * * 1,00 * 4,1 or -1,1 = 435 or 56 3. Roof/Ceiling - Ambient A 955,4 * 0,110 * 1,00 * 4,1 or 0,5 = -1953 or -1953 4. Floor slab / basement ceiling B 910,2 * 1,977 * 1,00 * 4,1 or 0,5 = 5 5. A * * 1,00 * 4,1 or 0,5 = 6. A * * 1,00 * 4,1 or 0,5 = 7. X * * 0,75 * 4,1 or 0,5 = 8. Windows A 198,0 * 2,636 * 1,00 * 4,1 or 0,5 = 2155 or 277 9. Exterior Door A 3,0 * 0,800 * 1,00 * 4,1 or 0,5 = 10 or 1 10. Exterior TB (length/m) A 203,3 * 0,081 * 1,00 * 4,1 or 0,5 = 68 or 9 11. Perimeter TB (length/m) P 123,8 * -0,036 * 1,00 * -1,1 or -1,1 = 5 or 5 12. Ground TB (length/m) B * * 1,00 * -1,1 or -1,1 = 13. House/DU Partition Wall I * * 1,00 * 4,0 or 4,0 = 14. Radiation correction ambient air L _{Ambient} W/K -15,6 * 4,1 or 0,5 = -64 or -8 15. Radiation correction sky L _{Sky} W/K 15,4 * -7,5 or -5,4 = -115 or -83										
Transmission heat load P_T					Total = 830 or -1660					
Ventilation load V _V n _{V,equal,fraction} n _{V,equal,fraction} c _{Air} TempDiff 1 TempDiff 2 P _V 1 P _V 2 m ³ 1/h 1/h Wh/(mK) K K W W					Exterior P _{V,o} 2121 * 0,820 or 0,820 * 0,33 * 4,1 or 0,5 = 2370 or 304 Ground PL,e 2121 * 0,000 or 0,000 * 0,33 * -12,3 or +12,3 = 0 or 0 Summer ventilation P _{L,s} 2121 * 0,000 or 0,000 * 0,33 * 0,0 or 0,0 = 0 or 0					
Ventilation heat load P_V					Total = 2370 or 304					
Orientation of the area Area g-Value Reduction Factor Radiation 1 Radiation 2 P _T 1 P _T 2 m ² (perp. radiation) (see 'Windows' worksheet) W/m ² W/m ² W W					1. North 58,2 * 0,7 * 0,36 * 124 or 86 = 1839 or 1270 2. East 12,5 * 0,7 * 0,17 * 201 or 215 = 292 or 313 3. South 100,8 * 0,8 * 0,19 * 201 or 215 = 2895 or 3108 4. West 26,5 * 0,7 * 0,18 * 135 or 93 = 463 or 320 5. Horizontal 0,0 * 0,0 * 0,40 * 349 or 269 = 0 or 0 6. Sum opaque areas * * * * * 790 or 630					
Solar load P_S					Total = 6279 or 5641					
Internal heating load P_I					Spec. Power P _I 1 P _I 2 W/m ² m ² W W 2,8 * * 848 = 2376 or 2376					
P _T + P _V + P _S + P _I = 11855 or 6661										
Cooling load P_C					= 11855 W					
Area specific cooling load P_C / A_{TFA}					= 14,0 W/m ²					
Please enter the minimum supply air temperature: 3 °C Supply air temperature without cooling θ _{Supply,Min} °C W 28,1 W 24,5					= 11081 W/m ² W/m ² 9494 specific 13,1 11,2					
For comparison: cooling load, transportable through the supply air P _{Supply,Max}					(yes/no) Air conditioning over the supply air possible? no					
Daily internal temperature stroke					Transmission Ventilation Solar load Time Spec. Capacity A _{TFA} W W W h/d W/m ² m ² (830,1 + 2370,4 + 6278,6) * 24 / (204 * 848) = 1,3 K					
Dehumidification load from 'Cooling' worksheet										
Absolute humidity exterior air 13,4 or 13,4 g/kg Ambient air mass flow 476 or 476 kg/h Summer ventilation air mass flow 0 or 0 kg/h Humidity load, outside air 686 or 686 g/h					Absolute humidity supply air 13,4 or 13,4 g/kg Supply air mass flow 1577 or 1577 kg/h Humidity load, supply air 2276 or 2276 g/h Humidity load, internal 1697 or 1697 g/h					
Enthalpy of vaporisation Wh/kg 707,122 / 1000 * 4659 or 4659 = 3295 or 3295										
Dehumidification load P_T					= 3295 W					
Area specific dehumidification load P_T / A_{TFA}					= 3,9 W/m ²					
Monthly Average values										
Spec. Cooling Demand Jan Feb Mar Apr May Jun Jul Aug Sep Oct Nov Dec kWh/m ² 0,0 0,0 0,0 0,0 0,0 0,0 0,2 0,0 0,0 0,0 0,0 0,0 Spec. dehumidification demand 0,0 0,0 0,0 0,0 0,0 0,0 0,1 0,0 0,0 0,0 0,0 0,0 Sensible Fraction 100% 100% 100% 100% 100% 100% 70% 100% 100% 100% 100% 100%										
Minimum of sensible cooling load fraction occurred 100%										

HEAT DISTRIBUTION AND DHW SYSTEM

Building: Primary School 3 "Tzanko Diustabanov" - Section A

Interior Temperature:	18	°C
Building type:	School	
Treated Floor Area A_{TFK} :	848	m ²
Occupancy:	50,0	Pers
Number of dwelling units:	1	
Annual heating demand q_{Heating}	39278	kWh/a
Length of Heating Period:	189	d
Average heating load Pave:	8,7	kW
Marginal Utilisability of Additional Heat Gains:	98%	

Space Heat Distribution

Length of Distribution Pipes	L_H (Project)
Heat Loss Coefficient per m Pipe	Ψ (Project)
Temperature of the Room Through Which the Pipes	ϑ_X Mechanical Room
Design Flow Temperature	ϑ_{dist} Flow, Design Value
Design system heating load	Q_{heating} (exist./calc.)
Flow Temperature Control (check)	
Design Return Temperature	ϑ_R = $0.714^*(J_{\text{dist}}-20)+20$
Annual Heat Emission per m of Plumbing	Q^*_{HL} = $Y(J_m-\vartheta_X) t_{\text{heating}} * 0.024$
Possible Utilization Factor of Released Heat	η_G
Annual Losses	Q_{HL} = $L_H \cdot q^*_{\text{HL}} \cdot (1-\eta_G)$
Specif. losses	q_{HL} = $\sum Q_{\text{HL}} / A_{TFK}$
*Performance ratio of heat distribution	$e_{a,HL}$ = $(q_H + q_{HL}) / q_H$

Warm region	Parts			Total
	1	2	3	
20,00	4,00			m
0,192	0,192			W/(mK)
18	10,0			°C
55,0	55,0			°C
22,2	22,2			kW
x				
45,0	45,0			°C
15	35			kWh/(m·a)
98%	0%			-
6	139	0	145	kWh/a
			100%	kWh/(m ² a)
			0,2	

DHW: Standard Useful Heat

DHW Consumption per Person and Day (60 °C)	V_{DHW} (Project or Average Value 25 Litres/P/d)
Average Cold Water Temperature of the Supply	ϑ_{DHW} Temperature of drinking water (Electricity worksheet)
DHW Non-Electric Wash and Dish	Q_{DHW}
Useful heat - DHW	
Specif. useful heat - DHW	q_{DHW} = Q_{DHW} / A_{TFK}

20,0	11,7	0	20459	24,1
20,0	11,7	0		
20,0	11,7	0		
20,0	11,7	0		

DHW Distribution and Storage

Length of Circulation Pipes (Flow + Return)	L_{HS} (Project)
Heat Loss Coefficient per m Pipe	Ψ (Project)
Temperature of the Room Through Which the Pipes	ϑ_X Mechanical Room
Design Flow Temperature	ϑ_{dist} Flow, Design Value
Daily circulation period of operation.	t_{circ} (Project)
Design Return Temperature	ϑ_R = $0.875^*(\vartheta_{\text{dist}}-20)+20$
Circulation period of operation per year	t_{circ} = $365 t_{\text{circ}}$
Annual Heat Released per m of Pipe	q^*_{Z} = $Y(J_m-\vartheta_X) t_{\text{circ}}$
Possible Utilization Factor of Released Heat	$\eta_{G,DHW}$ = $\eta_{\text{heating}}/365d * \eta_G$
Annual Heat Loss from Circulation Lines	Q_Z = $L_{HS} \cdot q^*_{\text{Z}} \cdot (1-\eta_{G,DHW})$

Warm region	Parts			Total
	1	2	3	
10,0				m
0,153				W/m/K
18				°C
60,0				°C
10,0				h/d
55				°C
3650				h/a
22				kWh/m/a
51%				-
109			109	kWh/a

Total length of individual pipes

 L_U (Project) $d_{U,Pipe}$ (Project)

Exterior pipe diameter	
Tap openings per person per day	
Utilisation days per year	
Heat loss per tap opening	
Amount of tap openings per year	
Annual Heat Loss	
Possible Utilization Factor of Released Heat	
Annual Heat Loss of individual pipes	

6,00				m
0,030				m
3	3	3		-
365	365	365		d
0,1767				kWh/tap opening
54750				Tap openings per year
9676				kWh/a
51%				-
4763			4763	kWh/a

Average Heat Released from storage

 P_S $\eta_{G,S}$ $= \eta_{\text{heating}}/8760 * \eta_G$

Annual Heat Losses from storage

 Q_S = $P_S \cdot 8,760 \text{ kWh} / (1-\eta_{G,S})$

49				w
51%				
211			211	kWh/a

Total heat losses of the DHW system

 Q_{WL} $= Q_Z + Q_U + Q_S$

5083

kWh/a

Specif. losses of the DHW system	Q_{WL}	$= Q_{WL} / A_{TFK}$	5,0
Performance ratio DHW-distribution + storage	$e_{a,WL}$	$= (q_{TDHW} + q_{WL}) / q_{TDHW}$	

125%

-

25541

kWh/a

Total heating demand of DHW system	Q_{gDHW}	$= Q_{DHW} + Q_{WL}$
Totalspec. heating demand of DHW system	Q_{gDHW}	$= Q_{gDHW} / A_{TFK}$ 30,1

Secondary calculation: Ψ -values of plumbing

Nominal width:	25	mm
Insulation Thickness:	50	mm
Mirrored?	Yes	
	x	No
Thermal Conductivity	0,040	W/(mK)
$\Delta\vartheta$	30 K	
Interior Pipe Diameter:	0,025 m	
Exterior Pipe Diameter	0,027 m	
Exterior Pipe Diameter	0,127 m	
α -Surface	6,08 W/(m²K)	
Ψ -Value	0,153 W/(mK)	
Surface Temperature Difference	1,886 K	

EnerPHit planning:

SOLAR THERMAL SYSTEM

Building: Primary School 3 "Tzanko Diustabanov" - Section A Building type: School
 Treated Floor Area A_{TFA} : 848,4 m²

Solar fraction

Heating Demand DHW	q_{gDHW}	25541 kWh/a 39424 kWh/a	(DHW+Distribution)
Annual heating demand			(Worksheets Heating & DHW+Distribution)
Heating support (please check, if applicable)			
DHW priority (check if appropriate)			
Latitude:		43,1 °	(Worksheet Climate)
Collector: 7 Improved flat plate collector			
Solar Collector Area		28,00 m ²	
Deviation from North		180 °	
Angle of Inclination from the Horizontal		26 °	
Height of the Collector Field		1,00 m	
Height of Horizon	h_{Hori}	m	
Horizontal Distance	a_{Hori}	m	
Additional Reduction Factor Shading	r_{other}		
Occupancy		50,0 Persons	
Specific Collector Area		0,6 m ² /Pers	

Estimated solar DHW fraction


Estimated solar coverage for heating

Solar heat contribution total

39%	9886 kWh/a	12 kWh/(m ² a)
13%	5300 kWh/a	6 kWh/(m ² a)
23%	15186 kWh/a	18 kWh/(m ² a)

Secondary Calculation of Storage Losses

Solar Storage: 9 Simple solar storage	Total storage volume	500 litre
	Volume Standby Part (above)	150 litre
	Volume Solar Part (below)	350 litre
	Specific heat losses storage (total)	3,6 W/K
	Typical Temperature DHW	60 °C
	Room Temperature	10 °C
	Storage heat losses (standby part only)	38 W
	Total storage heat losses	180 W



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Heating demand DHW-preparation	2169	1959	2169	2099	2169	2099	2169	2169	2099	2169	2099	2169	25541
Heating demand space heating	9980	7296	5180	1517	22	0	0	0	5	1125	4958	9340	39424
Heating demand	12149	9256	7349	3616	2191	2099	2169	2169	2105	3295	7058	11509	64965
Radiation on Tilted Collector Surface	1653	2180	3279	4273	4828	4825	5146	4822	4040	3059	1857	1477	41437
Please enter: Solar production for DHW													0 kWh/month
Please enter: Solar production for heating													0 kWh/month
DHW heat demand covered by solar	0	8	49	514	1778	1822	1955	1858	1529	364	9	0	9886 kWh/month
Heating demand covered by solar	298	736	1338	1317	22	0	0	0	5	851	538	196	5300 kWh/month
Heating demand covered by solar	298	744	1387	1831	1800	1822	1955	1858	1534	1215	547	196	15186 kWh/month
Solar fraction	2%	8%	19%	51%	82%	87%	90%	86%	73%	37%	8%	2%	- 23%

Hit planning:

PHOTOVOLTAIC SYSTEM

Building: Primary School 3 "Tzanko Diustabanov" - Section A

Building type: school

Climate: Велико Търново РНІ

Information from the module data sheet

Technology Amorph-Si

Nominal current
Nominal voltage
Nominal power
Temperature coefficient short-circuit current
Temperature coefficient open-circuit voltage

I_{MPP0}
 U_{MPP0}
 P_n
 α
 β

A
V
W_p
%/K
%/K

Further specifications

Latitude:
Number of modules
Deviation from North
Angle of inclination from the horizontal
Height of module array
Height of horizon
Horizontal distance
Additional Reduction Factor Shading
Efficiency of the inverter


n_M
 h_{Hori}
 a_{Hori}
 r_{other}
 η_{HRV}

43,1
°
°
°
m
m
m
g/kWh

(Worksheet Climate)

Annual yield of the inverter
Annual losses due to shading
PE value (non-renewable)
CO₂-equivalent emission value

kWh
kWh
g/kWh



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
Solar radiation on tilted surface	0	0	0	0	0	0	0	0	0	0	0	0	kWh/m²/a
Ambient temperature	-1	2	5	10	16	20	22	22	16	11	6	0	°C
total monthly generation	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Losses due to shading situation	0	0	0	0	0	0	0	0	0	0	0	0	kWh/a

ELECTRICITY DEMAND

Building: Primary School 3 "Tzanko Diustabanov" - Section Calculation in worksheet 'Electricity non-res'!

Column Nr.	1	2	3	4	5	6	7	8a	9	10	11	12	13	14	
	Used ? (1/0)	Within the Thermal Envelope? (1/0)	Norm Demand	Utilization Factor	Frequency	Reference Quantity	Useful Energy (kWh/a)	Electric Fraction	Non-Electric Fraction	Additional demand	Marginal Performance Ratio	Solar F-Ration	Non-Electric Demand (kWh/a)	Primary Energy-Demand (kWh/a)	
Households	1	HH													
Persons	50,0	P													
Living Area	848	m ²													
Annual heating demand	46	kWh/(m ² a)													
Dishwashing	1	1	1,10	kWh/Use	*	1,00	*	65	/P*a)	*	50,0 P	=	3575	100% 0%	
Cold water connection					*		*	57	/P*a)	*	50,0 P	=	3135	100% 0%	
Clothes washing	1	1	1,10	kWh/Use	*	1,00	*	57	/P*a)	*	50,0 P	=	8728	100% 0%	
Cold water connection					*		*	57	/P*a)	*	50,0 P	=	0	100% 0%	
Clothes drying with:					*	0,88	*	57	/P*a)	*	50,0 P	=	0	100% 0%	
Condensation Dryer	1	1	3,50	kWh/Use	*	0,60	*	57	/P*a)	*	50,0 P	=	285	100% 0%	
Energy consumed by evaporation	0	1	3,13	kWh/Use	*	0,60	*	57	/P*a)	*	1 HH	=	289	100% 0%	
Refrigerating	1	1	0,78	kWh/d	*	1,00	*	365	d/a	*	1 HH	=	0	100% 0%	
Freezing or combination	1	0	0,88	kWh/d	*	0,90	*	365	d/a	*	1 HH	=	6250	100% 0%	
Cooking with:	0	1	1,00	kWh/d	*	1,00	*	365	d/a	*	1 HH	=	8700	100% 0%	
Electricity	1	1	0,25	kWh/Use	*	1,00	*	500	/P*a)	*	50,0 P	=	2200	100% 0%	
Lighting	1	1	60	W	*	1,00	*	2,90	kh/P*a)	*	50,0 P	=	2500	100% 0%	
Consumer electronics	1	1	80	W	*	1,00	*	0,55	kh/P*a)	*	50,0 P	=	7392	100% 0%	
Small appliances, etc.	1	1	50	kWh	*	1,00	*	1,00	/P*a)	*	50,0 P	=	7392	100% 0%	
Total aux. electricity															
Other:															
Total										0	0	0	0	0	
Specific Demand										0	0	0	0	0	
Recommended maximum value										43053	kWh	43053	kWh	43053	kWh
										50,7	kWh/(m ² a)	0,0	0,0	0,0	kWh/(m ² a)
										18		131,9		50	

UTILISATION non-residential Use

Building: Primary School 3 "Tzanko Diustabakov" - Section A

		Periods of utilisation and operation																	
		Begin Utilisation [h]	End Utilisation [h]	Daily Utilisation Hours [h/d]	Annual Utilisation Days [da]	Annual Utilisation Hours [h/a]	Annual Utilisation Hours During Daytime [h/a]	Annual Utilisation Hours During Nighttime [h/a]	Daily operating hours of heating	Daily operating hours of ventilation	Lighting	Illumination Level [lux]	Height of utilisation level (0,8 or 0,0 m)	Height of utilisation level (0,8 or 0,0 m)	Relative Absenteeism	Part Use Factor of Building Operating Period for Lighting	Average Occupancy [m²/Pers.]		
2	Utilisation Pattern																		
1	Classroom	7,5	18	11	180	1890	1803	87	13	13		300	0,8	0,8	0,25	0,9	3,0		
2	Corridors	7,5	18	11	300	3150	3004	146	13	13		100	0,0	0,0	0,80	1,0			
3	Lobbies	7,5	18	11	180	1890	1803	87	13	13		200	0,0	0,0	0,80	1,0			
4	Computer room	7,5	18	11	180	1890	1803	87	13	13		300	0,8	0,8	0,30	0,4	2,0		
5	Bookstore	9,0	18	9	180	1620	1534	86	11	11		300	0,8	0,8	0,90	1,0			
6	Canteen	10,0	16	6	180	990	990	0	8	8		100	0,8	0,8	0,80	0,4			
7	Kitchen	10,0	16	6	180	990	990	0	8	8		100	0,8	0,8	0,80	0,4			
8	Stairs	7,5	18	11	300	3150	3004	146	13	13		100	0,0	0,0	0,80	1,0			
9	WC, Sanitary	7,5	18	11	180	1890	1803	87	13	13		200	0,8	0,8	0,90	1,0			
10	Teacher offices	7,5	18	11	180	1890	1803	87	13	13		300	0,8	0,8	0,30	0,7	10,0		
11	Dressing room	7,5	23	16	300	4650	3156	1494	18	18		300	0,8	0,8	0,30	0,7			
12	Bath, showers	7,5	23	16	300	4650	3156	1494	18	18		200	0,8	0,8	0,90	1,0			
13				0	0	0	0	0	2	2			0,8						
14				0	0	0	0	0	2	2			0,8						
15				0	0	0	0	0	2	2			0,8						
16				0	0	0	0	0	2	2			0,8						
17				0	0	0	0	0	2	2			0,8						
18				0	0	0	0	0	2	2			0,8						
19				0	0	0	0	0	2	2			0,8						
20				0	0	0	0	0	2	2			0,8						
21	Single Office	7	18	11	250	2750	2543	207	13			500	0,8	0,8	0,30	0,70	10,00		
22	Group Office	7	18	11	250	2750	2543	207	13			500	0,8	0,8	0,30	0,70			
23	Open-Plan Office	7	18	11	250	2750	2543	207	13			500	0,8	0,8	0,00	1,00	15,00		
24	Meeting	7	18	11	250	2750	2543	207	13			500	0,8	0,8	0,50	1,00	2,00		
25	Counter Area	7	18	11	250	2750	2543	207	13			200	0,8	0,8	0,00	1,00			
26	Retail	8	20	12	300	3600	2999	601	14			300	0,8	0,8	0,00	1,00	7,00		
27	Classroom	8	15	7	200	1400	1398	2	9			300	0,8	0,8	0,25	0,90	2,00		
28	University Auditorium	8	18	10	150	1500	1409	91	12			500	0,8	0,8	0,25	0,70	0,75		
29	Bedroom	0	24	24	365	8760	4407	4353	24			300	0,8	0,8	0,00	0,50			
30	Hotel Room	21	8	11	365	4015	755	3260	24			200	0,8	0,8	0,25	0,30			
31	Canteen	8	15	7	250	1750	1748	2	9			200	0,8	0,8	0,00	1,00			
32	Restaurant	10	0	14	300	4200	2404	1796	16			200	0,8	0,8	0,00	1,00	1,50		
33	Kitchen Non-Residential	10	23	13	300	3900	2404	1496	15			500	0,8	0,8	0,00	1,00			
34	Kitchen, Storage, Preparation	7	23	16	300	3900	2404	1496	15			300	0,8	0,8	0,50	1,00			
35	WC, Sanitary	7	18	11	250	2750	2543	207	13			200	0,8	0,8	0,90	1,00			
36	Other Habitable Rooms	7	18	11	250	2750	2543	207	13			300	0,8	0,8	0,50	1,00			
37	Secondary Areas	7	18	11	250	2750	2543	207	13			100	0,8	0,8	0,90	1,00			
38	Circulation Area	7	18	11	250	2750	2543	207	13			100	0,0	0,0	0,80	1,00			
39	Storage, Services	7	18	11	250	2750	2543	207	13			100	0,8	0,8	0,98	1,00			
40	Server Room	0	24	24	365	8760	4407	4353	24			500	0,8	0,8	0,50	0,50			
41	Workshop	7	16	9	250	2250	2192	58	11			500	0,8	0,8	0,00	1,00			
42	Theatre Auditorium	19	23	4	250	1001	55	946	6			200	0,8	0,8	0,00	1,00			
43	Theatre Foyer	19	23	4	250	1001	55	946	6			300	0,8	0,8	0,50	1,00			
44	Theatre Stage	13	23	10	250	2500	1253	1247	12			1000	0,8	0,8	0,00	0,60			
45	Fair, Congress	13	18	5	150	1350	1260	90	11			300	0,8	0,8	0,50	1,00			
46	Exhibition	10	18	8	250	2001	1850	151	24			200	0,8	0,8	0,00	1,00			
47	Library Reading Room	8	20	12	300	3600	2999	601	14			500	0,8	0,8	0,00	1,00			
48	Open Access Library	8	20	12	300	3600	2999	601	14			200	0,8	0,8	0,00	1,00			
49	Library Repository	8	20	12	300	3600	2999	601	14			100	0,8	0,8	0,90	1,00			
50	Gymnasium	8	23	15	300	4500	3002	1498	17			300	0,8	0,8	0,30	1,00			
51	Parking Garage	7	18	11	250	2750	2543	207	0			75	0,0	0,0	0,95	1,00			
52	Public Parking Garage	9	0	15	365	5475	3290	2185	0			75	0,0	0,0	0,80	1,00			

EnerPHit planning:

ELECTRICITY DEMAND Non-Residential Use

EnerPHit planning:

AUXILIARY ELECTRICITY

Building: Primary School 3 "Tzanko Diustabakov" - Section A

Treated Floor Area Heating period Air Volume Dwelling Units Enclosed Volume	848 189 2121 1 6224	m ² d m ³ HH m ³	Operation Vent. System Winter Operation Vent. System Summer Air Change Rate Defrosting HX from	4,54 4,22 0,38 2,0	kh/a kh/a h ⁻¹ °C	Primary Energy factor - Electricity Annual Space Heating Demand Boiler Rated Power DHW System Heating Demand Design Flow Temperature	2,60 46 22 25541 55	kWh/kWh kWh/(m ² a) kW kWh/a °C
Column Nr.	1	2	3	4	5	6	7	8
Application	Used ? (1/0)	Within the Thermal Envelope ? (1/0)	Norm Demand	Utilization Factor	Period of Operation	Reference Size	Electricity Demand (kWh/a)	Available as Interior Heat
<u>Ventilation System</u>								
Winter Ventilation	1	0	0,40 Wh/m ³	* 0,38 h ⁻¹	* 4,5 kh/a	* 2121 m ³	= 1467	considered in heat recovery efficiency
Defroster HX	1	0	3785 W	* 1,00	* 0,6 kh/a	* 1 m ³	= 2096	* 1,0 / 4,54 = 0
Summer Ventilation	1	0,55	0,40 Wh/m ³	* 0,63 h ⁻¹	* 4,2 kh/a	* 2121 m ³	= 2256	* 1,0 / 4,22 =
Additional ventilation summer	1	0,55	0,40 Wh/m ³	* 0,01 h ⁻¹	* 4,2 kh/a	* 2121 m ³	= 51	* 1,0 / 4,22 =
<u>Heating System</u>				Controlled/UnControlled (1/0)				
Circulation Pump	1	1	214 W	* 1,0	* 4,5 kh/a	* 1	= 973	* 1,0 / 4,54 = 214
Boiler Electricity Consumption at 30% Load								
Aux. Energy - Heat Boiler	0	0	66 W	* 1,00	* 0,00 kh/a	* 1	= 0	* 1,0 / 4,54 = 0
Aux. Energy - Wood fired/pellet boiler	0	0					= 0	* 1,0 / 4,54 = 0
<u>DHW system</u>				Data entries in Boiler worksheet. Auxiliary energy demand including possible drinking water prod.				
Circulation Pump	1	43	W	* 1,00	* 7,5 kh/a	* 1	= 321	* 0,5 / 8,76 = 0
Storage Load Pump DHW		162	W	* 1,00	* 1,2 kh/a	* 1	= 0	* 1,0 / 4,54 = 0
DHW Boiler Aux. Energy	0	0	198 W	* 1,00	* 0,0 kh/a	* 1	= 0	* 1,0 / 4,54 = 0
Solar Aux Electricity	1	130	W	* 1,00	* 1,8 kh/a	* 1	= 227	* 0,5 / 8,76 = 0
Misc. Aux. Electricity							= 0	* 1,0 / 8,76 = 0
Total							7392	214
Specific Demand	kWh/(m ² a) divided by treated floor area:						8,7	22,7

INTERNAL HEAT GAINS

Building: Primary School 3 "Tzanko Diustabanov" - Section Calculation in worksheet 'IHG non-res'!

Utilisation Pattern: School **2,80** W/m²
 Type of Values Used: Standard **6,59** W/m² in summer

No data input necessary **1,34** W/m²[Go to utilisation pattern selection](#)

Calculation Internal Heat Household	Column Nr.	Persons Living Area	Heating Demand Heating period	10						
Application	1	2	3	4	5	6	7	8	9	10
	Existing (1/0), or number of people	In the Thermal Envelope (1/0)	Norm Consumption	Utilization Factor	Frequency	Useful Energy (kWh/a)	Included in Electricity Balance?	Availability	Used During Time Period (kh/a)	Internal heat source Winter (W)
Dishwashing	1	1	1,1	kWh/Use	1,00	3575	*	0,30	8,76	= 122
Clothes Washing	1	1	1,1	kWh/Use	1,00	3135	*	0,30	8,76	= 107
Clothes drying with:	1	1	3,5	kWh/Use	0,88	8728	*	0,70	8,76	= 697
Condensation Dryer	1	1	0,0	kWh/Use	0,60	0	*	0,80	8,76	= 0
Energy consumed by evaporation	0	1	-3,1	kWh/Use	0,60	0	*	0,00	8,76	= 0
Refrigerating	1	1	0,8	kWh/d	1,00	285	*	1,00	8,76	= 33
Freezing	1	0	0,9	kWh/d	0,90	289	*	1,00	8,76	= 0
or combination	0	1	1,0	kWh/d	1,00	0	*	1,00	8,76	= 0
Cooking	1	1	0,3	kWh/Use	1,00	6250	*	0,50	8,76	= 357
Lighting	1	1	60,0	W	1,00	8700	*	1,00	8,76	= 993
Consumer Electronics	1	1	80,0	W	1,00	2200	*	1,00	8,76	= 251
Household Appliances/Other	1	1	50,0	kWh	1,00	2500	*	1,00	8,76	= 285
Auxiliary Appliances (cf. Aux Electricity Sheet)										= 214
Other Applications (cf. Electricity Sheet)	0	0,0						0	8,76	= 0
Persons	50	1	80,0	W/P	1,00	0	*	0,55	8,76	= 2200
Cold Water	50	1	-3,1	W/P	1,00	35040	*	0,55	8,76	= -153
DHW - circulation	1	1	25,2	W	1,00	8,76	*	1,00	8,76	= 25
DHW - individual pipes	1	1	1104,5	W	1,00	221	*	1,00	8,76	= 1105
DHW - storage	1	1	49,0	W	1,00	9676	*	1,00	8,76	= 49
Evaporation	50	1	-25,0	W/P	1,00	8,76	*	1,00	8,76	= -1250
Total										W 3858
Specific Demand										W/m² 4,55
Heat Available From Internal Sources								189,2 d/a		kWh/(m²a) 20,6

EnerPHit planning:

INTERNAL HEAT GAINS non-residential Use

Building: Primary School 3 "Tzanko Diustabakov" - Sectio

Utilisation Pattern: School

2,80 W/m²

Type of Values Used: Standard

No data input necessary

Calculation Internal Heat		Persons: 50,0 Treated floor area: 848,4 m ²		P	Heating period: 189,17 d/a		Room Temperature: 18 °C Internal Heat Gains Aux. Electricity: 214,3 W												
Column Nr.	Persons	Select	Utilisation Pattern	Select	Activity of Persons	Number of Occupants	Floor Area of Utilisation Zone (m ²)	Average Occupancy (Persons / m ²)	Heat emitted per person (W)	Utilisation Hours per Year [h/a]	Relative Presence	Used in Time Span (h/a)	Average Heat Emitted by Persons (W)						
Persons A	50 Gymnasium	3 >10 yr., standing or light work	1 Planning with occupancy	{ 50 }* or { 1 }	1 Planning with occupancy	{ 50 }* or { 1 }	27	No standard value	100 * 4500 * 0,70	8760 / 0,70 = 1798									
Persons B	11 Dressing room	3 >10 yr., standing or light work	1 Planning with occupancy	{ 50 }* or { 1 }	1 Planning with occupancy	{ 50 }* or { 1 }	100 * 4650 * 0,70	No standard value	8760 / 0,70 = 1858										
Persons C	10 Teacher offices	2 > 10 yr., sitting	1 Planning with occupancy	{ 1 }* or { 0,1 }	1 Planning with occupancy	{ 1 }* or { 0,1 }	80 * 1890 * 0,70	No standard value	8760 / 0,70 = 12										
Persons D		Invalid data input	1 Enter occupancy or floor area	{ 1 }* or { 0,1 }	1 Enter occupancy or floor area	{ 1 }* or { 0,1 }	0 * 0 * 1,00	0 standard value	8760 / 0,70 = 0										
Persons E		Invalid data input	1 Enter occupancy or floor area	{ 1 }* or { 0,1 }	1 Enter occupancy or floor area	{ 1 }* or { 0,1 }	0 * 0 * 1,00	0 standard value	8760 / 0,70 = 0										
Persons F		Invalid data input	1 Enter occupancy or floor area	{ 1 }* or { 0,1 }	1 Enter occupancy or floor area	{ 1 }* or { 0,1 }	0 * 0 * 1,00	0 standard value	8760 / 0,70 = 0										
Persons G		Invalid data input	1 Enter occupancy or floor area	{ 1 }* or { 0,1 }	1 Enter occupancy or floor area	{ 1 }* or { 0,1 }	0 * 0 * 1,00	0 standard value	8760 / 0,70 = 0										
Evaporation (person specific)				{ 99 }*			4650 * 0,70	8760 / 0,70 = 0											
Lighting / Equipment / Aux. Electricity		Planning with the number of persons or via floor area of utilisation zone (planning via area only if the occupancy is available for this utilisation pattern). Pers./Area (1 / 0)		Number of Occupants		Floor Area of Utilisation Zone (m ²)		Average Occupancy (Persons / m ²)		Heat emitted per person (W)		Utilisation Hours per Year [h/a]		Relative Presence		Used in Time Span (h/a)		Average Heat Emitted by Persons (W)	
Lighting		1 Planning with occupancy		Entered occupancy		100 * 4500 * 0,70		18		8760 / 0,70 = 1798		18		1798					
Office Applications (Within Therm. Envelope)		1 Planning with occupancy		100 * 4650 * 0,70		8760 / 0,70 = 1858		18		8760 / 0,70 = 12		12		12					
Cooking (Within Therm. Envelope)		1 Planning with occupancy		0 * 0 * 1,00		8760 / 0,70 = 0		0		8760 / 0,70 = 0		0		0					
Dishwashing (Within Therm. Envelope)		1 Planning with occupancy		0 * 0 * 1,00		8760 / 0,70 = 0		0		8760 / 0,70 = 0		0		0					
Cooling (Within Therm. Envelope)		1 Planning with occupancy		0 * 0 * 1,00		8760 / 0,70 = 0		0		8760 / 0,70 = 0		0		0					
Other (Within Therm. Envelope)		1 Planning with occupancy		0 * 0 * 1,00		8760 / 0,70 = 0		0		8760 / 0,70 = 0		0		0					
Auxiliary Appliances (See Aux Electricity Worksheet)		1 Planning with occupancy		8857		8760 / 0,70 = 1011		1,00		8,76 = 1011		1,00		1011					
Heat loss due to cold water (calculation from column AJ)		on/off (1 / 0)		71		8,76 = 8		1,00		8,76 = 8		0,50		8,76 = 0					
Cold Water Due to Flushing WC		1		0		8,76 = 0		0,30		8,76 = 0		1,00		8,76 = 0					
Total		2		8		8,76 = 0		1,00		8,76 = 0		1,00		8,76 = 0					
Specific Demand		x		0		8,76 = 0		1,00		8,76 = 0		1,00		8,76 = 0					
Heat Available From Internal Sources		Number of WCs (user data)		DT: Cold Water Temp. - Room Temp. [K]		Occupied Days per Year [d/a]		Loss daytime [W]		Loss Nighttime [W]		Availability		Used in Period (d/a)					
		Amount of WCs: Standard values for schools are used (X)		-6		8		0 + -21 *		1,00 / 365 = 0		W		4901					
												W/m ²		5,8					
												kWh/(m ² a)		26					

PRIMARY ENERGY VALUE

Building: Primary School 3 "Tzanko Diustabakov" - Section A		Building type: School
Treated Floor Area A _{FA} :	848	m ²
Space Heating Demand incl. Distribution:	46	kWh/(m ² a)
Useful cooling demand incl. dehumidification:	0	kWh/(m ² a)
Final Energy	Primary Energy	Emissions CO ₂ -Equivalent
kWh/(m ² a)	kWh/(m ² a)	kg/(m ² a)
Electricity Demand (without Heat Pump)		PE Value CO ₂ -Emissions Factor (CO ₂ -Equivalent)
Covered Fraction of Space Heating Demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	2,6 680
Direct Electric Heating Q _{H,de}	0,0	0,0 0,0
Hot water, direct electric (without DHW wash&dish) Q _{DHW,de} (DHW+Distribution, SolarDHW)	0,0	0,0 0,0
Electric Post heating DHW Wash&Dish (Electricity, SolarDHW)	0,0	0,0 0,0
Electricity demand lighting/auxiliary tools/kitchen Q _{EHH} (Electricity worksheet)	10,5	27,4 7,2
Electricity Demand - Auxiliary Electricity	8,7	22,7 5,9
Total electricity demand (without heat pump)	19,2	50,0 13,1
Heat pump		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of Space Heating Demand (Project)	70%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	60%	2,6 680
Energy Carrier - Supplementary Heating	Electricity	2,6 680
Annual coefficient of performance of heat pump 1 (heating / heating&DHW) SPF _{H-1} (HP worksheet)	1,9	
Annual coefficient of performance of heat pump 2 (DHW) SPF _{H-1} (HP worksheet)		
Heat generation efficiency (excl. DHW wash&dish) (HP worksheet)	0,60	
Heat generation efficiency (incl. DHW wash&dish) (HP worksheet)	0,60	
Electricity Demand Heat Pump (without DHW Wash&Dish) Q _{HP} (HP worksheet)	23,5	61,0 16,0
Non-Electric Demand, DHW Wash&Dish (HP worksheet)	0,0	0,0 0,0
Total electricity demand heat pump	23,5	61,0 16,0
Compact Heat Pump Unit		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	2,6 680
Energy Carrier - Supplementary Heating	Electricity	2,6 680
COP Heat Pump Heating SPF _{H-1} (Compact worksheet)	0,0	
COP Heat Pump DHW SPF _{H-1} (Compact worksheet)	0,0	
Heat generation efficiency (excl. DHW wash&dish) (Compact worksheet)		
Heat generation efficiency (incl. DHW wash&dish) (Compact worksheet)		
Electricity Demand Heat Pump (without DHW Wash&Dish) Q _{HP} (Compact worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (Compact worksheet)	0,0	0,0 0,0
Total Compact Unit	0,0	0,0 0,0
Boiler		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	250
Boiler Type (Boiler worksheet)		
Performance Ratio of Heat Generator (Boiler worksheet)	0%	
Annual Energy Demand (without DHW Wash&Dish) (Boiler worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (Electricity worksheet)	0,0	0,0 0,0
Total heating oil/gas/wood	0,0	0,0 0,0
District Heat		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	30%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	40%	0,8 240
Heat source (District heating worksheet)	Hard Coal CGS 70% PHC	
Performance Ratio of Heat Generator (District heating worksheet)	10%	
Heating Demand District Heat (without DHW Wash&Dish) (District heating worksheet)	20,4	16,3 4,9
Non-Electric Demand, DHW Wash&Dish (Electricity worksheet)	0,0	0,0 0,0
Total district heat	20,4	16,3 4,9
Other		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered fraction of space heating demand (Project)	0%	kWh/kWh g/kWh
Covered Fraction of DHW Demand (Project)	0%	0,2 55
Heat source (Project)	Wood	
Performance Ratio of Heat Generator (Project)	0%	
Annual Energy Demand, Space Heating (Project)	0,0	0,0 0,0
Annual Energy Demand, DHW (without DHW Wash&Dish) (Electricity worksheet)	0,0	0,0 0,0
Non-Electric Demand, DHW Wash&Dish (Electricity worksheet)	0,0	0,0 0,0
Non-Electric Demand Cooking/Drying (Gas) (Electricity worksheet)	0,0	0,0 0,0
Total - Other	0,0	0,0 0,0
Cooling with Electric Heat Pump		PE Value CO ₂ -Emission Factor (CO ₂ -Equivalent)
Covered Fraction of Cooling Demand (Project)	100%	kWh/kWh g/kWh
Heat source (Project)	Electricity	2,6 680
Seasonal energy efficiency ratio cooling (Project)		
Energy Demand Space Cooling (Project)	0,2	0,5 0,1
Heating, cooling, DHW, auxiliary electricity, lighting, electrical appliances	63,3	127,9 34,1
Total PE Value	127,9	kWh/(m ² a)
Total emissions CO₂-Equivalent	34,1	kg/(m ² a) (Yes/No)
Primary Energy Requirement		158 kWh/(m ² a) yes
Heating, DHW, auxiliary electricity (no lighting and electrical appliances)	52,6	100,0 26,8
Specific PE Demand - Mechanical System	100,0	kWh/(m ² a)
Total emissions CO₂-Equivalent	26,8	kg/(m ² a)
Solar electricity	PE-Value (Generation)	CO ₂ -Emission Factor
Planned Annual Electricity Generation (Worksheet PV)	kWh/a	kWh/kWh g/kWh
Specific Demand		
PE Value: conservation by solar electricity		
Saved CO ₂ emissions through solar electricity		

EnerPHit planning:

H E A T P U M P

Building: Primary School 3 "Tzanko Diustabakov" - Section C Climate: Велико Търново PHI	Building type: School Treated Floor Area A_{TFA} : 848 m ²												
C), DHW solar <small>(Covered fraction of space heating demand)</small> Space Heat Demand + Distribution Losses Solar fraction for space heat Effective Annual Heat Demand $Q_{H,W} = Q_H * (1 - \eta_{Solar, H})$													
<small>(PE Value worksheet)</small> $Q_{H+DHW} = Q_H + Q_{DHW}$ <small>(DHW+Distribution)</small> $\eta_{Solar, H}$ <small>(SolarDHW worksheet)</small> $Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">70%</td> <td style="width: 90%;">kWh/a</td> </tr> <tr> <td>39424</td> <td></td> </tr> <tr> <td>13%</td> <td></td> </tr> <tr> <td>23886</td> <td>kWh/a</td> </tr> </table>		70%	kWh/a	39424		13%		23886	kWh/a				
70%	kWh/a												
39424													
13%													
23886	kWh/a												
Covered Fraction of DHW Demand Total heat demand of DHW system Solar fraction for DHW Effective DHW demand $Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$ Number of heat pumps in the system Functionality													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">60%</td> <td style="width: 90%;">kWh/a</td> </tr> <tr> <td>26644</td> <td></td> </tr> <tr> <td>37%</td> <td></td> </tr> <tr> <td>10055</td> <td>kWh/a</td> </tr> <tr> <td colspan="2" style="text-align: center;">1</td> </tr> <tr> <td colspan="2" style="text-align: center;">Heating & DHW</td> </tr> </table>		60%	kWh/a	26644		37%		10055	kWh/a	1		Heating & DHW	
60%	kWh/a												
26644													
37%													
10055	kWh/a												
1													
Heating & DHW													
Heating Selection of HP: Daikin Altherma 16 kW Selection of distribution system Design distribution temperature Nominal Power of distribution system													
Heat source: θ_{design} <small>(DHW+Distribution)</small> P_{nom}													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Ambient air</td> <td style="width: 90%;">°C</td> </tr> <tr> <td>Radiators</td> <td></td> </tr> <tr> <td>55,00</td> <td></td> </tr> <tr> <td>150,00</td> <td>kW</td> </tr> </table>		Ambient air	°C	Radiators		55,00		150,00	kW				
Ambient air	°C												
Radiators													
55,00													
150,00	kW												
Distribution system (fulfilled from expert users only) Nominal Power of distribution system Radiator exponent													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">P_{nom}</td> <td style="width: 90%;">kW</td> </tr> <tr> <td>n</td> <td></td> </tr> </table>		P _{nom}	kW	n									
P _{nom}	kW												
n													
Heating storage Specific heat losses storage Storage location in thermal envelope Room temperature (Storage location: outside of thermal envelope) Sink temperature of heat pump for heating													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">U * A_{Storage}</td> <td style="width: 90%;">W/K</td> </tr> <tr> <td>Inside or outside of the thermal envelope</td> <td></td> </tr> <tr> <td>10,00</td> <td>°C</td> </tr> <tr> <td>61,50</td> <td>°C</td> </tr> </table>		U * A _{Storage}	W/K	Inside or outside of the thermal envelope		10,00	°C	61,50	°C				
U * A _{Storage}	W/K												
Inside or outside of the thermal envelope													
10,00	°C												
61,50	°C												
Entries in relation to the domestic hot water system Selection of HP: Daikin Altherma 16 kW DHW temperature DHW storage location Specific heat losses storage Room temperature (Storage location: outside of thermal envelope)													
Heat source: θ_{room} <small>(DHW+Distribution)</small> $U * A_{Storage}$ <small>(DHW+Distribution)</small>													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Ambient air</td> <td style="width: 90%;">°C</td> </tr> <tr> <td>60,00</td> <td></td> </tr> <tr> <td>Outside</td> <td></td> </tr> <tr> <td>2,5</td> <td>W/K</td> </tr> <tr> <td>0,00</td> <td>°C</td> </tr> </table>		Ambient air	°C	60,00		Outside		2,5	W/K	0,00	°C		
Ambient air	°C												
60,00													
Outside													
2,5	W/K												
0,00	°C												
Type of backup heater $\Delta\theta$ of Electric flow type heater													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Electr. immersion heater</td> <td style="width: 90%;">K</td> </tr> <tr> <td>5,0</td> <td></td> </tr> </table>		Electr. immersion heater	K	5,0									
Electr. immersion heater	K												
5,0													
In case of one heat pump with functionality: Heating & DHW Same heat pump's sink temperature for Heating and for DHW Heat Pump Priority													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Yes</td> <td style="width: 90%;">(Manufacturer, Techn. Data)</td> </tr> <tr> <td>DHW priority</td> <td></td> </tr> </table>		Yes	(Manufacturer, Techn. Data)	DHW priority									
Yes	(Manufacturer, Techn. Data)												
DHW priority													
Control Control strategy													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">On / off</td> <td style="width: 90%;">(Manufacturer, Techn. Data)</td> </tr> <tr> <td>On / off</td> <td></td> </tr> </table>		On / off	(Manufacturer, Techn. Data)	On / off									
On / off	(Manufacturer, Techn. Data)												
On / off													
Heating Depth (horizontal / vertical) ground heat exchanger Power of pump for ground heat exchanger													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">z</td> <td style="width: 90%;">m</td> </tr> <tr> <td>50,0</td> <td></td> </tr> <tr> <td>0,05</td> <td>kW</td> </tr> </table>		z	m	50,0		0,05	kW						
z	m												
50,0													
0,05	kW												

EnerPHit planning:

H E A T P U M P

Daikin Altherma 16 kW

HeatingHeat pump:
Source:Daikin Altherma 16 kW
Ambient air

	θ_{source} °C	θ_{sink} °C	Heating capacity kW	COP
Test Point 1	-15,0	35,0	12,9	2,0
Test Point 2	-7,0	35,0	14,9	2,6
Test Point 3	-2,0	35,0	15,4	2,9
Test Point 4	2,0	35,0	15,6	3,3
Test Point 5	7,0	35,0	16,1	4,2
Test Point 6	12,0	35,0	16,7	4,4
Test Point 7	15,0	35,0	18,2	4,8
Test Point 8	-15,0	50,0	10,6	1,6
Test Point 9	-7,0	50,0	12,4	1,9
Test Point 10	-2,0	50,0	13,6	2,1
Test Point 11	2,0	50,0	14,4	2,3
Test Point 12	7,0	50,0	14,5	2,8
Test Point 13	12,0	50,0	15,1	3,0
Test Point 14	15,0	50,0	16,4	3,2
Test Point 15				

Temperature difference in sink

 $\Delta\theta_{\text{Sink}}$

8,0 K

DHWHeat pump:
Source:Daikin Altherma 16 kW
Ambient air

	θ_{source} °C	θ_{sink} °C	Heating capacity kW	COP
Test Point 1	-15,0	35,0	12,9	2,0
Test Point 2	-7,0	35,0	14,9	2,6
Test Point 3	-2,0	35,0	15,4	2,9
Test Point 4	2,0	35,0	15,6	3,3
Test Point 5	7,0	35,0	16,1	4,2
Test Point 6	12,0	35,0	16,7	4,4
Test Point 7	15,0	35,0	18,2	4,8
Test Point 8	-15,0	50,0	10,6	1,6
Test Point 9	-7,0	50,0	12,4	1,9
Test Point 10	-2,0	50,0	13,6	2,1
Test Point 11	2,0	50,0	14,4	2,3
Test Point 12	7,0	50,0	14,5	2,8
Test Point 13	12,0	50,0	15,1	3,0
Test Point 14	15,0	50,0	16,4	3,2
Test Point 15				

Temperature difference in sink

 $\Delta\theta_{\text{Sink}}$

8,0 K

Electrical energy consumption of pump (groundwater / ground)
 Energy by Direct Electricity
 Space heat supplied by HP
 Winter DHW supplied by HP
 Summer DHW supplied by HP
 Space heating supplied by HP without storage losses
 Winter DHW supplied by HP without storage losses
 Summer DHW supplied by HP without storage losses
 Electrical consumption of HP

Q_{pump}
 $Q_{E,\text{dir}}$
 $Q_{HP,\text{Heating}}$
 $Q_{HP,\text{DHW,Winter}}$
 $Q_{HP,\text{DHW,Summer}}$
 $Q_{HP,\text{Heating}}$
 $Q_{HP,\text{DHW,Winter}}$
 $Q_{HP,\text{DHW,Summer}}$
 $Q_{el,HP}$

0	kWh/a
3791	kWh/a
20095	kWh/a
6482	kWh/a
3573	kWh/a
20095	kWh/a
11420	kWh/a
3104	kWh/a
16126	kWh/a

Seasonal performance factor of Heat Pump
 Seasonal Performance factor of System
 Heat generation efficiency DHW & heating

SPF_{H-1}
 SPF_{H-3}

1. HP: Heating or heating & DHW

1,87
1,66
60%

2. HP: Domestic hot water

23,5
61,0
16,0

Final electrical energy demand heat generation
 Annual primary energy demand
 Annual CO₂-Equivalent Emissions

 Q_{final}

EnerPHit planning:

HP Ground (Ground probes / Ground collectors)

<p>Building: Primary School 3 "Tzanko Diustabakov" - Section A</p> <p>Climate: Велико Търново PHI</p>	<p>Building type: School</p> <p>Treated Floor Area A_{TFA}: 848 m²</p>																																
Ground probes <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Probe field configuration</td> <td style="width: 90%; text-align: center;">A Individual probe</td> </tr> <tr> <td>Length of probe</td> <td>H 50 m</td> </tr> <tr> <td>Probes spacing/distance</td> <td>B m</td> </tr> <tr> <td>Depth (z=H/2)</td> <td>z 25 m</td> </tr> <tr> <td>Type of probe</td> <td>A Double-U</td> </tr> <tr> <td>Borehole radius</td> <td>R_b m</td> </tr> <tr> <td>Inner radius of pipe</td> <td>R_i m</td> </tr> <tr> <td>Exterior pipe radius</td> <td>R_a m</td> </tr> <tr> <td>Distance between pipes</td> <td>BU m</td> </tr> <tr> <td>Inner radius of pipe casing (only coaxial)</td> <td>R₁₂ m</td> </tr> <tr> <td>Exterior radius casing pipe (only coaxial)</td> <td>R_{s2} m</td> </tr> <tr> <td>Thermal conductivity of pipe</td> <td>λ_p W/(mK)</td> </tr> <tr> <td>Thermal conductivity of back fill</td> <td>λ_f W/(mK)</td> </tr> <tr> <td>Probe time constant</td> <td>t_p #DIV/0! d</td> </tr> <tr> <td>Internal borehole resistance</td> <td>R_a Km/W</td> </tr> <tr> <td>Borehole resistance</td> <td>R_b Km/W</td> </tr> </table>		Probe field configuration	A Individual probe	Length of probe	H 50 m	Probes spacing/distance	B m	Depth (z=H/2)	z 25 m	Type of probe	A Double-U	Borehole radius	R _b m	Inner radius of pipe	R _i m	Exterior pipe radius	R _a m	Distance between pipes	BU m	Inner radius of pipe casing (only coaxial)	R ₁₂ m	Exterior radius casing pipe (only coaxial)	R _{s2} m	Thermal conductivity of pipe	λ_p W/(mK)	Thermal conductivity of back fill	λ_f W/(mK)	Probe time constant	t _p #DIV/0! d	Internal borehole resistance	R _a Km/W	Borehole resistance	R _b Km/W
Probe field configuration	A Individual probe																																
Length of probe	H 50 m																																
Probes spacing/distance	B m																																
Depth (z=H/2)	z 25 m																																
Type of probe	A Double-U																																
Borehole radius	R _b m																																
Inner radius of pipe	R _i m																																
Exterior pipe radius	R _a m																																
Distance between pipes	BU m																																
Inner radius of pipe casing (only coaxial)	R ₁₂ m																																
Exterior radius casing pipe (only coaxial)	R _{s2} m																																
Thermal conductivity of pipe	λ_p W/(mK)																																
Thermal conductivity of back fill	λ_f W/(mK)																																
Probe time constant	t _p #DIV/0! d																																
Internal borehole resistance	R _a Km/W																																
Borehole resistance	R _b Km/W																																
Ground <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Soil type</td> <td style="width: 90%; text-align: center;">J 0</td> </tr> <tr> <td>Density of the ground</td> <td>ρ_E 0 kg/m³</td> </tr> <tr> <td>Thermal capacity of ground</td> <td>c_{pE} 0 J/(kgK)</td> </tr> <tr> <td>Thermal conductivity of ground</td> <td>λ_E 0,0 W/(mK)</td> </tr> <tr> <td>Soil temperature conductivity</td> <td>a_E #DIV/0! m/s²</td> </tr> <tr> <td>Ground temperature gradient</td> <td>ΔT_G 0,022 K/m</td> </tr> </table>		Soil type	J 0	Density of the ground	ρ_E 0 kg/m ³	Thermal capacity of ground	c_{pE} 0 J/(kgK)	Thermal conductivity of ground	λ_E 0,0 W/(mK)	Soil temperature conductivity	a_E #DIV/0! m/s ²	Ground temperature gradient	ΔT_G 0,022 K/m																				
Soil type	J 0																																
Density of the ground	ρ_E 0 kg/m ³																																
Thermal capacity of ground	c_{pE} 0 J/(kgK)																																
Thermal conductivity of ground	λ_E 0,0 W/(mK)																																
Soil temperature conductivity	a_E #DIV/0! m/s ²																																
Ground temperature gradient	ΔT_G 0,022 K/m																																
Brine <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Brine (characteristics at 2 °C)</td> <td style="width: 90%; text-align: center;">E 0</td> </tr> <tr> <td>Density of the brine</td> <td>ρ_s 0 kg/m³</td> </tr> <tr> <td>dynamic viscosity of the brine</td> <td>η_s 0 kg/(ms)</td> </tr> <tr> <td>Heat capacity brine</td> <td>c_{ps} 0 J/(kgK)</td> </tr> <tr> <td>Thermal conductivity of brine</td> <td>λ_s 0 W/(mK)</td> </tr> <tr> <td>Brine - mass flow</td> <td>m_s kg/s</td> </tr> </table>		Brine (characteristics at 2 °C)	E 0	Density of the brine	ρ_s 0 kg/m ³	dynamic viscosity of the brine	η_s 0 kg/(ms)	Heat capacity brine	c_{ps} 0 J/(kgK)	Thermal conductivity of brine	λ_s 0 W/(mK)	Brine - mass flow	m _s kg/s																				
Brine (characteristics at 2 °C)	E 0																																
Density of the brine	ρ_s 0 kg/m ³																																
dynamic viscosity of the brine	η_s 0 kg/(ms)																																
Heat capacity brine	c_{ps} 0 J/(kgK)																																
Thermal conductivity of brine	λ_s 0 W/(mK)																																
Brine - mass flow	m _s kg/s																																
Operation type <p>Waste heat of active cooling to ground probe? Please check, if applicable.</p> <p>Heat pump operation duration</p> <p>Specific heat extraction rate as an annual average</p>																																	
<input checked="" type="checkbox"/> q_{ex} h/a H/R_b W/m W/K																																	
Ground collectors <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Inner radius of pipe</td> <td style="width: 90%; text-align: center;">r_i 0,013 m</td> </tr> <tr> <td>Exterior pipe radius</td> <td>r_a 0,016 m</td> </tr> <tr> <td>Thermal conductivity of pipe</td> <td>λ_t 0,420 W/(mK)</td> </tr> <tr> <td>Pipe depth</td> <td>z_{pipe} 50 m</td> </tr> <tr> <td>Ground water depth</td> <td>z_{gw} m</td> </tr> <tr> <td>Pipe spacing</td> <td>D 0,4 m</td> </tr> <tr> <td>Base area</td> <td>80 m²</td> </tr> <tr> <td>Pipe outer surface</td> <td>20,1 m²</td> </tr> <tr> <td>Pipe length</td> <td>L 200,0 m</td> </tr> </table>		Inner radius of pipe	r_i 0,013 m	Exterior pipe radius	r_a 0,016 m	Thermal conductivity of pipe	λ_t 0,420 W/(mK)	Pipe depth	z_{pipe} 50 m	Ground water depth	z_{gw} m	Pipe spacing	D 0,4 m	Base area	80 m ²	Pipe outer surface	20,1 m ²	Pipe length	L 200,0 m														
Inner radius of pipe	r_i 0,013 m																																
Exterior pipe radius	r_a 0,016 m																																
Thermal conductivity of pipe	λ_t 0,420 W/(mK)																																
Pipe depth	z_{pipe} 50 m																																
Ground water depth	z_{gw} m																																
Pipe spacing	D 0,4 m																																
Base area	80 m ²																																
Pipe outer surface	20,1 m ²																																
Pipe length	L 200,0 m																																
Brine <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Brine (characteristics at 2 °C)</td> <td style="width: 90%; text-align: center;">E 0</td> </tr> <tr> <td>Density of the brine</td> <td>ρ_s 0 kg/m³</td> </tr> <tr> <td>dynamic viscosity of the brine</td> <td>η_s 0 kg/(ms)</td> </tr> <tr> <td>Heat capacity brine</td> <td>c_{ps} 0 J/(kgK)</td> </tr> <tr> <td>Thermal conductivity of brine</td> <td>λ_s 0 W/(mK)</td> </tr> <tr> <td>Brine - mass flow</td> <td>m_s 0,5 kg/s</td> </tr> </table>		Brine (characteristics at 2 °C)	E 0	Density of the brine	ρ_s 0 kg/m ³	dynamic viscosity of the brine	η_s 0 kg/(ms)	Heat capacity brine	c_{ps} 0 J/(kgK)	Thermal conductivity of brine	λ_s 0 W/(mK)	Brine - mass flow	m _s 0,5 kg/s																				
Brine (characteristics at 2 °C)	E 0																																
Density of the brine	ρ_s 0 kg/m ³																																
dynamic viscosity of the brine	η_s 0 kg/(ms)																																
Heat capacity brine	c_{ps} 0 J/(kgK)																																
Thermal conductivity of brine	λ_s 0 W/(mK)																																
Brine - mass flow	m _s 0,5 kg/s																																
Specific heat extraction rate <p>q_{ex} W/m²</p> <p>$U * A$ W/K</p>																																	
Climate <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Period duration</td> <td style="width: 90%; text-align: center;">365 d</td> </tr> <tr> <td>Average ground surface temperature</td> <td>T_{m0} 11,7 °C</td> </tr> <tr> <td>Surface temperature amplitude</td> <td>T₁ 11,4 °C</td> </tr> <tr> <td>Phase shifting surface</td> <td>t₀₂ 31 d</td> </tr> </table>		Period duration	365 d	Average ground surface temperature	T _{m0} 11,7 °C	Surface temperature amplitude	T ₁ 11,4 °C	Phase shifting surface	t ₀₂ 31 d																								
Period duration	365 d																																
Average ground surface temperature	T _{m0} 11,7 °C																																
Surface temperature amplitude	T ₁ 11,4 °C																																
Phase shifting surface	t ₀₂ 31 d																																

HP Ground (Ground probes / Ground collectors)

Ground characteristics		Thermal conductivity [W/(mK)]	Density [kg/m³]	Heat capacity [J/(kg K)]	Heat capacity [MJ/(m³ K)]	Temperature conductivity [10⁻⁷ m²/s]	Source
A	Sand, 9% moisture	0,980	1440	1507	2,170	4,520	[Neiß 1977]
B	Sand, 13% moisture	1,500	1600	1800	2,880	5,210	[Neiß 1977]
C	Ground, coarse gravel	0,520	2000	1840	3,680	1,410	[VDI 1984]
D	Loam, 36% moisture	2,300	1650	2847	4,700	4,900	[Neiß 1977]
E	Clay	1,280	1500	880	1,320	9,700	[VDI 1984]
F	Clay / Silt	2,200	2550	882	2,250	9,780	[VDI 2000]
G	Slate	2,100	2700	870	2,350	8,940	[VDI 2000]
H	Silt	1,500	1920	2938	5,640	2,660	[ISO 13370]
I	Rock	3,500	2500	2500	6,250	5,600	[ISO 13370]
J							

Result ground probe calculation	
Month	Borehole Temperature °C
1	
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	

Properties of the brine		Temperature	Density	Heat capacity	Thermal conductivity	Dynamic viscosity
		[°C]	[kg/m³]	[J/(kg K)]	[W/(mK)]	[kg/(ms)]
A	Ethylene glycol 25%	2	1052	3950	0,480	0,0052
B	Potassium carbonate	2	1265	2941	0,544	0,0031
C	Potassium formate	2	1226	3190	0,534	0,00237
D	Water	2	997	4190	0,590	0,001307
E						

COMPACT UNIT WITH EXHAUST AIR HEAT PUMP

Calculation based on measured values of the laboratory evaluation for component certification

Building: Primary School 3 "Tzanko Diustabakov" - Section A	Building type: School
Treated Floor Area A_{IFA} :	848 m ²
Covered fraction of space heating demand (PE Value worksheet)	0%
Space Heating Demand + Distribution Losses $Q_{H,HP} + Q_{DHW}$ (DHW+Distribution)	39424 kWh
Solar contribution for space heating $\eta_{Solar, H}$ (SolarDHW worksheet)	13%
Effective Annual heating demand $Q_{H,W} = Q_H * (1 - \eta_{Solar, H})$	0 kWh
Covered Fraction of DHW Demand (PE Value worksheet)	0%
Total Heating Demand of DHW system Q_{DHW} (DHW+Distribution)	25541 kWh
Solar contribution for DHW $\eta_{Solar, DHW}$ (SolarDHW worksheet)	39%
Effective DHW Demand $Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$	0 kWh
Sort: AS LIST	
Go to list of compact units	
Invalid selection: for the time being compact HP units or combined HPs can ONLY be considered as single units, meaning they can ONLY be calculated with the 'Ventilation' worksheet (please check the	
Compact unit selection:	
Measured Values from Laboratory Test	
Ventilation	
Effective heat recovery efficiency η_{eff} (Test stand)	
Electric Efficiency (Test stand)	Wh/m ³
Heating	
Ambient Air Temperature T_{amb}	
Measured Thermal Power Heat Pump Heating $P_{HP,Heating}$	
Measured COP Heating $COP_{Heating}$	
Domestic Hot Water	
Ambient Air Temperature T_{amb}	
Measured Thermal Power DHW Storage Heating-Up $P_{DHW,Heating-Up}$	
Measured Thermal Power DHW Storage Reload $P_{DHW,Reload}$	
Measured COP DHW Storage Heating-Up $COP_{DHW,Heating-Up}$	
Measured COP DHW Storage Reload $COP_{DHW,Reload}$	
Standby (inputs required only if different from storage reload)	
Ambient Air Temperature T_{amb}	
Measured Thermal Power Heat Pump Standby $P_{HP,Standby}$	
Measured COP Standby $COP_{Standby}$	
Specific heat loss storage incl. connections $U * A_{Storage}$ (Test stand)	0%
Average Storage Temperature in Standby Mode $T_{avg,Standby}$ (Test stand)	°C
Heat pump priority	
separate heat pumps	DHW Priority
Room temperature (°C) T_{amb}	18
Av. Ambient Temp. Heating P. (°C) $T_{avg,Heating}$	4
Av. Ground Temp (°C) $T_{avg,Ground}$	12
Efficiency SHX Exhaust Air Mixing η_{SHX}	
Heat Recovery Efficiency SHX Exhaust Air Mixing (if applicable) $\eta_{SHX,add}$ (Design Value)	0%
Volume Flow Rate of Added Exhaust Air (if applicable) V_{add} (Test stand)	m ³ /h
Hydraulic frost protection	
Heat supplied by direct electricity $Q_{E,dr}$	kWh/a
Space heat supplied by HP $Q_{HP,Heating}$	kWh/a
Winter DHW supplied by HP $Q_{HP,DHW,Water}$	0 kWh/a
Winter standby heat supplied by HP $Q_{HP,Standby,Water}$	kWh/a
Summer DHW supplied by HP $Q_{HP,DHW,Summer}$	0 kWh/a
Summer standby heat supplied by HP $Q_{HP,Standby,Summer}$	kWh/a
Performance Ratio of Heat Generator, DHW & Space Heating	
Annual Coefficient of Performance SPF_{H3}	
Final energy demand heat generation Q_{final}	kWh/a
Annual primary energy demand	kWh/(m ² a)
Annual CO ₂ -Equivalent Emissions	kg/a
	kg/(m ² a)
	kWh/a
	kg/(m ² a)

Building: Primary School 3 "Tzanko Diustabanov" - Section A		Building type: School	
Treated Floor Area $A_{TF,A}$	848 m ²		
Covered fraction of space heating demand	(PE Value worksheet)	0%	
Space Heating Demand + Distribution Losses	$Q_{HS} + Q_{DHW}$ (DHW+Distribution)	39424 kWh	
Solar contribution for space heating	$\eta_{Solar, HS}$ (SolarDHW worksheet)	13%	
Effective Annual heating demand	$Q_{HS,W} = Q_{HS} * (1 - \eta_{Solar, HS})$	0 kWh	
Space Heating Demand without Distribution Losses	Q_{HS} (Verification sheet)	39278 kWh	
Covered Fraction of DHW Demand	(PE Value worksheet)	0%	
Total Heating Demand of DHW system	Q_{DHW} (DHW+Distribution)	25541 kWh	
Solar contribution for DHW	$\eta_{Solar, DHW}$ (SolarDHW worksheet)	39%	
Effective DHW Demand	$Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$	0 kWh	
Boiler Type	(Project)	None	Additional selection only in the case of Natural Gas
Primary Energy factor	(Data worksheet)		kWh/kWh
CO ₂ -Emissions Factor (CO ₂ -Equivalent)		250 g/kWh	
Useful heat provided	Q_{Use}		kWh/a
Max. Heating Power Required for Heating the Building	P_{BH} (Heating load worksheet)	22,18 kW	
Length of the Heating Period	t_{HP}	4540 h	
Length of DHW Heating Period	t_{DHW}	8760 h	
Use characteristic values entered (check if appropriate)?			
Design Output	P_{Nom} (Rating Plate)	22 kW	Standard Values
Installation of Boiler (Outdoor: 0, Indoor: 1)		0	Input field
Input Values (Oil and Gas Boiler)			
Boiler Efficiency at 30% Load	$\eta_{10\%}$ (Manufacturer)		
Boiler Efficiency at Nominal Output	$\eta_{100\%}$ (Manufacturer)		
Standby Heat Loss Boiler at 70 °C	$q_{B,70}$ (Manufacturer)		
Average Return Temperature Measured at 30% Load	$\vartheta_{30\%}$ (Manufacturer)		°C
Input Values (Biomass Heat Generator)			
Efficiency of Heat Generator in Basic Cycle	η_{GZ} (Manufacturer)		
Efficiency of Heat Generator in Constant Operation	η_{SO} (Manufacturer)		
Average Fraction of Heat Output Released to Heating Circuit	$Z_{IC,m}$ (Manufacturer)		
Temperature Difference Betw. Power-On and Power-Off	$\Delta\vartheta$ (Manufacturer)		
For Interior Installations: Area of Mechanical Room	$A_{Install}$ (Project)		m ²
Useful heat output per basic cycle	$Q_{N,GZ}$ (Manufacturer)		kWh
Average Power Output of the Heat Generator	$Q_{N,m}$ (Manufacturer)		kWh
Heat generator without pellets conveyor			
Unit with regulation (no fan / no starting aid)			
Heating energy demand for a basic machine cycle	$Q_{HE,GZ}$ (Manufacturer)		kWh
Power consumption in steady state operation	$P_{el,SB}$ (Manufacturer)		W
Utilisation factor heat generator heating run	$h_{H,gK} = \eta_g * \eta_K$	0%	
Utilisation factor heat generator DHW run	$h_{TW,gK} = \eta_{100\%} / \eta_{g,TW}$	0%	
Utilisation factor heat generator DHW & heating	h_{gK}	0%	
Final energy demand space heating	$Q_{Final, HE} = Q_{HS,W} * \epsilon_{H,gK}$	0 kWh/a	
Final energy demand DHW	$Q_{Final, DHW} = Q_{DHW,W} * \epsilon_{TW,gK}$	0 kWh/a	
Total final energy demand	$Q_{Final} = Q_{Final,DHW} + Q_{Final,HE}$	0,0 kWh/(m ²)	
Annual primary energy demand			
Annual CO ₂ -Equivalent Emissions		0 kg/a	
			kg/(m ² a)
		0,0	

Building: Primary School 3 "Tzanko Diustabakov" - Section A	Building type: School										
Treated Floor Area A_{TFP} :	848 m ²										
Covered fraction of space heating demand (PE Value worksheet)	30%										
Annual heating demand kWh/a Q_H (DHW+Distribution)	39424 kWh										
Solar contribution for space heating $\eta_{Solar, H}$ (SolarDHW worksheet)	13%										
Effective Annual heating demand $Q_{H,W} = Q_H * (1 - \eta_{Solar, H})$	10237 kWh										
Covered Fraction of DHW Demand (PE Value worksheet)	40%										
DHW Demand Q_{DHW} (DHW+Distribution)	25541 kWh										
Solar contribution for DHW $\eta_{Solar, DHW}$ (SolarDHW worksheet)	39%										
Effective DHW Demand $Q_{DHW,W} = Q_{DHW} * (1 - \eta_{Solar, DHW})$	6262 kWh										
Heat source	Hard Coal COS 70% PHC										
Primary Energy factor (Data worksheet)	0.8 kWh/kWh										
CO ₂ -Emissions factor (CO ₂ -Equivalent) (Data worksheet)	240 g/kWh										
Utilisation factor of heat transfer station ha,HX	105%										
Final energy demand heat generation $Q_{final} = Q_{use} * \epsilon_{a,DH}$	<table border="1"> <tr> <td>kWh/a</td> <td>kWh/(m²a)</td> </tr> <tr> <td>17324</td> <td>20,4</td> </tr> <tr> <td>13859</td> <td>16,3</td> </tr> <tr> <td>kg/a</td> <td>kg/(m²a)</td> </tr> <tr> <td>4158</td> <td>4,9</td> </tr> </table>	kWh/a	kWh/(m ² a)	17324	20,4	13859	16,3	kg/a	kg/(m ² a)	4158	4,9
kWh/a	kWh/(m ² a)										
17324	20,4										
13859	16,3										
kg/a	kg/(m ² a)										
4158	4,9										
Annual primary energy demand											
Annual CO₂-Equivalent Emissions											

Table of Primary Energy Factors and CO₂-Equivalent Emissions Factors of Various Energy Carriers

Energy Type		Energy Carrier	PE (non-regenerative) kWh _{Prim} /kWh _{Final}	CO ₂ GEMIS 3.0 kg/kWh _{Final}
Fuel Source	1	None		
	2	Oil	1,1	0,31
	3	Natural Gas	1,1	0,25
	4	LPG	1,1	0,27
	5	Hard Coal	1,1	0,44
	6	Wood	0,2	0,05
Electricity	7	Electricity-Mix	2,6	0,68
	8	Electricity from Photovoltaics	0,7	0,25
District Heat	1	None	0	0
	2	Hard Coal CGS 70% PHC	0,8	0,24
	3	Hard Coal CGS 35% PHC	1,1	0,32
	4	Hard Coal HS 0% PHC	1,5	0,41
	5	Gas CGS 70% PHC	0,7	-0,07
	6	Gas CGS 35% PHC	1,1	0,13
Gas CGS	7	Gas HS 0% PHC	1,5	0,32
	8	Oil CGS 70% PHC	0,8	0,1
	9	Oil CGS 35% PHC	1,1	0,25
	10	Oil HS 0% PHC	1,5	0,41
Heating Oil-EL CGS	11	Oil HS 35% PHC	0,8	0,1
	12	Oil HS 0% PHC	1,5	0,41
	13	Oil HS 35% PHC	0,8	0,1

Data Source: DIN V 4701-10/GEMIS 4.14

Heat Generator		Selection of gas type	
Nr.	Type	Nr.	Type
1	None	1	Natural Gas
2	Improved gas condensing boi-ler	2	LPG
3	Improved oil condensing boi-ler	3	
4	Condensing boiler gas		
5	Condensing boiler oil		
6	Low Temperature Boi-ler Gas		
7	Low Temperature Boi-ler Oil		
8	Wood Log Burning (Direct and Indirect Release of Heat)		
9	Wood Pellet Burning (Direct and Indirect Release of Heat)		
10	Wood Pellet Burning (Only Indirect Release of Heat)		
11	Reserve		

Dishwashing	Washing
1	DHW Connection
2	Cold water connection

Clothes Drying		Availability	Electricity	Availability	Evaporation
1	Clothesline		1		1
2	Drying Closet (cold!)		1		1
3	Drying Closet (cold!) in Exhaust Air		0,9		0,9
4	Condensation Dryer		0,7		0
5	Electric Exhaust Air Dryer		1		1
6	Gas Exhaust Air Dryer		1		1

Cooking		Electric Fraction	Primärenergiefaktor	CO ₂ factor
1	Electricity	100%	2,6	0,68
2	Natural Gas	0%	1,1	0,25
3	LPG	0%	1,1	0,27