

BRIEF INSTRUCTIONS

Place your mouse here to see the PHPP help.

If no help appears when the mouse passes over cell B4, you can activate it by going into the Menu Bar Tools/Options/View, and under "Comments", select "Comment Indicator Only".


Passive House verification: meaning of field formats

Example	Field Format	Meaning
78,8	Arial, blue, bold with yellow background	Input field: Please enter the required value here
01ud Triple-low-e Kr08	Arial Narrow, blue, with yellow background	Data entry field with drop down list
80	Arial, blue, bold with grey background	Link (through Variants-macro). Attention: do not overwrite!
6619	Arial, black, standard on white background	Calculation field; please do not change
78,8	Arial, violet, bold with white background	Field with reference to another worksheet
126,0	Arial, black, large & bold on green background	Important result

Passive House planning: worksheet directory

Worksheet name (to show/hide worksheets please use the separate 'Profile settings' tool)	Function	Brief description	Required for the certification?
Verification	Building data; summary of results	Building description, selection of the calculation method, summary of results	yes
Overview	Overview of the specific data of the project entered	In-depth project description, overview of all results and input variables, specific details on building envelope, building services systems as well as general information.	no
Cross check	Data entry assistance	Information in case PHPP does not calculate, overview of errors, plausibility checks	yes
Variants	Calculation of variants	Input parameters and results for variant calculation. Predefined fields for frequent entries, as well as user-defined area.	no
Comparison	Comparison between two variants	Comparison between two variants from the perspective of energy demand and economic viability. Input of comparison configurations.	No
Climate	Climate region selection or definition of user data	Climate data for: 'Annual heating', 'Windows', 'Heating load', 'Heating', 'Summer', 'Cooling', 'Cooling units', 'Cooling load' worksheets	yes
U-Values	Calculation of standard building assembly U-Values	Heat transmission coefficient calculations in accordance with DIN EN ISO 6946.	yes
Areas	Areas summary	Building assembly areas, thermal bridges, treated floor area. Use exterior dimension references!	yes
Ground	Calculation of reduction factors below ground	More precise calculation of heat losses through the ground	if applicable
Components	Building component database	Database of certified, Passive House suitable components and entry of user-defined components	yes
Windows	UW-Value determination	Input of geometry, orientation, frame lengths, frame widths, U _f and U-values of the frame, and the thermal bridge heat loss coefficients of the connections; from these inputs, determine U _w and total radiation.	yes
Shading	Determination of shading coefficients	Input of shading parameters, e.g. balcony, neighbouring building, window reveal and calculating the shading factors	yes
Ventilation	Air flow rates, Exhaust/Supply air balancing, Pressurization test results	Sizing the ventilation system from extract and supply air requirements, infiltration air change rate and actual efficiency of heat recovery, input of pressurization test results	yes
Addl vent	Design and planning of ventilation systems with diverse ventilation units	Extension of the 'Ventilation' worksheet for dimensioning air flows, for special building uses and systems with various ventilation units	if used
Annual heating	Annual space heating demand / Annual method	Calculation of the annual space heating demand according to the energy balance method following EN 13790: Transmission + Ventilation - h (Solar gains + Internal gains)	no
Heating	Space heating demand calculation Monthly method according to EN 13790	Calculation procedure for the monthly method following EN 13790. Make appropriate selection in the 'Verification' worksheet, if calculations should be performed following this procedure	yes
Heating Load	Building heating load calculation	Calculation of the nominal heating load using a balance procedure for the design day: max transmission + max ventilation - η (minimum solar gains + internal heat gains)	yes
SummVent	Determination of summer ventilation	Ventilation in cooling case and estimation of air flow rates for natural ventilation during the summer period	yes
Summer	Assessment of summer climate	Calculation of the frequency of overheating as a measure of summer comfort	yes
Cooling	Monthly method for cooling demand	Annual useful cooling demand calculation	if present
Cooling units	Latent cooling energy	Calculation of the energy demand for dehumidification and choice of cooling method	if present
Cooling load	Building cooling load calculation	Calculation of the daily average cooling load of the building	no
DHW+Distribution	Distribution losses; DHW requirement and losses	Heat loss calculation of the distribution systems (heating; DHW); calculation of the useful heat requirement of DHW and storage losses	yes
SolarDHW	Solar DHW heating	Solar contribution calculation for DHW and space heating contribution	if solar panels are used
PV	Electricity generation by photovoltaic	Electricity generation calculation of PV system	no
Electricity	Electricity demand for dwellings	Calculation of the electricity demand of Passive Houses with residential use	yes
Use non-res	Patterns of non-residential utilisation	Input or selection of utilisation patterns for planning of electricity demand and internal heat gains	no
Electricity non-res	Electricity demand for non-residential use	Calculation of the electricity demand for lighting, electric devices and kitchens for non-residential buildings	no
Aux Electricity	Auxiliary electricity demand	Calculation of auxiliary electricity and corresponding primary energy demand	yes
IHG	Internal heat gains in dwellings	Calculation of the internal heat gains based on the Electricity and Aux Electricity sheets.	no
IHG non-res	Internal heat gains for non-residential use	Calculation of the internal heat gains for non-residential buildings based on the 'Electricity non-res' worksheet and the occupancy	no
PER	Specific primary energy and CO ₂ demands	Selection of heat generators, calculation of the primary energy and CO ₂ specific demands from the present results	yes
Compact	Performance ratio of heat generator Compact heat pump unit	Calculation of the performance ratio of combined heat generation for heating and DHW by means of an electric heat pump compact unit exclusively, considering the specific project boundary conditions.	if present
HP	Performance ratio of heat generation of the heat pump	Calculation of the performance ratio for heat generation for one to two electric-run heat pumps, considering the specific project boundary conditions.	if present
HP Ground	Ground probe or ground collector in combination with a heat pump	Heat source calculation for a ground probe or horizontal subsoil heat exchanger for ground-coupled heat pumps, considering the specific project boundary conditions.	if present
Boiler	Performance ratio of heat generator Boiler	For the calculation of the performance ratio of heat generation with standard boilers (NT and calorific boilers) for the project given boundary conditions.	if present
District Heating	District heat transfer station	Calculation of the final and primary energy demands (heat)	if present
Data	Database	Table of primary energy factors following [GEMIS] and database of EnEV (German energy efficiency regulation).	No

EnerPHit Verification



Architecture: Cabinet d'architecture Archipente
 Street: 2 rue du Repos
 Postcode/City: 42600 MONTBRISON
 Province/Country: FR-France

Energy consultancy: La Maison Passive
 Street: 110 rue Réaumur
 Postcode/City: 75002 Paris
 Province/Country: FR-France

Year of construction: 2017
 No. of dwelling units: 1
 No. of occupants: 10,0

Building: Archipente
 Street: 2 rue du Repos
 Postcode/City: 42600 MONTBRISON
 Province/Country: FR-France
 Building type:
 Climate data set: ud---00-Montbrison1314
 Climate zone: 4: Warm-temperate Altitude of location: 399 m

Home owner / Client: Cabinet d'architecture Archipente
 Street: 2 rue du Repos
 Postcode/City: 42600 MONTBRISON
 Province/Country: FR-France

Mechanical system:
 Street:
 Postcode/City:
 Province/Country:

Certification: La Maison Passive
 Street: 110 rue Réaumur
 Postcode/City: 75002 Paris
 Province/Country: FR-France

Interior temperature winter [°C]: 20,0 Interior temp. summer [°C]: 25,0
 Internal heat gains (IHG) heating case [W/m²]: 3,5 IHG cooling case [W/m²]: 3,5
 Specific capacity [Wh/K per m² TFA]: 60 Mechanical cooling:

Specific building characteristics with reference to the treated floor area						
	Treated floor area m²			Criteria	Alternative criteria	Fulfilled? ²
Space heating	Heating demand kWh/(m²a)	14	≤	20	-	yes
	Heating load W/m²	19	≤	-	-	-
Space cooling	Cooling & dehum. demand kWh/(m²a)	-	≤	-	-	-
	Cooling load W/m²	-	≤	-	-	-
	Frequency of overheating (> 25 °C) %	5	≤	10	-	yes
	Frequency excessively high humidity (> 12 g/kg) %	0	≤	20	-	yes
Airtightness	Pressurization test result n ₅₀ 1/h	1,0	≤	1,0	-	yes
Non-renewable Primary Energy (PE)	PE demand kWh/(m²a)	110	≤	120	-	yes
Primary Energy	PER demand kWh/(m²a)	91	≤	-	-	-
Renewable (PER)	Generation of renewable energy kWh/(m²a)	70	≥	-	-	-

EnerPHit (refurbishment): Component characteristics						
	Building envelope to exterior air ¹ (U-value) W/(m²K)	-	≤	-	-	-
	Building envelope to ground ¹ (U-value) W/(m²K)	0,23	≤	-	-	-
	Wall w/int. insulation in contact w/external air (U-value) W/(m²K)	0,16	≤	-	-	-
	Wall w/interior insulation in contact w/ground (U-value) W/(m²K)	-	≤	-	-	-
	Flat roof (SRI) -	19	≥	-	-	-
	Inclined and vertical external surface (SRI) -	19	≥	-	-	-
	Windows/Entrance doors (U _{w,D,installed}) W/(m²K)	0,87	≤	-	-	-
	Windows (U _{w,installed}) W/(m²K)	-	≤	-	-	-
	Windows (U _{w,installed}) W/(m²K)	-	≤	-	-	-
	Glazing (g-value) -	0,61	≥	-	-	-
	Glazing/sun protection (max. solar load) kWh/(m²a)	174	≤	-	-	-
	Ventilation (effective heat recovery efficiency) %	81	≥	-	-	-
	Ventilation (humidity recovery efficiency) %	73	≥	-	-	-

¹ Without windows, doors and external walls with interior insulation
² Empty field: Data missing; -: No requirement

I confirm that the values given herein have been determined following the PHPP methodology and based on the characteristic values of the building. The PHPP calculations are attached to this verification.

Task: _____ First name: IngeProjetsLAMP Surname: _____
 Issued on: _____ City: _____

EnerPHit Classic? **yes**
 Signature: _____

Project data imported from designPH 1.0.6 PHPP9 display.code:

PHPP Check

EnerPHit with PHPP Version 9.:

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

▼ Overview input errors

Congratulations! There are no error messages in your PHPP.

Verification	-
Climate	-
U-Values	-
Areas	-
Ground	-
Components	-
Windows	-
Shading	-
Ventilation	-
Add vent	-
SummVent	-
Cooling units	-
DHW+Distribution	-
SolarDHW	-
PV	-
Electricity	-
Use non-res	-
Electricity non-res	-
Aux Electricity	-
IHG	-
IHG non-res	-
PER	-
Compact	-
HP	-
HP Ground	-
Boiler	-
District heating	-

▼ Are results missing from 'Verification' worksheet? Possible causes can be found next

Variant calculation

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

		Active						
		6 PV + Efficient Lighting and elec. equipment	Existing	Walls + Ventilation + Suspended floor	Roof + Windows + Efficient hot water storage + Boiler regulation	Airtightness floor	PV + Efficient Lighting and elec equipment	National Regulation
Select the active variant here >>>>>>		5	1	2	3	4	5	6
Results	Units							
Heating demand	kWh/(m ² a)	13,8	155,0	74,1	18,7	13,8	13,8	78,1
Heating load	W/m ²	19,2	99,5	58,1	26,7	19,2	19,2	67,1
Cooling & dehum. demand	kWh/(m ² a)							
Cooling load	W/m ²							
Frequency of overheating (> 25 °C)	%	5,0	9,2	9,9	4,9	5,0	5,0	4,2
PER demand	kWh/(m ² a)	90,9	409,5	235,4	113,4	103,3	90,9	246,4
EnerPHit Classic?	yes / no	yes	no	no	no	no	yes	no

Final energy - - - - -

User determined results		5	1	2	3	4	5	6
PE demand [kWh/(m ² a)]		109,5	179,6	155,4	137,3	134,5	109,5	160,5
newable Energy Production [kWh/(m ² ground.a)]	kWh/(m ² ground.a)	70,4	0,0	0,0	0,0	0,0	70,4	0,0
DU PT	W/(m ² .K)	0,01	0,03	0,01	0,01	0,01	0,01	0,02
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0
			0,0	0,0	0,0	0,0	0,0	0,0

Input variables

		Units	Value	1	2	3	4	5	6
Building assembly layers		U-Value							
Radiation balance		Areas							
Thermal bridges		Areas							
Windows and shading		Windows Shading							
Ventilation		Ventilation							
Ventilation type	select	1-Balanced PH ventilation with HR	2-Extract air unit	1-Balanced PH ventilation with HR	1-Balanced PH ventilation with HR	1-Balanced PH ventilation with HR	1-Balanced PH ventilation with HR	1-Balanced PH ventilation with HR	2-Extract air unit
Air change rate at pressurisation test (n ₅₀)	1/h	1,00	6,77	4	2,5	1	1	1	6,77
Design air flow rate (maximum)	m ³ /h	173	173	173	173	173	173	173	173
Installation site ventilation unit	Inside / Outside	2-Outside of thermal envelope		2-Outside of thermal envelope	2-Outside of thermal envelope	2-Outside of thermal envelope	2-Outside of thermal envelope	2-Outside of thermal envelope	
Ventilation unit selection	select	0304vs03-PAUL - novus F 300		0304vs03-PAUL - novus F 300	0304vs03-PAUL - novus F 300	0304vs03-PAUL - novus F 300	0304vs03-PAUL - novus F 300	0304vs03-PAUL - novus F 300	
Summer ventilation		SummVent							
Heat generator		PER							
Compressor cooling units		Cooling units							
User determined parameters									

Comparison between two variants

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Selection of comparison configuration

Description	1-
Component type	
Building component	

Calculation of the selected configuration

	Poorer energy efficiency	Better energy efficiency	Difference / Savings / Profit
Design according to variant			
Minimum inside surface temperature			°C

Investment costs						
	Per m ² of building element	Complete building element	Per m ² of building element	Complete building element	Per m ² of building element	Complete building element
Area of building element	1		1		1	
Investment costs minus financial support						
Annuity (annual capital costs)						

Operation (heating + cooling + mechanical ventilation)						
	Per m ² of TFA	Entire building	Per m ² of TFA	Entire building	Per m ² of building element	Complete building element
Area	1		1		1	
Heating demand						
Cooling + dehumidification demand						
CO ₂ emissions						
Primary energy renewable (PER)						
Annual operation costs						

Cost-effectiveness	
Maximal economically viable additional investment costs	€
Average cost for saved kWh of final energy	Cent/kWh
Total annual costs	€

Boundary conditions					
Interest rate + inflation		Price of final energy [€/kWh]		Utilisation period [a]	
Nominal interest rate	3,0%	Electricity	0,15	Assembly layers	50
Inflation	1,0%	Gas / Oil	0,09	Vent. system	30
Period under consideration [a]	20	Wood	0,07	Thermal bridges	50
		District heating	0,10	Entire building	50
		Other	0,09	Windows	40



Surface temperature

Annuity

Energy, CO₂, Costs

Boundary conditions

Input of comparison configurations	1	2	3	4	5
Description					
Component type					
Building component					
Variant "Poorer energy efficiency"					
Investment costs [€]					
Annual maintenance costs [€/a]					
Variant "Better energy efficiency"					
Investment costs [€]					
Annual maintenance costs [€/a]					
Financial support (present value) [€]					

Results (manual transfer)

Description	1	2	3	4	5
	9,09				

Climate data

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Selection of climate data

Country:

Region:

Climate data set:

Climate zone:

Altitude

Weather station: m


Building location: m

Result overview

Annual heating demand	13,8	kWh/(m²a)
Heating load	19,2	W/m²
Frequency of overheating	5,0	%
Sensible cooling	8,9	kWh/(m²a)
Latent cooling	0,1	kWh/(m²a)
Cooling load	-	W/m²
PER demand	90,9	kWh/(m²a)

Data for heating

Annual method	Heating	Cooling	d/a
Heating / cooling period	180	273	365
Heating / cooling degree hours	57	73	-121
Radiation North	91	185	322
Radiation East	201	417	714
Radiation South	378	676	966
Radiation West	202	429	726
Horizontal radiation	372	747	1285



	Month	Days												Heating load		Cooling load		PER factors
		1	2	3	4	5	6	7	8	9	10	11	12	Weather 1	Weather 2	Weather 1	Weather 2	
	ud--00-Montbrison1314	Latitude °	45,6	Longitude °	4,1	Altitude [m]	399	Daily temperature swing Summer [K]				4,0	Radiation: [W/m²]		Radiation: [W/m²]			
° C	Exterior temperature	6,0	6,8	8,1	11,6	14,4	20,2	18,9	19,2	17,0	14,5	5,6	5,0	-6,0	-2,0	25,1	25,1	1,30
kWh/(m²month)	Radiation North	10	15	24	30	42	50	50	37	26	18	12	8	10	5	104	104	1,30
kWh/(m²month)	Radiation East	21	32	57	72	85	96	111	90	68	40	24	18	15	5	185	185	1,80
kWh/(m²month)	Radiation South	54	64	96	90	83	88	98	104	107	80	55	47	50	10	208	208	1,10
kWh/(m²month)	Radiation West	21	30	59	79	89	96	107	94	69	43	23	16	15	5	207	207	1,15
kWh/(m²month)	Horizontal radiation	37	58	123	140	145	191	189	158	114	67	36	26	20	5	347	347	
° C	Dew point temperature	0,2	0,9	2,6	4,4	9,6	11,4	13,5	13,9	10,9	8,9	3,5	0,9			16,9		
° C	Sky temperature	-10,9	-9,0	-5,1	-0,9	5,6	8,1	10,6	10,4	5,7	0,7	-5,6	-10,7			14,3	12,3	
° C	Ground temperature	13,6	13,1	15,3	16,2	17,5	18,9	20,0	20,5	20,3	19,3	16,1	14,7	13,1	13,1	20,5	20,5	
	Comment:	Text																

U-value of building assemblies

EnerPHit with PHPP Version 9.3

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Secondary calculation: Equivalent thermal conductivity of still air spaces -> (on the right)

Wedge-shaped assembly layer -> (on the right)

Unheated / uncooled attic -> (on the right)

Assembly no.	Building assembly description					Interior insulation?
01ud	MurOB					0
Heat transmission resistance [m ² K/W]						
Orientation of building element	0,13	interior R _{si}		0,13		
Adjacent to	0,04	exterior R _{se} :		0,04		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
Fermacell	0,350		0,000		0,000	13
LaineBois	0,040	OssatureBois	0,130		0,000	100
IsoToit	0,040		0,000		0,000	200
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
91%		9,0%		0,0%		31,3 cm
U-value supplement			0,00 W/(m ² K)		U-value: 0,135 W/(m ² K)	

Assembly no.	Building assembly description					Interior insulation?
02ud	MurBetonEntree					0
Heat transmission resistance [m ² K/W]						
Orientation of building element	0,13	interior R _{si}		0,13		
Adjacent to	0,04	exterior R _{se} :		0,04		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
Fermacell	0,350		0,000		0,000	13
PSE	0,040		0,000		0,000	100
Beton	2,300		0,000		0,000	160
	0,040		0,000		0,000	200
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%		0,0%		0,0%		47,3 cm
U-value supplement			0,00 W/(m ² K)		U-value: 0,129 W/(m ² K)	

Assembly no.	Building assembly description					Interior insulation?
03ud	Auvent					0
Heat transmission resistance [m ² K/W]						
Orientation of building element	0,1	interior R _{si}		0,10		
Adjacent to	0,04	exterior R _{se} :		0,04		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
TroisPlis	0,130		0,000		0,000	30
	0,032		0,000		0,000	100
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%		0,0%		0,0%		13,0 cm

U-value supplement **0,00** W/(m²K)

U-value: **0,286** W/(m²K)

Assembly no.		04ud				PorteFaux		Interior insulation?	0
		Heat transmission resistance [m ² K/W]							
Orientation of building element		0,17		interior R _{si}		0,17			
Adjacent to		0,04		exterior R _{se}		0,04			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
Parquet	0,130		0,000		0,000	60			
LaineMin	0,040	Ossature	0,130		0,000	180			
TroisPlis	0,130		0,000		0,000	20			
	0,032		0,000		0,000	100			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
91%		9,0%		0,0%		36,0 cm			
U-value supplement		0,00 W/(m ² K)		U-value:		0,127 W/(m ² K)			

Assembly no.		05ud				IsolantSousSol		Interior insulation?	0
		Heat transmission resistance [m ² K/W]							
Orientation of building element		0,17		interior R _{si}		0,17			
Adjacent to		0,17		exterior R _{se}		0,17			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
Parquet	0,130		0,000		0,000	13			
LaineMin	0,040	Ossature	0,130		0,000	100			
LaineMin	0,040	Ossature	0,130		0,000	80			
Melamine	0,130		0,000		0,000	22			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%		0,0%		0,0%		21,5 cm			
U-value supplement		0,00 W/(m ² K)		U-value:		0,196 W/(m ² K)			

Assembly no.		06ud				VR		Interior insulation?	0
		Heat transmission resistance [m ² K/W]							
Orientation of building element		0,13		interior R _{si}		0,13			
Adjacent to		0,04		exterior R _{se}		0,04			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
LaineMin	0,040		0,000		0,000	50			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
	0,000		0,000		0,000	0			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%		0,0%		0,0%		5,0 cm			
U-value supplement		0,00 W/(m ² K)		U-value:		0,704 W/(m ² K)			

Assembly no.		07ud Rampant				Interior insulation?	0
Heat transmission resistance [m ² K/W]							
Orientation of building element	0,1	interior R _{si}	0,10				
Adjacent to	0,04	exterior R _{se}	0,04				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
Isotoit	0,040		0,000		0,000	22	
LaineMin	0,040		0,000		0,000	60	
LaineMin	0,040	OssatureBois	0,130		0,000	200	
Triply	0,130		0,000		0,000	22	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
95%		5,0%		0,0%		30,4 cm	
U-value supplement	0,00 W/(m ² K)	U-value: 0,144 W/(m ² K)					

Assembly no.		08ud SolivesSousSol				Interior insulation?	0
Heat transmission resistance [m ² K/W]							
Orientation of building element	0,17	interior R _{si}	0,17				
Adjacent to	0,17	exterior R _{se}	0,17				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
Solives	0,130		0,000		0,000	180	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%		0,0%		0,0%		18,0 cm	
U-value supplement	0,00 W/(m ² K)	U-value: 0,580 W/(m ² K)					

Assembly no.		09ud ToitureEntree				Interior insulation?	0
Heat transmission resistance [m ² K/W]							
Orientation of building element	0,1	interior R _{si}	0,10				
Adjacent to	0,04	exterior R _{se}	0,04				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
Fermacell	0,350		0,000		0,000	10	
LaineMin	0,040	OssatureBois	0,130		0,000	180	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
90%		10,0%		0,0%		19,0 cm	
U-value supplement	0,00 W/(m ² K)	U-value: 0,259 W/(m ² K)					

Assembly no.		10ud				PlancherBetonEntree		Interior insulation?		0
		Heat transmission resistance [m ² K/W]								
Orientation of building element		0,17		interior R _{si}		0,17				
Adjacent to		0,17		exterior R _{se}		0,17				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]				
Beton	2,100		0,000		0,000	180				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total				
100%		0,0%		0,0%		18,0		cm		
U-value supplement		0,00		W/(m ² K)		U-value:		2,349 W/(m ² K)		

Assembly no.		11ud				PlancherBasBois		Interior insulation?		0
		Heat transmission resistance [m ² K/W]								
Orientation of building element		3-Floor		interior R _{si}		0,17				
Adjacent to		3-Ventilated		exterior R _{se}		0,17				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]				
Parquet	0,130		0,000		0,000	60				
LaineMin	0,040	Ossature	0,130		0,000	180				
TroisPlis	0,130		0,000		0,000	20				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total				
84%		16,0%		0,0%		26,0		cm		
U-value supplement		0,00		W/(m ² K)		U-value:		0,228 W/(m ² K)		

Assembly no.		12ud						Interior insulation?		0
		Heat transmission resistance [m ² K/W]								
Orientation of building element		0		interior R _{si}		0,00				
Adjacent to		0		exterior R _{se}		0,00				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
	0,000		0,000		0,000	0				
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total				
100%		0,0%		0,0%						
U-value supplement		0,00		W/(m ² K)		U-value:		##### W/(m ² K)		

Assembly no.		13ud				Interior insulation?	0
		Heat transmission resistance [m ² K/W]					
Orientation of building element	0	interior R _{si}	0,00				
Adjacent to	0	exterior R _{se}	0,00				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%		0,0%		0,0%			cm
U-value supplement		0,00		W/(m ² K)		U-value: ##### W/(m ² K)	

Assembly no.		14ud				Interior insulation?	0
		Heat transmission resistance [m ² K/W]					
Orientation of building element	0	interior R _{si}	0,00				
Adjacent to	0	exterior R _{se}	0,00				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%		0,0%		0,0%			cm
U-value supplement		0,00		W/(m ² K)		U-value: ##### W/(m ² K)	

Assembly no.		15ud				Interior insulation?	0
		Heat transmission resistance [m ² K/W]					
Orientation of building element	0	interior R _{si}	0,00				
Adjacent to	0	exterior R _{se}	0,00				
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
	0,000		0,000		0,000	0	
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total	
100%		0,0%		0,0%			cm
U-value supplement		0,00		W/(m ² K)		U-value: ##### W/(m ² K)	

Assembly no.						Interior insulation?
16ud						0
Heat transmission resistance [m ² K/W]						
Orientation of building element		interior R _{si}		0,00		
Adjacent to		exterior R _{se}		0,00		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%		0,0%		0,0%		cm
U-value supplement		0,00		W/(m ² K)		U-value: ##### W/(m ² K)

Assembly no.						Interior insulation?
17ud						0
Heat transmission resistance [m ² K/W]						
Orientation of building element		interior R _{si}		0,00		
Adjacent to		exterior R _{se}		0,00		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%		0,0%		0,0%		cm
U-value supplement		0,00		W/(m ² K)		U-value: ##### W/(m ² K)

Assembly no.						Interior insulation?
18ud						0
Heat transmission resistance [m ² K/W]						
Orientation of building element		interior R _{si}		0,00		
Adjacent to		exterior R _{se}		0,00		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%		0,0%		0,0%		cm
U-value supplement		0,00		W/(m ² K)		U-value: ##### W/(m ² K)

Assembly no.						Interior insulation?
19ud						0
Heat transmission resistance [m ² K/W]						
Orientation of building element		interior R _{si}		0,00		
Adjacent to		exterior R _{se}		0,00		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%		0,0%		0,0%		cm
U-value supplement			U-value:			
0,00 W/(m ² K)			##### W/(m ² K)			

Assembly no.						Interior insulation?
20ud						0
Heat transmission resistance [m ² K/W]						
Orientation of building element		interior R _{si}		0,00		
Adjacent to		exterior R _{se}		0,00		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
	0,000		0,000		0,000	0
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total
100%		0,0%		0,0%		cm
U-value supplement			U-value:			
0,00 W/(m ² K)			##### W/(m ² K)			

Areas determination

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Summary					Building assembly overview	Average U-value [W/(m²K)]	Radiation-gains heating season [kWh/a]	Radiation-load cooling period [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit				
	Treated floor area	1	163,00	m²	Treated floor area according to PHPP manual			
A	North windows	2	13,66	m²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	0,890	655
A	East windows	3	15,63	m²		East windows	0,877	2011
A	South windows	4	29,57	m²		South windows	0,845	6028
A	West windows	5	15,54	m²		West windows	0,884	1787
A	Horizontal windows	6	0,00	m²		Horizontal windows		
A	Exterior door	7	0,00	m²		Exterior door		
A	External wall - Ambient	8	70,49	m²	Please subtract area of door from respective building assembly Temperature zone "A" is ambient air	External wall - Ambient	0,117	16
B	External wall - Ground	9	0,00	m²	Temperature zone "B" is the ground	External wall - Ground		
A	Roof/Ceiling - Ambient	10	231,58	m²		Roof/Ceiling - Ambient	0,177	430
B	Floor slab / Basement ceiling	11	97,79	m²		Floor slab / Basement ceiling	0,228	1105
		12	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
		13	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
X		14	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor (0 < f < 1):	Factor for X	75%	
Thermal bridges - Overview						Ψ [W/(mK)]		
A	Thermal bridges Ambient	15	159,30	m	Units in m	Thermal bridges Ambient	0,021	
P	Perimeter thermal bridges	16	35,65	m	Units in m; temperature zone "P" is perimeter (see "Ground" worksheet)	Perimeter thermal bridges	0,000	
B	Thermal bridges FS/BC	17	9,00	m	Units in m	Thermal bridges FS/BC	0,211	
I	Building element towards neighbour	18	0,00	m²	No heat losses, only considered for the heating load calculation	Building element towards neighbour		
Total thermal envelope						Average therm. envelope	0,298	

Area input												Go to building components list												
Area no.	Building assembly description	To group No.	Assigned to group	Quantity	x (a [m]	x	b [m]	+	User determined [m²]	-	User subtraction [m²]	-	Subtraction window areas [m²]) =	Area [m²]	Selection building assembly / Building system	U-Value [W/(m²K)]	Deviation from North	Angle of inclination from the horizontal	Orientation	Reduction factor shading	Exterior absorptivity	Exterior emissivity
	Projected building footprint	0	Projected building footprint	1	x (+	97,79	-		-) =	97,8								
	Treated floor area	1	Treated floor area	1	x (+	163,00	-		-) =	163,0								
	Exterior door	7	Exterior door		x (+		-		-) =		Exterior door							
1	Roof_311968_H	10	Roof/Ceiling - Ambient	1	x (12,60	x	4,03	+		-		-	0,0) =	50,8	07ud Rampant	0,144	360	19	Hor	1,00	0,80	0,90
2	Roof_311891_H	10	Roof/Ceiling - Ambient	1	x (12,60	x	4,03	+		-		-	0,0) =	50,8	07ud Rampant	0,144	180	19	Hor	1,00	0,80	0,90
3	Roof_312125_H	10	Roof/Ceiling - Ambient	1	x (x		+	18,95	-		-	0,0) =	19,0	03ud Auvent	0,286	180	9	Hor	1,00	0,80	0,90
4	Roof_312172_H	10	Roof/Ceiling - Ambient	1	x (x		+	18,79	-		-	0,0) =	18,8	03ud Auvent	0,286	360	9	Hor	1,00	0,80	0,90
5	Roof_156322_H	8	External wall - Ambient	1	x (7,66	x	2,40	+		-		-	0,0) =	18,4	09ud ToitureEntree	0,259	90	0	Hor	1,00	0,80	0,90
6	Roof_312301_H	10	Roof/Ceiling - Ambient	1	x (x		+	12,17	-		-	0,0) =	12,2	03ud Auvent	0,286	270	9	Hor	1,00	0,80	0,90
7	Roof_312061_H	10	Roof/Ceiling - Ambient	1	x (x		+	12,06	-		-	0,0) =	12,1	03ud Auvent	0,286	90	9	Hor	1,00	0,80	0,90
8	Wall_161399_N	8	External wall - Ambient	0	x (2,66	x	2,11	+		-		-	1,2) =	-1,2	02ud MurBetonEntree	0,129	0	90	North	0,90	0,80	0,90
9	Wall_161577_N	8	External wall - Ambient	0	x (2,66	x	2,11	+		-		-	1,2) =	-1,2	02ud MurBetonEntree	0,129	0	90	North	0,90	0,80	0,90
10	Wall_311866_S	8	External wall - Ambient	1	x (12,60	x	0,30	+		-		-	0,0) =	3,8	01ud MurOB	0,135	180	90	South	0,90	0,80	0,90
11	Wall_311917_N	8	External wall - Ambient	1	x (12,60	x	0,30	+		-		-	0,0) =	3,8	01ud MurOB	0,135	360	90	North	0,90	0,80	0,90
12	Wall_534934_E	8	External wall - Ambient	0	x (x		+	4,79	-		-	1,0) =	-1,0	02ud MurBetonEntree	0,129	90	90	East	0,90	0,80	0,90
13	Wall_312786_N	8	External wall - Ambient	1	x (3,00	x	1,56	+		-		-	0,9) =	3,7	01ud MurOB	0,135	360	90	North	0,90	0,80	0,90
14	Wall_312383_N	8	External wall - Ambient	1	x (3,00	x	1,56	+		-		-	1,0) =	3,7	01ud MurOB	0,135	0	90	North	0,90	0,80	0,90
15	Wall_534926_W	8	External wall - Ambient	0	x (x		+	4,79	-		-	1,1) =	-1,1	02ud MurBetonEntree	0,129	270	90	West	0,90	0,80	0,90
16	Wall_313691_S	8	External wall - Ambient	1	x (3,00	x	1,56	+		-		-	1,0) =	3,7	01ud MurOB	0,135	180	90	South	0,90	0,80	0,90
17	Wall_313865_E	8	External wall - Ambient	1	x (3,00	x	1,56	+		-		-	1,0) =	3,7	01ud MurOB	0,135	90	90	East	0,90	0,80	0,90
18	Wall_313427_W	8	External wall - Ambient	1	x (3,00	x	1,56	+		-		-	1,0) =	3,7	01ud MurOB	0,135	270	90	West	0,90	0,80	0,90
19	Wall_312998_W	8	External wall - Ambient	1	x (3,00	x	1,56	+		-		-	1,0) =	3,7	01ud MurOB	0,135	270	90	West	0,90	0,80	0,90
20	Wall_313517_S	8	External wall - Ambient	1	x (3,00	x	1,56	+		-		-	1,0) =	3,7	01ud MurOB	0,135	180	90	South	0,90	0,80	0,90
21	Wall_314198_E	8	External wall - Ambient	1	x (3,00	x	1,56	+		-		-	1,0) =	3,7	01ud MurOB	0,135	90	90	East	0,90	0,80	0,90
22	Wall_536451_N	8	External wall - Ambient	1	x (x		+	3,59	-		-	0,0) =	3,6	01ud MurOB	0,135	360	90	North	0,90	0,80	0,90
23	Wall_312507_N	8	External wall - Ambient	1	x (3,00	x	1,25	+		-		-	0,8) =	2,9	01ud MurOB	0,135	0	90	North	0,90	0,80	0,90
24	Wall_312701_N	8	External wall - Ambient	1	x (3,00	x	1,25	+		-		-	0,8) =	2,9	01ud MurOB	0,135	0	90	North	0,90	0,80	0,90
25	Wall_313591_S	8	External wall - Ambient	1	x (3,00	x	1,25	+		-		-	0,9) =	2,9	01ud MurOB	0,135	180	90	South	0,90	0,80	0,90
26	Wall_314031_E	8	External wall - Ambient	1	x (3,00	x	1,25	+		-		-	0,9) =	2,9	01ud MurOB	0,135	90	90	East	0,90	0,80	0,90
27	Wall_313282_W	8	External wall - Ambient	1	x (3,00	x	1,25	+		-		-	0,9) =	2,9	01ud MurOB	0,135	270	90	West	0,90	0,80	0,90
28	Wall_313355_W	8	External wall - Ambient	1	x (3,00	x	1,25	+		-		-	0,9) =	2,9	01ud MurOB	0,135	270	90	West	0,90	0,80	0,90
29	Wall_313201_W	8	External wall - Ambient	1	x (3,00	x	1,25	+		-		-	0,9) =	2,9	01ud MurOB	0,135	270	90	West	0,90	0,80	0,90
30	Wall_313949_E	8	External wall - Ambient	1	x (3,00	x	1,25	+		-		-	0,9) =	2,9	01ud MurOB	0,135	90	90	East	0,90	0,80	0,90

Areas determination

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Summary					Comment	Building assembly overview	Average U-value [W/(m²K)]	Radiation-gains heating season [kWh/a]	Radiation-load cooling period [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit					
	Treated floor area	1	163,00	m²	Treated floor area according to PHPP manual				
A	North windows	2	13,66	m²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	0,890	655	631
A	East windows	3	15,63	m²		East windows	0,877	2011	1932
A	South windows	4	29,57	m²		South windows	0,845	6028	3100
A	West windows	5	15,54	m²		West windows	0,884	1787	1648
A	Horizontal windows	6	0,00	m²		Horizontal windows			
A	Exterior door	7	0,00	m²		Exterior door			
A	External wall - Ambient	8	70,49	m²	Please subtract area of door from respective building assembly Temperature zone "A" is ambient air	External wall - Ambient	0,117	16	109
B	External wall - Ground	9	0,00	m²	Temperature zone "B" is the ground	External wall - Ground			
A	Roof/Ceiling - Ambient	10	231,58	m²		Roof/Ceiling - Ambient	0,177	430	1105
B	Floor slab / Basement ceiling	11	97,79	m²		Floor slab / Basement ceiling	0,228		
		12	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
		13	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
X		14	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor (0 < f < 1):	Factor for X	75%		
						Thermal bridges - Overview	Ψ [W/(mK)]		
A	Thermal bridges Ambient	15	159,30	m	Units in m	Thermal bridges Ambient	0,021		
P	Perimeter thermal bridges	16	35,65	m	Units in m; temperature zone "P" is perimeter (see "Ground" worksheet)	Perimeter thermal bridges	0,000		
B	Thermal bridges FS/BC	17	9,00	m	Units in m	Thermal bridges FS/BC	0,211		
I	Building element towards neighbour	18	0,00	m²	No heat losses, only considered for the heating load calculation	Building element towards neighbour			
Total thermal envelope						Average therm. envelope	0,298		

[Go to building components list](#)

ID	Wall	Group	External wall - Ambient	U	g	h	+	-	g	h	+	-	g	h	U-value	Heating	Cooling	Orientation	Heating	Cooling	Heating	Cooling		
31	Wall_313770_S	8	External wall - Ambient	1	x	(3,00	x	1,25	+	-	-	0,9	=	2,9	0,135	180	90	South	0,90	0,80	0,90	0,90	
32	Wall_312880_N	8	External wall - Ambient	1	x	(x		+	3,59	-	-	0,8	=	2,8	0,135	0	90	North	0,90	0,80	0,90	0,90
33	Wall_154561_W	8	External wall - Ambient	1	x	(x		+	2,40	-	-	0,0	=	2,4	0,135	270	90	West	0,90	0,80	0,90	0,90
34	Wall_154312_E	8	External wall - Ambient	1	x	(x		+	2,40	-	-	0,0	=	2,4	0,135	90	90	East	0,90	0,80	0,90	0,90
35	Wall_154480_W	8	External wall - Ambient	1	x	(x		+	2,40	-	-	0,0	=	2,4	0,135	270	90	West	0,90	0,80	0,90	0,90
36	Wall_154395_E	8	External wall - Ambient	1	x	(x		+	2,40	-	-	0,0	=	2,4	0,135	90	90	East	0,90	0,80	0,90	0,90
37	Wall_156313_N	8	External wall - Ambient	0	x	(7,66	x	0,23	+	-	-	0,0	=	0,0	0,129	0	90	North	0,90	0,80	0,90	0,90	
38	Wall_539190_E	8	External wall - Ambient	0	x	(x		+	1,71	-	-	0,0	=	0,0	0,129	90	90	East	0,90	0,80	0,90	0,90
39	Surface_161827_W	8	External wall - Ambient	0	x	(x		+	1,71	-	-	0,0	=	0,0	0,129	270	90	West	1,00	0,80	0,90	0,90
40					x	(x		+	-	-	0,0	=		270	180	Hor	1,00	0,80	0,90	0,90	0,90	
41					x	(x		+	-	-	0,0	=		90	0	Hor	1,00	0,80	0,90	0,90	0,90	
42	Wall_311899_E	8	External wall - Ambient	1	x	(x		+	1,29	-	-	0,0	=	1,3	0,135	90	90	East	0,90	0,80	0,90	0,90
43	Wall_311856_E	8	External wall - Ambient	1	x	(x		+	1,29	-	-	0,0	=	1,3	0,135	90	90	East	0,90	0,80	0,90	0,90
44	Wall_311936_W	8	External wall - Ambient	1	x	(x		+	1,29	-	-	0,0	=	1,3	0,135	270	90	West	0,90	0,80	0,90	0,90
45	Wall_311882_W	8	External wall - Ambient	1	x	(x		+	1,29	-	-	0,0	=	1,3	0,135	270	90	West	0,90	0,80	0,90	0,90
46					x	(x		+	-	-	0,0	=		90	180	Hor	1,00	0,80	0,90	0,90	0,90	
47					x	(x		+	-	-	0,0	=		90	180	Hor	1,00	0,80	0,90	0,90	0,90	
48	Wall_161561_E	8	External wall - Ambient	0	x	(2,59	x	0,22	+	-	-	0,0	=	0,0	0,129	90	90	East	0,90	0,80	0,90	0,90	
49	Wall_313018_S	8	External wall - Ambient	1	x	(2,35	x	0,21	+	-	-	0,0	=	0,5	0,135	180	90	South	0,90	0,80	0,90	0,90	
50					x	(x		+	-	-	0,0	=		180	90	South	0,90	0,80	0,90	0,90	0,90	
51	Wall_357159_N	8	External wall - Ambient	1	x	(1,15	x	0,36	+	-	-	0,0	=	0,4	0,135	0	90	North	0,90	0,80	0,90	0,90	
52	Wall_357175_N	8	External wall - Ambient	1	x	(1,15	x	0,36	+	-	-	0,0	=	0,4	0,135	0	90	North	0,90	0,80	0,90	0,90	
53	Wall_357095_N	8	External wall - Ambient	1	x	(1,15	x	0,36	+	-	-	0,0	=	0,4	0,135	0	90	North	0,90	0,80	0,90	0,90	
54	Wall_357119_N	8	External wall - Ambient	1	x	(1,15	x	0,36	+	-	-	0,0	=	0,4	0,135	0	90	North	0,90	0,80	0,90	0,90	
55	Wall_357127_N	8	External wall - Ambient	1	x	(1,15	x	0,36	+	-	-	0,0	=	0,4	0,135	0	90	North	0,90	0,80	0,90	0,90	
56	Wall_357087_N	8	External wall - Ambient	1	x	(1,15	x	0,36	+	-	-	0,0	=	0,4	0,135	0	90	North	0,90	0,80	0,90	0,90	
57	Wall_357143_N	8	External wall - Ambient	1	x	(1,15	x	0,36	+	-	-	0,0	=	0,4	0,135	0	90	North	0,90	0,80	0,90	0,90	
58	Wall_357199_N	8	External wall - Ambient	1	x	(1,15	x	0,36	+	-	-	0,0	=	0,4	0,135	0	90	North	0,90	0,80	0,90	0,90	
59	Wall_315124_E	8	External wall - Ambient	1	x	(1,25	x	0,29	+	-	-	0,0	=	0,4	0,135	90	90	East	0,90	0,80	0,90	0,90	
60	Wall_161412_E	8	External wall - Ambient	0	x	(2,09	x	0,09	+	-	-	0,0	=	0,0	0,129	90	90	East	0,90	0,80	0,90	0,90	
61	Wall_161480_W	8	External wall - Ambient	0	x	(2,09	x	0,09	+	-	-	0,0	=	0,0	0,129	270	90	West	0,90	0,80	0,90	0,90	
62					x	(x		+	-	-	0,0	=		85	180	Hor	1,00	0,80	0,90	0,90	0,90	
63					x	(x		+	-	-	0,0	=		78	180	Hor	1,00	0,80	0,90	0,90	0,90	
64	Wall_313078_S	8	External wall - Ambient	1	x	(0,36	x	0,21	+	-	-	0,0	=	0,1	0,135	180	90	South	0,90	0,80	0,90	0,90	
65	Wall_314298_N	8	External wall - Ambient	1	x	(0,36	x	0,21	+	-	-	0,0	=	0,1	0,135	0	90	North	0,90	0,80	0,90	0,90	
66	Wall_314360_S	8	External wall - Ambient	1	x	(0,36	x	0,21	+	-	-	0,0	=	0,1	0,135	180	90	South	0,90	0,80	0,90	0,90	
67	Wall_313121_N	8	External wall - Ambient	1	x	(0,36	x	0,21	+	-	-	0,0	=	0,1	0,135	0	90	North	0,90	0,80	0,90	0,90	
68	Wall_357151_N	8	External wall - Ambient	1	x	(0,36	x	0,10	+	-	-	0,0	=	0,0	0,135	0	90	North	0,90	0,80	0,90	0,90	

Areas determination

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Summary										Building assembly overview		Average U-value [W/(m ² K)]	Radiation-gains heating season [kWh/a]	Radiation-load cooling period [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit	Comment							9 Months	12 Months	
	Treated floor area	1	163,00	m ²	Treated floor area according to PHPP manual									
A	North windows	2	13,66	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.					North windows	0,890	655	631	
A	East windows	3	15,63	m ²						East windows	0,877	2011	1932	
A	South windows	4	29,57	m ²						South windows	0,845	6028	3100	
A	West windows	5	15,54	m ²						West windows	0,884	1787	1648	
A	Horizontal windows	6	0,00	m ²						Horizontal windows				
A	Exterior door	7	0,00	m ²						Please subtract area of door from respective building assembly				
A	External wall - Ambient	8	70,49	m ²	Temperature zone "A" is ambient air					External wall - Ambient	0,117	16	109	
B	External wall - Ground	9	0,00	m ²	Temperature zone "B" is the ground					External wall - Ground				
A	Roof/Ceiling - Ambient	10	231,58	m ²						Roof/Ceiling - Ambient	0,177	430	1105	
B	Floor slab / Basement ceiling	11	97,79	m ²						Floor slab / Basement ceiling	0,228			
		12	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"									
		13	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"									
X		14	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f < 1):					Factor for X	75%			
										Thermal bridges - Overview		Ψ [W/(mK)]		
A	Thermal bridges Ambient	15	159,30	m	Units in m					Thermal bridges Ambient	0,021			
P	Perimeter thermal bridges	16	35,65	m	Units in m; temperature zone "P" is perimeter (see "Ground" worksheet)					Perimeter thermal bridges	0,000			
B	Thermal bridges FS/BC	17	9,00	m	Units in m					Thermal bridges FS/BC	0,211			
I	Building element towards neighbour	18	0,00	m ²	No heat losses, only considered for the heating load calculation					Building element towards neighbour				
Total thermal envelope			474,27	m ²						Average therm. envelope	0,298			

										Go to building components list									
ID	Label	Group	Area	Length	Unit	U	g	h	h _{int}	h _{ext}	U _{total}	g _{total}	h _{total}	h _{total}	h _{total}	h _{total}	h _{total}	h _{total}	h _{total}
69	Wall_357191_N	8	External wall - Ambient	1 x (0,36 x 0,10 +	-	0,0	=	0,0	0,135	0	90	North	0,90	0,80	0,90				
70	Wall_357079_N	8	External wall - Ambient	1 x (0,36 x 0,10 +	-	0,0	=	0,0	0,135	0	90	North	0,90	0,80	0,90				
71	Wall_357111_N	8	External wall - Ambient	1 x (0,36 x 0,10 +	-	0,0	=	0,0	0,135	0	90	North	0,90	0,80	0,90				
72	Wall_311793_S	8	External wall - Ambient	1 x (0,36 x 0,05 +	-	0,0	=	0,0	0,135	180	90	South	0,90	0,80	0,90				
73	Wall_311704_N	8	External wall - Ambient	1 x (0,36 x 0,05 +	-	0,0	=	0,0	0,135	0	90	North	0,90	0,80	0,90				
74	Wall_311630_S	8	External wall - Ambient	1 x (0,36 x 0,05 +	-	0,0	=	0,0	0,135	180	90	South	0,90	0,80	0,90				
75	Wall_311569_N	8	External wall - Ambient	1 x (0,36 x 0,05 +	-	0,0	=	0,0	0,135	0	90	North	0,90	0,80	0,90				
76	Wall_357183_S	8	External wall - Ambient	1 x (0,36 x 0,05 +	-	0,0	=	0,0	0,135	180	90	South	0,90	0,80	0,90				
77	Wall_357103_S	8	External wall - Ambient	1 x (0,36 x 0,05 +	-	0,0	=	0,0	0,135	180	90	South	0,90	0,80	0,90				
78	Wall_357135_N	8	External wall - Ambient	1 x (0,36 x 0,05 +	-	0,0	=	0,0	0,135	0	90	North	0,90	0,80	0,90				
79	Wall_357167_S	8	External wall - Ambient	1 x (0,36 x 0,05 +	-	0,0	=	0,0	0,135	180	90	South	0,90	0,80	0,90				
80	Wall_314117_E	8	External wall - Ambient	1 x (3,00 x 1,25 +	-	3,9	=	-0,1	0,135	90	90	East	0,90	0,80	0,90				
81	Wall_312587_N	8	External wall - Ambient	1 x (x + 0,11	-	0,8	=	-0,7	0,135	0	90	North	0,90	0,80	0,90				
82	Wall_311667_S	8	External wall - Ambient	1 x (2,50 x 0,36 +	-	1,7	=	-0,8	0,704	180	90	South	0,90	0,80	0,90				
83	Wall_311802_S	8	External wall - Ambient	1 x (2,50 x 0,36 +	-	1,7	=	-0,8	0,704	180	90	South	0,90	0,80	0,90				
84	Wall_311647_S	8	External wall - Ambient	1 x (2,50 x 0,36 +	-	1,8	=	-0,9	0,704	180	90	South	0,90	0,80	0,90				
85	Wall_315282_E	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	1,4	=	-1,0	0,135	90	90	East	0,90	0,80	0,90				
86	Wall_315022_S	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	1,4	=	-1,0	0,135	180	90	South	0,90	0,80	0,90				
87	Wall_314928_S	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	1,4	=	-1,0	0,135	180	90	South	0,90	0,80	0,90				
88	Wall_314591_S	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	1,4	=	-1,0	0,135	180	90	South	0,90	0,80	0,90				
89	Wall_314429_S	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	1,4	=	-1,0	0,135	180	90	South	0,90	0,80	0,90				
90	Wall_315626_W	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	1,4	=	-1,0	0,135	270	90	West	0,90	0,80	0,90				
91	Wall_313130_W	8	External wall - Ambient	1 x (3,75 x 0,36 +	-	2,6	=	-1,3	0,135	270	90	West	0,90	0,80	0,90				
92	Wall_314329_E	8	External wall - Ambient	1 x (3,75 x 0,36 +	-	2,6	=	-1,3	0,704	90	90	East	0,90	0,80	0,90				
93	Wall_311560_S	8	External wall - Ambient	1 x (2,50 x 0,36 +	-	3,4	=	-2,5	0,704	180	90	South	0,90	0,80	0,90				
94	Wall_314508_S	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	2,9	=	-2,5	0,135	180	90	South	0,90	0,80	0,90				
95	Wall_314670_S	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	2,9	=	-2,5	0,135	180	90	South	0,90	0,80	0,90				
96	Wall_315497_W	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	2,9	=	-2,5	0,135	270	90	West	0,90	0,80	0,90				
97	Wall_314821_S	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	2,9	=	-2,5	0,135	180	90	South	0,90	0,80	0,90				
98	Wall_315454_W	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	2,9	=	-2,6	0,135	270	90	West	0,90	0,80	0,90				
99	Wall_314753_S	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	2,9	=	-2,6	0,135	180	90	South	0,90	0,80	0,90				
100	Wall_315269_E	8	External wall - Ambient	1 x (1,25 x 0,29 +	-	3,0	=	-2,6	0,135	90	90	East	0,90	0,80	0,90				
101	MurPorteEntree	8	External wall - Ambient	1 x (2,34 x 2,60 +	-	6,1	=	0,0	0,135	0	90	North	0,90	0,80	0,90				
102				x (x +	-	0,0	=												
103	PlancherBas_PorteFaux	10	Roof/Ceiling - Ambient	1 x (10,62 x 15,62 +	-	97,79	=	68,1	0,127	180	0	Hor	0,90	0,80	0,90				
104	PlancherBas_R-1	11	Floor slab / Basement ceiling	1 x (7,70 x 12,70 +	-	0,0	=	97,8	0,228										
105	PlancherBas_Entree	11	Floor slab / Basement ceiling	0 x (x +	-	16,51	=	0,0	2,349										
106				x (x +	-	0,0	=												

Areas determination

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Summary					Building assembly overview	Average U-value [W/(m²K)]	Radiation-gains heating season [kWh/a]	Radiation-load cooling period [kWh/a]	
Temp.-zone	Area group	Group no.	Area / Length	Unit					Comment
	Treated floor area	1	163,00	m²	Treated floor area according to PHPP manual				
A	North windows	2	13,66	m²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	0,890	655	631
A	East windows	3	15,63	m²		East windows	0,877	2011	1932
A	South windows	4	29,57	m²		South windows	0,845	6028	3100
A	West windows	5	15,54	m²		West windows	0,884	1787	1648
A	Horizontal windows	6	0,00	m²		Horizontal windows			
A	Exterior door	7	0,00	m²		Please subtract area of door from respective building assembly	Exterior door		
A	External wall - Ambient	8	70,49	m²	Temperature zone "A" is ambient air	External wall - Ambient	0,117	16	109
B	External wall - Ground	9	0,00	m²	Temperature zone "B" is the ground	External wall - Ground			
A	Roof/Ceiling - Ambient	10	231,58	m²		Roof/Ceiling - Ambient	0,177	430	1105
B	Floor slab / Basement ceiling	11	97,79	m²		Floor slab / Basement ceiling	0,228		
		12	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
		13	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
X		14	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor (0 < ft < 1):	Factor for X			
						Thermal bridges - Overview	Ψ [W/(mK)]		
A	Thermal bridges Ambient	15	159,30	m	Units in m	Thermal bridges Ambient	0,021		
P	Perimeter thermal bridges	16	35,65	m	Units in m; temperature zone "P" is perimeter (see "Ground" worksheet)	Perimeter thermal bridges	0,000		
B	Thermal bridges FS/BC	17	9,00	m	Units in m	Thermal bridges FS/BC	0,211		
I	Building element towards neighbour	18	0,00	m²	No heat losses, only considered for the heating load calculation	Building element towards neighbour			
Total thermal envelope						Average therm. envelope	0,298		

[Go to building components list](#)

107					x (x	+	-) -	0,0	=								
108					x (x	+	-) -	0,0	=								
109					x (x	+	-) -	0,0	=								
110					x (x	+	-) -	0,0	=								

Aend

Areas determination

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Summary						Building assembly overview	Average U-value [W/(m ² K)]	Radiation-gains heating season [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit	Comment			
	Treated floor area	1	163,00	m ²	Treated floor area according to PHPP manual			9 Months
A	North windows	2	13,66	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	0,890	655
A	East windows	3	15,63	m ²		East windows	0,877	2011
A	South windows	4	29,57	m ²		South windows	0,845	6028
A	West windows	5	15,54	m ²		West windows	0,884	1787
A	Horizontal windows	6	0,00	m ²		Horizontal windows		
A	Exterior door	7	0,00	m ²		Please subtract area of door from respective building assembly	Exterior door	
A	External wall - Ambient	8	70,49	m ²	Temperature zone "A" is ambient air	External wall - Ambient	0,117	16
B	External wall - Ground	9	0,00	m ²	Temperature zone "B" is the ground	External wall - Ground		
A	Roof/Ceiling - Ambient	10	231,58	m ²		Roof/Ceiling - Ambient	0,177	430
B	Floor slab / Basement ceiling	11	97,79	m ²		Floor slab / Basement ceiling	0,228	
		12	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
		13	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
X		14	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f < 1):	Factor for X	75%	
						Thermal bridges - Overview	Ψ [W/(mK)]	
A	Thermal bridges Ambient	15	159,30	m	Units in m	Thermal bridges Ambient	0,021	
P	Perimeter thermal bridges	16	35,65	m	Units in m; temperature zone "P" is perimeter (see 'Ground' worksheet)	Perimeter thermal bridges	0,000	
B	Thermal bridges FS/BC	17	9,00	m	Units in m	Thermal bridges FS/BC	0,211	
I	Building element towards neighbour	18	0,00	m ²	No heat losses, only considered for the heating load calculation	Building element towards neighbour		
Total thermal envelope						Average therm. envelope	0,298	

[Go to building components list](#)

Thermal bridge inputs																
No.	Thermal bridge - denomination	Group No.	Assigned to group	Quantity	x (Length [m]	-	Subtraction length [m]	=	Length l [m]	User determined Ψ-Wert [W/(mK)]	User determined f _{Rsi=0,25} (optional)	or	Selection building system	Ψ-Value [W/(mK)]	f _{Rsi} -Requirement met?
1	PorteFaux/MurExt	15	Thermal bridges Ambient	1	x (51,72	-	7,66) =	44,06	0,020		or		0,020	
2	PlancherEntree/MurExt	16	Perimeter thermal bridges	0	x (12,20	-) =	0,00	0,500		or		0,500	
3	AnglesExtSortants	15	Thermal bridges Ambient	4	x (3,72	-) =	14,88	-0,020		or		-0,020	
4	AnglesExtRentrants	15	Thermal bridges Ambient	2	x (3,72	-) =	7,44	0,050		or		0,050	
5	Auvent/MurExt	15	Thermal bridges Ambient	1	x (51,72	-) =	51,72	0,020		or		0,020	
6	Auvent/Pignons	15	Thermal bridges Ambient	1	x (16,00	-) =	16,00	0,050		or		0,050	
7	Auvent/Rampants	15	Thermal bridges Ambient	1	x (25,20	-) =	25,20	0,020		or		0,020	
8	RefendsR-1/PlancherBas	17	Thermal bridges FS/BC	1	x (7,00	-) =	7,00	0,100		or		0,100	
9	MursR-1/PlancherBas	16	Perimeter thermal bridges	1	x (40,80	-	5,15) =	35,65	0,000		or		0,000	
10	PiliersRefend/Plancherbas	17	Thermal bridges FS/BC	2	x (1,00	-) =	2,00	0,600		or		0,600	
11					x (-) =				or			
12					x (-) =				or			
13					x (-) =				or			
14					x (-) =				or			
15					x (-) =				or			
16					x (-) =				or			
17					x (-) =				or			
18					x (-) =				or			
19					x (-) =				or			
20					x (-) =				or			
21					x (-) =				or			
22					x (-) =				or			
23					x (-) =				or			
24					x (-) =				or			
25					x (-) =				or			
26					x (-) =				or			
27					x (-) =				or			
28					x (-) =				or			
29					x (-) =				or			
30					x (-) =				or			
31					x (-) =				or			
32					x (-) =				or			
33					x (-) =				or			
34					x (-) =				or			

Areas determination

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Summary					Comment	Building assembly overview	Average U-value [W/(m²K)]	Radiation-gains heating season [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit				
	Treated floor area	1	163,00	m²	Treated floor area according to PHPP manual Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas. which is displayed in the 'Windows' worksheet. <i>Please subtract area of door from respective building assembly</i> <i>Temperature zone "A" is ambient air</i> <i>Temperature zone "B" is the ground</i> <i>Temperature zones "A", "B", "P" and "X" may be used. NOT "I"</i> <i>Temperature zones "A", "B", "P" and "X" may be used. NOT "I"</i> <i>Temperature zone "X": Please provide user-defined reduction factor (0 < ft < 1):</i>			
A	North windows	2	13,66	m²		North windows	0,890	655
A	East windows	3	15,63	m²		East windows	0,877	2011
A	South windows	4	29,57	m²		South windows	0,845	6028
A	West windows	5	15,54	m²		West windows	0,884	1787
A	Horizontal windows	6	0,00	m²		Horizontal windows		
A	Exterior door	7	0,00	m²		Exterior door		
A	External wall - Ambient	8	70,49	m²		External wall - Ambient	0,117	16
B	External wall - Ground	9	0,00	m²		External wall - Ground		
A	Roof/Ceiling - Ambient	10	231,58	m²		Roof/Ceiling - Ambient	0,177	430
B	Floor slab / Basement ceiling	11	97,79	m²		Floor slab / Basement ceiling	0,228	
		12	0,00	m²				
		13	0,00	m²		Factor for X		
X		14	0,00	m²	75%			
Thermal bridges - Overview						Ψ [W/(mK)]		
A	Thermal bridges Ambient	15	159,30	m	Units in m	Thermal bridges Ambient	0,021	
P	Perimeter thermal bridges	16	35,65	m	Units in m; temperature zone "P" is perimeter (see 'Ground' worksheet)	Perimeter thermal bridges	0,000	
B	Thermal bridges FS/BC	17	9,00	m	Units in m	Thermal bridges FS/BC	0,211	
I	Building element towards neighbour	18	0,00	m²	No heat losses, only considered for the heating load calculation	Building element towards neighbour		
Total thermal envelope				474,27	m²	Average therm. envelope	0,298	

[Go to building components list](#)

35				x (-) =								or		
36				x (-) =								or		
37				x (-) =								or		
38				x (-) =								or		
39				x (-) =								or		
40				x (-) =								or		
41				x (-) =								or		
42				x (-) =								or		
43				x (-) =								or		
44				x (-) =								or		
45				x (-) =								or		
46				x (-) =								or		
47				x (-) =								or		
48				x (-) =								or		
49				x (-) =								or		
50				x (-) =								or		
51				x (-) =								or		
52				x (-) =								or		
53				x (-) =								or		
54				x (-) =								or		
55				x (-) =								or		
56				x (-) =								or		
57				x (-) =								or		
58				x (-) =								or		
59				x (-) =								or		
60				x (-) =								or		
61				x (-) =								or		
62				x (-) =								or		
63				x (-) =								or		
64				x (-) =								or		
65				x (-) =								or		
66				x (-) =								or		
67				x (-) =								or		
68				x (-) =								or		
69				x (-) =								or		
70				x (-) =								or		
71				x (-) =								or		
72				x (-) =								or		

Areas determination

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Summary						Building assembly overview	Average U-value [W/(m ² K)]	Radiation-gains heating season [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit	Comment			
	Treated floor area	1	163,00	m ²	Treated floor area according to PHPP manual			9 Months
A	North windows	2	13,66	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	0,890	655
A	East windows	3	15,63	m ²		East windows	0,877	2011
A	South windows	4	29,57	m ²		South windows	0,845	6028
A	West windows	5	15,54	m ²		West windows	0,884	1787
A	Horizontal windows	6	0,00	m ²		Horizontal windows		
A	Exterior door	7	0,00	m ²		Please subtract area of door from respective building assembly	Exterior door	
A	External wall - Ambient	8	70,49	m ²	Temperature zone "A" is ambient air	External wall - Ambient	0,117	16
B	External wall - Ground	9	0,00	m ²	Temperature zone "B" is the ground	External wall - Ground		
A	Roof/Ceiling - Ambient	10	231,58	m ²		Roof/Ceiling - Ambient	0,177	430
B	Floor slab / Basement ceiling	11	97,79	m ²		Floor slab / Basement ceiling	0,228	
		12	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
		13	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
X		14	0,00	m ²	Temperature zone "X". Please provide user-defined reduction factor (0 < f _t < 1):	Factor for X	75%	
						Thermal bridges - Overview	Ψ [W/(mK)]	
A	Thermal bridges Ambient	15	159,30	m	Units in m	Thermal bridges Ambient	0,021	
P	Perimeter thermal bridges	16	35,65	m	Units in m; temperature zone "P" is perimeter (see 'Ground' worksheet)	Perimeter thermal bridges	0,000	
B	Thermal bridges FS/BC	17	9,00	m	Units in m	Thermal bridges FS/BC	0,211	
I	Building element towards neighbour	18	0,00	m ²	No heat losses, only considered for the heating load calculation	Building element towards neighbour		
Total thermal envelope						Average therm. envelope	0,298	

[Go to building components list](#)

73					x (-) =					or		
74					x (-) =					or		
75					x (-) =					or		
76					x (-) =					or		
77					x (-) =					or		
78					x (-) =					or		
79					x (-) =					or		
80					x (-) =					or		
81					x (-) =					or		
82					x (-) =					or		
83					x (-) =					or		
84					x (-) =					or		
85					x (-) =					or		
86					x (-) =					or		
87					x (-) =					or		
88					x (-) =					or		
89					x (-) =					or		
90					x (-) =					or		
91					x (-) =					or		
92					x (-) =					or		
93					x (-) =					or		
94					x (-) =					or		
95					x (-) =					or		
96					x (-) =					or		
97					x (-) =					or		
98					x (-) =					or		
99					x (-) =					or		
100					x (-) =					or		

TBend

Heat losses through the ground

EnerPHit with PHPP Version 9.3

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Building section 1

Ground characteristics

Thermal conductivity	λ	2,0	W/(mK)
Heat capacity	ρc	2,0	MJ/(m ³ K)
Periodic penetration depth	δ	3,17	m

Climate data

Avg indoor temp. winter	T_i	20,0	°C
Avg indoor temp. summer	$T_{i,s}$	25,0	°C
Avg ground surface temperature	$T_{g,ave}$	13,3	°C
Amplitude of $T_{g,ave}$	$T_{g,\Delta}$	7,6	°C
Phase shifting of $T_{e,m}$	τ	1,1	Months
Length of the heating period	n	5,9	Months
Heating degree hours - exterior	G_e	57,2	kKh/a

Building data

Area of ground floor slab / basement ceiling	A	114,3	m ²
Perimeter length	P	35,7	m
Charact. dimension of floor slab	B'	6,41	m

U-value floor slab/basement ceiling	U_f	0,671	W/(m ² K)
TBs floor slab / basement ceiling	$\Psi_{f,i}$	1,90	W/K
U-value floor slab / basement ceiling i	$U_{f,i}$	0,688	W/(m ² K)
Equivalent thickness floor	d_t	2,91	m

Floor slab type (select only one)

Slab on grade			
Perimeter insulation width/depth	D		m
Perimeter insulation thickness	d_n		m
Conductivity perimeter insulation	λ_n		W/(mK)
Orientation of perimeter insulation			
		horizontal	
		vertical	x
Heated basement or floor slab completely / partially below ground level			
Basement wall height below ground level	z		m
		U-Value wall below ground	U_{WB}
			W/(m ² K)
x Unheated basement			
Height aboveground wall	h	2,70	m
Basement wall height below ground level	z	1,97	m
Air change unheated basement	n	0,20	h ⁻¹
Air flow basement	V	264	m ³
		U-Value wall above ground	U_{Ww}
			0,360 W/(m ² K)
		U-Value wall below ground	U_{WB}
			0,360 W/(m ² K)
		U-Value basement floor slab	U_{fB}
			1,000 W/(m ² K)
Suspended floor above a ventilated crawl space (at max. 0.5 m below ground)			
U-Value crawl space	U_{Crawl}		W/(m ² K)
Height of crawl space wall	h		m
U-Value crawl space wall	U_{Ww}		W/(m ² K)
		Area of ventilation openings	εP
			m ²
		Wind velocity at 10 m height	v
			4,0 m/s
		Wind shield factor	f_{Ww}
			0,05
Additional thermal bridge heat losses at perimeter			
Phase shift	β		Months
		Steady-state fraction	$\Psi_{P,stat}^{*1}$
			6,100 W/K
		Harmonic fraction	$\Psi_{P,harm}^{*1}$
			6,100 W/K
Groundwater correction			
Depth of the groundwater table	z_w	3,0	m
Groundwater flow rate	q_w	0,05	m/d
		Groundwater correction factor	G_w
			1,03457249 -

Interim results

Phase shift	β	1,10 Months	Steady-state heat flow	Φ_{stat}	351,5 W
Steady-state transmittance	L_S	52,27 W/K	Periodic heat flow	Φ_{harm}	125,7 W
Exterior periodic transmittance	L_{pe}	30,46 W/K	Heat losses during heating period	Q_{tot}	2059 kWh
Transmittance building	L_0	84,73 W/K			

Monthly average temperatures in the ground for monthly method (building assembly 1)

Month	1	2	3	4	5	6	7	8	9	10	11	12	Avg. value
Winter	13,6	13,1	13,4	14,3	15,6	17,0	18,1	18,6	18,3	17,4	16,1	14,7	15,9
Summer	15,5	15,0	15,3	16,2	17,5	18,9	20,0	20,5	20,3	19,3	18,0	16,6	17,8

Design ground temperature for 'Heating load' worksheet

13,1

For 'Cooling load' worksheet

20,5

Reduction factor for 'Annual heating' worksheet

0,43

Total result (all building parts)

Phase shift	β	1,10 Months	Steady-state heat flow	Φ_{stat}	351,5 W
Steady-state transmittance	L_S	52,27 W/K	Periodic heat flow	Φ_{harm}	125,7 W
Exterior periodic transmittance	L_{pe}	30,46 W/K	Heat losses during heating period	Q_{tot}	2059 kWh
Transmittance building	L_0	84,73 W/K	Charact. dimension of floor slab	B'	6,41 m

Monthly Average temperatures in the ground for monthly method (all building assemblies)

Month	1	2	3	4	5	6	7	8	9	10	11	12	Avg. value
Winter	13,6	13,1	13,4	14,3	15,6	17,0	18,1	18,6	18,3	17,4	16,1	14,7	15,9
Summer	15,5	15,0	15,3	16,2	17,5	18,9	20,0	20,5	20,3	19,3	18,0	16,6	17,8

Design ground temperature for 'Heating load' worksheet

13,1

For 'Cooling load' worksheet

20,5

Reduction factor for 'Annual heating' worksheet

0,43

Passive House Components

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Go to: [AREAS](#) www.passivehouse.com/component-database
[Thermal bridges \(Psi-values\)](#) [Ventilation units](#)
[Glazing](#) [Compact units](#)
[Window frame](#) [Heat recovery DHW](#)

Building assemblies (U-Values)					
Recommended starting values for optimisation: U-values for walls and roofs Floor slabs: 0,3 W/(m²K) 0,45 W/(m²K)					
ID	Building system	Building assembly	Total thickness	U-Value	Interior insulation
Summary of the constructions calculated in 'U values' worksheet			m	W/(m²K)	-
01ud	MurOB	MurOB	0,313	0,135	1
02ud	MurBetonEntree	MurBetonEntree	0,473	0,129	1
03ud	Auvent	Auvent	0,130	0,286	1
04ud	PorteFaux	PorteFaux	0,360	0,127	1
05ud	IsolantSousSol	IsolantSousSol	0,215	0,196	1
06ud	VR	VR	0,050	0,704	1
07ud	Rampant	Rampant	0,304	0,144	1
08ud	SolivesSousSol	SolivesSousSol	0,180	0,580	1
09ud	ToitureEntree	ToitureEntree	0,190	0,259	1
10ud	PlancherBetonEntree	PlancherBetonEntree	0,180	2,349	1
11ud	PlancherBasBois	PlancherBasBois	0,260	0,228	1
12ud					
13ud					
14ud					
15ud					
16ud					
17ud					
18ud					
19ud					
20ud					
21ud					
22ud					
23ud					
24ud					
25ud					
26ud					
27ud					
28ud					
29ud					
30ud					
31ud					
32ud					
33ud					
34ud					
35ud					
36ud					
37ud					
38ud					
39ud					
40ud					
41ud					
42ud					
43ud					
44ud					
45ud					
46ud					
47ud					
48ud					
49ud					
50ud					
51ud					
52ud					

Building assemblies (U-Values)					
Recommended starting values for optimisation: U-values for walls and roofs Floor slabs: 0,3 W/(m²K) 0,45 W/(m²K)					
ID	Building system	Building assembly	Total thickness	U-Value	Interior insulation
Summary of the constructions calculated in 'U values' worksheet			m	W/(m²K)	-
53ud					
54ud					
55ud					
56ud					
57ud					
58ud					
59ud					
60ud					
61ud					
62ud					
63ud					
64ud					
65ud					
66ud					
67ud					
68ud					
69ud					
70ud					
71ud					
72ud					
73ud					
74ud					
75ud					
76ud					
77ud					
78ud					
79ud					
80ud					
81ud					
82ud					
83ud	PH Wall	PH Wall	0,500	0,100	0
84ud	PH Roof	PH Roof	0,500	0,100	0
85ud	PH Floor	PH Floor	0,500	0,150	0
86ud	PH Basement wall	PH Basement wall	0,500	0,150	0
87ud			0,000	0,000	0
88ud			0,000	0,000	0
89ud			0,000	0,000	0
90ud			0,000	0,000	0
91ud			0,000	0,000	0
92ud			0,000	0,000	0
93ud	Brickwork 24 years old	Brickwork 24 years old	0,275	1,440	0
94ud	Solid Brick 38-old	Solid Brick 38-old	0,415	1,640	0
95ud	Half timbered 18-old	Half timbered 18-old	0,210	1,800	0
96ud	Brickwork 30 years old	Brickwork 30 years old	0,335	1,230	0
97ud	Precast concrete-old	Precast concrete-old	0,275	1,300	0
98ud	Wooden joist ceiling-old	Wooden joist ceiling-old	0,284	0,990	0
99ud	Basement ceiling-old	Basement ceiling-old	0,242	1,230	0

Glazing		Glazing	
	Recommended glazing type to start planning: Triple thermally insulated glazing (Please consider the comfort criterion!)		
ID	Description	g-Value	U _g -Value
			W/(m²K)
01ud	PH Glazing	0,50	0,80
02ud	Vitrage RT Ex	0,70	2,00
03ud		0,00	0,00
04ud		0,00	0,00
05ud		0,00	0,00
06ud		0,00	0,00
07ud		0,00	0,00
08ud		0,00	0,00
09ud		0,00	0,00
10ud		0,00	0,00
11ud		0,00	0,00
12ud		0,00	0,00
13ud		0,00	0,00
14ud		0,00	0,00
15ud		0,00	0,00
16ud		0,00	0,00
17ud		0,00	0,00
18ud		0,00	0,00
19ud		0,00	0,00
20ud		0,00	0,00
21ud		0,00	0,00
22ud		0,00	0,00
23ud		0,00	0,00
24ud		0,00	0,00
25ud		0,00	0,00
26ud		0,00	0,00
27ud		0,00	0,00
28ud		0,00	0,00
29ud		0,00	0,00
30ud		0,00	0,00
31ud		0,00	0,00
32ud		0,00	0,00
33ud		0,00	0,00
34ud		0,00	0,00
35ud		0,00	0,00
36ud		0,00	0,00
37ud		0,00	0,00
38ud		0,00	0,00
39ud		0,00	0,00
40ud		0,00	0,00
41ud		0,00	0,00
42ud		0,00	0,00
43ud		0,00	0,00
44ud		0,00	0,00
45ud		0,00	0,00
46ud		0,00	0,00
47ud		0,00	0,00
48ud		0,00	0,00
49ud		0,00	0,00
50ud		0,00	0,00
51ud		0,00	0,00
52ud		0,00	0,00
53ud		0,00	0,00
54ud		0,00	0,00
55ud		0,00	0,00
56ud		0,00	0,00
57ud		0,00	0,00
58ud		0,00	0,00
59ud		0,00	0,00
60ud		0,00	0,00

Glazing		Glazing	
	Recommended glazing type to start planning: Triple thermally insulated glazing (Please consider the comfort criterion!)		
ID	Description	g-Value	U _g -Value
			W/(m²K)
61ud		0,00	0,00
62ud		0,00	0,00
63ud		0,00	0,00
64ud		0,00	0,00
65ud		0,00	0,00
66ud		0,00	0,00
67ud		0,00	0,00
68ud		0,00	0,00
69ud		0,00	0,00
70ud		0,00	0,00
71ud		0,00	0,00
72ud		0,00	0,00
73ud		0,00	0,00
74ud		0,00	0,00
75ud		0,00	0,00
76ud		0,00	0,00
77ud		0,00	0,00
78ud		0,00	0,00
79ud		0,00	0,00
80ud		0,00	0,00
81ud		0,00	0,00
82ud		0,00	0,00
83ud		0,00	0,00
84ud		0,00	0,00
85ud		0,00	0,00
86ud		0,00	0,00
87ud		0,00	0,00
88ud		0,00	0,00
89ud		0,00	0,00
90ud		0,00	0,00
91ud		0,00	0,00
92ud	Single glazing	0,87	5,80
93ud	Double glazing 4/12mm air/4	0,77	2,90
94ud	Double glazing 4/16mm air/4	0,77	2,70
95ud	Double glazing 4/20mm air/4	0,77	2,80
96ud	Double glazing 4/25mm air/4	0,77	2,80
97ud	Double glazing 4/30mm air/4	0,77	2,80
98ud	Triple glazing 4/10 air/4/10 air/4	0,70	2,00
99ud	Double low-e 4/16Argon90%/4 Epsilon=0.1	0,64	1,30

Window frame											Window frame								
ID	Description	U _r -Value				Frame width				Glazing edge thermal bridge				Installation thermal bridge				Curtain wall facades:	
		left	right	bottom	above	left	right	bottom	above	Ψ _{Glazing edge left}	Ψ _{Glazing edge right}	Ψ _{Glazing edge bottom}	Ψ _{Glazing edge top}	Ψ _{Installation left}	Ψ _{Installation right}	Ψ _{Installation bottom}	Ψ _{Installation top}	X _{cc} -value Glass carrier	
		W/(m²K)	W/(m²K)	W/(m²K)	W/(m²K)	m	m	m	m	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/(mK)	W/K	
61ud	INSTALLATION SITUATION: timber, not insulated, masonry, not insulated	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,088	0,000	0,000	0,000	0,000	0,000
62ud	INSTALLATION SITUATION: timber, not insulated, covered with 60 mm EIFS	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,002	0,000	0,000	0,000	0,000	0,000
63ud	INSTALLATION SITUATION: PVC, not insulated, masonry, not insulated	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,088	0,000	0,000	0,000	0,000	0,000
64ud	INSTALLATION SITUATION: PVC, not insulated,insulated with EIFS 6cm WDVS 6 cm	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,002	0,000	0,000	0,000	0,000	0,000
65ud	INSTALLATION SITUATION: Metal, no thermal break, masonry wall, not insulated	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,088	0,000	0,000	0,000	0,000	0,000
66ud	INSTALLATION SITUATION: insulated timber, EIFS, in insulation layer	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,009	0,000	0,000	0,000	0,000	0,000
67ud	INSTALLATION SITUATION: insulated timber, EIFS, partially on masonry wall	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,021	0,000	0,000	0,000	0,000	0,000
68ud	INSTALLATION SITUATION: insulated timber, EIFS, flush with the masonry wall on the outside	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,076	0,000	0,000	0,000	0,000	0,000
69ud	INSTALLATION SITUATION: insulated timber, lightweight wall (optimal)	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,009	0,000	0,000	0,000	0,000	0,000
70ud	INSTALLATION SITUATION: insulated timber, insulated concrete formwork (optimal)	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,001	0,000	0,000	0,000	0,000	0,000
71ud	INSTALLATION SITUATION: insulated PVC, EIFS, insulation layer	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,009	0,000	0,000	0,000	0,000	0,000
72ud	INSTALLATION SITUATION: insulated PVC, EIFS, partially on masonry wall	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,021	0,000	0,000	0,000	0,000	0,000
73ud	INSTALLATION SITUATION: insulated PVC, EIFS, flush with the masonry wall on the outside	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,076	0,000	0,000	0,000	0,000	0,000
74ud	INSTALLATION SITUATION: insulated PVC, lightweight wall (optimal)	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,009	0,000	0,000	0,000	0,000	0,000
75ud	INSTALLATION SITUATION: insulated PVC, insulated concrete formwork (optimal)	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,001	0,000	0,000	0,000	0,000	0,000
76ud	INSTALLATION SITUATION: insulated timber-aluminium, EIFS, insulation layer	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,013	0,000	0,000	0,000	0,000	0,000
77ud	INSTALLATION SITUATION: insulated timber-aluminium, EIFS, partially on masonry wall	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,023	0,000	0,000	0,000	0,000	0,000
78ud	INSTALLATION SITUATION: insulated timber-aluminium, lightweight wall (centre)	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,013	0,000	0,000	0,000	0,000	0,000
79ud	INSTALLATION SITUATION: insulated timber-aluminium, insulated concrete formwork (optimal)	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,002	0,000	0,000	0,000	0,000	0,000
80ud	INSTALLATION SITUATION: insulated timber-aluminium, insulated concrete formwork (inside i	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,013	0,000	0,000	0,000	0,000	0,000
81ud	INSTALLATION SITUATION: insulated timber-aluminium, short alum casing, EIFS, insulation la	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,002	0,000	0,000	0,000	0,000	0,000
82ud	INSTALLATION SITUATION: insulated timber-aluminium, short alum casing, lightweight wall (c	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,010	0,000	0,000	0,000	0,000	0,000
83ud	INSTALLATION SITUATION: insulated timber-aluminium, short alum casing, insulated concrete	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,006	0,000	0,000	0,000	0,000	0,000
84ud	INSTALLATION SITUATION: insulated timber-aluminium, short alum casing, insulated concrete	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,013	0,000	0,000	0,000	0,000	0,000
85ud	INSTALLATION SITUATION MULLION-TRANSOM: timber, outside, in front of the facade	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,343	0,000	0,000	0,000	0,000	0,000
86ud	INSTALLATION SITUATION MULLION-TRANSOM: timber, flush with the facade on the outside	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,036	0,000	0,000	0,000	0,000	0,000
87ud	INSTALLATION SITUATION MULLION-TRANSOM: timber, in the insulation layer	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,034	0,000	0,000	0,000	0,000	0,000
88ud	INSTALLATION SITUATION MULLION-TRANSOM: timber, between insulation layer and wall	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,059	0,000	0,000	0,000	0,000	0,000
89ud	INSTALLATION SITUATION MULLION-TRANSOM: timber, flush with the insulation layer on the	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,397	0,000	0,000	0,000	0,000	0,000
90ud	INSTALLATION SITUATION MULLION-TRANSOM: steel, outside, in front of the facade	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,666	0,000	0,000	0,000	0,000	0,000
91ud	INSTALLATION SITUATION MULLION-TRANSOM: steel, flush with the insulation layer on the o	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,047	0,000	0,000	0,000	0,000	0,000
92ud	INSTALLATION SITUATION MULLION-TRANSOM: steel, in the insulation layer	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,044	0,000	0,000	0,000	0,000	0,000
93ud	INSTALLATION SITUATION MULLION-TRANSOM: steel, between insulation layer and wall	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,062	0,000	0,000	0,000	0,000	0,000
94ud	INSTALLATION SITUATION MULLION-TRANSOM: steel, flush with the insulation layer on the in	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,409	0,000	0,000	0,000	0,000	0,000
95ud	INSTALLATION SITUATION MULLION-TRANSOM: Alum, outside, in front of the facade	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,747	0,000	0,000	0,000	0,000	0,000
96ud	INSTALLATION SITUATION MULLION-TRANSOM: Alum, flush with the insulation layer on the o	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,056	0,000	0,000	0,000	0,000	0,000
97ud	INSTALLATION SITUATION MULLION-TRANSOM: Alum, in the insulation layer	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,053	0,000	0,000	0,000	0,000	0,000
98ud	INSTALLATION SITUATION MULLION-TRANSOM: Alum, between insulation layer and wall	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,070	0,000	0,000	0,000	0,000	0,000
99ud	INSTALLATION SITUATION MULLION-TRANSOM: Alum, flush with the insulation layer on the in	0,00	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,000	0,421	0,000	0,000	0,000	0,000	0,000

Ventilation units with heat recovery				Ventilation units with heat recovery										
ID	Description	Recommended specifications to start planning: Frost protection: Yes; Humidity recovery: Yes		75 %	0,45	Additional Device Data								
		Effective heat recovery efficiency	Energy recovery value η_{ER}	Electric efficiency	Application range		External pressure per section	Fittings $D_{p_{Intern}}$	Frost protection necessary	Noise protection			Additional info	
		%	%	Wh/m ³	m ³ /h	m ³ /h	Pa	Pa			35 dB(A)	Supply air dB(A)	Extract air dB(A)	
01ud			0%											
02ud			0%											
03ud														
04ud														
05ud														
06ud														
07ud														
08ud														
09ud														
10ud														
11ud														
12ud														
13ud														
14ud														
15ud														
16ud														
17ud														
18ud														
19ud														
20ud														
21ud														
22ud														
23ud														
24ud														
25ud														
26ud														
27ud														
28ud														
29ud														
30ud														
31ud														
32ud														
33ud														
34ud														
35ud														
36ud														
37ud														
38ud														
39ud														
40ud														
41ud														
42ud														
43ud														
44ud														
45ud														
46ud														
47ud														
48ud														
49ud														
50ud														
51ud														
52ud														
53ud														
54ud														
55ud														
56ud														
57ud														
58ud														
59ud														
60ud														

Ventilation units with heat recovery					Ventilation units with heat recovery								
ID	Recommended specifications to start planning: Frost protection: Yes; Humidity recovery: Yes	Effective heat recovery efficiency	Energy recovery value η_{ER}	Electric efficiency	Additional Device Data								
					Application range		External pressure per section	Fittings $D_{p_{Intern}}$	Frost protection necessary	Noise protection		Additional info	
					m³/h	m³/h				Pa	Pa		35 dB(A)
User defined area		%	%	Wh/m³									
61ud													
62ud													
63ud													
64ud													
65ud													
66ud													
67ud													
68ud													
69ud													
70ud													
71ud													
72ud													
73ud													
74ud													
75ud													
76ud													
77ud													
78ud													
79ud													
80ud													
81ud													
82ud													
83ud													
84ud													
85ud													
86ud													
87ud													
88ud													
89ud													
90ud													
91ud													
92ud													
93ud													
94ud													
95ud													
96ud													
97ud	Default	75%		0,45									
98ud	Extract air system	0%		0,25									
99ud	Compact unit selected in 'Compact' worksheet												

Heating degree hours [kKh]: 57,2

Quantity	Description	Deviation from north	Angle of inclination from the horizontal	Orientation	Window rough openings		Installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge (Avg.)	Installation situation				Results					
					Width	Height	Selection from 'Areas' worksheet	Selection from 'Components' worksheet	Selection from 'Components' worksheet		Perpendicular radiation	Glazing		Frames (avg.)	Ψ _{Installation} (Avg.)	left	right	bottom	top	Window Area	Glazing area	U _w installed	Glazed fraction per window
					m	m		Sort: AS LIST	Sort: AS LIST		-	W/(m²K)		W/(m²K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m²	m²	W/(m²K)
1	Win_313677_S	180	90	South	1,267	0,698	83-Wall_311802_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,9	0,58	0,93	65%	
1	Win_313657_S	180	90	South	1,230	0,698	84-Wall_311647_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,9	0,56	0,93	65%	
1	Win_313661_S	180	90	South	1,279	0,698	84-Wall_311647_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,9	0,58	0,93	65%	
1	Win_315400_E	90	90	East	1,242	1,110	85-Wall_315282_E	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,76	0,026	0	0	1	0	0,040	1,4	1,00	0,82	73%	
1	Win_315069_S	180	90	South	1,250	1,110	86-Wall_315022_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,76	0,026	0	1	1	0	0,040	1,4	1,01	0,85	73%	
1	Win_314981_S	180	90	South	1,267	1,110	87-Wall_314928_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,76	0,026	0	0	1	0	0,040	1,4	1,03	0,82	73%	
1	Win_314628_S	180	90	South	1,267	1,110	88-Wall_314591_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,76	0,026	0	0	1	0	0,040	1,4	1,03	0,82	73%	
1	Win_314466_S	180	90	South	1,267	1,110	89-Wall_314429_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,76	0,026	1	0	1	0	0,040	1,4	1,03	0,85	73%	
1	Win_315643_W	270	90	West	1,267	1,110	90-Wall_315626_W	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,76	0,026	0	0	1	0	0,040	1,4	1,03	0,82	73%	
1	Win_313163_W	270	90	West	1,238	0,696	91-Wall_313130_W	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,9	0,56	0,93	65%	
1	Win_313167_W	270	90	West	1,209	0,696	91-Wall_313130_W	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,8	0,54	0,93	65%	
1	Win_313171_W	270	90	West	1,292	0,696	91-Wall_313130_W	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,9	0,59	0,93	65%	
1	Win_314368_E	90	90	East	1,230	0,698	92-Wall_314329_E	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,9	0,56	0,93	65%	
1	Win_314372_E	90	90	East	1,267	0,698	92-Wall_314329_E	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,9	0,58	0,93	65%	
1	Win_314376_E	90	90	East	1,255	0,698	92-Wall_314329_E	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,9	0,57	0,93	65%	
1	Win_313649_S	180	90	South	1,230	0,698	93-Wall_311560_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,9	0,56	0,93	65%	
1	Win_313653_S	180	90	South	1,279	0,698	93-Wall_311560_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,77	0,026	0	0	1	1	0,040	0,9	0,58	0,93	65%	
1	Win_315073_S	180	90	South	1,280	1,270	93-Wall_311560_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,76	0,026	1	0	0	1	0,040	1,6	1,22	0,84	75%	
1	Win_314545_S	180	90	South	1,220	2,350	94-Wall_314508_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,74	0,026	0	0	1	0	0,040	2,9	2,28	0,77	80%	
1	Win_314707_S	180	90	South	1,233	2,350	95-Wall_314670_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,74	0,026	0	0	1	0	0,040	2,9	2,31	0,77	80%	
1	Win_315558_W	270	90	West	1,237	2,346	96-Wall_315497_W	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,74	0,026	0	1	1	1	0,040	2,9	2,32	0,82	80%	
1	Win_314977_S	180	90	South	1,229	2,370	97-Wall_314821_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,74	0,026	0	0	1	0	0,040	2,9	2,32	0,77	80%	
1	Win_315480_W	270	90	West	1,249	2,350	98-Wall_315454_W	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,74	0,026	1	0	1	1	0,040	2,9	2,35	0,82	80%	
1	Win_314790_S	180	90	South	1,254	2,350	99-Wall_314753_S	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,74	0,026	0	0	1	0	0,040	2,9	2,36	0,77	80%	
1	Win_315278_E	90	90	East	1,250	2,370	100-Wall_315269_E	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,74	0,026	0	1	1	0	0,040	3,0	2,37	0,81	80%	
1	PorteEntree	0	90	North	2,340	2,600	101-MurPorteEntree	0422gI03-Interpane - Iplus 3 LS und LST (4/16:/4/16:/4 Ar 90%)	0076wi03-pro Passivhausfenster - smartwin - SuperSp. Tri-Seal	0,61	0,69	0,75	0,026	1	1	1	1	0,040	6,1	5,26	0,80	87%	

Heating degree hours [kKh]: **57,2**

Quantity	Description	Deviation from north	Angle of inclination from the horizontal	Orientation	Window rough openings		Installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge	Installation situation					Results			
					Width	Height	Selection from 'Areas' worksheet	Selection from 'Components' worksheet	Selection from 'Components' worksheet	Perpendicular radiation	Glazing	Frames (avg.)	Ψ _{Glazing edge (Avg.)}	user determined value for Ψ _{Installation} or *1*: Ψ _{Installation} from 'Components' worksheet *0*: in the case of abutting windows				Window Area	Glazing area	U _w installed	Glazed fraction per window	
					m	m		Sort: AS LIST	Sort: AS LIST	-	W/(m²K)	W/(m²K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m²	m²	W/(m²K)	%
		*	*				Sort: AS LIST	Sort: AS LIST	-	W/(m²K)	W/(m²K)	W/(mK)	W/(mK) or 1/0				W/(mK)	m²	m²	W/(m²K)	%	

Quantity	Description	Deviation from North	Angle of inclination from the horizontal	Orientation	Glazing width	Glazing height	Glazing area	Height of the shading object	Horizontal distance	Window reveal depth	Distance from glazing edge to reveal	Overhang depth	Distance from upper glazing edge to overhang	Additional reduction factor winter shading	Additional reduction factor summer shading	Reduction factor z for temporary sun protection	Reveal (m) / transparent	Horizon	Reveal	Overhang	Total for heating case	Horizon	Reveal	Overhang	Total for cooling case	Total for cooling load	
		[Degree]	[Degree]		w _G [m]	h _G [m]	A _G [m ²]	h _{shad} [m]	d _{horiz} [m]	o _{Reveal} [m]	d _{Reveal} [m]	o _{over} [m]	d _{over} [m]	f _{shad,wint} [%]	f _{shad,sum} [%]	z [%]		r _h [%]	r _r [%]	r _o [%]	f _s [%]	r _h [%]	r _r [%]	r _o [%]	f _{s,1} [%]	f _{s,2} [%]	

Quantity	Description	Deviation from North	Angle of inclination from the horizontal	Orientation	Glazing width	Glazing height	Glazing area	Height of the shading object	Horizontal distance	Window reveal depth	Distance from glazing edge to reveal	Overhang depth	Distance from upper glazing edge to overhang	Additional reduction factor winter shading	Additional reduction factor summer shading	Reduction factor z for temporary sun protection	Reveal (mm) / transparent	Horizon	Reveal	Overhang	Total for heating case	Horizon	Reveal	Overhang	Total for cooling case	Total for cooling load	
		[Degree]	[Degree]		w _G [m]	h _G [m]	A _G [m ²]	h _{shad} [m]	d _{horiz} [m]	o _{Reveal} [m]	d _{Reveal} [m]	o _{over} [m]	d _{over} [m]	f _{shaded,w} [%]	f _{shaded,s} [%]	z [%]		r _h [%]	r _r [%]	r _o [%]	f _s [%]	r _h [%]	r _r [%]	r _o [%]	f _{s,1} [%]	f _{s,2} [%]	

Ventilation data

Archipente / Climate: Monbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Treated floor area A_{TFA}	m ²	163	(Areas' worksheet)
Room height h	m	3,34	3,34
Volume of ventilated space ($A_{TFA} \cdot h$) : V_V	m ³	544	(Worksheet 'Annual heating')

Ventilation type

Please select 1-Balanced PH ventilation with HR

Infiltration air change rate

Wind protection coefficients e and f		
Coefficient e for wind protection class	Several side exposed	One side exposed
No protection	0,10	0,03
Moderate protection	0,07	0,02
High protection	0,04	0,01
Coefficient f	15	20

Wind protection coefficient, e		For annual demand: 0,07	For heating load: 0,18		
Wind protection coefficient, f		15	15	Net air volume for press. test V_{r50}	Air permeability q_{50}
Air change rate at press. test n_{50}	1/h	1,00	1,00	543 m ³	1,14 m ³ /(h·m ²)
Excess extract air	1/h	0,00	0,00		
Infiltration air change rate $n_{V,Rest}$	1/h	0,070	0,175		

Selection of ventilation input - Results

PHPP offers two methods for dimensioning air quantities and choosing the ventilation unit. With "Standard data input for balanced ventilation", supply or extract air quantities for residential buildings and parameters for ventilation systems with a maximum of 1 ventilation unit can be planned. Projects with up to 10 different ventilation units and air quantities determined according to rooms or zones can be entered in the 'Addl vent' worksheet. Please select your design method here:

Ventilation unit / Heat recovery efficiency design		Average air flow rate	Average air change rate	Extract air excess (extract air system)	Effective heat recovery efficiency unit	Energy recovery	Specific power input	Heat recovery efficiency SHX
		m ³ /h	1/h	1/h	[-]	[-]	Wh/m ³	[-]
<input checked="" type="checkbox"/>	Standard design <small>(Ventilation' worksheet, see below)</small>	133	0,24	0,00	81,3%	73,0%	0,26	0,0%
<input type="checkbox"/>	Multiple ventilation units, non-res <small>(Addl vent' worksheet)</small>							

Cooling degree Efficiency SHX

Average interior humidity during winter operation

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
100%	100%	100%	100%	100%	-	-	-	100%	100%	100%	100%

Standard data input for balanced ventilation

Dimensioning of ventilation system with only one ventilation unit

Occupancy	m ² /P	16				
Number of occupants	P	10,0				
Supply air per person	m ³ /(P*h)	30				
Supply air requirement	m ³ /h	300				
Extract air rooms		Kitchen	Bathroom	Bathroom (shower only)	WC	Extraction
Quantity						1
Extract air requirement per room	m ³ /h	60	40	20	20	300
Total extract air requirement	m ³ /h	300				
Design air flow rate should cover at least the extract air demand according to DIN 1946!						
Design air flow rate (maximum)	m ³ /h	173	Recommended:	300	m ³ /h	

Average air change rate calculation

Type of operation	Daily operation times h/d	Factors referenced to maximum	Air flow rate m ³ /h	Air change rate 1/h
maximum		1,00	173	0,32
Standard	24,0	0,77	133	0,24
Grundlüftung		0,54	93	0,17
Minimum		0,40	69	0,13
Average value		0,77	Average air flow rate (m ³ /h) 133	Average air change rate (1/h) 0,24

Selection of ventilation unit with heat recovery

Location of ventilation unit: **2-Outside of thermal envelope**

Ventilation unit selection	Heat recovery efficiency Unit η_{WRG}	Energy recovery η_{ERV}	Specific efficiency [Wh/m ³]	Application [m ³ /h]	Frost power input
Go to ventilation units list Sortierung: WIE LISTE 0304vs03-PAUL - novus F 300	0,84	0,73	0,26	121 - 231	yes
Implementation of frost protection					2-Elec.
Limit temperature [°C]					0
Useful energy [kWh/a]					35
Room temperature (°C)					20
Avg. ambient temp. heat. period (°C)					7,9
Avg. ground temp (°C)					13,3

Conductivity supply air duct	Y	W/(mK)	0,361
Length of supply air duct		m	2,5
Conductivity extract air duct	Y	W/(mK)	0,361
Length of extract air duct		m	2,5
Temperature of mechanical services room		°C	10,0
(Enter only if the central unit is outside of the thermal envelope)			

Effective heat recovery efficiency $\eta_{HR,eff}$ **81,3%**

Effective heat recovery efficiency subsoil heat exchanger

SHX efficiency	η^{SHX}	
Heat recovery efficiency SHX	η_{SHX}	0%

Secondary calculation	
Ψ -value supply or outdoor air duct	
Nominal width	125 mm
Insulation thick	50 mm
Reflective coating?	<input checked="" type="checkbox"/> No
Thermal conductivity	0,040 W/(mK)
Nominal air flow rate	133 m ³ /h
$\Delta\vartheta$	10 K
Exterior duct diameter	0,125 m
Exterior diameter	0,225 m
α -Interior	14,11 W/(m ² K)
α -Surface	5,65 W/(m ² K)
Ψ -value	0,361 W/(mK)
Surface temperature difference	0,905 K

Secondary calculation	
Ψ -value extract or exhaust air duct	
Nominal width:	125 mm
Insulation thickness	50 mm
Reflective coating?	<input checked="" type="checkbox"/> no
Thermal conductivity	0,040 W/(mK)
Nominal air flow rate	133 m ³ /h
$\Delta\vartheta$	10 K
Exterior duct diameter	0,125 m
Exterior diameter	0,225 m
α -Interior	14,11 W/(m ² K)
α -Surface	5,65 W/(m ² K)
Ψ -value	0,361 W/(mK)
Surface temperature difference	0,905 K

Extended input for balanced ventilation (at the moment this worksheet is inactive. Calculation takes place in the 'Ventilation' worksheet.)

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Planning ventilation systems with multiple ventilation units

Ventilation unit / Heat recovery efficiency design
In Ventilation sheet (standard design)
In 'Addl vent worksheet (this worksheet)

x	(<i>'Ventilation' worksheet</i>)
0,0	(<i>'Addl vent'</i>)

Treated floor area A_{TFA}

m² 163 (*'Areas' worksheet*)

Room height h

m 3,34 (*'Worksheet 'Annual heating'*)

Room air volume for ventilation (A_{TFA}*h) = V_V

m³ 544 (*'Worksheet 'Annual heating'*)

Number of occupants

P 10,0 (*'Ventilation' worksheet*)

Room temperature

°C 20 (*'Worksheet 'Annual heating'*)

Average external temp. heating period

°C 7,9 (*'Ventilation' worksheet*)

Average ground temp.

°C 13,3 (*'Ground' worksheet*)

Length of the heating period

d/a 180 (*'Heating' worksheet*)

Ventilation type

1-Balanced PH ventilation with HR (*'Ventilation' worksheet*)

Results of ventilation design and unit selection:

Ventilation unit no.	Description of the unit	Design		Annual average value		Air ch.rt. 1/h
		V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{SUP} m ³ /h	V _{ETA} m ³ /h	
1						---
2						---
3						---
4						---
5						---
6						---
7						---
8						---
9						---
10						---

Result for overall vent. syst.

--	--	--	--	--	--

Effective heat recovery efficiency	Energy recovery efficiency	Spec. input power	Heat recov. efficiency SHX

--	--	--	--

Recommendations for dimensioning air quantities

Use of low odour and low VOCs building materials/furnishings:

It is strongly recommended to use building materials that cause no or very low VOCs/odours instead of increasing the outdoor air volume in order to clear the air.

This holds true independently from the chosen approach to determine air quality; emissions of all sources in the room should be considered, e.g. furniture, carpets and ventilation or air-conditioning unit.

Assessment of volume flow rates according to the number of persons

Also in non-residential buildings, the number of persons is fundamentally important for assessing the volume air flow rates. For good indoor air quality volumes between 20 to 30 m³/h/person are sufficient.

Higher outdoor air amounts may lead to excessively dry indoor air in winter. The air flow rates are specified by classification according to EN 13779. The classification must be agreed with the client in advance.

IDA 3 is adequate for office buildings. IDA 4 has proven satisfactory for school buildings as flushing ventilation is carried out during breaks anyway. For typical outdoor air CO₂ concentrations of around 400-500 ppm,

it is possible to comply even with 1500 ppm. Exceeding this figure temporarily is permissible.

Outdoor air flow rates per person:

- Recommended for residential buildings: around 30 m³/(h person)

- Recommended for offices and similar uses: around 30 m³/(h person) (AMEV: 28 m³/(h person); EN 13779 / IDA 3: at least 24 m³/(h person))

- Recommended for schools and day care centres: 15 to 20 m³/(h person) (Source: Guidelines for energy-efficient educational buildings, Passive House Institute, 2010)

- Recommendation for sport halls: 60 m³/(h person) (DIN 18032-1)

Flushing phase for intermittent ventilation operation

In case the ventilation is to be used intermittently (turned off at night), then it should be flushed in the morning, approx. 1 to 2 hours before building is occupied. This should be done in order to refresh air from emissions such as VOCs. Flushing the building causes that the ventilation system works for a longer period (utilisation time + flushing phase). Please consider this at design stage.

Dimensioning of air quantities

When dimensioning the air quantities, please consider the design recommendations given above.

The operation period of the ventilation can be determined on the basis of daily utilisation hours, including flushing phase if applicable. In addition, time periods with reduced ventilation requirements (operation modes) can be taken into account by means of reduction factors.

Room no.	Amount a	Room name	Allocation to ventilation unit (No.)	Area A m ²	Clear height h m	Room vol. A x h m ³	Volume flow per room			Air chng. rt. per room n 1/h	Utilisation times h/d d/week d	Duration of holidays d	Reduction factor 1	Operation red. 1	Reduction factor 2	Operation red. 2	Reduction factor 3	Operation red. 3	Annual average value:				
							V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{TRANS} m ³ /h										V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{TRANS} m ³ /h	Change rate 1/h	
1											0	100%	100%										
2											0	100%	100%										
3											0	100%	100%										
4											0	100%	100%										
5											0	100%	100%										
6											0	100%	100%										
7											0	100%	100%										
8											0	100%	100%										
9											0	100%	100%										
10											0	100%	100%										
11											0	100%	100%										
12											0	100%	100%										
13											0	100%	100%										
14											0	100%	100%										
15											0	100%	100%										
16											0	100%	100%										
17											0	100%	100%										
18											0	100%	100%										
19											0	100%	100%										
20											0	100%	100%										
21											0	100%	100%										
22											0	100%	100%										
23											0	100%	100%										
24											0	100%	100%										
25											0	100%	100%										
26											0	100%	100%										
27											0	100%	100%										
28											0	100%	100%										
29											0	100%	100%										
30											0	100%	100%										
Additional lines: Please mark complete lines above, copy and paste multiple times																						---	

Ventilation unit selection

Up to 10 different ventilation units are considered. By changing the amount, identical units can be considered. The data from PHI certified ventilation units as well as the entry data lines for user data for other ventilation units can also be found in the worksheet 'Components'. When choosing to use a compact unit the standard design in the 'Ventilation' worksheet has to be used.

[Go to ventilation units list](#)

Ventilation unit no.	Quantity [-]	Description of ventilation units	Selection of type of ventilation unit	Design vol. flow per unit m³/h	Application range for volume flow rate		Electrical efficiency Pa	Pressure loss calculation			Application range		Interior location (x)	Exterior location (x)	Heat recovery efficiency		Energy recovery efficiency [-]	Frost protection necessary	Subsoil HX		Frost protection (electr. / hydr.)				
					from	to		ΔP_{Duct}	ΔP_{Duct}	ΔP_{Intern}	per line $\Delta P_{External}$	Subtraction ΔP_{Intern} degree			Unit	Effective			Efficiency of heat recovery	Effective efficiency of heat recovery	Type perature	Limit temperature	Useful V_{SUP} kWh/a		
1																						2-Elec.		0	
2																							2-Elec.		0
3																							2-Elec.		0
4																							2-Elec.		0
5																							2-Elec.		0
6																							2-Elec.		0
7																							2-Elec.		0
8																							2-Elec.		0
9																							2-Elec.		0
10																							2-Elec.		0
																							Total (directly electric)		0
																							Total (hydraulic and heat generator)		0

Data entries for duct sections between the ventilation unit and the thermal envelope

The duct sections between the ventilation unit and the thermal envelope should be as short as possible and should be well insulated, whether the ventilation unit is located indoors or outdoors. The dimensions of these duct sections can be entered here. The heat losses of the overlying duct sections will be considered for the effective heat recovery efficiency. One section of a duct entered here may also be used for multiple ventilation units.

If in the section "Ventilation unit - selection" (above) a ventilation unit is selected as multiple units (amount larger than 1 for identical units), then the corresponding duct sections may simply be entered (duct sections for one ventilation unit).

Temperature of installation location (only enter when at least one unit is installed outside of the thermal envelope)

Quantity	Round duct ins. diameter mm	Rectangular duct		Insulation thickness mm	Thermal conductivity W/(m K)	Reflective insulation duct (x)	Duct transmittance W/(m K)	Length of supply air duct m	Outdoor or supply air duct (1)	Exhaust or extract air duct (1)	Duct type	Design volume rate	Assignment to ventilation unit (enter 1 for the corresponding ventilation unit)													
		Width mm	Height mm										Vent. unit 1	Vent. unit 2	Vent. unit 3	Vent. unit 4	Vent. unit 5	Vent. unit 6	Vent. unit 7	Vent. unit 8	Vent. unit 9	Vent. unit 10				
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														
												0														

Additional lines: Please mark complete lines above, copy and paste multiple times

Specific energy for heating (annual method)

EnerPHit with PHPP Version 9.3

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Interior temperature: °C
 Building type:
 Treated floor area A_{TFAi}: m²

Building assembly	Temperature zone	Area m ²	U-Value W/(m ² K)	Temp. factor f _t	G _i kKWh/a	kWh/a	Per m ² of treated floor area	
External wall - Ambient	A	70,5	0,117	1,00	57,2	472	2,90	
External wall - Ground	B			0,43				
Roof/Ceiling - Ambient	A	231,6	0,177	1,00	57,2	2344	14,38	
Floor slab / Basement ceiling	B	97,8	0,228	0,43	57,2	543	3,33	
	A			1,00				
	A			1,00				
	X			0,75				
Windows	A	74,4	0,868	1,00	57,2	3693	22,66	
Exterior door	A			1,00				
Exterior TB (length/m)	A	159,3	0,021	1,00	57,2	188	1,16	
Perimeter TB (length/m)	P	35,7	0,000	0,43	57,2	0	0,00	
Ground TB (length/m)	B	9,0	0,211	0,43	57,2	46	0,28	
Total of all building envelope areas		474,3					kWh/(m ² a)	
Transmission heat losses Q_T						Total	7286	44,7

Ventilation system:

Effective heat recovery efficiency η_{eff}

Efficiency of subsoil heat exchanger η_{SHX}

Heat recovery efficiency of SHX η_{SHX}

Effective air volume, V_V m³

Energetically effective air changes n_V 1/h

Clear room height m

A_{TFA} m²

Clear room height m

V_V m³

n_V 1/h

η_{HR}

η_{V,Res}

η_{HR}

η_{V,Res}

C_{Air} kWh/(m²K)

G_i kKWh/a

V_V m³

n_V 1/h

C_{Air} kWh/(m²K)

G_i kKWh/a

Ventilation heat losses Q_V kWh/a kWh/(m²a)

Total heat losses Q_L kWh/a kWh/(m²a)

Q_T kWh/a

Q_V kWh/a

Reduction factor night/weekend Saving

Orientation of the area	Reduction factor See 'Windows' sheet	g-Value (perp. radiation)	Area m ²	Radiation HP kWh/(m ² a)	kWh/a	kWh/(m ² a)	
North	0,42	0,61	13,66	91	321		
East	0,51	0,61	15,63	201	970		
South	0,49	0,61	29,57	378	3370		
West	0,44	0,61	15,54	202	842		
Horizontal	0,00	0,00	0,00	372	0		
Available solar heat gains Q_S					Total	5502	33,8

Internal heat gains Q_I kWh/a kWh/(m²a)

Length heating period d/a

Spec. power q_i W/m²

A_{TFA} m²

Free heat Q_F kWh/a kWh/(m²a)

Ratio of free heat to losses $Q_F / Q_V =$

Utilisation factor heat gains h_G $(1 - (Q_F / Q_L)^5) / (1 - (Q_F / Q_L)^6) =$

Heat gains Q_G kWh/a kWh/(m²a)

Annual heating demand Q_H kWh/a kWh/(m²a)

Limiting value kWh/(m²a)

Requirement met? Yes

Specific energy for heating (monthly method)

EnerPHit with PHPP Version 9.3

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

The sum of the heating periods calculated through the monthly method will be presented on this side.

Interior temperature:	<input type="text" value="20"/>	°C
Building type:	<input type="text"/>	
Treated floor area A _{TFA} :	<input type="text" value="163,0"/>	m ²
Spec. Capacity:	<input type="text" value="60"/>	Wh/(m ² K)

Building assembly	Temperature zone	Area m ²	U-Value W/(m ² K)	Month. red. fac.	G _i kWh/a	=	kWh/a	Per m ² of treated floor area	
External wall - Ambient	A	70,5	0,117	1,00	73	=	601	3,69	
External wall - Ground	B			1,00		=			
Roof/Ceiling - Ambient	A	231,6	0,177	1,00	73	=	2985	18,31	
Floor slab / Basement ceiling	B	97,8	0,228	1,00	25	=	548	3,36	
	A			1,00		=			
	X			0,75		=			
Windows	A	74,4	0,868	1,00	73	=	4703	28,85	
Exterior door	A			1,00		=			
Exterior TB (length/m)	A	159,3	0,021	1,00	73	=	240	1,47	
Perimeter TB (length/m)	P	35,7	0,000	1,00	25	=	0	0,00	
Ground TB (length/m)	B	9,0	0,211	1,00	25	=	47	0,29	
							Total	9123	56,0

Effective air volume V _v m ³	A _{TFA} m ²	Clear room height m	=	m ³
<input type="text" value="163"/>	<input type="text" value="163"/>	<input type="text" value="3,34"/>	=	<input type="text" value="544"/>
n _{v,system} 1/h	η ^{SHX}	η _{HR}		n _{v,Res} 1/h
<input type="text" value="0,244"/>	<input type="text" value="0%"/>	<input type="text" value="0,81"/>	+	<input type="text" value="0,070"/>
Effective air change rate Ambient n _{v,e}	* (1 -)	* (1 -)	+	=
<input type="text" value="0,244"/>	<input type="text" value="0%"/>	<input type="text" value="0,81"/>	+	<input type="text" value="0,116"/>
Effective air change rate Ground n _{v,g}	* (1 -)			=
<input type="text" value="0,244"/>	<input type="text" value="0%"/>			<input type="text" value="0,000"/>
V _v m ³	n _{v,equi, fraction} 1/h	C _{Air} Wh/(m ² K)		G _i kWh/a
<input type="text" value="544"/>	<input type="text" value="0,116"/>	<input type="text" value="0,33"/>	*	<input type="text" value="73"/>
Ventilation losses ambient Q _v	*	*	*	=
<input type="text" value="544"/>	<input type="text" value="0,116"/>	<input type="text" value="0,33"/>	*	<input type="text" value="44"/>
Ventilation losses ground Q _{v,e}	*	*	*	=
<input type="text" value="544"/>	<input type="text" value="0,000"/>	<input type="text" value="0,33"/>	*	<input type="text" value="0"/>
Total				
1512				
9,3				

Q _T kWh/a	+	Q _v kWh/a)	Reduction factor night/weekend saving	=	kWh/a	kWh/(m ² a)
<input type="text" value="9123"/>	+	<input type="text" value="1512"/>)	<input type="text" value="1,0"/>	=	<input type="text" value="10635"/>	<input type="text" value="65,2"/>

Orientation of the area	Reduction factor see 'Windows' worksheet	g-Value (perp. radiation)	Area m ²	Global radiation kWh/(m ² a)	=	kWh/a
North	<input type="text" value="0,42"/>	<input type="text" value="0,61"/>	<input type="text" value="13,7"/>	<input type="text" value="185"/>	=	<input type="text" value="655"/>
East	<input type="text" value="0,51"/>	<input type="text" value="0,61"/>	<input type="text" value="15,6"/>	<input type="text" value="417"/>	=	<input type="text" value="2011"/>
South	<input type="text" value="0,49"/>	<input type="text" value="0,61"/>	<input type="text" value="29,6"/>	<input type="text" value="676"/>	=	<input type="text" value="6028"/>
West	<input type="text" value="0,44"/>	<input type="text" value="0,61"/>	<input type="text" value="15,5"/>	<input type="text" value="429"/>	=	<input type="text" value="1787"/>
Horizontal	<input type="text" value="0,00"/>	<input type="text" value="0,00"/>	<input type="text" value="0,0"/>	<input type="text" value="747"/>	=	<input type="text" value="0"/>
Sum opaque areas					=	<input type="text" value="1358"/>
Total						
11839						
72,6						

Length Heat. Period kh/d	Spec. Power q _i W/m ²	A _{TFA} m ²	=	kWh/a	kWh/(m ² a)
<input type="text" value="0,024"/>	<input type="text" value="273"/>	<input type="text" value="163,0"/>	=	<input type="text" value="3738"/>	<input type="text" value="22,9"/>
Free heat Q _F					
				Q _S + Q _i	=
				<input type="text" value="15577"/>	<input type="text" value="95,6"/>
Ratio free heat to losses					
				Q _F / Q _L	=
				<input type="text" value="1,46"/>	
Utilisation factor heat gains h _G					
				=	
				<input type="text" value="54%"/>	
Heat gains Q _G					
				η _G * Q _F	=
				<input type="text" value="8390"/>	<input type="text" value="51,5"/>


Annual heating demand Q _H	Q _L - Q _G	=	<input type="text" value="2245"/>	<input type="text" value="14"/>
Limiting value	<input type="text" value="20"/>	Requirement met?	<input checked="" type="checkbox"/> Yes	

Specific energy for heating (monthly method)

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Interior temperature: °C
 Building type:
 Treated floor area A_{TFA}: m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Heating degree hours - External	11,4	9,7	9,6	6,8	4,7	0,5	1,3	1,1	2,8	4,9	11,0	12,0	76	kKh
Heating degree hours - Ground	4,8	4,6	3,5	2,7	1,8	0,8	0,0	-0,4	-0,2	0,5	2,8	3,9	25	kKh
Losses - Exterior	1568	1336	1325	932	646	69	176	149	384	673	1514	1662	10435	kWh
Losses - Ground	115	112	85	66	45	19	0	-9	-4	12	68	96	604	kWh
Sum spec. losses	10,3	8,9	8,7	6,1	4,2	0,5	1,1	0,9	2,3	4,2	9,7	10,8	67,7	kWh/m ²
Solar gains - North	35	53	85	106	149	177	177	131	92	64	42	28	1140	kWh
Solar gains - East	101	154	275	347	410	463	535	434	328	193	116	87	3444	kWh
Solar gains - South	481	571	856	802	740	785	874	927	954	713	490	419	8613	kWh
Solar gains - West	87	125	246	329	371	400	446	392	287	179	96	67	3025	kWh
Solar gains - Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Solar gains - Opaque	66	105	222	257	269	352	350	290	207	121	65	46	2350	kWh
Internal heat gains	424	383	424	411	424	411	424	424	411	424	411	424	4998	kWh
Sum spec. gains solar + internal	7,3	8,5	12,9	13,8	14,5	15,9	17,2	15,9	14,0	10,4	7,5	6,6	144,6	kWh/m ²
Utilisation factor	92%	82%	62%	44%	29%	3%	6%	5%	17%	40%	90%	95%	37%	
Annual heating demand	586	301	98	18	3	0	0	0	0	9	488	742	2245	kWh
Spec. heating demand	3,6	1,8	0,6	0,1	0,0	0,0	0,0	0,0	0,0	0,1	3,0	4,6	13,8	kWh/m ²



Annual heating demand: Comparison

Monthly method	(Heating) 2245 kWh/a	13,8 kWh/(m ² a) reference to treated floor area according to PHPP
Annual method	(Annual heating) 1639 kWh/a	10,1 kWh/(m ² a) reference to treated floor area according to PHPP

Heating load

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Interior temperature: **20** °C
 Building type:
 Treated floor area A_{TFA}: **163,0** m²

	Design temperature	Radiation:	North	East	South	West	Horizontal
Weather 1:	-6,0 °C		10	15	50	15	20 W/m ²
Weather 2:	-2,0 °C		5	5	10	5	5 W/m ²
Ground design temp:	13,1 °C						

Building assembly	Temperature zone	Area m ²	U-Value W/(m ² K)	Factor always 1 (except "X")	TempDiff 1 K	TempDiff 2 K	PT 1 W	PT 2 W
External wall - Ambient	A	70,5	0,117	1,00	26,0 or 6,9	22,0 = 6,9	215	182
External wall - Ground	B			1,00	6,9			
Roof/Ceiling - Ambient	A	231,6	0,177	1,00	26,0 or 22,0	22,0 = 6,9	1066	902
Floor slab / Basement ceiling	B	97,8	0,228	1,00	6,9	6,9	154	154
	A			1,00	26,0 or 22,0	22,0 =		
	X			0,75	26,0 or 22,0	22,0 =		
Windows	A	74,4	0,868	1,00	26,0 or 22,0	22,0 =	1679	1421
Exterior door	A			1,00	26,0 or 22,0	22,0 =		
Exterior TB (length/m)	A	159,3	0,021	1,00	26,0 or 6,9	22,0 = 6,9	86	72
Perimeter TB (length/m)	P	35,7	0,000	1,00	6,9	6,9	0	0
Ground TB (length/m)	B	9,0	0,211	1,00	6,9	6,9	13	13
Building element towards neighbour	I			1,00	3,0	3,0		

Transmission heat load P_T
 Total = **3212** or **2743**

Ventilation system:	Effective air volume, V _V m ³	A _{TFA} m ²	Clear room height m	m ³	Heat recovery efficiency η _{HR}	Heat recovery efficiency SHX	Heat recovery efficiency SHX	Heat recovery efficiency SHX
	163,0		3,34	544	81%	0%	0%	0%
Energetically effective air changes n _V	0,175	0,244	0,81	0,81			1/h	1/h
V _V m ³	544,4	0,220	0,220	0,33	26,0	22,0	P _V 1 W	P _V 2 W
							1029	871

Total heating load P_L
 P_T + P_V = **4241** or **3614**

Orientation of the area	Area m ²	g-Value (perp. radiation)	Reduction factor (see 'Windows' worksheet)	Radiation 1 W/m ²	Radiation 2 W/m ²	P _T 1 W	P _T 2 W
North	13,7	0,6	0,42	10	5	35	18
East	15,6	0,6	0,51	15	5	72	24
South	29,6	0,6	0,49	50	10	446	89
West	15,5	0,6	0,44	15	5	62	21
Horizontal	0,0	0,0	0,40	20	5	0	0

Solar heating power P_S
 Total = **616** or **152**

Internal heating load P _I	Spec. power W/m ²	A _{TFA} m ²	P _I 1 W	P _I 2 W
	3,0	163	489	489

Heating power (gains) P_G
 P_T + P_I = **1105** or **641**

P_L - P_G = **3136** or **2973**

Heating load P_H = **3136** W

Area specific space heating load P_H / A_{TFA} = **19,2** W/m²

Input max. supply air temperature	52 °C	Supply air temperature without heating	15,1 °C
Max. supply air temperature θ _{Supply,Max}	52 °C	Supply air temperature without heating	15,1 °C

For comparison: heating load transportable by the supply Air P_{Supply Air,Max} = **1619** W specific: **9,9** W/m²

Supply air heating: Sufficient? **No**

Summer ventilation

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Building volume:	<input type="text" value="544"/>	m ³	Building type:	<input type="text"/>
Max. indoor absolute humidity:	<input type="text" value="12"/>	g/kg	Heat recovery η_{HRV} :	<input type="text" value="81%"/>
Internal humidity sources:	<input type="text" value="100"/>	g/(P*h)	Energy recovery η_{ER} :	<input type="text" value="73%"/>
			Subsoil heat exchanger η^*_{SHX} :	<input type="text" value="0%"/>

Results passive cooling		Results active cooling			
Frequency of overheating:	<input type="text" value="5,0%"/>	at the overheating limit $\delta_{max} = 25$ °C	Useful cooling demand:	<input type="text" value="8,9"/>	kWh/(m ² a)
max. humidity:	<input type="text" value="12,6"/>	g/kg	Dehumidification demand:	<input type="text" value="0,1"/>	kWh/(m ² a)
Frequency of exceeded humidity:	<input type="text" value="0,3%"/>		Frequency of exceeded humidity:	<input type="text" value="0,3%"/>	

Summer basic ventilation to ensure adequate air quality

Air change rate via vent. system with supply air:	<input type="text"/>	1/h	HRV/ERV in summer (check only one field)
			None <input type="text"/>
			Automatic bypass, controlled by temperature difference <input type="text"/>
			Automatic bypass, controlled by enthalpy difference <input type="text"/>
			Always <input type="text"/>
Air change rate via extract air system:	<input type="text"/>	1/h	Specific power consumption (for extract air system) <input type="text" value="0,20"/>
			Wh/m ³
Window ventilation air change rate:	<input type="text" value="3,00"/>	1/h	

Effective air change rate

	$n_{V,system}$ 1/h	η^*_{SHX}	η_{HP}	$n_{V,equi,fraction}$ 1/h
Exterior $n_{V,e}$	<input type="text" value="0,000"/>	<input type="text" value="0%"/>	<input type="text" value="0,81"/>	<input type="text" value="0,000"/>
without HR	<input type="text" value="0,000"/>	<input type="text" value="0%"/>	<input type="text" value="0,81"/>	<input type="text" value="0,000"/>
Ground $n_{L,g}$	<input type="text" value="0,000"/>	<input type="text" value="0%"/>	<input type="text" value="0,81"/>	<input type="text" value="0,000"/>
without HR	<input type="text" value="0,000"/>	<input type="text" value="0%"/>	<input type="text" value="0,81"/>	<input type="text" value="0,000"/>

Ventilation conductance

	V_V m ³	$n_{V,equi,fraction}$ 1/h	C_{Air} Wh/(m ³ K)	
exterior $H_{V,e}$	<input type="text" value="544"/>	<input type="text" value="0,000"/>	<input type="text" value="0,33"/>	<input type="text" value="0,0"/>
without HR	<input type="text" value="544"/>	<input type="text" value="0,000"/>	<input type="text" value="0,33"/>	<input type="text" value="0,0"/>
ground $H_{V,g}$	<input type="text" value="544"/>	<input type="text" value="0,000"/>	<input type="text" value="0,33"/>	<input type="text" value="0,0"/>
without HR	<input type="text" value="544"/>	<input type="text" value="0,000"/>	<input type="text" value="0,33"/>	<input type="text" value="0,0"/>
Infiltration, window, extract air system	<input type="text" value="544"/>	<input type="text" value="3,070"/>	<input type="text" value="0,33"/>	<input type="text" value="551,5"/>

Additional summer ventilation for cooling

Additional ventilation regulation

Minimum acceptable indoor temp. °C

Type of additional ventilation

Window night ventilation, manual	Night ventilation value <input type="text" value="0,00"/>	1/h	
Mechanical, automatically Controlled ventilation	Corresponding air change rate during operation, in addition to basic air change <input type="text"/>	1/h	Controlled by (please check)
	Specific power consumption <input type="text"/>	Wh/m ³	Temperature diff. <input type="text"/>
			Humidity diff. <input type="text" value="x"/>

Secondary calculation: Hygienic air change rate through window ventilation

Estimation for window air change rate to ensure sufficient air quality

Description						
Open duration [h/d]						
Climate boundary conditions						
Temperature diff interior - exterior						K
Wind velocity						m/s
Window group 1						
Quantity						
Clear width						m
Clear height						m
Tilting window (check if appropriate)						
Opening width (for tilting windows)						m
Window group 2 (cross ventilation)						
Quantity						
Clear width						m
Clear height						m
Tilting window (check if appropriate)						
Opening width (for tilting windows)						m
Difference in height to window 1						m
Result: Air change rate	0,00	0,00	0,00	0,00	0,00	0,00
						Total
						0,00 1/h

Secondary calculation: Additional night ventilation for cooling

Air change value during additional window night ventilation

Description						
Reduction factor						
Climate boundary conditions						
Temperature diff interior - exterior	1	1	1	1	1	1
Wind velocity	0	0	0	0	0	0
Window group 1						
Quantity						
Clear width						m
Clear height						m
Tilting window (check if appropriate)						
Opening width (for tilting windows)						m
Window group 2 (cross ventilation)						
Quantity						
Clear width						m
Clear height						m
Tilting window (check if appropriate)						
Opening width (for tilting windows)						m
Difference in height to window 1						m
Result: Night ventilation values	0,00	0,00	0,00	0,00	0,00	0,00
						Total
						0,00 1/h

Summer: Passive cooling

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Building type:		
Upper temperature limit:	25	°C
Nominal humidity:	12	g/kg
Spec. capacity:	60	Wh/(m ² K)

Treated floor area A _{TFA} :	163,0	m ²
Building volume:	544	m ³
Internal humidity sources:	6,1	g/(m ² h)

Building assembly	Temperature zone	Area m ²	U-Value W/(m ² K)	Red. factor f _{r,Summer}	H _{Summer} heat conductance
External wall - Ambient	A	70,5	0,117	1,00	8,3
External wall - Ground	B			1,00	
Roof/Ceiling - Ambient	A	231,6	0,177	1,00	41,0
Floor slab / Basement ceiling	B	97,8	0,228	1,00	22,3
	A			1,00	
	A			1,00	
	X			0,75	
Windows	A	74,4	0,868	1,00	64,6
Exterior door	A			1,00	
Exterior TB (length/m)	A	159,3	0,021	1,00	3,3
Perimeter TB (length/m)	P	35,7	0,000	1,00	0,0
Ground TB (length/m)	B	9,0	0,211	1,00	1,9
Exterior thermal transmittance, H_{T,e}					117,1 W/K
Ground thermal transmittance, H_{T,g}					24,2 W/K

Summer ventilation from 'SummVent' worksheet

Ventilation unit conductance

exterior H _{v,e}	0,0	W/K
without HR	0,0	W/K
ground H _{v,g}	0,0	W/K
without HR	0,0	W/K

Ventilation conductance, others

exterior	551,5	W/K
----------	-------	-----

Ventilation parameter

Temperature amplitude summer	4,0	K
Minimum acceptable indoor temperature	22,0	°C
Heat capacity air	0,33	Wh/(m ² K)
Supply air changes	0,00	1/h
Outdoor air changes	3,07	1/h
Window night ventilation air change rate, manual @ 1K	0,00	1/h
Air change rate due to mech. automatically controlled vent.	0,00	1/h
Specific power consumption for	0,00	Wh/m ³
η _{HR}	81%	
η _{ERV}	73%	
η* _{SHX}	0%	

Summer ventilation regulation

None	HRV/ERV
Controlled by temperature	
Controlled by enthalpy	
Always	
Controlled by temperature	
Controlled by humidity	x

Orientation of the area	Angle factor Summer	Shading factor Summer	Shading dirt	g-Value (perp. radiation)	Area m ²	Portion of glazing	Aperture m ²	
North	0,9	0,27	0,95	0,61	13,7	73%	1,4	
East	0,9	0,33	0,95	0,61	15,6	71%	1,9	
South	0,9	0,20	0,95	0,61	29,6	73%	2,3	
West	0,9	0,28	0,95	0,61	15,5	71%	1,6	
Horizontal	0,9	1,00	0,95	0,00	0,0	0%	0,0	
Sum opaque areas							2,0	
Solar aperture							9,2 m ²	0,06 m ² /m ²

Internal heat gains Q_i	Specif. power q _i W/m ²	A _{TFA} m ²	W	W/m ²
	3,5	163	571	3,5

Frequency of overheating h_{0,≥jmax} **5,0%** At the overheating limit $\vartheta_{max} = 25\text{ °C}$

If the "frequency over 25°C" exceeds 10%, additional measures to protect against the heat during the summer are necessary.

Daily internal temperature stroke

Transmission kWh/d	Ventilation kWh/d	Solar load kWh/d	1/k	Spec. capacity Wh/(m ² K)	A _{TFA} m ²	
(5,6)	+ (26,5)	+ (47,0)	* 1000	/ ((60)	* (163)	= (8,1) K


Cooling: energy value for useful cooling energy

EnerPHit with PHPP Version 9.3

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Interior Temperature: °C
 Building type:
 Treated Floor Area A_{TFA}: m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Heating degree hours - Exterior	15,3	13,2	13,5	10,5	8,5	4,2	5,1	4,9	6,5	8,7	14,7	15,9	121	kKh
Heating degree hours - Ground	8,5	8,0	7,2	6,3	5,6	4,4	3,7	3,4	3,4	4,2	6,4	7,7	69	kKh
Losses - Exterior	9584	8294	8515	6564	5357	2384	3090	2944	3937	5332	9424	10072	75497	kWh
Losses - Ground	205	193	175	154	135	106	90	81	83	102	155	186	1665	kWh
Losses summer ventilation	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Sum spec. heat losses	60,1	52,1	53,3	41,2	33,7	15,3	19,5	18,6	24,7	33,3	58,8	62,9	473,4	kWh/m ²
Solar load North	20	29	47	59	82	98	98	73	51	35	24	16	631	kWh
Solar load East	57	87	154	195	230	260	300	244	184	108	65	49	1932	kWh
Solar load South	173	205	308	289	266	282	315	334	343	257	177	151	3100	kWh
Solar load West	48	68	134	179	202	218	243	213	157	98	52	36	1648	kWh
Solar load Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Solar load Opaque	66	105	222	257	269	352	350	290	207	121	65	46	2350	kWh
Internal heat gains	424	383	424	411	424	411	424	424	411	424	411	424	4998	kWh
Sum spec. loads solar + internal	4,8	5,4	7,9	8,5	9,0	9,9	10,6	9,7	8,3	6,4	4,9	4,4	89,9	kWh/m ²
Utilisation factor losses	8%	10%	14%	20%	25%	51%	41%	43%	31%	18%	8%	7%	17%	
Useful cooling energy demand	7	12	32	61	97	363	434	269	126	40	7	5	1453	kWh
Spec. cooling demand	0,0	0,1	0,2	0,4	0,6	2,2	2,7	1,6	0,8	0,2	0,0	0,0	8,9	kWh/m ²
Specif. dehumidification demand	0,0	0,0	0,0	0,0	0,0	0,0	0,1	0,0	0,0	0,0	0,0	0,0	0,1	kWh/m ²
Sensible fraction	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%	99%	



Cooling: energy value for useful cooling energy

EnerPHit with PHPP Version 9.3

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

The sum of the cooling periods calculated through the monthly method will be presented on this side.

Building type:		Treated floor area A _{TFA} :	163,0	m ²
Interior temperature summer:	25	°C	Building volume:	544
Nominal humidity:	12	g/kg	Internal humidity sources:	6,1
Spec. capacity:	60	Wh/(m ² K)		g/(m ² h)

Building assembly	Temperature zone	Area m ²	U-Value W/(m ² K)	Mon. red. fac.	G _i kWh/a	kWh/a	per m ² treated floor area
External wall - Ambient	A	70,5	0,117	1,00	121	998	6,12
External wall - Ground	B			1,00			
Roof/Ceiling - Ambient	A	231,6	0,177	1,00	121	4957	30,41
Floor slab / Basement ceiling	B	97,8	0,228	1,00	69	1534	9,41
	A			1,00			
	A			1,00			
	X			0,75			
Windows	A	74,4	0,868	1,00	121	7809	47,91
Exterior door	A			1,00			
Exterior TB (length/m)	A	159,3	0,021	1,00	121	398	2,44
Perimeter TB (length/m)	P	35,7	0,000	1,00	121	0	0,00
Ground TB (length/m)	B	9,0	0,211	1,00	69	131	0,80
						15827	97,1

Transmission losses Q_T (negative: heat loads)

Summer ventilation from SummVent worksheet

Ventilation conductance, vent. unit	
exterior H _{v,e}	0,0 W/K
without HR	0,0 W/K
ground H _{v,g}	0,0 W/K
without HR	0,0 W/K
Ventilation conductance, others	
exterior	551,5 W/K

Ventilation parameter	
Temperature amplitude summer	4,0 K
Minimum acceptable indoor temperature	22,0 °C
Heat capacity air	0,33 Wh/(m ² K)
Supply air changes	0,00 1/h
Outdoor air changes	3,07 1/h
Window night vent. air change rate, manual @ 1K	0,00 1/h
Air changes rate due to mech., autom. controlled vent.	0,00 1/h
Specific power consumption for	0,00 Wh/m ³
η _{HR}	81%
η _{ERV}	73%
η [*] _{SHX}	0%

Summer ventilation regulation	
HRV/ERV in summer	
Controlled by temp.	
Controlled by enthalpy	
Always	
Additional ventilation	
Controlled by temp.	
Controlled by humidity	x

Hygienic air change

Effective air change rate Ambient n _{v,a}	0,000	*(1 - 0%)	*(1 - 0,81)	+ 3,070	= 3,070
Effective air change rate Ground n _{v,g}	0,000	* (1 - 0%)	* (1 - 0,81)		= 0,000

V _v m ³	544	n _{v,eq} fraction 1/h	3,070	C _{Air} Wh/(m ² K)	0,33	G _i kWh/a	111	kWh/a	61335	kWh/(m ² a)	376,3
Ventilation losses ambient Q _V	544		0,000		0,33	0	0	0	0	0,0	
Ventilation losses ground Q _{V,g}	544		0,000		0,33	0	0	0	0	0,0	
Heat losses summer ventilation	544		0,000		0,33	0	0	0	0	0,0	
									61335	376,3	

Ventilation heat losses Q_V

Total heat losses Q _L		Q _T kWh/a	15827	+	Q _V kWh/a	61335	=	77162	kWh/(m ² a)	473,4
----------------------------------	--	----------------------	-------	---	----------------------	-------	---	-------	------------------------	-------

Orientation of the area	Reduction factor	g-Value (perp. radiation)	Area m ²	Global radiation kWh/(m ² a)	kWh/a	
North	0,24	0,61	13,7	322	631	
East	0,28	0,61	15,6	714	1932	
South	0,18	0,61	29,6	966	3100	
West	0,24	0,61	15,5	726	1648	
Horizontal	0,40	0,00	0,0	1285	0	
Sum opaque areas					2350	
					9661	59,3

Available solar heat gains Q_S

Internal heat gains Q _I		kWh/d	0,024	Length heat. period d/a	365	Spec. power q _i W/m ²	3,5	A _{TFA} m ²	163,0	kWh/a	4998	kWh/(m ² a)	30,7
									14659	89,9			

Sum heat loads Q_F

Ratio of losses to free heat gains		Q _L / Q _F	= 5,26
Utilisation factor heat losses η _G			= 17%
Useful heat losses Q _{V,n}	η _G * Q _L	13206	kWh/(m ² a)
Useful cooling demand Q _K	Q _F - Q _{V,n}	1453	kWh/(m ² a)
Recommended maximum value		15	kWh/(m ² a)
Requirement met?		Yes	(Yes/No)

Compressor - cooling units

EnerPHit with PHPP Version 9.3

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Building type:			Treated floor area A _{TFA} :	163,0	m ²
Interior temperature summer:	25,0	°C	Mechanical cooling:		
Nominal humidity:	12,0	g/kg	Air change rate via ventilation system with supply air:	0,0	
Internal humidity sources:	6,1	g/(m ² h)			

Supply air cooling

check as appropriate

On/Off mode (check as appropriate)	
Max. cooling capacity (sensible + latent)	kW
Temperature reduction dry	K
Seasonal energy efficiency ratio	

Recirculation cooling

check as appropriate

On/Off mode (check as appropriate)	
Max. cooling capacity (sensible + latent)	kW
Volume flow rate at nominal power	m ³ /h
Temperature reduction dry	K
Variable air volume (check if appropriate)	
Seasonal energy efficiency ratio	

Additional dehumidification

check as appropriate

Waste heat to room (please check if applicable)	
Seasonal energy efficiency ratio	

Panel cooling

check as appropriate

Seasonal energy efficiency ratio	
----------------------------------	--


	Sensible kWh/(m ² a)	Latent kWh/(m ² a)	COP	Electricity demand (kWh/a) kWh/(m ² a)	Sensible fraction
Useful cooling total	8,9	0,1			99%
Cooling contribution by:					
Supply air cooling	() + ()) /	0,0	=	()
Recirculation cooling	() + ()) /	0,0	=	()
Dehumidification	()	/		=	0%
Remaining for panel cooling	()	/	0,0	=	100%
Cooling distribution	()	/		=	100%
Total	(0,0 + 0,0)) /		= 0,0	0%
Unsatisfied demand	()	()			(Yes/No)
				Cooling demand covered?	()

Compressor - cooling units

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Humidity loads and humidity removal

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Internal humidity sources	3,2	2,9	3,2	3,1	3,2	3,1	3,2	3,2	3,1	3,2	3,1	3,2	38	kWh/m ²
Infiltration/Window/Extract air system	-52,0	-45,8	-47,4	-42,0	-29,1	-22,3	-14,5	-13,3	-24,0	-31,3	-44,0	-50,8	-417	kWh/m ²
Supply air ventilation system	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Summer ventilation window	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Summer ventilation mechanically	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Total humidity load	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Dehumidification by supply air cooling	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Dehumidification by circulation cooling	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Additional dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Total dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Unnecessary dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²
Missing dehumidification	0,0	0,0	0,0	0,0	0,0	0,0	0,1	0,0	0,0	0,0	0,0	0,0	0	kWh/m ²



Cooling load

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13.8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Building type:					Treated floor area A _{TFA} :	163,0	m ²	Spec. capacity:	60	Wh/(m ²)
					Building volume:	544	m ³	Nominal humidity:	12,0	g/kg
					Interior temperature:	25	°C	Internal humidity sources:	6,1	g/kg
Temperature:	Outdoor air	Dew point	Sky		Radiation:	North	East	South	West	Horizontal
Weather 1:	25,1	16,9	14,3	°C		104	185	208	207	347
Weather 2:	25,1		12,3	°C		104	185	208	207	347
Ground design temp.:	20,5		SHX 13,3	°C						

Building assembly	Temperature zone	Area m ²	U-Value W/(m ² K)	Factor always 1 (except 'X')	TempDiff 1 K	TempDiff 2 K	P _T 1 W	P _T 2 W
External wall - Ambient	A	70,5	0,117	1,00	0,1	0,1	1	1
External wall - Ground	B			1,00	-4,5	-4,5		
Roof/Ceiling - Ambient	A	231,6	0,177	1,00	0,1	0,1	3	3
Floor slab / Basement ceiling	B	97,8	0,228	1,00	-4,5	-4,5	-101	-101
	A			1,00	0,1	0,1		
	A			1,00	0,1	0,1		
	X			0,75	0,1	0,1		
Windows	A	74,4	0,868	1,00	0,1	0,1	5	5
Exterior door	A			1,00	0,1	0,1		
Exterior TB (length/m)	A	159,3	0,021	1,00	0,1	0,1	0	0
Perimeter TB (length/m)	P	35,7	0,000	1,00	-4,5	-4,5	0	0
Ground TB (length/m)	B	9,0	0,211	1,00	-4,5	-4,5	-9	-9
Building element towards neighbour	I			1,00	3,0	3,0		
Radiation correction outdoor air			L _{ambient} W/K	-10,7	0,1	0,1	-1	-1
Radiation correction sky			L _{sky} W/K	10,6	-10,7	-10,7	-113	-134

Transmission heat load P_T Total = **-214** or **-235**

	V _V m ³	ρ _{V,liquid} fraction 1/h	ρ _{V,air} fraction 1/h	C _{air} Wh/(m ³ K)	TempDiff 1 K	TempDiff 2 K	P _V 1 W	P _V 2 W
Exterior P _{V,D}	544	3,070	3,070	0,33	0,1	0,1	40	40
Ground P _{V,e}	544	0,000	0,000	0,33	-11,7	-11,7	0	0
Summer ventilation P _{V,S}	544	0,000	0,000	0,33	0,0	0,0	0	0

Ventilation heat load P_V Total = **40** or **40**

Orientation of the area	Area m ²	g-Value (perp. radiation)	Reduction factor (see 'Windows' worksheet)	Radiation 1 W/m ²	Radiation 2 W/m ²	P _T 1 W	P _T 2 W
North	13,7	0,6	0,17	104	104	145	145
East	15,6	0,6	0,20	185	185	358	358
South	29,6	0,6	0,13	208	208	476	476
West	15,5	0,6	0,17	207	207	336	336
Horizontal	0,0	0,0	0,40	347	347	0	0
Sum opaque areas						641	641

Solar load P_S Total = **1956** or **1956**

	Spec. power W/m ²	A _{TFA} m ²	P _I 1 W	P _I 2 W
Internal heating load P _I	3,5	163	571	571

P_T + P_V + P_S + P_I = **2352** or **2331**

Cooling load P_C = **2352** W
 Area specific cooling load P_C / A_{TFA} = **14,4** W/m²

Please enter the minimum supply air temperature: °C Supply air temperature without cooling θ_{Supply,Min} = **25,0** °C

For comparison: cooling load, transportable through the supply air P_{Supply,Max} = **0** W
 specific: **0,0** W/m²

Air conditioning over the supply air possible? (yes/no)

Daily internal temperature stroke
 ((-214,3 + 39,7 + 1956,5) * 24 / (60 * 163)) = **4,4** K

Absolute humidity exterior air		Absolute humid. supply air		Humid. load, supply air		Humidity load, internal	
12,1	9,6	12,0	11,4	0	0	1000	1000
1972	1972	0	0	0	0		
0	0						
101	-4639						

Enthalpy of vaporisation Wh/kg / g/kg * Humidity load g/h = **779** W or **0** W

Dehumidification load P_T = **779** W

Area specific dehumidification load P_T / A_{TFA} = **4,8** W/m²

Monthly average values	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Specific cooling demand	0,0	0,1	0,2	0,4	0,6	2,2	2,7	1,6	0,8	0,2	0,0	0,0
Specific dehumidification demand	0,0	0,0	0,0	0,0	0,0	0,0	0,1	0,0	0,0	0,0	0,0	0,0
Sensible fraction	100%	100%	100%	100%	100%	100%	96%	100%	100%	100%	100%	100%

Minimum of sensible cooling load fraction occurred **100%**

DHW useful heat

DHW demand for showers, per person and day (with 60°C)		litre/person/d	0,0
DHW demand others, per person and day (with 60°C)		litre/person/d	1,0
Performance of shower drain-water heat recovery		-	0%
Effective DHW demand	V_{DHW}	litre/person/d	1
Average cold water temperature of the supply	ϑ_{TW}	°C	13,3
DHW demand for washing machines and dishwashers non-elect		kWh/a	73
Effective useful heat DHW	Q_{DHW}	kWh/a	271

kWh/a	kWh/m²a
271	1,7

Auxiliary calculation - DHW demand calculation (for non-res)

DHW distribution

			Inside thermal envelope					Outside thermal envelope					Total values	
			1	2	3	4	5	1	2	3	4	5	Absolute	Specific
Temp. of room through which the pipes pass	ϑ_x	°C	20,0	20,0	20,0	20,0	20,0	12,3	12,3	12,3	12,3	12,3		
Design forward flow temperature	ϑ_{dist}	°C	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0	60,0			
DHW circulation pipes														
Length of circulation pipes (forward + return flow)	L_{HS}	m												
Nominal width of pipe		mm												
Insulation thickness		mm												
Insulation reflective coating?		-												
Thermal conductivity of insulation		W/(mK)												
Heat loss coefficient per m of insulated pipe		W/(mK)												
Insulation quality of mountings, pipe suspensions, etc.		-	1-None	1-None	1-None	1-None	1-None	1-None	1-None	1-None	1-None			
Thermal bridge supplement		W/K												
Total heating loss coefficient per m of pipe	Ψ	W/(mK)												
Daily circulation period of operation.	td_{Circ}	h/d												
Design return flow temperature	ϑ_R	°C												
Circulation period of operation per year	t_{Circ}	h/a												
Annual heat released per m of pipe	q^*_z	kWh/m/a												
Annual heat loss from circulation lines	QZ	kWh/a										0	0,0	
DHW individual pipes														
Exterior pipe diameter	d_{U_Pipe}	m					0,016							
Accumulated length per single pipes	L_U	m					15,00							
Amount of tapping points in building	$n_{tapping\ point}$	-					5,00							
Average pipe length per tapping point	$L_{U_average}$	m					3,0							
Tap openings per person per day		-					3							
Utilisation days per year		d					365							
Heat loss per tap opening	$q_{Individual}$	kWh/tap opening					0,0250							
Amount of tap openings per year and person	n_{Tap}	Tap openings per year					1095							
Annual heat loss of individual pipes	Q_U	kWh/a					273					273	1,7	
Total heat losses of DHW distribution	Q_{WL}												273	1,7
Performance ratio of DHW distribution pipes	ea_{rHL}	-											201%	

Storage heat losses

	Storage 1	Storage 2	Buffer storage tank (only heating)	Compact unit		
Selection of storage tank	1-DHW and heating	0-No storage tank	0-No storage tank	0-No		
Storage necessary for HP						
Solar DHW connection						
Heat loss rate	W/K 2,0	3,0				
Storage volume	litre 300			---		
Standby fraction	- 30%					
Location of storage tank, inside or outside of thermal envelope	2-Outside	1-Inside	2-Outside			
Temperature of mechanical room	°C 12,3					
Typical storage tank temperature	°C 60,0					
Manual entry of storage temperature	°C					
Average standby heat losses storage tank	W 29					
Additional heat losses storage tank, solar operation	W					
Possibly utilisation factor of heat losses	---	---	---	---		
Annual heat losses DHW storage tank	kWh/a 251				kWh/a 251	kWh/(m²a) 1,5
Annual heat losses buffer storage tank	---	---				

Auxiliary calculation - heat losses through storage tank according to EU efficiency classes

Total energy demand of domestic hot water

Heat losses of DHW distribution and storage	Q_{WL}	kWh/a 524	kWh/(m²a) 3,2
Performance ratio DHW-distribution + storage	$e_{a,WL}$	293%	
Total heating demand of DHW system			
Including storage tank	$Q_{g,DHW}$	kWh/a 795	kWh/(m²a) 4,9

Solar thermal system

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Building type:		
Treated floor area A _{TFA} :	163,0	m ²
Projected building footprint A _{Projected} :	97,8	m ²
Latitude (<i>Climate' worksheet</i>):	45,6	°
DHW demand (<i>DHW+Distribution</i>):	795	kWh/a
Heating demand ('Heating' and 'DHW+Distribution' worksheets):	2843	kWh/a
Occupancy:	10,0	Persons

Location: Selection in 'Areas' worksheet		
Size of selected area		m ²
Free area (less solar thermal and electrical systems)		m ²
Deviation from North		°
Angle of inclination from the horizontal		°
Alternative input: Deviation from North		°
Alternative input: Angle of inclination from the horizontal		°

Solar collector area		m ²
Specific collector area	0,0	m ² /Pers
Height of the collector field		m
Height of horizon		m
Horizontal distance		m
Additional reduction factor shading		


Collector	
Heating support (please check, if applicable)	
DHW priority (check if appropriate)	x

Results

	Projected building footprint area	
	kWh/(m ² Projected*a)	Absolute kWh/a
Solar contribution total	0%	0,0
Solar contribution to DHW	0%	0,0
Solar contribution to space heating	0%	0,0

1-CO2 factors GEMIS (Germany)	kgCO ₂ eq/	
	kgCO ₂ eq/m ² Projected*a	kgCO ₂ eq/a
kWhFinal		

Determination of PER factors		
Yield reference PV syst.	PER _{el}	PER _{sol,therm}
kWh _{ref} /a	kWh _{prim-el} /kWh _{el}	$\frac{kWh_{th}}{kWh_{prim-el} * kWh_{prim-el} / kWh_{el}}$
	1,30	
	1,80	



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Heating demand DHW-preparation	68	61	68	65	68	65	68	68	65	68	65	68	795	kWh/month
Space heating demand	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Heating demand	68	61	68	65	68	65	68	68	65	68	65	68	795	kWh/month
Radiation on tilted collector surface	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Please enter: Solar production for DHW													0	kWh/month
Please enter: Solar production for heating													0	kWh/month
DHW heating demand covered by solar	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Space heating demand covered by solar	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Heating demand covered by solar	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month
Solar fraction	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	-
Electricity generation of reference PV system														kWh/month


Photovoltaic systems

EnerPHit with PHPP Version 9.3

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Climate data set: **ud-00-Montbrison1314**
 Building type:
 Projected building footprint: **97,8** m²

	System 1	System 2	System 3	System 4	System 5	Reference PV syst.	
Name of system							
Location: Selection in 'Areas' worksheet							
Size of selected area							m ²
Deviation from North	180						°
Angle of inclination from horizontal	20						°
Alternative input: Deviation from North	180						°
Alternative input: Angle of inclination from the horizontal	20						°
Information from the module data sheet							
Technology	4-Mono-Si	5-Poly-Si	5-Poly-Si	5-Poly-Si	5-Poly-Si	4-Mono-Si	
Nominal current	I _{appo} 8,55					7,71	A
Nominal voltage	U _{appo} 32,00					30,50	V
Nominal power	P _n 274	0	0	0	0	235	Wp
Temperature coefficient short-circuit current	α 0,080					0,040	%/K
Temperature coefficient open-circuit voltage	β -0,360					-0,340	%/K
Module dimensions: Height	1,641					1,658	m
Module dimensions: Width	0,989					0,994	m
						1,6	Module area [m ²]
Further specifications							
Number of modules	n _M 22					0,0	
Height of module array							m
Height of horizon	h _{hor}						m
Horizontal distance	d _{hor}						m
Additional reduction factor shading	f _{other}						
Efficiency of the inverter	η _{inv} 95%					95%	
Results							
Area of module field	35,7	0,0	0,0	0,0	0,0	0,0	m ²
Free area on the selected building element							m ²
Allocation to building element							
Annual losses due to shading	0						kWh
Annual electricity yield of the inverter, absolute							
Related to projected building footprint area	6885					6885	kWh/a
CO ₂ -equivalent emissions according to 1-CO ₂ factors GEMIS (Germany)	70,4					70	kWh/m ² a _{Proj}
PE-factor according to 1-PE-factors (non-renewable) PHI Certification	895,1					895,1	kg/a
	0,00	0,00	0,00	0,00	0,00	0,00	kWh _{grid} /kWh



Information from the module data sheet

4-Mono-Si
 Nominal current
 Nominal voltage
 Nominal power
 Temperature coefficient short-circuit current
 Temperature coefficient open-circuit voltage

I_{MPP0}	8,6	A
U_{MPP0}	32,0	V
P_n	273,6	Wp
α	0,1	%/K
β	-0,4	%/K

Further specifications


Latitude
 Number of modules
 Deviation from North
 Angle of inclination from horizontal
 Height of module array
 Height of horizon
 Horizontal distance
 Additional reduction factor shading
 Efficiency of the inverter
 Annual losses due to shading

n_M	45,6	°
n_M	22,0	°
n_M	180,0	°
n_M	20,0	°
n_M	1,0	m
n_M	0,0	m
n_M	1000,0	m
n_M	1,00	
n_M	0,95	
n_M	0	kWh

Annual yield of inverter

Electricity	PER-factor	1-PE-factors (non-renewable) PHI Certification
6885	1,0	0,00
kWh/a		
$\text{kWh/m}^2\text{Projected}^a$	70,4	0,0

1-CO2 factors GEMIS (Germany)	Specific PE value (non-renewable)	Specific value of CO ₂ -equivalent emissions [g/kWh]
0,130	0,3	51,9
895		$\text{kgCO}_2\text{eq/a}$ (absolute)
9,2		$\text{CO}_2\text{eq/m}^2\text{Projected}^a$ (projected building footprint)



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Solar radiation on tilted surface	49	73	143	156	156	195	198	176	138	85	48	36	$\text{kWh/(m}^2\text{month)}$
Ambient temperature	6	7	8	12	14	20	19	19	17	15	6	5	°C
Total monthly yield	227	338	666	737	741	932	949	844	660	406	220	165	kWh/month
Losses through shading situation	0	0	0	0	0	0	0	0	0	0	0	0	kWh/month

Year	
1454,0	$\text{kWh/(m}^2\text{a)}$
12,3	°C
6885,1	kWh/a
0,0	kWh/a

Electricity demand for residential buildings (at the moment this worksheet is inactive. Calculation takes places in the 'Electricity non-res' works

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Households	1		PER and PE factors (KWh/kWh)		Electricity:	1,30	2,6	Solar fraction of DHW Laundry&Dish	0%					
Persons	10,0		Non-electric energy carrier for cooking, drying:		1,30	2,6	Marginal performance ratio DHW	116%						
Living area (m ²)	163		Energy carrier for heating:		1,32	0,7	Marginal performance ratio Heating	116%						
Heating demand [kWh/(m ² a)]	13,8		Energy carrier for DHW:		1,75	0,2								
Column no.	1	2	3	4	5	6	7	8	8a	9	10	11	12	13
Application	Used ? (1/0)	Within the thermal envelope? (1/0)	Norm demand	Utilisation factor	Frequency	Reference quantity	Useful energy (kWh/a)	Electric fraction	Non-electric fraction	Electricity demand (kWh/a)	Additional demand	Marginal performance ratio	Solar fraction	Non-electric demand (kWh/a)
Dishwashing	1	1	1,10 kWh/Use	1,00	65	/(P*a) * 10,0 P	715	100%	0%	715				
2-Cold water connection														
Clothes washing	1	1	1,10 kWh/Use	1,00	57	/(P*a) * 10,0 P	627	100%	0%	627				
2-Cold water connection														
Clothes drying with:	1	1	3,50 kWh/Use	0,88	57	/(P*a) * 10,0 P	1746	100%	0%	1746				
4-Condensation dryer				0,60			0							
Energy consumed by evaporation	0	1	3,13 kWh/Use	0,60	57	/(P*a) * 10,0 P	0		100%					
Refrigerating	1	1	0,78 kWh/d	1,00	365	d/a * 1 HH	285	100%		285				
Freezing	1	1	0,88 kWh/d	1,00	365	d/a * 1 HH	321	100%		321				
or combination	0	1	1,00 kWh/d	1,00	365	d/a * 1 HH	0	100%		0				
Cooking with:	1	1	0,25 kWh/Use	1,00	500	/(P*a) * 10,0 P	1250	100%		1250				
1-Electricity									0%					0
Lighting	1	1	60 W	1,00	2,90	kh/(P*a) * 10,0 P	1740	100%		1740				
Consumer electronics	1	1	80 W	1,00	0,55	kh/(P*a) * 10,0 P	440	100%		440				
Small appliances, etc.	1	1	50 kWh	1,00	1,00	/(P*a) * 10,0 P	500	100%		500				
Total aux. electricity							859			859				
Other:							0			0				
							0			0				
							0			0				
Total							8482 kWh			8482 kWh				0 kWh
Specific demand										52,0 kWh/(m ² a)				0,0 kWh/(m ² a)
Recommended maximum value										18				

Use non-residential buildings

EnerPHit with PHPP Version 9.3

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Latitude [°]: 46

	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	20	27
Utilisation pattern	Begin utilisation [h]	End utilisation [h]	Daily utilisation hours [h/d]	Annual utilisation days [d/a]	Annual utilisation hours [h/a]	Annual utilisation hours during daytime [h/d]	Annual utilisation hours during night-time [h/n]	Daily operating hours of heating	Daily operating hours of ventilation	Lighting	Illumination level [lux]	Height of utilisation level (0,8 or 0,0 m)	Height of utilisation level (0,8 or 0,0 m)	Relative absenteeism	Part use factor of building operating period for lighting	Average occupancy [m ² /Pers.]			
1			0		0											0,8			
2			0		0											0,8			
3			0		0											0,8			
4			0		0											0,8			
5			0		0											0,8			
6			0		0											0,8			
7			0		0											0,8			
8			0		0											0,8			
9			0		0											0,8			
10			0		0											0,8			
11			0		0											0,8			
12			0		0											0,8			
13			0		0											0,8			
14			0		0											0,8			
15			0		0											0,8			
16			0		0											0,8			
17			0		0											0,8			
18			0		0											0,8			
19			0		0											0,8			
20			0		0											0,8			
21 Single office	7	18	11	250	2750	2543	207	13						500	0,8	0,8	0,30	0,70	10,00
22 Group office	7	18	11	250	2750	2543	207	13						500	0,8	0,8	0,30	0,70	
23 Open-plan office	7	18	11	250	2750	2543	207	13						500	0,8	0,8	0,00	1,00	15,00
24 Meeting	7	18	11	250	2750	2543	207	13						500	0,8	0,8	0,50	1,00	2,00
25 Counter area	7	18	11	250	2750	2543	207	13						200	0,8	0,8	0,00	1,00	
26 Retail	8	20	12	300	3600	2999	601	14						300	0,8	0,8	0,00	1,00	7,00
27 Classroom	8	15	7	200	1400	1398	2	9						300	0,8	0,8	0,25	0,90	2,00
28 University auditorium	8	18	10	150	1500	1409	91	12						500	0,8	0,8	0,25	0,70	0,75
29 Bedroom	0	24	24	365	8760	4407	4353	24						300	0,8	0,8	0,00	0,50	
30 Hotel room	21	8	11	365	4015	755	3260	24						200	0,8	0,8	0,25	0,30	
31 Canteen	8	15	7	250	1750	1748	2	9						200	0,8	0,8	0,00	1,00	
32 Restaurant	10	0	14	300	4200	2404	1796	16						200	0,8	0,8	0,00	1,00	1,50
33 Kitchen non-residential	10	23	13	300	3900	2404	1496	15						500	0,8	0,8	0,00	1,00	
34 Kitchen, Storage, Preparation	7	23	16	300	3900	2404	1496	15						300	0,8	0,8	0,50	1,00	
35 W.C, Sanitary	7	18	11	250	2750	2543	207	13						200	0,8	0,8	0,90	1,00	
36 Other habitable rooms	7	18	11	250	2750	2543	207	13						300	0,8	0,8	0,50	1,00	
37 Secondary areas	7	18	11	250	2750	2543	207	13						100	0,8	0,8	0,90	1,00	
38 Circulation area	7	18	11	250	2750	2543	207	13						100	0,0	0,0	0,80	1,00	
39 Storage, Services	7	18	11	250	2750	2543	207	13						100	0,8	0,8	0,98	1,00	
40 Server room	0	24	24	365	8760	4407	4353	24						500	0,8	0,8	0,50	0,50	
41 Workshop	7	16	9	250	2250	2192	58	11						500	0,8	0,8	0,00	1,00	
42 Theatre auditorium	19	23	4	250	1001	55	946	6						200	0,8	0,8	0,00	1,00	
43 Theatre foyer	19	23	4	250	1001	55	946	6						300	0,8	0,8	0,50	1,00	
44 Theatre stage	13	23	10	250	2500	1253	1247	12						1000	0,8	0,8	0,00	0,60	
45 Fair, Congress	13	18	5	150	1350	1260	90	11						300	0,8	0,8	0,50	1,00	
46 Exhibition	10	18	8	250	2001	1850	151	24						200	0,8	0,8	0,00	1,00	
47 Library reading room	8	20	12	300	3600	2999	601	14						500	0,8	0,8	0,00	1,00	
48 Open access library	8	20	12	300	3600	2999	601	14						200	0,8	0,8	0,00	1,00	
49 Library repository	8	20	12	300	3600	2999	601	14						100	0,8	0,8	0,90	1,00	
50 Gymnasium	8	23	15	300	4500	3002	1498	17						300	0,8	0,8	0,30	1,00	
51 Parking garage	7	18	11	250	2750	2543	207	0						75	0,0	0,0	0,95	1,00	
52 Public parking garage	9	0	15	365	5475	3290	2185	0						75	0,0	0,0	0,80	1,00	

Electricity demand for non-residential buildings

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Treated floor area A _{TK} :	163,0	m²
Auxiliary electricity demand:	858,8	kWh/a
Electricity:	1,30	kWh/kWh
RE gas / Natural gas:	1,75	kWh/kWh
Energy carrier for DHW:	1,1	kWh/kWh
Solar fraction of DHW:	0%	
Marginal performance ratio DHW:		

PER factors:	PE factors:
1,30	2,6
1,75	1,1
	1,1

Window properties (from 'Windows' worksheet):

	Shading	Dirt factor	Non-perpendicular air radiation	Glazing fraction
North	0,72	0,95	0,85	0,73
East	0,88			0,71
South	0,84			0,73
West	0,77			0,71

Lighting / non-residential	Net ground area m²	Facade with windows				
		Room category	Power of nominal lighting Lux	Deviation from North Degrees	Orientation	Light transmission glazing -
Room / Zone	m²					

Geometry: input of a typical room				
Room depth	Room width	Room height	Lintel height	Window width
m	m	m	m	m
10,0	15,0	3,4	3,0	10,0

Daylight utilisation	User data: Installed lighting power	Installed lighting power (standard)	Lighting control	Motion detector used? ⁹	Lighting check	Utilisation hours per year	User determined: Lighting full load hours	Full load hours of lighting	Electricity demand (kWh/a)	Spec. electricity demand (kWh/(m²a))	PER demand	PE demand
W/m²	W/m²			[x]		h/a	h/a	h/a	kWh/a	kWh/(m²a)	kWh/a	kWh/a
Low	15	15,0	4	x	Bus system	2750		921	2251	13,8	2927	5854
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							
None		0,0	1	0	Manual							

15

Bureau	163,0	21-Single office	500	180	South	82%	x
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	
						69%	

10,0	15,0	3,4	3,0	10,0

Office equipment	Room category	Within the thermal envelope [1/0]	Existing [1/0]	Quantity	Power consumption [W]	Utilisation hours per year [h/a]	Relative absenteeism	Duration of utilisation in energy saving mode [h/a]	Useful energy (kWh/a)	Electricity demand [kWh/a]	PER demand [kWh/a]	PE demand [kWh/a]
PC 1	22-Group office	1	1	10	80	1925	0,3		1078	1078,0	1401	2803
PC in energy saving mode		1		10	2,0	1925	0,3		12	11,6	15	30
Monitor 1	22-Group office	1	1	10	28	1925	0,3		377	377,3	490	981
Monitor in energy saving mode		1		10	2,0	1925	0,3		12	11,6	15	30
PC 2		1	0		80	0	0		0	0,0	0	0
PC in energy saving mode		1		0	2,0	0	0		0	0,0	0	0
Monitor 2	22-Group office	1	1	10	28	1925	0,3		377	377,3	490	981
Monitor in energy saving mode		1		10	2,0	1925	0,3		12	11,6	15	30
Copier	22-Group office	1	1	1	400	2750		2475	110	110,0	143	286
Copier in energy saving mode		1		1	30	2475			74	74,3	97	193
Printer	22-Group office	1	1	2	300	2750		2475	165	165,0	215	429
Printer in energy saving mode		1		2	2	2475			10	9,9	13	26
Server	22-Group office	1	1	1	150	2750			413	412,5	536	1073
Server in energy saving mode		1		1	2,0	8760		2750	12	12,0	16	31
Telephone system		1	1	1	50	8760			438	438,0	569	1139
									0	0,0	0	0
									0	0,0	0	0
									0	0,0	0	0
									0	0,0	0	0
									0	0,0	0	0

Kitchen / Aux. electricity	Room category (predominant utilisation pattern of building)	Within the thermal envelope [1/0]	Existing [1/0]	Utilisation hours per year [h/a]	Number of meals per day of use	Norm consumption	Useful energy [kWh/a]	Non-electric fraction	Electric fraction	Additional demand	Marginal performance ratio	Solar fraction	Non-electric demand (kWh/a)	Electricity demand [kWh/a]	PER demand	PE demand
----------------------------	---	-----------------------------------	----------------	----------------------------------	--------------------------------	------------------	-----------------------	-----------------------	-------------------	-------------------	----------------------------	----------------	-----------------------------	----------------------------	------------	-----------

Cooking:	22-Group office	0	1	250	5	0,25	313	0%					0,0	0	0
Electricity								0%					0	0	0
Dishwashing		0	1	250	5	0,10	125	45%					68,8	89	179
1-DHW connection													88	154	97
Refrigerating		0	1	365		0,70	256	100%					255,5	332	664
							0	100%					0,0	0	0
							0	100%					0,0	0	0
							0	100%					0,0	0	0
							0	100%					0,0	0	0
							0	100%					0,0	0	0
							0	100%					0,0	0	0
							0	100%					0,0	0	0
							0	100%					0,0	0	0
							0	100%					0,0	0	0
							0	100%					0,0	0	0
							0	100%					0,0	0	0
							0	100%					0,0	0	0
Total auxiliary electricity							859						858,8	1545,9	2233,0

Total							6892 kWh		73		87,8		6523 kWh/a	9063	17058 kWh
Specific demand									0,4		0,5		40 kWh/(m²a)	56	105 kWh

Aux Electricity

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Treated floor area	163	m ²	Heat recovery efficiency ventilation unit		0,81	Annual space heating demand		14	kWh/(m ² a)
Heating period	180	d	Operation vent. system Winter		4,32	Boiler rated power		17	kW
Air volume	544	m ³	Operation vent. system Summer		4,44	DHW system heating demand		795	kWh/a
Dwelling units	1	HH	Air change rate		0,24	Design forward flow temperature		50	°C

Column no.	1	2	3	4	5	6	7	8	9	10	11									
Application	Existing [1/0]	Within the thermal envelope [1/0]	Norm demand	Utilisation factor	Period of operation	Reference size	Electricity demand [kWh/a]	Available as interior heat	Utilisation period [h/a]	Internal heat gains winter [W]	Internal heat gains summer [W]									
Ventilation system																				
Winter ventilation	1		0,26	Wh/m ³	*	0,24	h ⁻¹	*	4,3	kh/a	*	544	m ³	=	149	considered in heat recovery efficiency				
Defroster HX	1	1	Data entries in 'Ventilation' worksheet or in 'Addl vent'									35								
Summer ventilation	0	0,55	0,00	Wh/m ³	*	0,00	h ⁻¹	*	4,4	kh/a	*	544	m ³	=	0					
Additional vent. summer	0		0,00	Wh/m ³	*	0,00	h ⁻¹	*	4,4	kh/a	*	544	m ³	=	0	Internal heat sources 'Additional summer ventilation'				
Heating system																				
Controlled / non controlled																				
Enter the rated power of the pump																				
Circulator pump heating	1	1	70	W	*	0,8	*	4,3	kh/a	*	1	=	231	*	1,0	/	4,32	=	54	
Boiler electricity consumption at 30% load																				
Aux. energy - Heat boiler	0	0	58	W	*	1,00	*	0,00	kh/a	*	1	=	0	*	1,0	/	4,32	=	0	
Aux. energy - Wood fired/Pellet boiler	1	0	Data entries in 'Boiler' worksheet. Aux. energy demand including possible drinking water production.									443	*	1,0	/	4,32	=	0		
DHW system																				
Enter average power consumption of pump																				
Circulation pump DHW	0		29	W	*	1,00	*	4,8	kh/a	*	1	=	0	*	1,0	/	8,76	=	0	0
Enter the rated power of the pump																				
Storage load pump DHW			57	W	*	1,00	*	0,0	kh/a	*	1	=	0	*	1,0	/	8,76	=	0	0
Boiler electricity consumption at 100% load																				
DHW boiler aux. energy	1	0	175	W	*	1,00	*	0,0	kh/a	*	1	=	0	*	1,0	/	8,76	=	0	0
Enter the rated power of the solar DHW pump																				
Solar aux. electricity	0		41	W	*	1,00	*	1,8	kh/a	*	1	=	0	*	1,0	/	8,76	=	0	0
Aux. electricity cooling and dehumidification																				
Aux. electricity cooling				kWh/a	*	1,00	*	1,0	*	1	=	0	*	1,0	/	4,44	=	0		
Aux. electricity dehum.				kWh/a	*	1,00	*	1,0	*	1	=	0	*	1,0	/	4,44	=	0		
Misc. aux. electricity																				
Misc. aux. electricity				kWh/a	*	1,00	*	1,0	*	1	=	0	*	1,0	/	8,76	=	0	0	
Total							859			55	0									
Specific demand	kWh/(m ² a) (treated floor area)						5,3													

Internal heat gains for residential buildings (at the moment this worksheet is inactive)

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Utilisation: 20-Office / Admin. building

IHG heating **3,50** W/m²

Type of values used: 2-Standard

IHG cooling **4,34** W/m²

No input is necessary

[Go to utilisation pattern selection](#)

Application	Existing [1/0] or occupancy	Within the thermal envelope [1/0]	Norm consumption	Utilisation factor	Frequency	Useful energy [kWh/a]	Included in electricity balance?	Availability	Utilisation period [h/a]	Internal heat gains [W]
Persons				10,0	P	Heating demand 14 kWh/(m ² a)				
Living area				163	m ²	Heating period 180 d/a				
Dishwashing	1	1	1,1 kWh/Use	1,00	65 /(P*a)	715 *		0,30 /	8,76	= 24
Clothes washing	1	1	1,1 kWh/Use	1,00	57 /(P*a)	627 *		0,30 /	8,76	= 21
Clothes drying with:	1	1	3,5 kWh/Use	0,88	57 /(P*a)	1746 *		0,70 /	8,76	= 139
4-Condensation dryer		1	0,0			0		0,80		= 0
Energy consumed by evaporation	0	1	-3,1 kWh/Use	0,60	57 /(P*a)	0 * (1- 0) *	0,00 /	8,76		= 0
Refrigerating	1	1	0,8 kWh/d	1,00	365 d/a	285 *		1,00 /	8,76	= 33
Freezing	1	1	0,9 kWh/d	1,00	365 d/a	321 *		1,00 /	8,76	= 37
or combination	0	1	1,0 kWh/d	1,00	365 d/a	0 *		1,00 /	8,76	= 0
Cooking	1	1	0,3 kWh/Use	1,00	500 /(P*a)	1250 *		0,50 /	8,76	= 71
Lighting	1	1	60,0 W	1,00	2,9 kh/(P*a)	1740 *		1,00 /	8,76	= 199
Consumer electronics	1	1	80,0 W	1,00	0,55 kh/(P*a)	440 *		1,00 /	8,76	= 50
Household appliances/Other	1	1	50,0 kWh	1,00	1,0 /(P*a)	500 *		1,00 /	8,76	= 57
Auxiliary appliances (cf. aux Electricity sheet)										= 55
Other applications (cf. Electricity sheet)	0	0,0				0 *	0 /	8,76		= 0
Persons	10	1	80,0 W/P	1,00	8,76 kh/a	7008 *	0,55 /	8,76		= 440
Cold water	10	1	-11,4 W/P	1,00	8,76 kh/a					= -114
DHW - circulation	0	0	0,0 W	1,00	8,76 kh/a	0 *	1,00 /	8,76		= 0
DHW - individual pipes	1	1	0,0 W	1,00	8,76 kh/a	0 *	1,00 /	8,76		= 0
DHW storage tank heating case	1	0	0,0 W	1,00	8,76 kh/a	0 *	1,00 /	8,76		= 0
DHW storage tank cooling case	1	0	0,0 W	1,00	8,76 kh/a	0 *	1,00 /	8,76		= 0
Evaporation	10	1	-25,0 W/P	1,00	8,76 kh/a	-2190 *	1,00 /	8,76		= -250
Total IHG									W	763
Specific IHG									W/m ²	4,68
Heat available from internal sources									180 d/a kWh/(m ² a)	20,2

Internal heat gains for non residential buildings (at the moment this worksheet is inactive)

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Utilisation: 20-Office / Admin. building

IHG **3,50** W/m²

Type of values used: 2-Standard

No input is necessary **5,87** W/m²

Persons		Persons: 10,0 P		Treated floor area: 163 m²		Heating period: 180 d/a		Room temperature: 20 °C		Internal heat gains aux. electricity: 55 W															
Selection of user profile	Select	Activity of persons	Planning 0 = according to ground area or usable zone 1 = according to occupancy	Number of occupants	Ground area of useful zone [m²]	Average occupancy [Pers./m²]	Heat emitted per person [W]	Utilisation hours per year [h/a]	Relative presence	Utilisation period [h/a]	Average heat release persons [W]														
Persons A		Invalid input		{ }*	{ }	27 Not a standard value	0	9	1,00	8760	0														
Persons B		Invalid input		{ }*	{ }	Not a standard value	0	0	1,00	8760	0														
Persons C		Invalid input		{ }*	{ }	Not a standard value	0	0	1,00	8760	0														
Persons D		Invalid input		{ }*	{ }	Not a standard value	0	0	1,00	8760	0														
Persons E		Invalid input		{ }*	{ }	Not a standard value	0	0	1,00	8760	0														
Persons F		Invalid input		{ }*	{ }	Not a standard value	0	0	1,00	8760	0														
Persons G		Invalid input		{ }*	{ }	Not a standard value	0	0	1,00	8760	0														
Evaporation (person specific)				0				0	1,00	8760	0														
Lighting / Equipment / Aux. electricity		Useful energy [kWh/a]		Availability		Utilisation period [h/a]		Average heat release																	
Lighting		2251	1	8,76	257																				
Office applications (within therm. envelope)		3089	1	8,76	353																				
Cooking (within therm. envelope)		0	0,5	8,76	0																				
Dishwashing (within therm. envelope)		0	0,3	8,76	0																				
Cooling (within therm. envelope)		0	1	8,76	0																				
Other (within thermal envelope)		0	1	8,76	0																				
Auxiliary appliances (see 'Aux Electricity' worksheet)					55																				
Heat loss due to cold water (calculation from column AJ)		On/Off [1 / 0]		Predominant utilisation pattern of building (Data transferred from 'Electricity non-res' worksheet; input)		Number of WCs (user data)		Amount of WCs: Utilisation of standard values for schools?		Number of WCs (calculation value)		DT: Cold water temp. - Room temp. [K]		Occupied days per year [d/a]		Loss daytime [W]		Loss night-time [W]		Availability		Utilisation period [d/a]		Average power cold water	
Cold water due to flushing WC		22	Group office			0	-6,7	250	-13	-2	1	365	0												
Total IHG													W	665											
Specific IHG													W/m²	4,1											
Heat available from internal sources						180	d/a						kWh/(m²a)	18											

Primary Energy Renewable PER

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Selection of heat generation system Primary heat generator Heating boiler Secondary heat generator (optional)		<table border="1"> <tr> <th colspan="2">Contribution margin (useful energy)</th> </tr> <tr> <th>Heating</th> <th>DHW</th> </tr> <tr> <td>100%</td> <td>100%</td> </tr> <tr> <td>0%</td> <td>0%</td> </tr> </table>	Contribution margin (useful energy)		Heating	DHW	100%	100%	0%	0%	Addl. input in following worksheets Boiler	Heating demand incl. distribution & hydr. frost protection Cooling energy dem. incl. dehumidification DHW demand including distribution:	Building type: Treated floor area A _{TFA} : 163 m² Projected building footprint A _{projected} : 98 m² 17 kWh/(m²a) 5 kWh/(m²a)
Contribution margin (useful energy)													
Heating	DHW												
100%	100%												
0%	0%												


Reference: Treated floor area	Final energy		PER			PE		CO ₂		
	Contribution (final energy)	Final energy demand	PER factor	Effective PER factor (including biomass)	PER specific value	PE factor	PE Value	CO ₂ emissions factor (CO ₂ -eq)	CO ₂ -eq emissions	
		kWh/(m²a)	kWh/kWh	kWh/kWh	kWh/(m²a)	kWh/kWh	kWh/(m²a)	kg/kWh	kg/(m²a)	
						90,9	109,5	22,0		
Heating						1,32	35,2	0,67	18,0	3,3
Electricity (HP compact unit)			1,80			2,60		0,532		
Electricity (heat pump)			1,80			2,60		0,532		
District heating: 20-Gas CGS 70% PHC			2,8 4,5 3,3			0,70		-0,070		
Pelletefeuerung indirekt: 50-Pellets	100%	21,5	1,10	1,20	25,7	0,20	4,3	0,025	0,5	
Natural gas / RE gas			1,75			1,10		0,250		
Heating oil / RE methanol			2,30			1,10		0,320		
Solar thermal system										
Electricity (direct through DHW storage tank)			1,80			2,60		0,532		
Electricity (direct through heating resistance)			1,80			2,60		0,532		
Aux. electricity (vent.winter, frost protection, circ.pump, boiler, wood / pellets)		5,3	1,80	1,80	9,5	2,60	13,7	0,532	2,8	
Cooling and dehumidification						0,0	0,0		0,0	
Electricity cooling (heat pump)			1,10			2,60		0,532		
Auxiliary electricity cooling, ventilation summer			1,10			2,60		0,532		
Electricity dehumidification (heat pump)			1,15			2,60		0,532		
Auxiliary electricity (dehumidification)			1,15			2,60		0,532		
DHW generation						1,75	10,5	0,20	1,2	0,1
Electricity (HP compact unit)			1,30			2,60		0,532		
Electricity (heat pump)			1,30			2,60		0,532		
District heating: 20-Gas CGS 70% PHC			2,8 4,5 3,3			0,70		-0,070		
Pelletefeuerung indirekt: 50-Pellets	100%	6,0	1,10	1,75	10,5	0,20	1,2	0,025	0,1	
Natural gas / RE gas			1,75			1,10		0,250		
Heating oil / Methanol			2,30			1,10		0,320		
Solar thermal system										
Electricity (direct)			1,30			2,60		0,532		
Aux. electricity (circ.pump + storage charge, aux.energy DHW + solar DHW)			1,30			2,60		0,532		
Household electricity						34,8	45,2	90,4	18,5	
Electricity (household or non-residential lighting, etc.)		34,8	1,30	1,30	45,2	2,60	90,4	0,532	18,5	
Auxiliary electricity (other)			1,30			2,60		0,532		
Gas / RE gas dry/cook						0,0	0,0	0,270	0,0	

Reference: Projected building footprint area	Final energy		PER		PE		CO ₂	
	Final energy generation	Final energy generation	PER factor	PER specific value	PE factor	PE Value	Emission factor (CO ₂ -eq)	CO ₂ -eq emissions
	kWh/a	kWh/(m² _{projected} a)	kWh/kWh	kWh/(m² _{projected} a)	kWh/kWh	kWh/(m²a)	kg/kWh	kg/a
				70,4		0,0		895,1
PV electricity	6885	70,4	1,00	70,4	0,0	0,0	0,130	895,1
Solar thermal system	0	0,0	1,00	0,0	1,2	0,0		

PE demand requirement in case of verification through PE (non-renewable) [kWh/(m²a)]	120	Current building reaches following class for aspect	110	Requirement met?	yes
--	-----	---	-----	------------------	-----

Achievable energy standard through the verification of renewable primary energy (assessment of individual aspects)	Useful energy, performance				Airtightness P ₅₀ 1/h
	Annual heat. dem. Treated floor area	Heating load Treated floor area	Useful cool. energy Treated floor area	Cooling load Treated floor area	
	kWh/(m²a)	W/m²	kWh/(m²a)	W/m²	
Requirement EnerPHit Premium					1,00
Requirement EnerPHit Plus					
Requirement EnerPHit Classic					
Requirement					1,0
Current building reaches following class for aspect	14	Premium	19	Unachieved	Premium

Summary	Final energy		PER specific value	PE Value	CO ₂ eq emissions	CO ₂ eq substitution balance
	MWh/a	MWh/a				
Though, from the scientific point of view, not entirely correct, different energy carriers will be added together here. This is done to meet the criteria of other energy standards such as Effizienzhaus Plus.				1-PE-factors (non-renewable) PHI Certification MWh/a	1-CO ₂ factors GEMIS (Germany) kg/a	1-CO ₂ factors GEMIS (Germany) kg/a
Demand	11,0	14,8		17,86	3582	3582
Generation	-6,9	-6,9		0,00	87528	-2768
Demand, cumulative generation (annual balance)	4,11	7,93		17,86	91111	815
Demand w/o household electricity	5,3	7,5		3,13	569	569
Demand w/o household electricity, cum. generation	-1,55	0,57		3,13	88097	-2199



Passive House compact unit with exhaust air heat pump

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Calculation based on measured values of the laboratory evaluation for component certification

Building type:			
Treated floor area A _{TFA} :	163	m ²	
Covered fraction of space heating demand	(PER worksheet)	0%	
Space heating demand + distribution losses	Q _{s+Q_{dist}} : (DHW+Distribution)	2843	kWh
Solar contribution for space heating	η _{Solar, SH} (Solar/DHW worksheet)	0%	
Effective annual heating demand	Q _{N,SH} =Q _s ·(1-η _{Solar, SH})	0	kWh
Covered fraction of DHW demand	(PER worksheet)	0%	
Total heating demand of DHW system	Q _{DHW} : (DHW+Distribution)	722	kWh
Solar contribution for DHW	η _{Solar, DHW} (Solar/DHW worksheet)	0%	
Effective DHW demand	Q _{DHW,eff} =Q _{DHW} ·(1-η _{Solar, DHW})	0	kWh
Sort: AS LIST			
Compact unit selection:		Go to list of compact units	
Measured values from laboratory test			
Ventilation			
Effective heat recovery efficiency	η _{SH} (Test stand)		
Electric efficiency	(Test stand)		Wh/m ³
Heating			
Outdoor air temperature	T _{amb}	Test point 1	Test point 2
Measured thermal power heat pump Heating	P _{HP, Heating}	Test point 3	Test point 4
Measured COP Heating	COP _{Heating}		
Domestic hot water			
Outdoor air temperature	T _{amb}	Test point 1	Test point 2
Measured thermal power DHW storage heating-up	P _{DHW, Heating-Up}	Test point 3	Test point 4
Measured thermal power DHW storage reload	P _{DHW, Reload}		
Measured COP DHW storage heating-up	COP _{DHW, Heating-Up}		
Measured COP DHW storage reload	COP _{DHW, Reload}		
Standby (inputs required only if different from storage reload)			
Outdoor air temperature	T _{amb}	Test point 1	Test point 2
Measured thermal power heat pump Standby	P _{HP, Standby}	Test point 3	Test point 4
Measured COP Standby	COP _{Standby}		
Specific heat loss storage incl. connections	U · A _{storage} (Test stand)		W/K
Average storage temperature in standby mode	T _{DHW, Standby} (Test stand)		°C
Heat pump priority	separate heat pumps	DHW priority	Heating priority
Room temperature (°C)	20		
Av. ambient temp. Heating P. (°C)	8		
Av. Ground temp (°C)	13		
Efficiency SHX exhaust air mixing	η _{SHX}		0%
Heat recovery efficiency SHX exhaust air mixing (if applicable)	η _{SHX, add} (Design Value)		0%
Volume flow rate of added exhaust air (if applicable)	V _{add} (Test stand)		m ³ /h
Hydraulic frost protection			
Heat supplied by direct electricity	Q _{E, dir}		kWh/a
Space heat supplied by HP	Q _{HP, Heating}		kWh/a
Winter DHW supplied by HP	Q _{HP, DHW, Winter}	0	kWh/a
Winter standby heat supplied by HP	Q _{HP, Standby, Winter}		kWh/a
Summer DHW supplied by HP	Q _{HP, DHW, Summer}	0	kWh/a
Summer standby heat supplied by HP	Q _{HP, Standby, Summer}		kWh/a
Performance factor of heat generator, DHW & space heating	SPF _{T13}		
Seasonal performance factor			
Final energy demand heat generation	Q _{fuel}		kWh/a
Annual PE demand (non-renewable primary energy)			kWh/(m ² a)
Annual CO ₂ -equivalent emissions			kg/a

Including DHW connection for washing machines & dishes

795 kWh
0%

0 kWh

kWh/a
kWh/a
0 kWh/a
kWh/a
0 kWh/a
kWh/a

kWh/a kWh/(m²a)

kg/a kg/(m²a)

Heat pump

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

		Building type:	
		Treated floor area A _{TFA} :	163 m ²
Covered fraction of space heating demand	(<i>'PER' worksheet</i>)		0%
Space heating demand + distribution losses	$Q_{H1}+Q_{HL}$ (<i>DHW+Distribution</i>)		2843 kWh/a
Solar fraction for space heat	$\eta_{Solar, H}$ (<i>'SolarDHW' worksheet</i>)		0%
Effective annual heating demand	$Q_{H,WI}=Q_{H1}*(1-\eta_{Solar, H})$		0 kWh/a
Covered fraction of DHW demand	(<i>'PER' worksheet</i>)		0%
Total heating demand of DHW system	Q_{gDHW} (<i>DHW+Distribution</i>)		471 kWh/a
Solar fraction for DHW	$\eta_{Solar, DHW}$ (<i>'SolarDHW' worksheet</i>)		0%
Effective DHW demand	$Q_{DHW,WI}=Q_{DHW}*(1-\eta_{Solar, DHW})$		0 kWh/a
Number of heat pumps in the system			1
Functionality			Heating & DHW
Heating			
Selection of HP:	2-Standard brine/water heat pump	Heat source:	3-Ground probes
Selection of distribution system			3-Supply air heating
Design distribution temperature		θ_{design} (<i>DHW+Distribution</i>)	55,00 °C
Nominal power of distribution system		P_{nom}	0,00 kW
Distribution system (to be completed by experienced users only)			
Nominal power of distribution system		P_{nom}	
Radiator exponent		n	
Heat storage tank (buffer storage tank 'DHW+Distribution' worksheet)			0-No
Specific heat losses storage	$U * A_{Storage}$		W/K
Storage location in thermal envelope			2-Outside
Room temperature (storage location: outside of thermal envelope)	(<i>DHW+Distribution</i>)		°C
Sink temperature of heat pump for heating	θ_{sink}		61,50 °C
Entries in relation to the domestic hot water system			
Selection of HP:	0-None	Heat source:	
DHW temperature		(<i>DHW+Distribution</i>)	60,00 °C
Orientation of DHW storage tank ('storage 1' in 'DHW+Distribution' worksheet)			2-Outside
Specific heat losses storage	$U * A_{Storage}$		W/K
Room temperature (storage location: outside of thermal envelope)	(<i>DHW+Distribution</i>)		12,30 °C
Type of backup heater			
$\Delta\theta$ of electric continuous flow water heater			K
Additional options in case of one heat pump for both functions: Heating & DHW			
Same heat pump's sink temperature for Heating and for DHW			1-Yes
Heat pump priority	(<i>Manufacturer, tech. data</i>)		
Control strategy			
Heat pump control strategy			
Heating			
Depth ground water / Ground collector / Ground probe		z	m
Power of pump for ground heat exchanger		P_{pump}	kW

Heating

Heat pump:

Source:

	θ_{source} °C	θ_{sink} °C	Heating capacity kW	COP
Test point 1	-5,0	35,0	5,3	3,7
Test point 2	0,0	35,0	6,0	4,3
Test point 3	5,0	35,0	6,7	4,9
Test point 4	-5,0	50,0	5,1	2,6
Test point 5	0,0	50,0	5,9	3,0
Test point 6	5,0	50,0	6,5	3,4
Test point 7				
Test point 8				
Test point 9				
Test point 10				
Test point 11				
Test point 12				
Test point 13				
Test point 14				
Test point 15				

Temperature difference in sink $\Delta\theta_{\text{Sink}}$ K

DHW

Heat pump:

Source:

	θ_{source} °C	θ_{sink} °C	Heating capacity kW	COP
Test point 1	-5,0	35,0	5,3	3,7
Test point 2	0,0	35,0	6,0	4,3
Test point 3	5,0	35,0	6,7	4,9
Test point 4	-5,0	50,0	5,1	2,6
Test point 5	0,0	50,0	5,9	3,0
Test point 6	5,0	50,0	6,5	3,4
Test point 7				
Test point 8				
Test point 9				
Test point 10				
Test point 11				
Test point 12				
Test point 13				
Test point 14				
Test point 15				

Temperature difference in sink $\Delta\theta_{\text{Sink}}$ K

- Electr. energy consumption pump (grnd. water / ground)
- Energy by direct electricity
- Space heat supplied by HP
- Winter DHW supplied by HP
- Summer DHW supplied by HP
- Space heating supplied by HP without storage losses
- Winter DHW supplied by HP without storage losses
- Summer DHW supplied by HP without storage losses
- Electrical consumption of HP

- $Q_{\text{El,Pump}}$
- $Q_{\text{El,dir}}$
- $Q_{\text{HP,Heating}}$
- $Q_{\text{HP,DHW,Winter}}$
- $Q_{\text{HP,DHW,Summer}}$
- $Q_{\text{HP,Heating}}$
- $Q_{\text{HP,DHW,Winter}}$
- $Q_{\text{HP,DHW,Summer}}$
- $Q_{\text{el,HP}}$

<input type="text" value="0"/>	kWh/a
<input type="text" value="0"/>	kWh/a
<input type="text" value="0"/>	kWh/a
<input type="text" value="0"/>	kWh/a
<input type="text" value="0"/>	kWh/a
<input type="text" value="0"/>	kWh/a
<input type="text" value="0"/>	kWh/a
<input type="text" value="0"/>	kWh/a
<input type="text" value="0"/>	kWh/a

Seasonal performance factor of heat pump

SPF_{H-1}

1. HP: Heating or heating & DHW

kWh/a

2. HP: Domestic hot

kWh/(m²a)

Final electrical energy demand heat generation

Q_{final}

Annual primary energy demand

kg/a

kg/(m²a)

Annual CO₂-equivalent emissions

Heat pump ground (ground collectors / ground probes)

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

Building type:
 Treated floor area A_{TFA}: m²

Ground probes

Probe field configuration (HP worksheet)

H	Individual probe	<input type="text" value="0"/>	m
B		<input type="text"/>	m
z		<input type="text" value="0"/>	m

Type of probe

A	Double-U
---	----------

Borehole radius

r _b	<input type="text"/>	m
----------------	----------------------	---

Inner radius of pipe

r _i	<input type="text"/>	m
----------------	----------------------	---

Exterior pipe radius

r _a	<input type="text"/>	m
----------------	----------------------	---

Distance between pipes

B _U	<input type="text"/>	m
----------------	----------------------	---

Inner radius of pipe casing (only coaxial)

r _{i2}	<input type="text"/>	m
-----------------	----------------------	---

Exterior radius casing pipe (only coaxial)

r _{a2}	<input type="text"/>	m
-----------------	----------------------	---

Thermal conductivity of pipe

λ _R	<input type="text"/>	W/(mK)
----------------	----------------------	--------

Thermal conductivity of back fill

λ _F	<input type="text"/>	W/(mK)
----------------	----------------------	--------

Probe time constant

t _p	<input type="text" value="0"/>	d
----------------	--------------------------------	---

Internal borehole resistance

R _a	<input type="text"/>	Km/W
----------------	----------------------	------

Borehole resistance

R _b	<input type="text"/>	Km/W
----------------	----------------------	------

Ground

Soil type

A	Sand, 9% moisture
---	-------------------

Density of the ground

ρ _E	<input type="text" value="1440"/>	kg/m ³
----------------	-----------------------------------	-------------------

Thermal capacity of ground

c _{pE}	<input type="text" value="1507"/>	J/(kgK)
-----------------	-----------------------------------	---------

Thermal conductivity of ground

λ _E	<input type="text" value="1,0"/>	W/(mK)
----------------	----------------------------------	--------

Soil temperature conductivity

a _E	<input type="text" value="4,516E-07"/>	m/s ²
----------------	--	------------------

Ground temperature gradient

ΔT _{IG}	<input type="text" value="0,022"/>	K/m
------------------	------------------------------------	-----

Brine

Brine (characteristics at 2 °C)

A	Ethylene glycol 25%
---	---------------------

Density of the brine

ρ _S	<input type="text" value="1052"/>	kg/m ³
----------------	-----------------------------------	-------------------

dynamic viscosity of the brine

η _S	<input type="text" value="0,0052"/>	kg/(ms)
----------------	-------------------------------------	---------

Heat capacity brine

c _{pS}	<input type="text" value="3950"/>	J/(kgK)
-----------------	-----------------------------------	---------

Thermal conductivity of brine

λ _S	<input type="text" value="0,48"/>	W/(mK)
----------------	-----------------------------------	--------

Brine - mass flow

m _S	<input type="text"/>	kg/s
----------------	----------------------	------

Operation type

Waste heat from active cooling to ground probe? Please check, if applicable.

Heat pump operation duration

<input type="text"/>	h/a
----------------------	-----

Specific heat extraction rate as an annual average

q _{ex}	<input type="text"/>	W/m
H/R _b	<input type="text"/>	W/K

Ground collectors

Inner radius of pipe

r _i	<input type="text"/>	m
----------------	----------------------	---

Exterior pipe radius

r _a	<input type="text"/>	m
----------------	----------------------	---

Thermal conductivity of pipe

λ _P	<input type="text"/>	W/(mK)
----------------	----------------------	--------

Pipe depth

Z _{pipe}	<input type="text" value="0"/>	m
-------------------	--------------------------------	---

Ground water depth

Z _{gw}	<input type="text"/>	m
-----------------	----------------------	---

Pipe spacing

D	<input type="text"/>	m
---	----------------------	---

Base area

<input type="text"/>	m ²
----------------------	----------------

Pipe outer surface

<input type="text" value="#DIV/0!"/>	m ²
--------------------------------------	----------------

Pipe length

L	<input type="text" value="#DIV/0!"/>	m
---	--------------------------------------	---

Brine

Brine (characteristics at 2 °C)

A	Ethylene glycol 25%
---	---------------------

Density of the brine

ρ _S	<input type="text" value="1052"/>	kg/m ³
----------------	-----------------------------------	-------------------

dynamic viscosity of the brine

η _S	<input type="text" value="0,0052"/>	kg/(ms)
----------------	-------------------------------------	---------

Heat capacity brine

c _{pS}	<input type="text" value="3950"/>	J/(kgK)
-----------------	-----------------------------------	---------

Thermal conductivity of brine

λ _S	<input type="text" value="0,48"/>	W/(mK)
----------------	-----------------------------------	--------

Brine - mass flow

m _S	<input type="text"/>	kg/s
----------------	----------------------	------

Specific heat extraction rate

q _{ex}	<input type="text"/>	W/m ²
-----------------	----------------------	------------------

U * A

<input type="text"/>	W/K
----------------------	-----

Climate

Period duration

<input type="text" value="365"/>	d
----------------------------------	---

Average ground surface temp.

T _{m0}	<input type="text" value="13,3"/>	°C
-----------------	-----------------------------------	----

Surface temperature amplitude

T ₁	<input type="text" value="7,6"/>	°C
----------------	----------------------------------	----

Phase shifting surface

t ₀₂	<input type="text" value="33"/>	d
-----------------	---------------------------------	---

Ground characteristics

	Thermal conductivity [W/(mK)]	Density [kg/m ³]	Heat capacity [J/(kg K)]	Heat capacity [MJ/(m ³ K)]	Thermal conductivity [10 ⁻⁷ m ² /s]	Source
A	0,980	1440	1507	2,170	4,520	[NeiB 1977]
B	1,500	1600	1800	2,880	5,210	[NeiB 1977]
C	0,520	2000	1840	3,680	1,410	[VDI 1984]
D	2,300	1650	2847	4,700	4,900	[NeiB 1977]
E	1,280	1500	880	1,320	9,700	[VDI 1984]
F	2,200	2550	882	2,250	9,780	[VDI 2000]
G	2,100	2700	870	2,350	8,940	[VDI 2000]
H	1,500	1920	2938	5,640	2,660	[ISO 13370]
I	3,500	2500	2500	6,250	5,600	[ISO 13370]
J	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	

Result ground probe calculation

Month	Borehole temperature °C
1	<input type="text"/>
2	<input type="text"/>
3	<input type="text"/>
4	<input type="text"/>
5	<input type="text"/>
6	<input type="text"/>
7	<input type="text"/>
8	<input type="text"/>
9	<input type="text"/>
10	<input type="text"/>
11	<input type="text"/>
12	<input type="text"/>

Properties of the brine

	Temperature [°C]	Density [kg/m ³]	Heat capacity [J/(kg K)]	Thermal conductivity [W/(mK)]	Dynamic viscosity [kg/(ms)]
A	2	1052	3950	0,480	0,0052
B	2	1265	2941	0,544	0,0031
C	2	1226	3190	0,534	0,00237
D	2	997	4190	0,590	0,001307
E	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>

Boiler (gas, oil and wood)

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13.8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90.9 kWh/(m²a)

Building type:		
Treated floor area A _{TFA} :	163	m ²
Covered fraction of space heating demand (<i>'PER' worksheet</i>)	100%	
Space heating demand + distribution losses Q _H +Q _{HS} : (DHW+Distribution)	2843	kWh
Solar contribution for space heating η _{Solar, H} (<i>'SolarDHW' worksheet</i>)	0%	
Effective annual heating demand Q _{H,W} =Q _H *(1-η _{Solar, H})	2843	kWh
Space heating demand without distribution losses Q _H (<i>'Verification' worksheet</i>)	2245	kWh
Covered fraction of DHW demand (<i>'PER' worksheet</i>)	100%	
Total heating demand of DHW system Q _{DHW} (DHW+Distribution)	795	kWh
Solar contribution for DHW η _{Solar, DHW} (<i>'SolarDHW' worksheet</i>)	0%	
Effective DHW demand Q _{DHW, W} =Q _{DHW} *(1-η _{Solar, DHW})	795	kWh

Boiler type	32-Wood pellets (only indirect heat emission)	
Fuel	50-Pellets	
PER factors (renewable primary energy) (<i>'Data' worksheet</i>)	1,10	kWh _{PER} /kWh _{Final}
PE factor (non-renewable primary energy) (<i>'Data' worksheet</i>)	0,20	kWh _{PE} /kWh _{Final}
CO ₂ emissions factor (CO ₂ -equivalent) (<i>'Data' worksheet</i>)	0,025	g/kWh
Useful heat provided Q _{Use}	3638	kWh/a
Max. heating power required for heating the building P _{BH} (<i>'Heating load' worksheet</i>)	3,14	kW
Length of the heating period t _{HP}	4316	h
Length of DHW heating period t _{DHW}	8760	h

Use characteristic values entered (check if appropriate)? x

	Project data	Standard values	Input field
Design output P _{nom} (Rating plate)	17 kW	15 kW	17
Installation of boiler (Outdoor: 0, Indoor: 1)	0	0	0
Input values (oil and gas boiler)			
Boiler efficiency at 30% load η _{30%} (Manufacturer)			
Boiler efficiency at nominal output η _{100%} (Manufacturer)			
Standby heat loss boiler at 70 °C q _{8,70} (Manufacturer)			
Average return flow temperature measured at 30% load θ _{30%} (Manufacturer)			
Input values (biomass heat generator)			
Efficiency of heat generator in basic cycle η _{GZ} (Manufacturer)	81%	77%	81%
Efficiency of heat generator in steady-state operation η _{SO} (Manufacturer)	86%	80%	86%
Average fraction of heat output released to heating circuit z _{HC,m} (Manufacturer)	1,0	1,0	
Temperature difference betw. power-on and power-off Δθ (Manufacturer)	10 K	10 K	
In case of inside installation: area of installation room A _{inst,al} (Project)	0 m ²	0 m ²	
Useful heat output per basic cycle Q _{N,GZ} (Manufacturer)	15,3 kWh	15,3 kWh	
Average power output of the heat generator Q _{N,m} (Manufacturer)	8,5 kW	8,5 kW	
Heat generator with built in conveyor for pellets Unit only with regulation (no fan / no starting aid)			
Auxiliary energy demand for a basic cycle Q _{HE,GZ} (Manufacturer)	0,53 kWh	0,53 kWh	
Power consumption in steady-state operation P _{el,SB} (Manufacturer)	265 W	265 W	
Utilisation factor of heat generator space heating η _{H,g,K} = f ₁ *h _K	81%		
Utilisation factor heat generator DHW η _{DW,g,K} = h _{100%}/f_{1,DW}}	81%		
Utilisation factor heat generator DHW & space heating η _{g,K}	81%		
Final energy demand space heating Q _{Final,HE} = Q _{H,w} * e _{H,g,K}	3497 kWh/a	kWh/(m ² a)	
Final energy demand DHW Q _{Final,TW} = Q _{DHW,w} * e _{TW,g,K}	978 kWh/a		
Total final energy demand Q _{Final} = Q _{End,HE} + Q _{End,TW}	4475 kWh/a	27,5 kg/(m ² a)	
Annual PE demand (non-renewable primary energy)	895 kWh/a	5,5 kg/(m ² a)	
Annual CO₂-equivalent emissions	112 kg/a	0,7 kg/(m ² a)	

District heating and combined heat power (CHP)

Archipente / Climate: Montbrison1314 / TFA: 163 m² / Heating: 13,8 kWh/(m²a) / Freq. overheating: 5 % / PER: 90,9 kWh/(m²a)

	Building type: <input style="width: 100%;" type="text"/>	
	Treated floor area A _{TFA} : <input style="width: 50px; text-align: center; border: 1px solid black;" type="text" value="163"/> m ²	
Covered fraction of space heating demand	(<i>PER worksheet</i>)	<input style="width: 50px; text-align: center; border: 1px solid black;" type="text" value="0%"/>
Annual heating demand kWh/a	Q _H (DHW+Distribution)	<input style="width: 50px; text-align: center; border: 1px solid black;" type="text" value="2843"/> kWh
Solar contribution for space heating	η _{Solar, H} (<i>SolarDHW worksheet</i>)	<input style="width: 50px; text-align: center; border: 1px solid black;" type="text" value="0%"/>
Effective annual heating demand	Q _{H, WI} = Q _H * (1 - η _{Solar, H})	<input style="width: 50px; text-align: center; border: 1px solid black;" type="text" value="0"/> kWh
Covered fraction of DHW demand	(<i>PER worksheet</i>)	<input style="width: 50px; text-align: center; border: 1px solid black;" type="text" value="0%"/>
DHW demand	Q _{DHW} (DHW+Distribution)	<input style="width: 50px; text-align: center; border: 1px solid black;" type="text" value="795"/> kWh
Solar contribution for DHW	η _{Solar, DHW} (<i>SolarDHW worksheet</i>)	<input style="width: 50px; text-align: center; border: 1px solid black;" type="text" value="0%"/>
Effective DHW demand	Q _{DHW, WI} = Q _{DHW} * (1 - η _{Solar, DHW})	<input style="width: 50px; text-align: center; border: 1px solid black;" type="text" value="0"/> kWh

	PE factor (non-renewable)	CO₂ emissions factor (CO₂-eq)
Definition of heat source for PE factor and CO ₂ emissions	<input style="width: 100%;" type="text" value="20-Gas CGS 70% PHC"/>	kWh _{PE} /kWh _{Final} kg/kWh
		0,70 -0,070

Definition of heat source for calculation of PER factor	Heat net	Efficiency district heating net
		<input style="width: 100%;" type="text" value=""/>

PHC complex & boiler for peak loads	<table border="1" style="width: 100%; border-collapse: collapse; text-align: center;"> <thead> <tr> <th style="width: 25%;">Fraction</th> <th style="width: 25%;">Efficiency Electricity</th> <th style="width: 50%;">Heat</th> </tr> </thead> <tbody> <tr> <td style="background-color: #ffffcc;">PHC complex</td> <td style="background-color: #ffffcc;"></td> <td style="background-color: #ffffcc;"></td> </tr> <tr> <td style="background-color: #ffffcc;">Boiler for peak loads</td> <td style="background-color: #ffffcc;">100%</td> <td style="background-color: #ffffcc;"></td> </tr> <tr> <td style="background-color: #ffffcc;">Total</td> <td style="background-color: #ffffcc;">100%</td> <td style="background-color: #ffffcc;"></td> </tr> </tbody> </table>	Fraction	Efficiency Electricity	Heat	PHC complex			Boiler for peak loads	100%		Total	100%			
Fraction	Efficiency Electricity	Heat													
PHC complex															
Boiler for peak loads	100%														
Total	100%														
		Within biomass budget	PER factors PER factors	1,10 2,80											
		Excess of biomass budget	PER factors PER factors	1,80 4,50											
		DHW Summer	PER factors PER factors	1,30 3,30											

Performance ratio of heat transfer station	η _{a, HX}	<input style="width: 100%;" type="text" value=""/>
Utilisation factor of heat transfer station	η _{a, SHX}	<input style="width: 50px; text-align: center; border: 1px solid black;" type="text" value="0%"/>

Final energy demand heat generation	Q _{Final} = Q _{Use} * e _{a, DH}	kWh/a	kWh/(m ² a)
		0	0,0
Annual PE demand (non-renewable primary energy)		0	0,0
		kg/a	kg/(m ² a)
Annual CO ₂ -equivalent emissions		0	0,0

Table of PER and PE factors as well as CO ₂ -equivalent emission factors of different energy carriers and uses from different sources				
Energy type	Number	Energy carrier	Transfer to 'PER' works	
			PER-factor	1-PE-factors (non-renewable) PHI Certification
			$\frac{kWh_{prim-el}}{kWh_{final}}$	$\frac{kWh_{prim}}{kWh_{final}}$
	10	None		
Fuel source	20	Heating oil	2,30	1,10
	30	Natural gas	1,75	1,10
	31	LPG	1,75	1,10
	41	Hard coal	2,30	1,10
	42	Brown coal	2,30	1,20
	32	Biogas	1,10	1,10
	21	Pyrolysis oil or bio oil	1,10	1,10
	43	Wood	1,10	0,20
	44	Wood logs	1,10	0,20
	50	Pellets	1,10	0,20
	46	Forest woodchips	1,10	0,20
	47	Poplar woodchips	1,10	0,20
	33	RE-Gas	1,75	
	22	RE-Methanol	2,30	
	48	Biomass	1,10	
Electricity	60	Electricity-mix		2,60
	61	Electricity mix from CHC		2,50
	00	Primary electricity	1,00	
	01	Household electricity	1,30	2,60
	02	Electricity for DHW	1,30	2,60
	03	Electricity for heating	1,80	2,60
	04	Electricity for cooling	1,10	2,60
	05	Electricity for dehumidification	1,15	2,60
	06	Platzhalter_EE-Stromanwendung	-	2,60
	62	Electricity from photovoltaics	1,00	0,00
	63	Monocrystalline photovoltaic electric	1,00	0,00
	64	Polycrystalline photovoltaic electric	1,00	0,00
	65	Onshore wind power	1,00	0,00
	66	Offshore wind power	1,00	0,00
67	Hydroelectric power station > 10MW	1,00	0,00	
Environmental energy, solar thermal energy	71	Ground heat, geothermal energy	0,00	0,00
	72	Ambient high temperature	0,00	0,00
	73	Ambient low temperature	0,00	0,00
	80	Solar thermal flat plate collector (ger	1,00	0,00
	81	Solar thermal evacuated tube collect	1,00	0,00
74	Waste heat	0,00	0,00	
User defined energy carrier (for generation, please enter user defined factors for demand in columns N and O)	98	Eigener Energieträger		
	99			
District heat	1	1-None		0,00
	10	10-Hard coal CGS 70% PHC		0,80
	11	11-Hard coal CGS 35% PHC		1,10
	12	12-Hard coal CGS 0% PHC		1,50
Gas CGS	20	20-Gas CGS 70% PHC	Calculation in 'District heating' worksheet	0,70
	21	21-Gas CGS 35% KWK		1,10
	22	22-Gas HS 0% PHC		1,50
Heating oil-EL CGS	30	30-Oil CGS 70% PHC		0,80
	31	31-Oil CGS 35% PHC		1,10
	32	32-Oil CGS 0% PHC		1,50
District heating: User determined	40	40-Eigene Eingabe: 90% KWK		0,80
District heating combined heat power (CHP)	13	Fossil fuel		0,70
District heating from heating station	14	Renewable fuel		0,00
	15	Fossil fuel		1,30
	16	Renewable fuel		0,10

Heat generator	No.	Type	Fuel ('Comparison' worksheet)	x) Gas will be used	
	1	1-None			
	10	10-Improved gas condensing boiler		1	x
	11	11-Improved oil condensing boiler		2	
	12	12-Gas condensing boiler		1	x
	13	13-Oil condensing boiler		2	
	20	20-Low temperature boiler gas		1	x
	21	21-Low temperature boiler oil		2	
	30	30-Firewood pieces (direct and indirect heat emission)		3	
	31	31-Wood pellets (direct and indirect heat emission)		4	
	32	32-Wood pellets (only indirect heat emission)		4	
	40	40-Reserve			

Dishwashers and washing machines
1-DHW connection
2-Cold water connection

Clothes drying	Availability electricity	Availability evaporation
1-Clothes line	1	1
2-Drying closet (cold)	1	1
3-Drying closet (cold) in extract air	0,9	0,9
4-Condensation dryer	0,7	0
5-Electric exhaust air dryer	1	1
6-Gas exhaust air dryer	1	1

Cooking	Electric fraction	PE factor	CO ₂ factor	PER-factor
1-Electricity	100%	2,60	0,53	1,30
2-Natural gas	0%	1,10	0,25	1,75
3-LPG	0%	1,10	0,27	1,75